



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 1-2824-00947/00004
Effective Date: 09/30/2010 Expiration Date: 09/29/2015

Permit Type: Title IV (Phase II Acid Rain)
Permit ID: 1-2824-00947/00010
Effective Date: 09/30/2010 Expiration Date: 09/29/2015

Permit Issued To: BETHPAGE ENERGY CENTER 3 LLC
717 TEXAS AVE STE 1000
HOUSTON, TX 77002

TBG COGEN PARTNERS
717 TEXAS AVE STE 1000
HOUSTON, TX 77002

CPN BETHPAGE 3RD TURBINE INC
717 TEXAS AVE STE 1000
HOUSTON, TX 77002

Contact: JULIE A STINEDURF
CALPINE CORPORATION
717 TEXAS AVE STE 1000
HOUSTON, TX 77002
(713) 830-8618

Facility: TBG COGEN FACILITY
939 S BROADWAY
HICKSVILLE, NY 11801-5032

Description:
This is a renewal of the facility's Title IV and Title V permits for 5 more years.

The existing TBG Cogen Partners facility includes a cogeneration plant, peaking power plant and a combined cycle power plant. The cogeneration plant consists of two identical GE LM2500 combustion turbines, two heat recovery boilers with duct burners and steam turbine generator. The LM2500 units are permitted to fire natural gas and distillate oil, while the duct burners are limited to natural gas. The peaking power plant consists of one GE LM6000 combustion turbine permitted to fire only natural gas. The combined cycle power plant consists of one GE LM6000 combustion turbine and once-through boiler with duct burner permitted to fire natural gas exclusively. The auxiliary boiler and furnaces will provide space heating for the turbine building when the cogeneration plant is out of service.

New York State Department of Environmental Conservation
Facility DEC ID: 1282400947



By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: SUSAN ACKERMAN
 NYSDEC - SUNY @ STONY BROOK
 50 CIRCLE RD
 STONY BROOK, NY 11790-3409

Authorized Signature: _____ Date: ____ / ____ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
 - Applications for permit renewals, modifications and transfers
 - Permit modifications, suspensions or revocations by the Department
 - Permit modifications, suspensions or revocations by the Department

Facility Level

- Submission of application for permit modification or renewal - REGION
1 HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted to the Department for review and approval.



Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

Condition 5: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 5.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**** Facility Level ****

Condition 6: Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 6.1:

Applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409
(631) 444-0365



New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: BETHPAGE ENERGY CENTER 3 LLC
717 TEXAS AVE STE 1000
HOUSTON, TX 77002

TBG COGEN PARTNERS
717 TEXAS AVE STE 1000
HOUSTON, TX 77002

CPN BETHPAGE 3RD TURBINE INC
717 TEXAS AVE STE 1000
HOUSTON, TX 77002

Facility: TBG COGEN FACILITY
939 S BROADWAY
HICKSVILLE, NY 11801-5032

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Permit Effective Date: 09/30/2010

Permit Expiration Date: 09/29/2015



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6 NYCRR 201-6.5 (a) (7): Fees
- 3 6 NYCRR 201-6.5 (c): Recordkeeping and reporting of compliance monitoring
- 4 6 NYCRR 201-6.5 (c) (2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6 NYCRR 201-6.5 (c) (3) (ii): Compliance Certification
- 6 6 NYCRR 202-2.1: Compliance Certification
- 7 6 NYCRR 202-2.5: Recordkeeping requirements
- 8 6 NYCRR 215.2: Open Fires - Prohibitions
- 9 6 NYCRR 200.7: Maintenance of Equipment
- 10 6 NYCRR 201-1.7: Recycling and Salvage
- 11 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 12 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 13 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 14 6 NYCRR 201-6.5 (a) (4): Standard Requirement - Provide Information
- 15 6 NYCRR 201-6.5 (a) (8): General Condition - Right to Inspect
- 16 6 NYCRR 201-6.5 (d) (5): Standard Requirements - Progress Reports
- 17 6 NYCRR 201-6.5 (f) (6): Off Permit Changes
- 18 6 NYCRR 202-1.1: Required Emissions Tests
- 19 6 NYCRR 211.3: Visible Emissions Limited
- 20 40 CFR Part 68: Accidental release provisions.
- 21 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 22 6 NYCRR Subpart 201-6: Emission Unit Definition
- 23 6 NYCRR 201-6.5 (e): Compliance Certification
- 24 6 NYCRR 225-1.2: Compliance Certification
- 25 6 NYCRR 225-1.2 (c): Compliance Certification
- 26 6 NYCRR 227-1.3 (a): Compliance Certification
- 27 6 NYCRR 231-2.4: Emission Reduction Credits
- 28 6 NYCRR 243-1.6 (a): Permit Requirements
- 29 6 NYCRR 243-1.6 (b): Monitoring requirements
- 30 6 NYCRR 243-1.6 (c): NOx Ozone Season Emission Requirements
- 31 6 NYCRR 243-1.6 (d): Excess emission requirements
- 32 6 NYCRR 243-1.6 (e): Recordkeeping and reporting requirements
- 33 6 NYCRR 243-2.1: Authorization and responsibilities of CAIR designated representative
- 34 6 NYCRR 243-2.4: Certificate of representation
- 35 6 NYCRR 243-8.1: General requirements
- 36 6 NYCRR 243-8.1: Prohibitions
- 37 6 NYCRR 243-8.5 (d): Quarterly reports
- 38 6 NYCRR 243-8.5 (e): Compliance certification
- 39 6 NYCRR Subpart 244-1: CAIR NOx Annual Trading Program General Conditions
- 40 6 NYCRR Subpart 244-2: Designated CAIR Representative
- 41 6 NYCRR Subpart 244-8: Compliance Certification



- 42 6 NYCRR Subpart 245-1: CAIR SO2 Trading Program General Provisions
- 43 6 NYCRR Subpart 245-2: Designated CAIR Representative
- 44 6 NYCRR Subpart 245-8: Compliance Certification
- 45 40CFR 52.21, Subpart A: Compliance Certification
- 46 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
- 47 40CFR 60.7(a), NSPS Subpart A: Date of construction notification.
- 48 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
- 49 40CFR 60.7(c), NSPS Subpart A: Excess emissions report.
- 50 40CFR 60.7(d), NSPS Subpart A: Excess emissions report.
- 51 40CFR 60.7(f), NSPS Subpart A: Facility files for subject sources.
- 52 40CFR 60.8(a), NSPS Subpart A: Performance testing timeline.
- 53 40CFR 60.8(b), NSPS Subpart A: Performance test methods.
- 54 40CFR 60.8(c), NSPS Subpart A: Required performance test information.
- 55 40CFR 60.8(d), NSPS Subpart A: Prior notice.
- 56 40CFR 60.8(e), NSPS Subpart A: Performance testing facilities.
- 57 40CFR 60.9, NSPS Subpart A: Availability of information.
- 58 40CFR 60.11, NSPS Subpart A: Opacity standard compliance testing.
- 59 40CFR 60.12, NSPS Subpart A: Circumvention.
- 60 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
- 61 40CFR 60.14, NSPS Subpart A: Modifications.
- 62 40CFR 60.15, NSPS Subpart A: Reconstruction
- 63 40 CFR Part 72: Facility Subject to Title IV Acid Rain Regulations and Permitting

Emission Unit Level

- 64 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 65 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

EU=U-00001

- 66 6 NYCRR 227-1.2 (a) (1): Compliance Certification
- 67 6 NYCRR 227-2.6 (a) (1): Testing, monitoring, and reporting requirements for very large boilers.
- 68 40CFR 52.21, Subpart A: Compliance Certification
- 69 40CFR 52.21, Subpart A: Compliance Certification
- 70 40CFR 52.21, Subpart A: Compliance Certification
- 71 40CFR 52.21, Subpart A: Compliance Certification
- 72 40CFR 52.21, Subpart A: Compliance Certification
- 73 40CFR 52.21, Subpart A: Compliance Certification
- 74 40CFR 60, NSPS Subpart Db: Compliance Certification
- 75 40CFR 60.332, NSPS Subpart GG: Compliance Certification

EU=U-00001,Proc=DBG,ES=000DB

- 76 40CFR 52.21, Subpart A: Compliance Certification

EU=U-00001,Proc=GTG,ES=000GT

- 77 40CFR 52.21, Subpart A: Compliance Certification
- 78 40CFR 52.21, Subpart A: Compliance Certification
- 79 40CFR 52.21, Subpart A: Compliance Certification

EU=U-00001,Proc=GTM

- 80 40CFR 52.21, Subpart A: Compliance Certification
- 81 40CFR 52.21, Subpart A: Compliance Certification



EU=U-00001,Proc=GTO,ES=000GT

- 82 40CFR 52.21, Subpart A: Compliance Certification
- 83 40CFR 52.21, Subpart A: Compliance Certification
- 84 40CFR 52.21, Subpart A: Compliance Certification

EU=U-00001,Proc=TGB

- 85 40CFR 52.21, Subpart A: Compliance Certification
- 86 40CFR 52.21, Subpart A: Compliance Certification
- 87 40CFR 52.21, Subpart A: Compliance Certification

EU=U-00001,Proc=TOB

- 88 40CFR 52.21, Subpart A: Compliance Certification
- 89 40CFR 52.21, Subpart A: Compliance Certification

EU=U-00001,Proc=TOB,ES=000GT

- 90 40CFR 52.21, Subpart A: Compliance Certification

EU=U-00002

- 91 6 NYCRR Subpart 201-6: Compliance Certification
- 92 6 NYCRR Subpart 201-6: Compliance Certification
- 93 6 NYCRR Subpart 201-6: Compliance Certification
- 94 6 NYCRR Subpart 201-6: Compliance Certification
- 95 6 NYCRR Subpart 201-6: Compliance Certification
- 96 6 NYCRR Subpart 201-6: Compliance Certification
- 97 6 NYCRR Subpart 201-6: Compliance Certification
- 98 6 NYCRR Subpart 201-6: Compliance Certification
- 99 40CFR 52.21, Subpart A: Compliance Certification

EU=U-00003

- 100 6 NYCRR Subpart 201-6: Compliance Certification
- 101 6 NYCRR Subpart 201-6: Compliance Certification
- 102 6 NYCRR Subpart 201-6: Compliance Certification
- 103 6 NYCRR Subpart 201-6: Compliance Certification
- 104 6 NYCRR Subpart 201-6: Compliance Certification
- 105 6 NYCRR Subpart 201-6: Compliance Certification
- 106 6 NYCRR Subpart 201-6: Compliance Certification
- 107 6 NYCRR Subpart 201-6: Compliance Certification
- 108 6 NYCRR Subpart 201-6: Compliance Certification
- 109 6 NYCRR Subpart 201-6: Compliance Certification
- 110 6 NYCRR Subpart 201-6: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 111 ECL 19-0301: Contaminant List
- 112 6 NYCRR 201-1.4: Unavoidable noncompliance and violations
- 113 6 NYCRR Subpart 201-5: Compliance Demonstration
- 114 6 NYCRR 211.2: Air pollution prohibited
- 115 6 NYCRR 237-1.4 (a): Applicable Facility, with a unit of a capacity of 25 MWe or greater
- 116 6 NYCRR 237-1.6 (a): General condition (specifying 12 month submittal)
- 117 6 NYCRR 237-1.6 (c): Compliance Demonstration
- 118 6 NYCRR 237-1.6 (e): Recordkeeping and Reporting Requirements

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



- 119 6 NYCRR 237-1.6 (f): Liability- facility no common stacks
- 120 6 NYCRR 237-1.6 (g): Effect on other Authorities
- 121 6 NYCRR Subpart 237-2: Authorization and responsibilities of the
NOx authorized account representative to be included in existing
permits.
- 122 6 NYCRR 237-4.1: Compliance Demonstration
- 123 6 NYCRR 237-7.1: Submission of NOx allowance transfers
- 124 6 NYCRR Subpart 237-8: Compliance Demonstration
- 125 6 NYCRR 238-1.6 (a): Permit requirements to be included in new
permits or units only
- 126 6 NYCRR 238-1.6 (c): Compliance Demonstration
- 127 6 NYCRR 238-1.6 (e): Record keeping and Reporting Requirements
- 128 6 NYCRR 238-1.6 (f): Liability
- 129 6 NYCRR 238-1.6 (g): Effect on Other Authorities
- 130 6 NYCRR 238-2.1: Submissions to the Department
- 131 6 NYCRR 238-4.1: Compliance Demonstration
- 132 6 NYCRR 238-7.1: Submission of SO2 allowance transfers
- 133 6 NYCRR Subpart 238-8: Monitoring and Reporting requirements
- 134 6 NYCRR 242-1.5: CO2 Budget Trading Program - Excess emission
requirements
- 135 6 NYCRR 242-8.5: Compliance Demonstration



FEDERALLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.3 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR 201-6.3 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR 201-6.5 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.5 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.5 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR 201-6.5 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.



Item I: Severability - 6 NYCRR 201-6.5 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR 201-6.5 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR 201-6.5 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is



three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York



The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

Condition 4: Monitoring, Related Recordkeeping, and Reporting Requirements.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR 201-6.5 (c) (2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 5: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR 201-6.5 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum



frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A



written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2011.
Subsequent reports are due every 6 calendar month(s).

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Condition 6: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

Condition 7: Recordkeeping requirements
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 7.1:

(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 8: Open Fires - Prohibitions
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 215.2

Item 8.1:

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 8.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:



- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 9: Maintenance of Equipment
Effective between the dates of 09/30/2010 and 09/29/2015**



Applicable Federal Requirement:6 NYCRR 200.7

Item 9.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 10: Recycling and Salvage
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-1.7

Item 10.1:

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 11: Prohibition of Reintroduction of Collected Contaminants to the air
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 11.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 12: Exempt Sources - Proof of Eligibility
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 12.1:

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 13: Trivial Sources - Proof of Eligibility
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 13.1:



The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 14: Standard Requirement - Provide Information
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (4)

Item 14.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 15: General Condition - Right to Inspect
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (8)

Item 15.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 16: Standard Requirements - Progress Reports
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-6.5 (d) (5)

Item 16.1:

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 17: Off Permit Changes
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 201-6.5 (f) (6)

Item 17.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 18.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Visible Emissions Limited
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 211.3

Item 19.1:

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Item 22.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

TWO IDENTICAL GE MODEL LM2500 PE GAS TURBINES AND ASSOCIATED HRSG WITH DUCT BURNERS. THE GAS TURBINES MAY FIRE NATURAL GAS, DISTILLATE OIL, OR MIXED FUEL (GAS/OIL). EACH HRSG ON EACH GAS TURBINE INCLUDES A DUCT BURNER FOR SUPPLEMENTAL FIRING ON NATURAL GAS ONLY. THE TURBINES MAY OPERATE WITH OR WITHOUT THE DUCT BURNERS. EACH TURBINE/HRSG COMBUSTION UNIT HAS A MAXIMUM HEAT INPUT OF 416 MMBTU/HR. THE TOTAL HEAT INPUT FOR THE EMISSION UNIT IS 832 MMBTU/HR. THERE ARE TWO EMISSION POINTS FOR THIS EMISSION UNIT CONSISTING OF ONE STACK FOR EACH COMBUSTION TURBINE/HRSG COMBUSTION UNIT.

Building(s): 1

Item 22.2:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00002

Emission Unit Description:

CPN BETHPAGE 3RD TURBINE, INC. INSTALLED A GE LM6000 PC SPRINT COMBUSTION TURBINE AT THE EXISTING COGENERATION FACILITY OWNED BY TBG COGEN PARTNERS. THE GE LM6000 COMBUSTION TURBINE IS FIRED EXCLUSIVELY WITH NATURAL GAS AND HAS A NOMINAL NET ELECTRICAL POWER OUTPUT OF LESS THAN 50 MW. THE COMBUSTION TURBINE EMPLOYS SELECTIVE CATALYTIC REDUCTION FOR NO_x CONTROL AND AN OXIDATION CATALYST SYSTEM FOR CO CONTROL.

Building(s): CT

Item 22.3:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00003

Emission Unit Description:

This emission unit will consist of a GE LM6000 SPRINT combined cycle combustion turbine, a once through steam generator equipped with duct burners, and a 2 cell cooling towers. The combustion turbine and the duct burners will operate exclusively on natural gas.

Building(s): CTG3

Condition 23: Compliance Certification



Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR 201-6.5 (e)

Item 23.1:

The Compliance Certification activity will be performed for the Facility.

Item 23.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions; and
 - such additional requirements as may be specified elsewhere in this permit related to compliance certification.
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.
- iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.
- iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well



TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 26: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)

Item 26.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 26.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (six minute average), except for one-six-minute period per hour of not more than 27 percent opacity.

The Department reserves the right to perform or require the performance of a Method 9 opacity evaluation at any time during facility operation.

The permittee will conduct daily observations of visible emissions from each emission unit whenever fuel oil is used. The permittee will investigate, in a timely manner, any instance where there is cause to believe that visible emissions have the potential to exceed the opacity standard.

The permittee shall investigate the cause, make any necessary corrections, and verify that the excess visible emissions problem has been corrected. If visible emissions with the potential to exceed the standard continue, the permittee will conduct a Method 9 assessment within the next operating day of the sources associated with the potential noncompliance to determine the degree of opacity and will notify the NYSDEC if the method 9 test indicates that the opacity standard is not met.

Records of visible emissions observations (or any follow-up method 9 tests), investigations and corrective actions will be kept on-site. Should the Department determine that permittee's record keeping format is inadequate to demonstrate compliance with this condition, it shall provide written notice to the permittee stating the inadequacies, and permittee shall have 90 days to revise its prospective record keeping format in a manner acceptable to the Department.



issued by the department under Subpart 243-3 for the source and operate the source and the unit in compliance with such CAIR permit.

Condition 29: Monitoring requirements
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 243-1.6 (b)

Item 29.1:

The emissions measurements recorded and reported in accordance with Subpart 243-8 shall be used to determine compliance by each CAIR NO_x Ozone Season source with the CAIR NO_x Ozone Season emissions limitation under subdivision (c) of this section.

Condition 30: NO_x Ozone Season Emission Requirements
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 243-1.6 (c)

Item 30.1:

As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the control period under section 243-6.5(a) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_x Ozone Season units at the source, as determined in accordance with Subpart 243-8. The CAIR NO_x ozone season is the period beginning May 1 of a calendar year, except as provided in section 243-1.6(c)(2), and ending on September 30 of the same year, inclusive.

A CAIR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(1) of this section for the control period starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under sections 243-8.1(b)(1), (2), (3), or (7) and for each control period thereafter.

A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (c)(1) of this section, for a control period in a calendar year before the year for which the CAIR NO_x Ozone Season allowance was allocated.

CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with Subparts 243-6, 243-7, and 243-9.

A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under section 243-1.5 and no provision of law shall be construed to limit the authority of the State or the United States to terminate or limit such authorization.

A CAIR NO_x Ozone Season allowance does not constitute a property right.

Upon recordation by the Administrator under Subpart 243-6, 243-7, or 243-9, every allocation, transfer, or deduction of a CAIR NO_x Ozone Season allowance to or from a CAIR NO_x Ozone



Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 243-2.1

Item 33.1:

Except as provided under section 243-2.2, each CAIR NOx Ozone Season source, including all CAIR NOx Ozone Season units at the source, shall have one and only one CAIR designated representative, with regard to all matters under the CAIR NOx Ozone Season Trading Program concerning the source or any CAIR NOx Ozone Season unit at the source.

The CAIR designated representative of the CAIR NOx Ozone Season source shall be selected by an agreement binding on the owners and operators of the source and all CAIR NOx Ozone Season units at the source and shall act in accordance with the certification statement in section 243-2.4(a)(4)(iv).

Upon receipt by the Administrator of a complete certificate of representation under section 243-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NOx Ozone Season source represented and each CAIR NOx Ozone Season unit at the source in all matters pertaining to the CAIR NOx Ozone Season Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source or unit.

No CAIR permit will be issued, no emissions data reports will be accepted, and no CAIR NOx Ozone Season Allowance Tracking System account will be established for a CAIR NOx Ozone Season unit at a source, until the Administrator has received a complete certificate of representation under section 243-2.4 for a CAIR designated representative of the source and the CAIR NOx Ozone Season units at the source.

Each submission under the CAIR NOx Ozone Season Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NOx Ozone Season source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

Condition 34: Certificate of representation

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 243-2.4

Item 34.1:

Unless otherwise required by the department or the Administrator, documents of agreement referred to in the certificate of representation shall not be submitted to the department or the



Administrator. Neither the department nor the Administrator shall be under any obligation to review or evaluate the sufficiency of such documents, if submitted.

Condition 35: General requirements
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 243-8.1

Item 35.1:

The owners and operators, and to the extent applicable, the CAIR designated representative, of a CAIR NOx Ozone Season unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this Subpart and in Subpart H of 40 CFR Part 75. For purposes of complying with such requirements, the definitions in section 243-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR NOx Ozone Season unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 243-1.2. The owner or operator of a unit that is not a CAIR NOx Ozone Season unit but that is monitored under 40 CFR 75.72(b)(2)(ii) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR NOx Ozone Season unit.

'Requirements for installation, certification, and data accounting.' The owner or operator of each CAIR NOx Ozone Season unit shall:

- (1) install all monitoring systems required under this Subpart for monitoring NOx mass emissions and individual unit heat input (including all systems required to monitor NOx emission rate, NOx concentration, stack gas moisture content, stack gas flow rate, CO2 or O2 concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.71 and 40 CFR 75.72);
- (2) successfully complete all certification tests required under section 243-8.2 and meet all other requirements of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraph (a)(1) of this section; and
- (3) record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section.

Condition 36: Prohibitions
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 243-8.1

Item 36.1:

No owner or operator of a CAIR NOx Ozone Season unit shall use any alternative monitoring system, alternative reference method, or any other alternative to any requirement of this Subpart without having obtained prior written approval in accordance with section 243-8.6.

No owner or operator of a CAIR NOx Ozone Season unit shall operate the unit so as to discharge, or allow to be discharged, NOx emissions to the atmosphere without accounting for all such emissions in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.



No owner or operator of a CAIR NO_x Ozone Season unit shall disrupt the continuous emission monitoring system, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NO_x mass emissions discharged into the atmosphere or heat input, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NO_x Ozone Season unit shall retire or permanently discontinue use of the continuous emission monitoring system, any component thereof, or any other approved monitoring system under this Subpart, except under any one of the following circumstances:

- (i) during the period that the unit is covered by an exemption under section 243-1.5 that is in effect;
- (ii) the owner or operator is monitoring emissions from the unit with another certified monitoring system approved, in accordance with the applicable provisions of this Subpart and 40 CFR Part 75, by the department for use at that unit that provides emission data for the same pollutant or parameter as the retired or discontinued monitoring system; or
- (iii) the CAIR designated representative submits notification of the date of certification testing of a replacement monitoring system for the retired or discontinued monitoring system in accordance with section 243-8.2(d)(3)(i).

Condition 37: Quarterly reports
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR 243-8.5 (d)

Item 37.1:

The CAIR designated representative shall submit quarterly reports, as follows:

If the CAIR NO_x Ozone Season unit is subject to an Acid Rain emissions limitation or a CAIR NO_x emissions limitation or if the owner or operator of such unit chooses to report on an annual basis under this Subpart, the CAIR designated representative shall meet the requirements of Subpart H of 40 CFR Part 75 (concerning monitoring of NO_x mass emissions) for such unit for the entire year and shall report the NO_x mass emissions data and heat input data for such unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:

- (i) for a unit that commences commercial operation before July 1, 2007, the calendar quarter covering May 1, 2008 through June 30, 2008;
- (ii) for a unit that commences commercial operation on or after July 1, 2007, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 243-8.1(b), unless that quarter is the third or fourth quarter of 2007 or the first quarter of 2008, in which case reporting shall commence in the quarter covering May 1, 2008 through June 30, 2008.

The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

For CAIR NO_x Ozone Season units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Annual Trading Program, CAIR SO₂ Trading Program, or the Mercury

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO_x mass emission data, heat input data, and other information required by this Subpart.

Condition 38: Compliance certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 243-8.5 (e)

Item 38.1:

The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

- (1) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR Part 75, including the quality assurance procedures and specifications;
- (2) for a unit with add-on NO_x emission controls and for all hours where NO_x data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO_x emissions; and
- (3) for a unit that is reporting on a control period basis under subparagraph (d)(2)(ii) of this section, the NO_x emission rate and NO_x concentration values substituted for missing data under Subpart D of 40 CFR Part 75 are calculated using only values from a control period and do not systematically underestimate NO_x emissions.

Condition 39: CAIR NO_x Annual Trading Program General Conditions
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 244-1

Item 39.1:

- 1) As of midnight of March 1, or midnight of the first business day thereafter if March 1 is not a business day, the owners and operators shall hold, in their compliance account, Clean Air Interstate Rule (CAIR) NO_x allowances available for compliance deductions for the previous control period (January 1 through December 31), in an amount not less than the total tons of nitrogen oxides emissions from all CAIR NO_x units at the source during that control period. A CAIR NO_x allowance shall not be deducted for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated. [244-1.6(c)(1), 244-1.2(b)(5), 244-1.2(b)(36), 244-1.6(c)(3)]
- 2) The owners and operators shall hold in their compliance account, CAIR NO_x allowances available for compliance deductions for the control period starting on the later of January 1, 2009 or the deadline for meeting a CAIR NO_x unit's monitor certification requirements under section 244-8.1(b)(1), (2), or (5) and for each control period thereafter. [244-1.6(c)(2)]
- 3) If a CAIR NO_x source emits nitrogen oxides during any control period in excess of the CAIR



NOx emissions limitation, the owners and operators of the CAIR NOx source shall surrender the CAIR NOx allowances required for deduction under 6NYCRR Part 244-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this permit, the Act, and applicable State law. [(244-1.6(d))]

4) Unless otherwise provided, the owners and operators of the CAIR NOx source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [(244-1.6(e))]

(i) The certificate of representation under 6NYCRR Part 244-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 244-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 244-8, provided that to the extent that 6NYCRR Part 244-8 provides for a three year period for recordkeeping, the three year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NOx Annual Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NOx Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NOx Annual Trading Program.

Condition 40: Designated CAIR Representative
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 244-2

Item 40.1:

1) Each Clean Air Interstate Rule (CAIR) NOx source shall have one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 244-2.2, with regard to all matters under the CAIR NOx Annual Trading Program. The CAIR designated representative shall be selected by an agreement binding on the owners and operators of the source and act in accordance with the certification statement in 6NYCRR Part 244-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 244-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NOx source represented in all matters pertaining to the CAIR NOx Annual Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source. [(244-2.1(a), (b) & (c))]

(2) Each submission under the CAIR NOx Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NOx source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the



statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment." [244-2.1(e)]

Condition 41: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 244-8

Item 41.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 41.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring and Reporting NOX emissions

(1) The owners and operators, and to the extent applicable, the CAIR designated representative shall comply with all recordkeeping and reporting requirements in this condition, the applicable recordkeeping and reporting requirements under 40 CFR 75, and the requirements of 6NYCRR Part 244-2.1(e)(1).

(2) The CAIR designated representative shall submit quarterly reports of the the NOx mass emissions data and heat input data for each CAIR NOx unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under 6NYCRR Part 244-8.1(b), unless that quarter is the third or fourth quarter of 2007, in which case reporting shall commence in the quarter covering January 1, 2008 through March 31, 2008.

(3) The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

(4) For CAIR NOx units that are also subject to an Acid



Rain emissions limitation or the CAIR NO_x Ozone Season Trading Program, CAIR SO₂ Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO_x mass emission data, heat input data, and other information required by this Subpart.

(5) 'Compliance certification.' The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(i) the monitoring data submitted were recorded in accordance with the applicable requirements of 6NYCRR Part 244 and 40 CFR Part 75, including the quality assurance procedures and specifications; and

(ii) for a unit with add-on NO_x emission controls and for all hours where NO_x data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO_x emissions.

(6) Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of 40 CFR part 75, data shall be substituted using the applicable missing data procedures in Subpart D or Subpart H of, or appendix D or appendix E to 40 CFR part 75. [244-8.3(a)]

(7) Whenever the owner or operator makes a replacement, modification, or change in any certified continuous emission monitoring system under 6NYCRR Part 244-8.1(a)(1) that may significantly affect the ability of the system to accurately measure or record NO_x mass emissions or heat input rate or to meet the quality-assurance and quality-control requirements of 40 CFR 75.21 or appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system in accordance with 40 CFR 75.20(b) . Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that may significantly change the stack flow or concentration



profile, the owner or operator shall recertify each continuous emission monitoring system whose accuracy is potentially affected by the change, in accordance with 40 CFR 75.20(b). Examples of changes to a continuous emission monitoring system that require recertification include replacement of the analyzer, complete replacement of an existing continuous emission monitoring system, or change in location or orientation of the sampling probe or site. Any fuel flowmeter system, and any excepted NOx monitoring system under appendix E to 40 CFR part 75, under 6NYCRR Part 244-8.1(a)(1) are subject to the recertification requirements in 40 CFR 75.20(g)(6). [224-8.2(d)(2)

Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL TOTAL
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 42: CAIR SO2 Trading Program General Provisions
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 245-1

Item 42.1:

- 1) As of midnight of March 1, or midnight of the first business day thereafter (if March 1 is not a business day) for a control period, the owners and operators of each Clean Air Interstate Rule (CAIR) SO2 source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO2 allowances available for compliance deductions for the control period (January 1 through December 31) not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO2 units at the source. A CAIR SO2 allowance shall not be deducted, for compliance with the requirements under paragraph (2) of this section, for a control period in a calendar year before the year for which the CAIR SO2 allowance was allocated. [(245-1.2(b)(5), 245-1.6(c)(1), 245-1.2(b)(36), 245-1.6(c)(3)]
- 2) The owners and operators shall hold in their compliance account, CAIR SO allowances available for compliance deductions for the control period starting on the later of January 1, 2010 or the deadline for meeting a CAIR SO2 unit's monitor certification requirements under section 245-8.1(b)(1), (2), or (5) and for each control period thereafter. [245-1.6(c)(2)]
- 3) If a CAIR SO2 source emits sulfur dioxide during any control period in excess of the CAIR SO2 emissions limitation, the owners and operators of the source shall surrender the CAIR SO2 allowances required for deduction under 6NYCRR Part 245-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law. [(245-1.6(d)]
- 4) Unless otherwise provided, the owners and operators of the CAIR SO2 source shall keep on



site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [245-1.6(e)]

(i) The certificate of representation under 6NYCRR Part 245-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 245-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 245-8, provided that to the extent that 6NYCRR Part 245-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program.

Condition 43: Designated CAIR Representative
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 245-2

Item 43.1:

1) Each CAIR SO₂ source shall have one and only one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 245-2.2, with regard to all matters under the CAIR SO₂ Trading Program. The CAIR designated representative of the CAIR SO₂ source shall be selected by an agreement binding on the owners and operators of the source and all CAIR SO₂ units at the source and shall act in accordance with the certification statement in 6NYCRR Part 245-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 245-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR SO₂ source represented and each CAIR SO₂ unit at the source in all matters pertaining to the CAIR SO₂ Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source or unit. [245-2.1(a), (b) & (c)]

(2) Each submission under the CAIR SO₂ Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR SO₂ source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment." [245-2.1(e)]



Condition 44: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 245-8

Item 44.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 44.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring and Reporting SO₂ emissions:

1) The owners and operators, and to the extent applicable, the Clean Air Interstate Rule (CAIR) designated representative, of a CAIR SO₂ unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. For purposes of complying with such requirements, the definitions in section 245-1.2 and 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR SO₂ unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 245-1.2. The owner or operator of a unit that is not a CAIR SO₂ unit but that is monitored under 40 CFR 75.16(b)(2) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR SO₂ unit. [245-8.1]

2)The owner or operator of each CAIR SO₂ unit shall:
[245-8.1(a)]

(i) install all monitoring systems required under this Subpart for monitoring SO₂ mass emissions and individual unit heat input (including all systems required to monitor SO₂ concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.11 and 40 CFR 75.16);

(ii) successfully complete all certification tests required under Part 245-8.2 and meet all other requirements of this section and 40 CFR Part 75 applicable to the monitoring systems under this section; and

(iii) record, report, and quality-assure the data from the monitoring systems under paragraph of this



section.

3) The owner or operator shall meet the monitoring system certification and other requirements of section 245-8.1(a)(1) and (2) on or before the following dates.

The owner or operator shall record, report, and quality-assure the data from the monitoring systems under section 245-8.1(a)(1) on and after the following dates.

[245-8.1(b)]

(i) For the CAIR SO₂ unit that commences commercial operation before July 1, 2008, by January 1, 2009.

(ii) For the CAIR SO₂ unit that commences commercial operation on or after July 1, 2008, by the later of the following dates: January 1, 2009; or 90 unit operating days or 180 calendar days, whichever occurs first, after the date on which the unit commences commercial operation.

4) Whenever the owner or operator makes a replacement, modification, or change in any certified continuous emission monitoring system under section 245-8.1(a)(1) that may significantly affect the ability of the system to accurately measure or record SO₂ mass emissions or heat input rate or to meet the quality-assurance and quality-control requirements of 40 CFR 75.21 or appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system in accordance with 40 CFR 75.20(b). Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that may significantly change the stack flow or concentration profile, the owner or operator shall recertify each continuous emission monitoring system whose accuracy is potentially affected by the change, in accordance with 40 CFR 75.20(b). Examples of changes to a continuous emission monitoring system that require recertification include: replacement of the analyzer, complete replacement of an existing continuous emission monitoring system, or change in location or orientation of the sampling probe or site. Any fuel flowmeter system under section 245-8.1(a)(1) is subject to the recertification requirements in 40 CFR 75.20(g)(6). [245-8.2(d)(2)]

5) Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of 40 CFR Part 75, data shall be substituted using the applicable missing data procedures in Subpart D of or appendix D to 40 CFR Part 75. [245-8.3(a)]

6) The CAIR designated representative shall comply with all recordkeeping and reporting requirements in section



245-8.3, the applicable recordkeeping and reporting requirements in Subparts F and G of 40 CFR Part 75, and the requirements of section 245-2.1(e)(1).

[245-8.5(a)]

7) The owner or operator of a CAIR SO₂ unit shall comply with requirements of 40 CFR 75.62 for monitoring plans.

[245-8.5(b)]

8) The CAIR designated representative shall submit an application to the department within 45 days after completing all initial certification or recertification tests required under section 245-8.2, including the information required under 40 CFR 75.63. [245-8.5(c)

]

9) The CAIR designated representative shall submit quarterly reports of the SO₂ mass emissions data and heat input data for each CAIR SO₂ unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:

[245-8.5(d)(1)]

i) the calendar quarter covering January 1, 2009 through March 31, 2009 for a unit that commences commercial operation before July 1, 2008; or

ii) for a unit that commences commercial operation on or after July 1, 2008, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 245-8.1(b), unless that quarter is the third or fourth quarter of 2008, in which case reporting shall commence in the quarter covering January 1, 2009 through March 31, 2009.

10) The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.64. [245-8.5(d)(2)]

11) For CAIR SO₂ units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the SO₂ mass emission data, heat input data, and other information required by this Subpart. [245-8.5(d)(3)]

12) The CAIR designated representative shall submit to

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Subsequent reports are due every 12 calendar month(s).

Condition 46: EPA Region 2 address.
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A

Item 46.1:

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2
290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Condition 47: Date of construction notification.
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.7(a), NSPS Subpart A

Item 47.1:

Any owner or operator subject to this part shall furnish the Administrator with the following information:

- 1) a notification of the date construction or reconstruction commenced, postmarked no later than 30 days after such date;
- 3) a notification of the actual date of initial start up, postmarked within 15 days after such date;
- 4) a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the change is specifically exempted under 40 CFR 60. The notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capability of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional information regarding the change;
- 5) a notification of the date upon which the demonstration of continuous monitoring system performance commences, postmarked not less than 30 days prior to such date;
- 6) a notification of the anticipated date for conducting the opacity observations, postmarked not



Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.7(f), NSPS Subpart A

Item 51.1:

The following files shall be maintained at the facility for all affected sources: all measurements, including continuous monitoring systems, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. The file shall be maintained for at least two years following the date of such measurements, reports, and records.

Condition 52: Performance testing timeline.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.8(a), NSPS Subpart A

Item 52.1:

Within 60 days after achieving the maximum production rate, but not later than 180 days after initial startup of the facility, the owner or operator of the facility shall conduct performance testing and provide the results of such tests, in a written report, to the Administrator.

Condition 53: Performance test methods.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.8(b), NSPS Subpart A

Item 53.1:

Performance testing shall be conducted in accordance with the methods and procedures prescribed in 40 CFR 60 or by alternative methods and procedures approved by the Administrator.

Condition 54: Required performance test information.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.8(c), NSPS Subpart A

Item 54.1:

Performance tests shall be conducted under such conditions specified by the Administrator, based upon representative performance data supplied by the owner or operator of the facility.

Condition 55: Prior notice.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.8(d), NSPS Subpart A

Item 55.1:

The owner or operator shall provide the Administrator with prior notice of any performance test at least 30 days in advance of testing.

Condition 56: Performance testing facilities.



Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.8(e), NSPS Subpart A

Item 56.1:

The following performance testing facilities shall be provided during all tests:

- 1) sampling ports adequate for tests methods applicable to such facility;
- 2) a safe sampling platform;
- 3) a safe access to the sampling platform; and
- 4) utilities for sampling and testing equipment.

Condition 57: Availability of information.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.9, NSPS Subpart A

Item 57.1:

The availability to the public of information provided to, or otherwise obtained by, the Administrator under this part shall be governed by 40 CFR Part 2.

Condition 58: Opacity standard compliance testing.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.11, NSPS Subpart A

Item 58.1:

The following conditions shall be used to determine compliance with the opacity standards:

- 1) observations shall be conducted in accordance with Reference Method 9, in Appendix A of 40 CFR Part 60(or an equivalent method approved by the Administrator including continuous opacity monitors);
- 2) the opacity standards apply at all times except during periods of start up, shutdown, and malfunction; and
- 3) all other applicable conditions cited in section 60.11 of this part.

Condition 59: Circumvention.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.12, NSPS Subpart A

Item 59.1:

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the



atmosphere.

Condition 60: Monitoring requirements.
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.13, NSPS Subpart A

Item 60.1:

All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

Condition 61: Modifications.
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.14, NSPS Subpart A

Item 61.1:

Within 180 days of the completion of any physical or operational change (as defined in section 60.14), compliance with the applicable standards must be achieved.

Condition 62: Reconstruction
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.15, NSPS Subpart A

Item 62.1:

The following shall be submitted to the Administrator prior to reconstruction (as defined in section 60.15):

- 1) a notice of intent to reconstruct 60 days prior to the action;
- 2) name and address of the owner or operator;
- 3) the location of the existing facility;
- 4) a brief description of the existing facility and the components to be replaced;
- 5) a description of the existing air pollution control equipment and the proposed air pollution control equipment;
- 6) an estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility;
- 7) the estimated life of the facility after the replacements; and
- 8) a discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.

Condition 63: Facility Subject to Title IV Acid Rain Regulations and Permitting
Effective between the dates of 09/30/2010 and 09/29/2015



Applicable Federal Requirement:40 CFR Part 72

Item 63.1: This facility is subject to the Title IV Acid Rain Regulations found in 40 CFR Parts 72, 73, 75, 76, 77 and 78. The Acid Rain Permit is an attachment to this permit.

****** Emission Unit Level ******

Condition 64: Emission Point Definition By Emission Unit
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 64.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001

Height (ft.): 100

Diameter (in.): 79

NYTMN (km.): 4511.423 NYTME (km.): 628.233 Building: 1

Item 64.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00002

Emission Point: 00002

Height (ft.): 80

Diameter (in.): 111

NYTMN (km.): 4511.523 NYTME (km.): 629.633

Item 64.3:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00003

Emission Point: U0003

Height (ft.): 100

Diameter (in.): 79

NYTMN (km.): 4511.523 NYTME (km.): 629.633

Condition 65: Process Definition By Emission Unit
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 65.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: DBG

Source Classification Code: 1-03-006-01

Process Description:

TWO DUCT BURNERS, ONE ON EACH HRSG, FIRING

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



NATURAL GAS WITHOUT OPERATION OF THE TURBINES. THIS PROCESS IS PROVIDED TO IDENTIFY THE EMISSION LIMIT FOR THE DUCT BURNERS. THE DUCT BURNERS CANNOT OPERATE WITHOUT THE TURBINES.

Emission Source/Control: 000DB - Combustion
Design Capacity: 162 million Btu per hour

Item 65.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
Process: GTG Source Classification Code: 2-03-002-03
Process Description:

TWO IDENTICAL GE COMBUSTION TURBINES FIRING NATURAL GAS WITHOUT SUPPLEMENTAL FIRING OF THE DUCT BURNER. NOX EMISSIONS ARE CONTROLLED WITH STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Emission Source/Control: 000GT - Combustion
Design Capacity: 254 million Btu per hour

Item 65.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
Process: GTM Source Classification Code: 2-03-002-03
Process Description:

TWO IDENTICAL GE COMBUSTION TURBINES FIRING MIXED FUEL (NATURAL GAS AND DISTILLATE OIL) WITH OR WITHOUT SUPPLEMENTAL FIRING OF THE DUCT BURNER ON GAS. NOX IS CONTROLLED BY STEAM INJECTION AND CO IS CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Emission Source/Control: 000DB - Combustion
Design Capacity: 162 million Btu per hour

Emission Source/Control: 000GT - Combustion
Design Capacity: 254 million Btu per hour

Item 65.4:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
Process: GTO Source Classification Code: 2-03-001-02
Process Description:

TWO IDENTICAL GE COMBUSTION TURBINES

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



FIRING OIL WITHOUT SUPPLEMENTAL FIRING OF THE DUCT BURNER. NOX EMISSIONS ARE CONTROLLED WITH STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Emission Source/Control: 000GT - Combustion
Design Capacity: 254 million Btu per hour

Item 65.5:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
Process: TGB Source Classification Code: 2-03-002-03
Process Description:

TWO IDENTICAL GE COMBUSTION TURBINES FIRING NATURAL GAS WITH SUPPLEMENTAL FIRING OF THE DUCT BURNER ON GAS. NOX EMISSIONS ARE CONTROLLED BY STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Emission Source/Control: 000DB - Combustion
Design Capacity: 162 million Btu per hour

Emission Source/Control: 000GT - Combustion
Design Capacity: 254 million Btu per hour

Item 65.6:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
Process: TOB Source Classification Code: 2-03-001-02
Process Description:

TWO IDENTICAL GE COMBUSTION TURBINES FIRING OIL WITH SUPPLEMENTAL FIRING OF THE DUCT BURNER ON GAS. NOX EMISSIONS ARE CONTROLLED BY STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Emission Source/Control: 000DB - Combustion
Design Capacity: 162 million Btu per hour

Emission Source/Control: 000GT - Combustion
Design Capacity: 254 million Btu per hour

Item 65.7:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002
Process: 003 Source Classification Code: 2-03-002-03

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Process Description:

GE LM6000 COMBUSTION TURBINE FIRING
EXCLUSIVELY NATURAL GAS.

Emission Source/Control: 00007 - Combustion
Design Capacity: 475 million Btu per hour

Emission Source/Control: 00009 - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Item 65.8:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003

Process: GSH

Source Classification Code: 1-05-001-06

Process Description:

This process consists of a GE LM 6000 SPRINT combustion turbine, 8 350,000 Btu/hr heat input gas fired only space heaters. The space heaters are exempt sources under 6 NYCRR Part 201-3.

Emission Source/Control: 8GFSH - Combustion
Design Capacity: 350,000 British thermal units per hour

Item 65.9:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003

Process: OFB

Source Classification Code: 1-02-005-03

Process Description:

This process consists of the operation of one 9.5 mmBtu/hr heat input distillate oil fired boiler. These are exempt sources under 6 NYCRR Part 201-3

Emission Source/Control: 1DOFB - Combustion
Design Capacity: 9.5 million BTUs per hour

Condition 66: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 227-1.2 (a) (1)

Item 66.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 66.2:

Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

THE PARTICULATE STANDARD IN THIS RULE IS LESS STRINGENT THAN THE PARTICULATE STANDARD CONTAINED IN FACILITY PSD PERMIT. COMPLIANCE WITH PARTICULATE STANDARD WAS DEMONSTRATED USING MANUFACTURER'S SPECIFICATIONS & INITIAL PERFORMANCE TESTS.

Upper Permit Limit: 0.1 pounds per million Btus

Reference Test Method: EPA METHOD 5

Monitoring Frequency: SINGLE OCCURRENCE

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 67: Testing, monitoring, and reporting requirements for very large boilers.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR 227-2.6 (a) (1)

Item 67.1:

This Condition applies to Emission Unit: U-00001

Item 67.2:

The owner/operator shall measure NOx emissions with a continuous emissions monitoring system (CEMS) as described in 6NYCRR 227-2.6(b).

Condition 68: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 68.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 68.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

THE CARBON MONOXIDE CONTROL EQUIPMENT SHALL BE USED WHENEVER THE TURBINES ARE BEING OPERATED. THE CO CATALYST IS

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



INTEGRAL TO THE COMBUSTION UNIT AND BY
DESIGN MUST OPERATE WHEN THE TURBINE/HRSG
IS ON-LINE.

Reference Test Method: NA

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2011.

Subsequent reports are due every 12 calendar month(s).

Condition 69: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 69.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 69.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE SULFUR DIOXIDE
EMISSION LIMIT IS DEMONSTRATED THROUGH
SULFUR MONITORING OF FUEL IN ACCORDANCE
WITH 40 CFR 60.334 AND 60.335.

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 86.6 pounds per hour

Reference Test Method: ASTM D-4294

Monitoring Frequency: CONTINUOUS

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2011.

Subsequent reports are due every 12 calendar month(s).

Condition 70: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 70.1:

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Reference Test Method: NA

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 72: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 72.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 72.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

CONTINUOUS EMISSION MONITORING OF CARBON MONOXIDE IS REQUIRED.

Manufacturer Name/Model Number: Thermo Environmental Industries 48C

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 0.102 pounds per million Btus

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2011.

Subsequent reports are due every 12 calendar month(s).

Condition 73: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 73.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 73.2:

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE SULFUR DIOXIDE
EMISSION LIMIT IS DEMONSTRATED THROUGH
SULFUR MONITORING OF FUEL IN ACCORDANCE
WITH 40 CFR 60.334 AND 60.335.

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 86.6 pounds per hour

Reference Test Method: ASTM D-4294

Monitoring Frequency: CONTINUOUS

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2011.

Subsequent reports are due every 12 calendar month(s).

Condition 74: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 40CFR 60, NSPS Subpart Db

Item 74.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 74.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

TBG HAS DEVELOPED AND SUBMITTED TO
NYSDEC AND USEPA FOR APPROVAL A CUSTOM
NSPS MONITORING, RECORDKEEPING AND
REPORTING PLAN PURSUANT TO 40 CFR 60.13i
TO SIMULTANEOUSLY COMPLY WITH 40 CFR 60
SUBPARTS Db AND Gg. USEPA APPROVED
(10/28/02) CUSTOM NSPS MONITORING,
RECORDKEEPING AND REPORTING PLAN.

Reference Test Method: NA

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Condition 75: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 60.332, NSPS Subpart GG

Item 75.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 75.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

A NO_x CEMS IS USED TO DEMONSTRATE
COMPLIANCE WITH SUBPART GG IN ACCORDANCE
WITH A CUSTOM NSPS MONITORING,
RECORDKEEPING AND REPORTING PLAN.

Manufacturer Name/Model Number: Thermo Environmental Industries 42C

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 96.4 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40CFR60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 76: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 76.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: DBG

Emission Source: 000DB

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 76.2:

Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

THIS LIMIT APPLIES ONLY TO THE DUCT BURNER. COMPLIANCE WITH THIS LIMIT WAS DEMONSTRATED DURING THE INITIAL PERFORMANCE TEST. THE INITIAL TEST REPORT WAS SUBMITTED TO NYSDEC FOLLOWING THE COMPLETION OF THE PERFORMANCE TEST.

Manufacturer Name/Model Number: Rosemont analytical NGA CLD by Emerson.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 0.2 pounds per million Btus

Reference Test Method: 40CFR60 METHOD 7

Monitoring Frequency: SINGLE OCCURRENCE

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 77: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 77.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: GTG

Emission Source: 000GT

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 77.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS DEMONSTRATED DURING THE INITIAL COMPLIANCE TEST AND THROUGH MANUFACTURER'S SPECIFICATIONS. THE INITIAL TEST REPORT WAS SUBMITTED TO NYSDEC FOLLOWING THE COMPLETION OF THE PERFORMANCE TEST.

Upper Permit Limit: 3.0 pounds per hour

Reference Test Method: EPA METHOD 5

Monitoring Frequency: SINGLE OCCURRENCE

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 78: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015



Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 78.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: GTG Emission Source: 000GT

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 78.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS DEMONSTRATED DURING THE INITIAL COMPLIANCE TEST AND THROUGH MANUFACTURER'S SPECIFICATIONS. THE INITIAL TEST REPORT WAS SUBMITTED TO NYSDEC FOLLOWING THE COMPLETION OF THE PERFORMANCE TEST.

Upper Permit Limit: 0.014 pounds per million Btus
Reference Test Method: EPA METHOD 5
Monitoring Frequency: SINGLE OCCURRENCE
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 79: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 79.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: GTG Emission Source: 000GT

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 79.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

CONTINUOUS EMISSION MONITORING OF NOX IS REQUIRED TO DEMONSTRATE COMPLIANCE WITH

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



THE NOX EMISSION LIMITS ESTABLISHED IN
THE PSD PERMIT. THESE LIMITS ARE MORE
STRINGENT THAN THE NSPS LIMITS.
COMPLIANCE REPORTING IS MADE TO NYSDEC.

Manufacturer Name/Model Number: TECO MODEL 14B/E

Upper Permit Limit: 42.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (ANNIVERSARY)

Initial Report Due: 01/28/2011 for the period 09/30/2010 through 12/29/2010

Condition 80: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 80.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: GTM

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 80.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT FOR
OIL AND GAS ONLY OPERATION WAS
DEMONSTRATED AS PART OF INITIAL
PERMITTING. THIS PROPOSED OPERATION ON
MIXED FUEL WILL PRODUCE FEWER PARTICULATE
EMISSIONS THAN OIL ONLY OPERATION.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 10.0 pounds per hour

Reference Test Method: EPA METHOD 5

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 81: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 81.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: GTM

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 81.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

COMPLIANCE WITH THE NITROGEN OXIDE
EMISSION LIMIT IS DEMONSTRATED USING A
CONTINUOUS EMISSION MONITOR.

Manufacturer Name/Model Number: TECO MODEL 48

Upper Permit Limit: 60.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (ANNIVERSARY)

Initial Report Due: 01/28/2011 for the period 09/30/2010 through 12/29/2010

Condition 82: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 82.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: GTO

Emission Source: 000GT

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 82.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS
DEMONSTRATED DURING THE INITIAL
COMPLIANCE TEST AND THROUGH
MANUFACTURER'S SPECIFICATIONS. THE

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



INITIAL TEST REPORT WAS SUBMITTED TO
NYSDEC FOLLOWING THE COMPLETION OF THE
PERFORMANCE TEST.

Upper Permit Limit: 0.031 pounds per million Btus
Reference Test Method: EPA METHOD 5
Monitoring Frequency: SINGLE OCCURRENCE
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 83: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 83.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: GTO Emission Source: 000GT

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 83.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS
DEMONSTRATED DURING THE INITIAL
COMPLIANCE TEST AND THROUGH
MANUFACTURER'S SPECIFICATIONS. THE
INITIAL TEST REPORT WAS SUBMITTED TO
NYSDEC FOLLOWING THE COMPLETION OF THE
PERFORMANCE TEST.

Upper Permit Limit: 7.5 pounds per hour
Reference Test Method: EPA METHOD 5
Monitoring Frequency: SINGLE OCCURRENCE
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 84: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 84.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Process: GTO

Emission Source: 000GT

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 84.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

CONTINUOUS EMISSION MONITORING OF NOX IS REQUIRED TO DEMONSTRATE COMPLIANCE WITH THE NOX EMISSION LIMITS ESTABLISHED IN THE PSD PERMIT. THESE LIMITS ARE MORE STRINGENT THAN THE NSPS LIMITS. COMPLIANCE REPORTING IS MADE TO NYSDEC.

Manufacturer Name/Model Number: TECO MODEL 14B/E

Upper Permit Limit: 65.0 parts per million by volume

(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (ANNIVERSARY)

Initial Report Due: 01/28/2011 for the period 09/30/2010 through 12/29/2010

Condition 85: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 85.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: TGB

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 85.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS DEMONSTRATED DURING THE INITIAL COMPLIANCE TEST AND THROUGH MANUFACTURER'S SPECIFICATIONS. THE INITIAL TEST REPORT WAS SUBMITTED TO NYSDEC FOLLOWING THE COMPLETION OF THE PERFORMANCE TEST.



Upper Permit Limit: 0.015 pounds per million Btus
Reference Test Method: EPA METHOD 5
Monitoring Frequency: SINGLE OCCURRENCE
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 86: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 86.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: TGB

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 86.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS
DEMONSTRATED DURING THE INITIAL
COMPLIANCE TEST AND THROUGH
MANUFACTURER'S SPECIFICATIONS. THE
INITIAL TEST REPORT WAS SUBMITTED TO
NYSDEC FOLLOWING THE COMPLETION OF THE
PERFORMANCE TEST.

Upper Permit Limit: 5.5 pounds per hour
Reference Test Method: EPA METHOD 5
Monitoring Frequency: SINGLE OCCURRENCE
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 87: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 87.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: TGB

Regulated Contaminant(s):

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 87.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

CONTINUOUS EMISSION MONITORING OF NOX IS
REQUIRED TO DEMONSTRATE COMPLIANCE WITH
THE NOX EMISSION LIMITS ESTABLISHED IN
THE PSD PERMIT. THESE LIMITS ARE MORE
STRINGENT THAN THE NSPS LIMITS.
COMPLIANCE REPORTING IS MADE TO NYSDEC.

Manufacturer Name/Model Number: TECO MODEL 14B/E

Upper Permit Limit: 42.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (ANNIVERSARY)

Initial Report Due: 01/28/2011 for the period 09/30/2010 through 12/29/2010

Condition 88: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 88.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: TOB

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 88.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS
DEMONSTRATED DURING THE INITIAL
COMPLIANCE TEST AND THROUGH
MANUFACTURER'S SPECIFICATIONS. THE
INITIAL TEST REPORT WAS SUBMITTED TO
NYSDEC FOLLOWING THE COMPLETION OF THE
PERFORMANCE TEST.

Upper Permit Limit: 10.0 pounds per hour

Reference Test Method: EPA METHOD 5

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Monitoring Frequency: SINGLE OCCURRENCE

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 89: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 89.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: TOB

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 89.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

COMPLIANCE WITH THE PM/PM10 LIMIT WAS DEMONSTRATED DURING THE INITIAL COMPLIANCE TEST AND THROUGH MANUFACTURER'S SPECIFICATIONS. THE INITIAL TEST REPORT WAS SUBMITTED TO NYSDEC FOLLOWING THE COMPLETION OF THE PERFORMANCE TEST.

Upper Permit Limit: 0.025 pounds per million Btus

Reference Test Method: EPA METHOD 5

Monitoring Frequency: SINGLE OCCURRENCE

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 90: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 90.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: TOB

Emission Source: 000GT

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 90.2:

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

CONTINUOUS EMISSION MONITORING OF NOX IS REQUIRED TO DEMONSTRATE COMPLIANCE WITH THE NOX EMISSION LIMITS ESTABLISHED IN THE PSD PERMIT. THESE LIMITS ARE MORE STRINGENT THAN THE NSPS LIMITS. COMPLIANCE REPORTING IS MADE TO NYSDEC.

Manufacturer Name/Model Number: TECO MODEL 14B/E

Upper Permit Limit: 65.0 parts per million by volume

(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (ANNIVERSARY)

Initial Report Due: 01/28/2011 for the period 09/30/2010 through 12/29/2010

Condition 91: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 91.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 007664-41-7 AMMONIA

Item 91.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous emission monitor for ammonia slip, in accordance with manufacturer's specifications. This limit shall apply at all times except during periods of start-up or shutdown. Emission in excess of this limit shall be reported quarterly through the facility excess emission report. All records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: Thermo Electron/42C

Parameter Monitored: AMMONIA

Upper Permit Limit: 10 parts per million by volume (dry,
corrected to 15% O₂)

Reference Test Method: Method 027

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 92: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 92.1:
The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Item 92.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A shutdown shall be defined as the period of time when the stop signal is initiated to when the fuel is no longer being combusted in the engine, not to exceed 20 minutes per occurrence. the owner or operator shall record each period of shutdown and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: DURATION OF SHUTDOWN
Upper Permit Limit: 20 minutes
Monitoring Frequency: CONTINUOUS
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER
OCCURRENCE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 93: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 93.1:
The Compliance Certification activity will be performed for:

Emission Unit: U-00002

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 93.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous emissions monitor for ammonia slip, in accordance with the manufacturer's specifications. This limit shall apply during periods of start-up or shutdown. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: Thermo Electron/42C

Parameter Monitored: AMMONIA

Upper Permit Limit: 7.4 pounds

Reference Test Method: 40 CFR 60 App. F

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 94: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 94.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 94.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Oxides of Nitrogen, NO_x, Continuous Emission Monitor is required. The limit of 5 pounds in 20 minutes shall apply only during periods of shut-down, not to be exceeded per occurrence. Emissions in excess of this limit shall be



Condition 96: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 96.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 96.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Compliance with the Oxides of Nitrogen, NO_x, is demonstrated through the use of a NO_x continuous emission monitor. The facility shall determine compliance based on an hour average for this emission unit (EU 00002). This limit shall apply at all times except during periods of start-up or shutdown. Emission in excess of this limit shall be reported quarterly through the facility excess emission report. All records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: GE/KVB-Entertec

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 2.5 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40CFR60 App. B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 97: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 97.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Item 97.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Compliance with the Carbon Monoxide, CO, limit is demonstrated using a continuous emission monitor. The facility shall determine compliance based on an hour average for this emission unit (EU 00002). All records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: GE/KVB Entertec

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 5.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40CFR60 App. B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 98: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 98.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Item 98.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A start-up shall be defined as the period of time when the gas turbine begins firing fuel until the point when the control equipment operation has achieved a mass rate below 5.0 lb/hr and a concentration rate of 2.5 ppmvd (at 15% O₂) for oxides of nitrogen. This period shall be limited to 30 minutes per occurrence. The owner or operator shall record each period of start-up and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained at the facility for a minimum of five

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



years.

Parameter Monitored: DURATION OF START UP

Upper Permit Limit: 30 minutes

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 99: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 99.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 99.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Compliance with the PM/PM-10 limit was demonstrated during the initial compliance test and through manufacturer's specifications.

Upper Permit Limit: 3.0 pounds per hour

Reference Test Method: EPA Method 5

Monitoring Frequency: SINGLE OCCURRENCE

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 100: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 100.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Item 100.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Oxides of Nitrogen, NO_x, Continuous Emission Monitor is required. The limit of 80 pounds in 4 hours shall apply only during periods of shut down, not to be exceeded per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility excess emission report.

Manufacturer Name/Model Number: Rosemont analytical NGA CLD by Emerson.

Upper Permit Limit: 80 pounds

Reference Test Method: NA

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE - SEE MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 101: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 101.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 101.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Oxides of Nitrogen, NO_x, Continuous Emission Monitor is required. The limit of 200 pounds in 4 hours shall apply only during periods of start-up, not to be exceeded per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility excess emission report.

Manufacturer Name/Model Number: Rosemont analytical NGA CLD by Emerson.

Upper Permit Limit: 200 pounds

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Reference Test Method: NA
Monitoring Frequency: CONTINUOUS
Averaging Method: MINIMUM - NOT TO FALL BELOW STATED
VALUE - SEE MONITORING DESCRIPTION
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 102: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 102.1:
The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Item 102.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A start-up shall be defined as the period of time when the gas turbine begins firing fuel until the point when the control equipment operation has achieved a concentration rate of 2.5 ppmvd (at 15% O₂) for oxides of nitrogen. This period shall be limited to 4 hours per occurrence. The owner or operator shall record each period of start-up and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: DURATION OF START UP
Upper Permit Limit: 4 hours
Monitoring Frequency: CONTINUOUS
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER
OCCURRENCE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 103: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Item 103.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Item 103.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A shutdown shall be defined as the period of time when the stop signal is initiated to when the fuel is no longer being combusted in the engine, not to exceed 4 hours per occurrence. The owner or operator shall record each period of shutdown and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: DURATION OF SHUTDOWN

Upper Permit Limit: 4 hours

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER
OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 104: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 104.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):

CAS No: 007664-41-7 AMMONIA

Item 104.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This limit shall apply when the gas turbine is operating without the duct burner.

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Manufacturer Name/Model Number: Rosemont Analytical MLT 2000 by Emerson
Parameter Monitored: AMMONIA
Upper Permit Limit: 6.33 pounds per hour
Reference Test Method: 40CFR 60 Part 60
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 105: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 105.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 105.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This limit shall apply when the gas turbine is operating
with duct firing.

Manufacturer Name/Model Number: Rosemont Analytical MLT 2000 by Emerson
Parameter Monitored: AMMONIA
Upper Permit Limit: 9.70 pounds per hour
Reference Test Method: 40 CFR Prt 60
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 106: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 106.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 106.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This limit shall apply when the gas turbine is operating with duct firing.

Manufacturer Name/Model Number: Rosemont Analytical MLT 2000 by Emerson

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 10.30 pounds per hour

Reference Test Method: 40 CFR Part 60

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 107: Compliance Certification

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 107.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 107.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This limit shall apply when the gas turbine is operating in combined cycle with duct firing.

Manufacturer Name/Model Number: Rosemont analytical NGA CLD by Emerson.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 6.60 pounds per hour

Reference Test Method: 40 CFR Part 75

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



The initial report is due 10/30/2010.
Subsequent reports are due every 3 calendar month(s).

Condition 108: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 108.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 108.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This limit shall apply when gas turbine is operating
without duct firing

Manufacturer Name/Model Number: Rosemont Analytical MLT 2000 by Emerson

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 7.75 pounds per hour

Reference Test Method: 40 CFR Part 60

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 109: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 109.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 109.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Monitoring Description:

This facility shall install, calibrate, maintain, and operate a continuous 40CFR Part 75 emissions monitor for measuring and recording Oxides of Nitrogen. The facility shall also install either a continuous monitor for Oxygen or Carbon Dioxide. All records shall be maintained at the facility for at least five years. The 2.5 ppmvd limit for natural gas firing shall be applicable at all times except during periods of start-up or shutdown.

Manufacturer Name/Model Number: Rosemont analytical NGA CLD by Emerson.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 2.5 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40CFR Part 75

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

Condition 110: Compliance Certification
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 110.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):

CAS No: 007664-41-7 AMMONIA

Item 110.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator of this facility shall install, calibrate, maintain, and operate a continuous emission monitor for ammonia slip. Records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: Rosemont Analytical MLT 2000 by Emerson

Parameter Monitored: AMMONIA

Upper Permit Limit: 10 parts per million by volume (dry,
corrected to 15% O₂)

Reference Test Method: 40 CFR Part 60

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

New York State Department of Environmental Conservation

Permit ID: 1-2824-00947/00004

Facility DEC ID: 1282400947



Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).



STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS
The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 111: Contaminant List
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:ECL 19-0301

Item 111.1:
Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000124-38-9
Name: CARBON DIOXIDE



CAS No: 000630-08-0
Name: CARBON MONOXIDE

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 0NY075-00-0
Name: PARTICULATES

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

CAS No: 0NY998-00-0
Name: VOC

**Condition 112: Unavoidable noncompliance and violations
Effective between the dates of 09/30/2010 and 09/29/2015**

Applicable State Requirement:6 NYCRR 201-1.4

Item 112.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain



reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 113: Compliance Demonstration
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 113.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 113.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

This facility was previously limited to combined cycle operation. The facility will be allowed to operate in simple cycle mode. The same emission limits and monitoring requirements apply during either mode of operation. The facility will maintain a log that records the hours of operation under both combined and simple cycle modes. These records must be kept for a minimum of five years. This log must be kept at the facility and available for inspection by the Department.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 114: Air pollution prohibited
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 211.2

Item 114.1:



No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 115: Applicable Facility, with a unit of a capacity of 25 MWe or greater

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 237-1.4 (a)

Item 115.1:

Any unit, that at any time on or after January 1, 1999, serves a generator with a nameplate capacity equal to or greater than 25 MWe and sells any amount of electricity shall be a NOx budget unit, and any source that includes one or more such units shall be a NOx budget source, subject to the requirements of NYCRR 237

Condition 116: General condition (specifying 12 month submittal)

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 237-1.6 (a)

Item 116.1: The NOx authorized account representative of each NOx budget unit shall: Submit to the department a complete NOx budget permit application under NYCRR 237-3.3; twelve (12) months before the date on which the NOx Budget unit commences operation; and submit in a timely manner any supplemental information that the department determines is necessary in order to review a NOx budget permit application and issue or deny a NOx budget permit.

The owners and operators of each NOx budget unit shall have a NOx budget permit and operate the unit in compliance with such NOx budget permit.

Condition 117: Compliance Demonstration

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 237-1.6 (c)

Item 117.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 117.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators of each NOx budget source and each NOx budget unit at the source shall hold NOx allowances available for compliance deductions under NYCRR 237-6.5, as of the NOx allowance transfer deadline, in the unit's compliance account and the source's overdraft



account in an amount not less than the total NOx emissions for the control period from the unit, as determined in accordance with NYCRR 237-8.

Each ton of NOx emitted in excess of the NOx budget emissions limitation shall constitute a separate violation of applicable State law.

A NOx budget unit shall be subject to the requirements under NYCRR 237-1.6(c)(1) starting when the unit commences operation.

NOx allowances shall be held in, deducted from, or transferred among NOx Allowance Tracking System accounts in accordance with NYCRR 237-5, 237-6, 237-7, and 237-9.

Except for future control period NOx allowances which may be deducted pursuant to NYCRR 237-6.5(f), a NOx allowance shall not be deducted, in order to comply with the requirements under NYCRR 237-1.6(c)(1), for a control period in a year prior to the year for which the NOx allowance was allocated.

A NOx allowance allocated by the department under the Acid Deposition Reduction (ADR) NOx Budget Trading Program is a limited authorization to emit one ton of NOx in accordance with the ADR NOx Budget Trading Program. No provision of the ADR NOx Budget Trading Program, the NOx budget permit application, or the NOx budget permit or any provision of law shall be construed to limit the authority of the State to terminate or limit such authorization.

A NOx allowance allocated by the department under the ADR NOx Budget Trading Program does not constitute a property right.

The owners and operators of a NOx budget unit that has excess emissions in any control period shall: Forfeit the NOx allowances required for deduction under NYCRR 237-6.5(d)(1); and pay any fine, penalty, or assessment or comply with any other remedy imposed under NYCRR 237-6.5(d)(3).

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 118: Recordkeeping and Reporting Requirements
Effective between the dates of 09/30/2010 and 09/29/2015**

Applicable State Requirement:6 NYCRR 237-1.6 (e)



Item 118.1:

Unless otherwise provided, the owners and operators of the NOx budget source and each NOx budget unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the department:

- 1) The account certificate of representation for the NOx authorized account representative for the source and each NOx budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with NYCRR 237-2.4; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new account certificate of representation changing the NOx authorized account representative.
- 2) All emissions monitoring information, in accordance with NYCRR 237-8.
- 3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the ADR NOx Budget Trading Program.
- 4) Copies of all documents used to complete a NOx budget permit application and any other submission under the ADR NOx Budget Trading Program or to demonstrate compliance with the requirements of the ADR NOx Budget Trading Program.

The NOx authorized account representative of a NOx budget source and each NOx budget unit at the source shall submit the reports and compliance certifications required under the ADR NOx Budget Trading Program, including those under NYCRR 237-4, 237-8, or 237-9.

Condition 119: Liability- facility no common stacks
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 237-1.6 (f)

Item 119.1:

No permit revision shall excuse any violation of the requirements of the ADR NOx Budget Trading Program that occurs prior to the date that the revision takes effect.

Any provision of the ADR NOx Budget Trading Program that applies to a NOx budget source (including a provision applicable to the NOx authorized account representative of a NOx budget source) shall also apply to the owners and operators of such source and of the NOx budget units at the source.

Condition 120: Effect on other Authorities
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 237-1.6 (g)

Item 120.1:

No provision of the ADR NOx Budget Trading Program, a NOx budget permit application, or a NOx budget permit, shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the NOx authorized account representative of a NOx budget source or NOx budget unit from compliance with any other provisions of applicable State and federal law and regulations.



Condition 121: Authorization and responsibilities of the NOx authorized account representative to be included in existing permits.

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR Subpart 237-2

Item 121.1: Except as provided under NYCRR 237-2.2, each NOx budget source, including all NOx budget units at the source, shall have one and only one NOx authorized account representative, with regard to all matters under the Acid Deposition Reduction (ADR) NOx Budget Trading Program concerning the source or any NOx budget unit at the source.

The NOx authorized account representative of the NOx budget source shall be selected by an agreement binding on the owners and operators of the source and all NOx budget units at the source.

Upon receipt by the department or its agent of a complete account certificate of representation under NYCRR 237-2.4, the NOx authorized account representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the NOx budget source represented and each NOx budget unit at the source in all matters pertaining to the ADR NOx Budget Trading Program, notwithstanding any agreement between the NOx authorized account representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the NOx authorized account representative by the department or a court regarding the source or unit.

Each submission under the ADR NOx Budget Trading Program shall be submitted, signed, and certified by the NOx authorized account representative for each NOx budget source on behalf of which the submission is made. Each such submission shall include the following certification statement by the NOx authorized account representative: "I am authorized to make this submission on behalf of the owners and operators of the NOx budget sources or NOx budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

Condition 122: Compliance Demonstration

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 237-4.1

Item 122.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 122.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:



For each control period in which one or more NOx budget units at a source are subject to the NOx budget emissions limitation, the NOx authorized account representative of the source shall submit to the department by the September 30 following the relevant control period, a compliance certification report for each source covering all such units.

The NOx authorized account representative shall include in the compliance certification report the following elements, in a format prescribed by the department, concerning each unit at the source and subject to the NOx budget emissions limitation for the control period covered by the report:

- (1) identification of each NOx budget unit;
- (2) except in instances when the NOx budget unit seeks to use future control period NOx allowances which may be deducted pursuant to NYCRR 237-6.5(f), at the NOx authorized account representative's option, the serial numbers of the NOx allowances that are to be deducted from each unit's compliance account under NYCRR 237-6.5 for the control period;
- (3) at the NOx authorized account representative's option, for units sharing a common stack and having NOx emissions that are not monitored separately or apportioned in accordance with NYCRR 237-8, the percentage of NOx allowances that is to be deducted from each unit's compliance account under NYCRR 237-6.5(e);
- (4) for units using future control period allowances for compliance purposes pursuant to NYCRR 237-6.5(f), the statement of intent and report required under NYCRR 237-6.5(f)(2); and
- (5) the compliance certification under NYCRR 237-4(c).

In the compliance certification report the NOx authorized account representative shall certify, based on reasonable inquiry of those persons with primary responsibility for operating the source and the NOx budget units at the source in compliance with the Acid Deposition Reduction (ADR) NOx Budget Trading Program, whether each NOx budget unit for which the compliance certification is submitted was operated during the calendar year covered by the report in compliance with the requirements of the ADR NOx Budget Trading Program applicable to the unit, including:

- (a) whether the unit was operated in compliance with the



NOx budget emissions limitation;

(b) whether the monitoring plan that governs the unit has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute NOx emissions to the unit, in accordance with NYCRR 237-8;

(c) whether all the NOx emissions from the unit, or a group of units (including the unit) using a common stack, were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with NYCRR 237-8. If conditional data were reported, the owner or operator shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;

(d) whether the facts that form the basis for certification under NYCRR 237-8 of each monitor at the unit or a group of units (including the unit) using a common stack, or for using an excepted monitoring method or alternative monitoring method approved under NYCRR 237-8, if any, has changed; and

(e) if a change is required to be reported in (4) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor recertification.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 123: Submission of NOx allowance transfers
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 237-7.1

Item 123.1:

The NOx authorized account representatives seeking recordation of a NOx allowance transfer shall submit the transfer to the department or its agent. To be considered correctly submitted, the NOx allowance transfer shall include the following elements in a format specified by the department or its agent:

(a) the numbers identifying both the transferor and transferee accounts;

(b) a specification by serial number of each NOx allowance to be transferred; and

(c) the printed name and signature of the NOx authorized account representative of the transferor account and the date signed.



Condition 124: Compliance Demonstration
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR Subpart 237-8

Item 124.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 124.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators, and to the extent applicable, the NOx authorized account representative of a NOx budget unit, shall comply with the monitoring and reporting requirements as provided in this NYCRR 237-8 and in Subpart H of 40 CFR part 75. For purposes of complying with such requirements, the definitions in NYCRR 237-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," and "designated representative" in 40 CFR part 75 shall be replaced by the terms "NOx budget unit," and "NOx authorized account representative," respectively, as defined in section 237-1.2.

For any NOx budget unit which is also a NOx budget unit under Part 204 of this title, prior or contemporaneous timely submissions in compliance with the requirements of Subpart 204-8 may, when appropriate, be summarily referenced by the owners and operators of the NOx budget unit in order to demonstrate compliance with the requirements of this Subpart:

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 125: Permit requirements to be included in new permits or units only

Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-1.6 (a)

Item 125.1:

The SO2 authorized account representative of each SO2 budget unit shall:

- (i) submit to the department a complete SO2 budget permit application under section 238-3.3 in accordance with the deadlines specified in NYCRR 238-3.2, which states the later of October 1, 2004 or 12 months before the date on which the SO2 budget unit commences operation;



(ii) submit in a timely manner any supplemental information that the department determines is necessary in order to review an SO₂ budget permit application and issue or deny an SO₂ budget permit.

The owners and operators of each SO₂ budget unit shall have an SO₂ budget permit and operate the unit in compliance with such SO₂ budget permit.

Condition 126: Compliance Demonstration
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-1.6 (c)

Item 126.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 126.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners and operators of each SO₂ budget source and each SO₂ budget unit at the source shall hold SO₂ allowances available for compliance deductions under NYCRR 238-6.5, as of the SO₂ allowance transfer deadline, in the unit's compliance account and the source's overdraft account in an amount not less than the total SO₂ emissions for the control period from the unit, as determined in accordance with NYCRR 238-8.

Each ton of sulfur dioxide emitted in excess of the SO₂ budget emissions limitation shall constitute a separate violation of this Part, the Act, and applicable State law.

An SO₂ budget unit shall be subject to the requirements under NYCRR 1.6 (c)(1) on the date on which the unit commences operation.

SO₂ allowances shall be held in, deducted from, or transferred among SO₂ Allowance Tracking System accounts in accordance with NYCRR 238-5, 238-6, and 238-7.

Except for future control period SO₂ allowances which may be deducted pursuant to NYCRR 238-6.5(f), an SO₂ allowance shall not be deducted, in order to comply with the requirements under NYCRR 238-1.6(c)(1) for a control period in a year prior to the year for which the SO₂ allowance was allocated.

An SO₂ allowance allocated by the department under the ADR SO₂ budget Trading Program is a limited authorization to



emit one ton of sulfur dioxide in accordance with the Acid Deposition Reduction (ADR) SO₂ Budget Trading Program. No provision of the ADR SO₂ Budget Trading Program, the SO₂ budget permit application, or the SO₂ budget permit or any provision of law shall be construed to limit the authority of the United States or the State to terminate or limit such authorization.

An SO₂ allowance allocated by the department under the ADR SO₂ Budget Trading Program does not constitute a property right.

The owners and operators of an SO₂ budget unit that has excess emissions in any control period shall: Forfeit the SO₂ allowances required for deduction under NYCRR 238-6.5(d)(1); and Pay any fine, penalty, or assessment or comply with any other remedy imposed under NYCRR 238-6.5(d)(3).

Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2011.
Subsequent reports are due every 12 calendar month(s).

Condition 127: Record keeping and Reporting Requirements
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-1.6 (e)

Item 127.1:

Unless otherwise provided, the owners and operators of the SO₂ budget source and each SO₂ budget unit at the source shall keep on site or at a site approved by the Department each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the department.

The account certificate of representation for the SO₂ authorized account representative for the source and each SO₂ budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with NYCRR 238-2.4; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new account certificate of representation changing the SO₂ authorized account representative;

All emissions monitoring information, in accordance with NYCRR 238-8;

Copies of all reports, compliance certifications, and other submissions and all records made or required under the ADR SO₂ Budget Trading Program;

Copies of all documents used to complete an SO₂ budget permit application and any other submission under the ADR SO₂ Budget Trading Program or to demonstrate compliance with the requirements of the ADR SO₂ Budget Trading Program;

The SO₂ authorized account representative of an SO₂ budget source and each SO₂ budget unit



at the source shall submit the reports and compliance certifications required under the ADR SO2 Budget Trading Program, including those under NYCRR 238-4, or 238-8.

Condition 128: Liability
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-1.6 (f)

Item 128.1:

No permit revision shall excuse any violation of the requirements of the ADR SO2 Budget Trading Program that occurs prior to the date that the revision takes effect.

Any provision of the ADR SO2 Budget Trading Program that applies to an SO2 budget source (including a provision applicable to the SO2 authorized account representative of an SO2 budget source) shall also apply to the owners and operators of such source and of the SO2 budget units at the source;

Any provision of the ADR SO2 Budget Trading Program that applies to an SO2 budget unit (including a provision applicable to the SO2 authorized account representative of an SO2 budget unit) shall also apply to the owners and operators of such unit. Except with regard to the requirements applicable to units with a common stack under Subpart 238-8, the owners and operators and the SO2 authorized account representative of one SO2 budget unit shall not be liable for any violation by any other SO2 budget unit of which they are not owners or operators or the SO2 authorized account representative and that is located at a source of which they are not owners or operators or the SO2 authorized account representative.

Condition 129: Effect on Other Authorities
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-1.6 (g)

Item 129.1:

No provision of the ADR SO2 Budget Trading Program, an SO2 budget permit application, or an SO2 budget permit, shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the SO2 authorized account representative of an SO2 budget source or SO2 budget unit from compliance with any other provisions of applicable State and federal law and regulation.

Condition 130: Submissions to the Department
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-2.1

Item 130.1:

Each submission under the Acid Deposition Reduction (ADR) SO2 Budget Trading Program shall be submitted, signed, and certified by the SO2 authorized account representative for each SO2 budget source on behalf of which the submission is made. Each such submission shall include the following certification statement by the SO2 authorized account representative:

"I am authorized to make this submission on behalf of the owners and operators of the SO2 budget sources or SO2 budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information



submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

Condition 131: Compliance Demonstration
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-4.1

Item 131.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 131.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

For each control period in which one or more SO₂ budget units at a source are subject to the SO₂ budget emissions limitation, the SO₂ authorized account representative of the source shall submit to the Department by the March 1 following the relevant control period, a compliance certification report for each source covering all such units; as per NYCRR 238-4.

The SO₂ authorized account representative shall include in the compliance certification the following elements, in a format prescribed by the department, concerning each unit at the source and subject to the SO₂ budget emissions limitation for the control period covered by the report:

- (1) identification of each SO₂ budget unit;
- (2) except in instances when the SO₂ budget unit seeks to use future control period SO₂ allowances which may be deducted pursuant to NYCRR 238-6.5(f), at the SO₂ authorized account representative's option, the serial numbers of the SO₂ allowances that are to be deducted from each unit's compliance account under NYCRR 238-6.5 for the control period;
- (3) at the SO₂ authorized account representative's option, for units sharing a common stack and having SO₂ emissions that are not monitored separately or apportioned in accordance with NYCRR 238-8, the percentage of SO₂ allowances that is to be deducted from each unit's compliance account under NYCRR 238-6.5(e);



(4) for units using future control period allowances for compliance purposes pursuant to NYCRR 238-6.5(f), the statement of intent and report required under NYCRR 238-6.5(f)(2); and

(5) the compliance certification under NYCRR 238-4.1(c).

In the compliance certification report, the SO₂ authorized account representative shall certify, based on reasonable inquiry of those persons with primary responsibility for operating the source and the SO₂ budget units at the source in compliance with the ADR SO₂ Budget Trading Program, whether each SO₂ budget unit for which the compliance certification is submitted was operated during the calendar year covered by the report in compliance with the requirements of the ADR SO₂ Budget Trading Program applicable to the unit, including:

(a) whether the unit was operated in compliance with the SO₂ budget emissions limitation;

(b) whether the monitoring plan that governs the unit has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute SO₂ emissions to the unit, in accordance with Subpart 238-8;

(c) whether all the SO₂ emissions from the unit, or a group of units (including the unit) using a common stack, were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with Subpart 238-8. If conditional data were reported, the owner or operator shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;

(d) whether the facts that form the basis for certification under Subpart 238-8 of each monitor at the unit or a group of units (including the unit) using a common stack, or for using an excepted monitoring method or alternative monitoring method approved under Subpart 238-8, if any, has changed; and

(e) if a change is required to be reported under (4) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor



recertification.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 132: Submission of SO₂ allowance transfers
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 238-7.1

Item 132.1:

The SO₂ authorized account representatives seeking recordation of an SO₂ allowance transfer shall submit the transfer to the department or its agent. To be considered correctly submitted, the SO₂ allowance transfer shall include the following elements in a format specified by the department or its agent:

- (a) the numbers identifying both the transferor and transferee accounts;
- (b) a specification by serial number of each SO₂ allowance to be transferred; and
- (c) the printed name and signature of the SO₂ authorized account representative of the transferor account and the date signed.

Condition 133: Monitoring and Reporting requirements
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR Subpart 238-8

Item 133.1: The owners and operators, and to the extent applicable, the SO₂ authorized account representative of an SO₂ budget unit, shall comply with the monitoring and reporting requirements as provided for in all applicable sections of 40 CFR part 75. For purposes of complying with such requirements, the definitions in NYCRR 238-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," and "designated representative" in 40 CFR part 75 shall be replaced by the terms "SO₂ budget unit," and "SO₂ authorized account representative," respectively, as defined in NYCRR 238-1.2.

Condition 134: CO₂ Budget Trading Program - Excess emission requirements
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement:6 NYCRR 242-1.5

Item 134.1:

The owners and operators of a CO₂ budget source that has excess emissions in any control period shall:

- (1) forfeit the CO₂ allowances required for deduction under 6 NYCRR Part 242-6.5(d)(1), provided CO₂ offset allowances may not be used to cover any part of such excess emissions; and
- (2) pay any fine, penalty, or assessment or comply with any other remedy imposed under 6 NYCRR Part 242-6.5(d)(2).



Condition 135: Compliance Demonstration
Effective between the dates of 09/30/2010 and 09/29/2015

Applicable State Requirement: 6 NYCRR 242-8.5

Item 135.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 000124-38-9 CARBON DIOXIDE

Item 135.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Recordkeeping and Reporting (6NYCRR Part 242-8.5)

(a) General provisions. The CO₂ authorized account representative shall comply with all recordkeeping and reporting requirements in this section, the applicable record keeping and reporting requirements under 40 CFR 75.73 and with the requirements of section 242-2.1(e) of this Part.

(b) Monitoring plans. The owner or operator of a CO₂ budget unit shall submit a monitoring plan in the manner prescribed in 40 CFR 75.62.

(c) Certification applications. The CO₂ authorized account representative shall submit an application to the department within 45 days after completing all CO₂ monitoring system initial certification or recertification tests required under section 242-8.2 of this Subpart including the information required under 40 CFR 75.63 and 40 CFR 75.53(e) and (f).

(d) Quarterly reports. The CO₂ authorized account representative shall submit quarterly reports, as follows:

(1) The CO₂ authorized account representative shall report the CO₂ mass emissions data and heat input data for the CO₂ budget unit, in an electronic format prescribed by the administrator unless otherwise prescribed by the department for each calendar quarter.

(2) The CO₂ authorized account representative shall submit each quarterly report to the department or its agent within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in subpart H of 40 CFR part 75 and 40 CFR 75.64. Quarterly reports shall be submitted for each CO₂ budget unit (or group of units



using a common stack), and shall include all of the data and information required in subpart G of 40 CFR part 75, except for opacity, NO_x, and SO₂ provisions.

(3) The CO₂ authorized account representative shall submit to the department or its agent a compliance certification in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(i) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR part 75, including the quality assurance procedures and specifications;

(ii) for a unit with add-on CO₂ emissions controls and for all hours where data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emissions controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B of 40 CFR part 75 and the substitute values do not systematically underestimate CO₂ emissions; and

(iii) the CO₂ concentration values substituted for missing data under Subpart D of 40 CFR part 75 do not systematically underestimate CO₂ emissions.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2010.

Subsequent reports are due every 3 calendar month(s).

