



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air State Facility
Permit ID: 1-2824-01747/00003
Mod 0 Effective Date: 07/19/2005 Expiration Date: No expiration date.
Mod 1 Effective Date: 04/16/2008 Expiration Date: No expiration date.

Permit Issued To: STATE UNIVERSITY OF NEW YORK
STATE UNIVERSITY PLAZA
381 BROADWAY
ALBANY, NY 12246

Contact: TIMOTHY MCGARRY
SUNY OLD WESTBURY
PO BOX 210
OLD WESTBURY, NY 11568-0210
(516) 876-3184

Facility: SUNY OLD WESTBURY
223 STORE HILL RD
OLD WESTBURY, NY 11568

Contact: WILLIAM A KIMMINS
SUNY OLD WESTBURY
223 STORE HILL RD PO BOX 210
OLD WESTBURY, NY 11568-0210
(516) 876-3270

Description:

This application is for the addition of an emission point consisting of a lithographic printer located in the Print Shop of the Campus Center Building. There are two hot water boilers burning natural gas or No. 2 oil. One boiler is rated at 63.3 mmBtu/hr and the other at 31.65 mmBtu/hr. There is also a 1780 KW lean-burn gas-fired engine cogenerating hot water to generate electricity for the campus. Some campus buildings have exempt (less than 10 mmbtu/hr) boilers/hot water heaters. Also there are exempt emergency generators. The applicant is seeking to cap the potential to emit (PTE) under Part 201-7.2 of the facility NOx emissions to 45000 lbs/yr.

New York State Department of Environmental Conservation
Facility DEC ID: 1282401747



By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: SUSAN ACKERMAN
 NYSDEC - REGION 1 SUNY @ STONY BROOK
 50 CIRCLE RD
 STONY BROOK, NY 11790-3409

Authorized Signature: _____ Date: ___ / ___ / _____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
 - Applications for permit renewals, modifications and transfers
 - Applications for Permit Renewals and Modifications
 - Permit modifications, suspensions or revocations by the Department
 - Permit Modifications, Suspensions and Revocations by the Department

Facility Level

- Submission of Applications for Permit Modification or Renewal-REGION 1 HEADQUARTERS
- Submission of application for permit modification or renewal-REGION 1 HEADQUARTERS



DEC GENERAL CONDITIONS
****** General Provisions ******
GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 1-1: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6 NYCRR 621.11

Item 1-1.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 1-1.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 1-1.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.



Condition 3: Applications for Permit Renewals and Modifications

Applicable State Requirement: 6 NYCRR 621.13

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 1-2: Permit modifications, suspensions or revocations by the Department

Applicable State Requirement: 6 NYCRR 621.13

Item 1-2.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

Condition 4: Permit Modifications, Suspensions and Revocations by the Department

Applicable State Requirement: 6 NYCRR 621.14

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental



conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;

e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of Applications for Permit Modification or Renewal-REGION 1 HEADQUARTERS

Applicable State Requirement: 6 NYCRR 621.5 (a)

Expired by Mod No: 1

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
SUNY Campus, Loop Road, Building 40
Stony Brook, NY 11790-2356
(631) 444-0365

Condition 1-3: Submission of application for permit modification or renewal-REGION 1

HEADQUARTERS

Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 1-3.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409
(631) 444-0365

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



Permit Under the Environmental Conservation Law (ECL)

**ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY
PERMIT**

IDENTIFICATION INFORMATION

Permit Issued To: STATE UNIVERSITY OF NEW YORK
STATE UNIVERSITY PLAZA
381 BROADWAY
ALBANY, NY 12246

Facility: SUNY OLD WESTBURY
223 STORE HILL RD
OLD WESTBURY, NY 11568

Authorized Activity By Standard Industrial Classification Code:
8221 - COLLEGES AND UNIVERSITIES, NEC

Mod 0 Permit Effective Date: 07/19/2005
date.

Permit Expiration Date: No expiration

Mod 1 Permit Effective Date: 04/16/2008
date.

Permit Expiration Date: No expiration



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1-1 6 NYCRR 201-7.2: Facility Permissible Emissions
- *1-2 6 NYCRR 201-7.2: Capping Monitoring Condition
- 1-3 6 NYCRR 225-1.2 (d): Compliance Demonstration
- 1-4 6 NYCRR 227-1.3 (a): Compliance Demonstration
- 1-5 6 NYCRR 234.1 (g): Facilities subject to Part 234 remain subject even if emissions go below applicability threshold
- 1-6 6 NYCRR 234.4 (b) (3): Compliance Demonstration
- 1-7 6 NYCRR 234.5 (a): Prohibition of Sale or Specification
- 1-8 6 NYCRR 234.6: Compliance Demonstration

Emission Unit Level

EU=U-00001

- 4 40CFR 60.40c, NSPS Subpart Dc: Applicability of this Subpart to this emission source
- 7 40CFR 60.48c(a), NSPS Subpart Dc: Compliance Demonstration

EU=U-00001,EP=EP002,Proc=OIL,ES=B0002

- 1-9 6 NYCRR 227.2 (b) (1): Compliance Demonstration

EU=U-00003

- 1-10 6 NYCRR 234.3 (b) (1): Compliance Demonstration
- 1-11 6 NYCRR 234.3 (e): Compliance Demonstration

EU=U-00003,Proc=LIT

- 1-12 6 NYCRR 234.5 (a): prohibition of sale or specification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 10 ECL 19-0301: Contaminant List
- 11 6 NYCRR 201-1.4: Unavoidable noncompliance and violations
- 12 6 NYCRR Subpart 201-5: Emission Unit Definition
- 13 6 NYCRR 201-7.2: Facility Permissible Emissions
- *14 6 NYCRR 201-7.2: Capping Monitoring Condition
- 15 6 NYCRR 211.2: Air pollution prohibited

Emission Unit Level

- 16 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
- 17 6 NYCRR Subpart 201-5: Process Definition By Emission Unit

NOTE: * preceding the condition number indicates capping.



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Sealing - 6 NYCRR 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6 NYCRR 200.7

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications,



required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2

If an existing emission source was subject to the permitting requirements of 6 NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

Item E: Recycling and Salvage - 6 NYCRR 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item F: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item G: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item H: Proof of Eligibility for Sources Defined as Trivial



All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS

The following conditions are federally enforceable.

Condition 1-1: Facility Permissible Emissions
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 201-7.2

Item 1-1.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 (From Mod 1) PTE: 45,000 pounds
per year

Name: OXIDES OF NITROGEN

Condition 1-2: Capping Monitoring Condition
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 201-7.2

Item 1-2.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6

Item 1-2.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 1-2.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart,



New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747

during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 1-2.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 1-2.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 1-2.6:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 1-2.7:

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Facility NOx emissions shall not exceed 45000 pounds per year by limiting the fuels combusted in the boilers, the lean-burn gas fired cogeneration engine, and the emergency generator engines.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: NUMBER 2 OIL

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 45000 pounds per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2009.

Subsequent reports are due every 12 calendar month(s).

Condition 1-3: Compliance Demonstration
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 225-1.2 (d)

Item 1-3.1:

The Compliance Demonstration activity will be performed for the Facility.

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 1-3.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

THE DISTILLATE NO. 2 OIL SUPPLIER WILL PROVIDE SULFUR ANALYSIS TO SHOW COMPLIANCE WITH THE 0.37% SULFUR LIMIT

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.37 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2009.

Subsequent reports are due every 12 calendar month(s).

Condition 1-4: Compliance Demonstration
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)

Item 1-4.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 1-4.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (six minute average), except for one-six-minute period per hour of not more than 27 percent opacity.

The Department reserves the right to perform or require the performance of a Method 9 opacity evaluation at any time during facility operation.

The permittee will conduct observations of visible emissions from the emission unit, process, etc. to which this condition applies at the monitoring frequency stated below while the process is in operation. The permittee



will investigate, in a timely manner, any instance where there is cause to believe that visible emissions have the potential to exceed the opacity standard.

The permittee shall investigate the cause, make any necessary corrections, and verify that the excess visible emissions problem has been corrected. If visible emissions with the potential to exceed the standard continue, the permittee will conduct a Method 9 assessment within the next operating day of the sources associated with the potential noncompliance to determine the degree of opacity and will notify the NYSDEC if the method 9 test indicates that the opacity standard is not met.

Records of visible emissions observations (or any follow-up method 9 tests), investigations and corrective actions will be kept on-site. Should the Department determine that permittee's record keeping format is inadequate to demonstrate compliance with this condition, it shall provide written notice to the permittee stating the inadequacies, and permittee shall have 90 days to revise its prospective record keeping format in a manner acceptable to the Department.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2009.
Subsequent reports are due every 12 calendar month(s).

Condition 1-5: Facilities subject to Part 234 remain subject even if emissions go below applicability threshold
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 234.1 (g)

Item 1-5.1:

Any printing process that is subject to the provisions of 6NYCRR Part 234 will remain subject to these provisions even if the emissions of volatile organic compounds from the facility later fall below the applicability criteria.

Condition 1-6: Compliance Demonstration
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 234.4 (b) (3)

Item 1-6.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



CAS No: 0NY998-00-0 VOC

Item 1-6.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Purchase, usage and/or production records of inks, VOC and solvents must be maintained in a format acceptable to the commissioner's representative, and upon request, these records must be submitted to the Department's representative. In addition, any other information required to determine compliance with 6NYCRR Part 234 must be provided to the Commissioner's representative in a format acceptable to him or her. Records must be maintained at the facility for a period of five years.

The facility shall maintain the following records for each ink, cleaning solvent, and other VOC used in the printing process, on a monthly basis:

1. The brand and product name or code for the material.
2. The quantity of material used during the calendar month.
3. The VOC content of the material.

In addition, copies of all purchase orders, invoices, and other documents for supplies and equipment that are used to support the monthly log are to be kept on site.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 1-7: Prohibition of Sale or Specification

Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 234.5 (a)

Item 1-7.1:

No person shall sell, specify, or require for use, the application of a coating or ink on a substrate at a facility with a printing process subject to the volatile organic compound control requirements of 6 NYCRR Part 234 if such use is prohibited by any of the provisions of this Part. The prohibition of this section shall apply to all written or oral contracts under the terms of which any coating or ink is to be applied to any substrate at any affected facility. This prohibition shall not apply to the following:

- (1) coatings and/or inks utilized at printing processes where control equipment



has been installed to achieve compliance;

(2) coatings and/or inks utilized at printing processes that have been granted variances for reasons of technological and economic feasibility.

Condition 1-8: Compliance Demonstration
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 234.6

Item 1-8.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 1-8.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The following work practices are prohibited:

(a) using open containers to store or dispose of cloth or paper impregnated with VOC and/or solvents that are used for surface preparation, cleanup or ink/coating removal;

(b) storage in open containers of spent or fresh VOC and/or solvents to be used for surface preparation, cleanup or ink/coating removal;

(c) use of open containers to store or dispose of inks and/or surface coatings; or

(d) use of open containers to store or dispense inks and/or surface coatings unless production, sampling, maintenance or inspection procedures require operational access. This provision does not apply to the actual device or equipment designed for the purposes of applying an ink or coating to a substrate.

To ensure that these work practices are not in use, the facility will conduct daily inspections for the presence of any open containers as described in the prohibitions above and maintain a log book of these inspections. Any such open containers shall be closed immediately. The log book should include the following information at a minimum:

- date and time of inspection
- items or areas observed
- corrective measures taken, if

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



necessary.

Monitoring Frequency: DAILY
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2008.
Subsequent reports are due every 6 calendar month(s).

****** Emission Unit Level ******

Condition 4: Applicability of this Subpart to this emission source
Effective between the dates of 07/19/2005 and Permit Expiration Date

Applicable Federal Requirement:40CFR 60.40c, NSPS Subpart Dc

Item 4.1:

This Condition applies to Emission Unit: U-00001

Item 4.2:

This emission source is subject to the applicable General Provisions of 40 CFR 60 Subpart Dc. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements.

Condition 7: Compliance Demonstration
Effective between the dates of 07/19/2005 and Permit Expiration Date

Applicable Federal Requirement:40CFR 60.48c(a), NSPS Subpart Dc

Item 7.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Item 7.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner and operator of each affected facility shall submit notification of the date of construction or reconstruction, anticipated startup, and actual startup, as provided by 40 CFR 60.7 of this part. This notification shall include:

(1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.

(2) If applicable, a copy of any Federally enforceable



New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747

requirement that limits the annual capacity factor for any fuel or mixture of fuels under 40 CFR 60.42c., or 40 CFR 60.43c.

(3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.

Monitoring Frequency: SINGLE OCCURRENCE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 1-9: Compliance Demonstration
Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 227.2 (b) (1)

Item 1-9.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Emission Point: EP002

Process: OIL

Emission Source: B0002

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 1-9.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

This emission source, International Boiler/WR1-1A 63 mmBtu/hr boiler, shall be tested for particulate matter to demonstrate compliance with the 0.10 lb/mmBtu-hr limit as required by 6NYCRR Part 227, Section 227.2(b).

This requirement shall take place within 180 days after the effective date of current modified Air State Facility permit.

The facility shall perform the following:

1- Submit to the Department an acceptable protocol for the testing of particulates emissions in a manner that will determine compliance with the limit cited in this condition.

2-Perform a stack test, based on approved test protocol, to determine compliance with the particulate emission limit established in this condition.

3-Submit an acceptable stack test report that outlines the results obtained during the test.

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



4-Facility shall keep records of all testing done at the boiler for a period of five years.

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: 40 CFR 60 Method 5

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: 2-HOUR BLOCK AVERAGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 1-10: Compliance Demonstration

Effective between the dates of 04/16/2008 and Permit Expiration Date

Applicable Federal Requirement:6 NYCRR 234.3 (b) (1)

Item 1-10.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 1-10.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Any owner or operator of an offset lithographic printing process subject to 6NYCRR Part 234 and employing fountain solutions containing volatile organic compounds shall not operate, cause, allow, or permit the operation of such process unless one of the control strategies specified in Part 234.3(b) are employed. Continuing compliance shall be verified by maintaining records of formulation data as specified in 6 NYCRR §234.4(b)(2) and (3). These records shall contain the following information:

1. Certification from the fountain solution supplier/manufacturer which verifies the composition of the fountain solution solvent/volatiles, if supported by actual batch records,
2. Purchase, usage, and/or production records of the fountain solutions and solvents.
3. Any other parameters used to verify compliance.

Upon request by DEC, the permittee shall perform Method 24 analyses (or supply samples to DEC for analysis) to verify the VOC content and volatile fraction of the fountain solutions. When there is any discrepancy between the calculated formulation and the Method 24 results, the Method 24 results shall be used for compliance



Applicable Federal Requirement:6 NYCRR 234.5 (a)

Item 1-12.1:

This Condition applies to Emission Unit: U-00003
Process: LIT

Item 1-12.2:

No person shall sell, specify, or require for use, the application of a coating or ink on a substrate at a facility with a printing process subject to the volatile organic compound control requirements of 6 NYCRR Part 234 if such use is prohibited by any of the provisions of this Part. The prohibition of this section shall apply to all written or oral contracts under the terms of which any coating or ink is to be applied to any substrate at any affected facility. This prohibition shall not apply to the following:

(1) coatings and/or inks utilized at printing processes where control equipment has been installed to achieve compliance;

(2) coatings and/or inks utilized at printing processes that have been granted variances for reasons of technological and economic feasibility.



STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)

Where emission source owners and/or operators keep records pursuant to compliance with the operational flexibility requirements of 6 NYCRR Subpart 201-5.4(b)(1), and/or the emission capping requirements of 6 NYCRR Subparts 201-7.2(d), 201-7.3(f), 201-7.3(g), 201-7.3(h)(5), 201-7.3(i) and 201-7.3(j), the Department



will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Emission source owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department of receipt of the request.

Item C: **General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state only enforceable.

Condition 10: Contaminant List
Effective between the dates of 07/19/2005 and Permit Expiration Date

Applicable State Requirement:ECL 19-0301

Item 10.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 0NY075-00-0
Name: PARTICULATES

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

CAS No: 0NY998-00-0
Name: VOC

Condition 11: Unavoidable noncompliance and violations
Effective between the dates of 07/19/2005 and Permit Expiration Date

Applicable State Requirement: 6 NYCRR 201-1.4

Item 11.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 12: Emission Unit Definition
Effective between the dates of 07/19/2005 and Permit Expiration Date

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 12.1(From Mod 1):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

End Date: 12/31/2014

Emission Unit Description:

This emission unit consists of two (2) package boilers burning natural gas or No. 2 Oil. One boiler is rated at 63.3 mmBtu/hr and the other at 31.65 mmBtu/hr. Each boiler exhausts above the building roof through its own stack.

Building(s): HP

Item 12.2(From Mod 1):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00002

Emission Unit Description:

This emission unit consists of a cogeneration engine rated at 1780 KW burning natural gas fuel only. The maximum heat input is 14.7 mm Btu/hr. Use of lean burn technology will control emissions to 0.6 gr/bhp. The cogeneration engine exhausts above the building roof through its own stack.

Building(s): HP

Item 12.3(From Mod 1):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00003

End Date: 12/31/2014

Emission Unit Description:

This emission unit consists of a lithographic printer that uses approximately 1.75 gallons of ink per month.

Building(s): 51

Condition 13: Facility Permissible Emissions
Effective between the dates of 07/19/2005 and Permit Expiration Date

Applicable State Requirement:6 NYCRR 201-7.2

Item 13.1:

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 (From Mod 1) PTE: 45,000 pounds
per year

Name: OXIDES OF NITROGEN

Condition 14: Capping Monitoring Condition
Effective between the dates of 07/19/2005 and Permit Expiration Date

Applicable State Requirement: 6 NYCRR 201-7.2

Item 14.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6

Item 14.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 14.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 14.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 14.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 14.6:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

New York State Department of Environmental Conservation

Permit ID: 1-2824-01747/00003

Facility DEC ID: 1282401747



Process Description:

DISTILLATE NO. 2 OIL IS BURNED IN THE TWO
BOILERS UNDER THIS PROCESS.

Emission Source/Control: B0001 - Combustion Removal Date: 07/05/2011
Design Capacity: 63.3 million Btu per hour

Emission Source/Control: B0002 - Combustion Removal Date: 12/31/2014
Design Capacity: 31.65 million Btu per hour

Item 17.3(From Mod 1):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002

Process: ENG

Process Description:

NATURAL GAS FUEL IS BURNED IN THE
LEAN-BURN ENGINE UNDER THIS PROCESS.

Emission Source/Control: COGEN - Combustion
Design Capacity: 1,780 kilowatts

Item 17.4(From Mod 1):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003

Process: LIT

Process End Date: 12/31/2014

Process Description:

This emission source consists of VOC's emitted during use
of lithographic printer.

Emission Source/Control: U0003 - Process Removal Date: 12/31/2014
Design Capacity: 1.75 pounds per month

