



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 1-4720-01046/00004
Effective Date:

Expiration Date:

Permit Issued To: NATIONAL GRID GENERATION LLC
175 E OLD COUNTRY RD
HICKSVILLE, NY 11801

Facility: WEST BABYLON GT FACILITY
RAILROAD AVE
WEST BABYLON, NY 11704

Contact: PAUL A LYNCH
KEYSPAN CORP - ENVIRON ENGINEERING
175 E OLD COUNTRY RD
HICKSVILLE, NY 11801-4280

Description:

This is a renewal and modification of the Title V Permit for this facility to renew the permit for 5 more years, and to add conditions developed in response to the United States Environmental Protection Agency's (EPA's) recent "Clean Air Interstate Rule" (CAIR). This facility consists of a single combustion turbine maintained on site to meet load demand and emergency power requirements, #1 and #2 fuel oil tanks, and several smaller tanks used for storing distillate, lubrication and/or dielectric oils.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: SUSAN ACKERMAN
NYSDEC - SUNY @ STONY BROOK
50 CIRCLE RD
STONY BROOK, NY 11790-3409

Authorized Signature: _____ Date: ___ / ___ / ___



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department
Relationship of this Permit to Other Department Orders and
Determinations
Applications for permit renewals, modifications and transfers
Permit modifications, suspensions or revocations by the Department
Permit modifications, suspensions or revocations by the Department

Facility Level

Submission of application for permit modification or renewal - REGION
1 HEADQUARTERS



DEC GENERAL CONDITIONS

**** General Provisions ****

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301.2(m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.



Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6NYCRR 621.13

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

Condition 5: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6NYCRR 621.13

Item 5.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 6: Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS
Applicable State Requirement: 6NYCRR 621.6(a)

Item 6.1:

Applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409
(631) 444-0365



Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: NATIONAL GRID GENERATION LLC
175 E OLD COUNTRY RD
HICKSVILLE, NY 11801

Facility: WEST BABYLON GT FACILITY
RAILROAD AVE
WEST BABYLON, NY 11704

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Permit Effective Date:

Permit Expiration Date:



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6NYCRR 201-6.5(a)(7): Fees
- 3 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 4 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 6 6NYCRR 201-6.5(e): Compliance Certification
- 7 6NYCRR 202-2.1: Compliance Certification
- 8 6NYCRR 202-2.5: Recordkeeping requirements
- 9 6NYCRR 215: Open Fires Prohibited at Industrial and Commercial Sites
- 10 6NYCRR 200.7: Maintenance of Equipment
- 11 6NYCRR 201-1.7: Recycling and Salvage
- 12 6NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6NYCRR 201-3.2(a): Exempt Sources - Proof of Eligibility
- 14 6NYCRR 201-3.3(a): Trivial Sources - Proof of Eligibility
- 15 6NYCRR 201-6.5(a)(4): Standard Requirement - Provide Information
- 16 6NYCRR 201-6.5(a)(8): General Condition - Right to Inspect
- 17 6NYCRR 201-6.5(d)(5): Standard Requirements - Progress Reports
- 18 6NYCRR 201-6.5(f)(6): Off Permit Changes
- 19 6NYCRR 202-1.1: Required Emissions Tests
- 20 6NYCRR 211.3: Visible Emissions Limited
- 21 40CFR 68: Accidental release provisions.
- 22 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 23 6NYCRR 201-6: Emission Unit Definition
- 24 6NYCRR 201-6.5(c): Compliance Certification
- 25 6NYCRR 204-1.6: Permit requirements.
- 26 6NYCRR 204-2.1: Submissions to the Department.
- 27 6NYCRR 204-4.1: Contents of reports and compliance certifications.
- 28 6NYCRR 204-4.1: Compliance Certification
- 29 6NYCRR 204-7.1: Submission of NOx allowance transfers.
- 30 6NYCRR 204-8.1: General provisions.
- 31 6NYCRR 204-8.1: Prohibitions.
- 32 6NYCRR 204-8.1: Requirements for installation, certification, and data accounting.
- 33 6NYCRR 204-8.2: Requirements for recertification of monitoring systems.
- 34 6NYCRR 204-8.2: Compliance Certification
- 35 6NYCRR 204-8.3: Out of control periods.
- 36 6NYCRR 204-8.4: Compliance Certification
- 37 6NYCRR 204-8.7: Compliance Certification
- 38 6NYCRR 227-1.3(a): Compliance Certification
- 39 6NYCRR 227-2: Compliance Certification
- 40 6NYCRR 227.2(b)(1): Compliance Certification
- 41 6NYCRR 231-2: Compliance Certification
- 42 6NYCRR 243-1.6(a): Permit Requirements
- 43 6NYCRR 243-1.6(b): Monitoring requirements
- 44 6NYCRR 243-1.6(c): NOx Ozone Season Emission Requirements



- 45 6NYCRR 243-1.6(d): Excess emission requirements
- 46 6NYCRR 243-1.6(e): Recordkeeping and reporting requirements
- 47 6NYCRR 243-2.1: Authorization and responsibilities of CAIR designated representative
- 48 6NYCRR 243-2.4: Certificate of representation
- 49 6NYCRR 243-8.1: General requirements
- 50 6NYCRR 243-8.1: Prohibitions
- 51 6NYCRR 243-8.5(d): Quarterly reports
- 52 6NYCRR 243-8.5(e): Compliance certification
- 53 6NYCRR 244-1: CAIR General and Permit Requirements
- 54 6NYCRR 244-1: CAIR NOx Annual Trading Program General Conditions
- 55 6NYCRR 244-2: Designated CAIR Representative
- 56 6NYCRR 244-8: Compliance Certification
- 57 6NYCRR 245-1: CAIR General and Permit Requirements
- 58 6NYCRR 245-1: CAIR SO2 Trading Program General Provisions
- 59 6NYCRR 245-2: Designated CAIR Representative
- 60 6NYCRR 245-8: Monitoring and Reporting SO2 Emissions

Emission Unit Level

- 61 6NYCRR 201-6: Emission Point Definition By Emission Unit
- 62 6NYCRR 201-6: Process Definition By Emission Unit

EU=U-GT001,EP=GT001,Proc=P28

- 63 6NYCRR 225-1.2(a)(2): Compliance Certification

EU=U-GT001,EP=GT001,Proc=P29

- 64 6NYCRR 225-1.2(a)(2): Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 65 ECL 19-0301: Contaminant List
- 66 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 67 6NYCRR 211.2: Air pollution prohibited
- 68 6NYCRR 237-1.4(a): Applicable Facility, with a unit of a capacity of 25 MWe or greater
- 69 6NYCRR 237-1.6(a): Permit Requirements
- 70 6NYCRR 237-1.6(c): Compliance Demonstration
- 71 6NYCRR 237-1.6(e): Recordkeeping and Reporting Requirements
- 72 6NYCRR 237-1.6(f): Liability- facility and units with common stacks
- 73 6NYCRR 237-1.6(g): Effect on other Authorities
- 74 6NYCRR 237-2: Authorization and responsibilities of the NOx authorized account representative
- 75 6NYCRR 237-4.1: Compliance Demonstration
- 76 6NYCRR 237-7.1: Submission of NOx allowance transfers
- 77 6NYCRR 237-8: Compliance Demonstration



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or

operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department

within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



- Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)**
Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.
- Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)**
Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**
The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**
This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
- Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)**
It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.
- Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)**
This permit does not convey any property rights of any sort or any exclusive privilege.
- Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)**



If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the



effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.



Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

**Condition 1: Acceptable Ambient Air Quality
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Condition 2: Fees
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6.5(a)(7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

**Condition 3: Recordkeeping and reporting of compliance monitoring
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6.5(c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;



(ii) The date(s) analyses were performed;

(iii) The company or entity that performed the analyses;

(iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;

(v) The results of such analyses including quality assurance data where required; and

(vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

Condition 4: Monitoring, Related Recordkeeping, and Reporting Requirements.

Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 5: Compliance Certification

Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification

Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(e)



Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2010.

Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires Prohibited at Industrial and Commercial Sites
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 215



Item 9.1:

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, refuse, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 10: Maintenance of Equipment
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Condition 11: Recycling and Salvage
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-1.7

Item 11.1:

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

**Condition 12: Prohibition of Reintroduction of Collected Contaminants to
the air
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 13: Exempt Sources - Proof of Eligibility
Effective for entire length of Permit**



Applicable Federal Requirement:6NYCRR 201-3.2(a)

Item 13.1:

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

**Condition 14: Trivial Sources - Proof of Eligibility
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-3.3(a)

Item 14.1:

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

**Condition 15: Standard Requirement - Provide Information
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6.5(a)(4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

**Condition 16: General Condition - Right to Inspect
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6.5(a)(8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;



(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

**Condition 17: Standard Requirements - Progress Reports
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6.5(d)(5)

Item 17.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

**Condition 18: Off Permit Changes
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6.5(f)(6)

Item 18.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

Condition 19: Required Emissions Tests



Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 202-1.1

Item 19.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time. Such person shall bear the cost of measurement and preparing the report of measured emissions. Failure of such person to submit a report acceptable to the commissioner within the time stated shall be sufficient reason for the commissioner to suspend or deny a certificate to operate.

Condition 20: Visible Emissions Limited
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 211.3

Item 20.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 21: Accidental release provisions.
Effective for entire length of Permit

Applicable Federal Requirement:40CFR 68

Item 21.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

Condition 22: Recycling and Emissions Reduction
Effective for entire length of Permit



Applicable Federal Requirement:40CFR 82, Subpart F

Item 22.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 23: Emission Unit Definition
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 201-6

Item 23.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-GT001

Emission Unit Description:

THIS UNIT IS A COMBUSTION TURBINE DESIGNED TO PROVIDE SUFFICIENT POWER TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE LONG ISLAND ELECTRIC DISTRIBUTION SYSTEM.

Building(s): WB4

Condition 24: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 201-6.5(c)

Item 24.1:

The Compliance Certification activity will be performed for the Facility.

Item 24.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Since this facility is unmanned and does not have any office space, all records required under this permit shall be kept at the National Grid facility from which personnel responsible for the operation and maintenance of the equipment are dispatched. West Babylon GT records shall be kept at the EF Barrett GT Facility.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).



**Condition 25: Permit requirements.
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 204-1.6

Item 25.1: The NOx authorized account representative of each NOx budget unit shall submit to the Department a complete NOx Budget permit application (as defined under Section 204-3.3) by May 1, 2002 or 12 months before the date on which the NOx Budget unit commences operation.

**Condition 26: Submissions to the Department.
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 204-2.1

Item 26.1: Each submission under the NOx Budget Trading Program shall be submitted, signed and certified by the NOx authorized account representative for each NOx Budget source on behalf of which the submission is made. Each submission shall include a certification statement (as stated in paragraph 204-2.4(a)(4)) by the NOx authorized account representative.

**Condition 27: Contents of reports and compliance certifications.
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 204-4.1

Item 27.1: The NOx authorized account representative shall include in the compliance certification report the following elements, in a format prescribed by the Administrator, concerning each unit at the source and subject to the NOx Budget emissions limitation for the control period covered by the report:

- (1) Identification of each NOx Budget unit; and
- (2) In the compliance certification report the NOx authorized account representative shall certify, based on reasonable inquiry of those persons with primary responsibility for operating the source and the NOx Budget units at the source in compliance with the NOx Budget Trading Program, whether each NOx Budget unit for which the compliance certification is submitted was operated during the calendar year covered by the report in compliance with the requirements of the NOx Budget Trading Program applicable to the unit, including:
 - (i) Whether the unit was operated in compliance with the NOx Budget emissions limitation;
 - (ii) Whether the monitoring plan that governs the unit has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute NOx emissions to the unit, in accordance with Subpart 204-8;
 - (iii) Whether all the NOx emissions from the unit, or a group of units (including the unit) using a common stack, were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with Subpart 204-8. If conditional data were reported, the owner or operator shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions has been made;
 - (iv) Whether the facts that form the basis for certification under Subpart 204-8 of each monitor at the unit or a group of units (including the unit) using a common stack, or for using an excepted monitoring method or alternative monitoring method approved under Subpart 204-8, if any, has



changed; and

(v) If a change is required to be reported under item (iv) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor recertification.

Condition 28: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 204-4.1

Item 28.1:

The Compliance Certification activity will be performed for the Facility.

Item 28.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 29: Submission of NO_x allowance transfers.
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 204-7.1

Item 29.1: The NO_x authorized account representatives seeking recordation of a NO_x allowance transfer shall submit the transfer to the Administrator. To be considered correctly submitted, the NO_x allowance transfer shall include the following elements in a format specified by the Administrator:

- (a) The numbers identifying both the transferor and transferee accounts;
- (b) A specification by serial number of each NO_x allowance to be transferred; and
- (c) The printed name and signature of the NO_x authorized account representative of the transferor account and the date signed.

Condition 30: General provisions.
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 204-8.1

Item 30.1: The owners and operators, and to the extent applicable, the NO_x authorized account representative of a NO_x Budget unit, shall comply with the monitoring and reporting requirements as provided in this Subpart and in Subpart H of 40 CFR Part 75. For purposes of complying with such requirements, the definitions in Section 204-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be replaced by the terms "NO_x Budget unit," "NO_x authorized account representative," and "continuous emission monitoring system" (or "CEMS"), respectively, as defined in Section 204-1.2.

Condition 31: Prohibitions.
Effective for entire length of Permit



Applicable Federal Requirement:6NYCRR 204-8.1

Item 31.1: No owner or operator of a NOx Budget unit or a non-NOx Budget unit monitored under 40 CFR 75.72(b)(2)(ii) shall:

- (1) use any alternative monitoring system, alternative reference method, or any other alternative for the required continuous emission monitoring system without having obtained prior written approval in accordance with Section 204-8.6;
- (2) operate the unit so as to discharge, or allow to be discharged, NOx emissions to the atmosphere without accounting for all such emissions in accordance with the applicable provisions of this Subpart and 40 CFR Part 75 except as provided for in 40 CFR 75.74;
- (3) disrupt the continuous emission monitoring system, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NOx mass emissions discharged into the atmosphere, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the applicable provisions of this Subpart and 40 CFR Part 75 except as provided for in 40 CFR 75.74; and
- (4) permanently discontinue use of the continuous emission monitoring system, any component thereof, or any other approved emission monitoring system under this Subpart, except under any one of the following circumstances:
 - (i) The owner or operator is monitoring emissions from the unit with another certified monitoring system approved, in accordance with the applicable provisions of this Subpart and 40 CFR Part 75, by the Department for use at that unit that provides emission data for the same pollutant or parameter as the discontinued monitoring system; or
 - (ii) The NOx authorized account representative submits notification of the date of certification testing of a replacement monitoring system in accordance with Paragraph 204-8.2(b)(2).

Condition 32: Requirements for installation, certification, and data accounting.
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 204-8.1

Item 32.1: The owner or operator of each NOx Budget unit must meet the following requirements. These provisions also apply to a unit for which an application for a NOx Budget opt-in permit is submitted and not denied or withdrawn, as provided in Subpart 204-9:

- (1) Install all monitoring systems required under this Subpart for monitoring NOx mass. This includes all systems required to monitor NOx emission rate, NOx concentration, heat input, and air or fuel flow, in accordance with 40 CFR 75.71 and 75.72.
- (2) Install all monitoring systems for monitoring heat input, if required under Section 204-8.7 for developing NOx allowance allocations.
- (3) Successfully complete all certification tests required under Section 204-8.2 and meet all other provisions of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraphs (a)(1) and (2) of this section.
- (4) Record and report data from the monitoring systems under paragraphs (a)(1) and (2) of this section.

Condition 33: Requirements for recertification of monitoring systems.
Effective for entire length of Permit



Applicable Federal Requirement:6NYCRR 204-8.2

Item 33.1: Whenever the owner or operator makes a replacement, modification, or change in a certified monitoring system that the Administrator or the Department determines significantly affects the ability of the system to accurately measure or record NOx mass emissions or heat input or to meet the requirements of 40 CFR 75.21 or Appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system according to 40 CFR 75.20(b). Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that the Administrator or the Department determines to significantly change the flow or concentration profile, the owner or operator shall recertify the continuous emissions monitoring system according to 40 CFR 75.20(b). Examples of changes which require recertification include: replacement of the analyzer, change in location or orientation of the sampling probe or site, or changing of flow rate monitor polynomial coefficients.

**Condition 34: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 204-8.2

Item 34.1:

The Compliance Certification activity will be performed for the Facility.

Item 34.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 35: Out of control periods.
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 204-8.3

Item 35.1: Whenever any monitoring system fails to meet the quality assurance requirements of Appendix B of 40 CFR Part 75, data shall be substituted using the applicable procedures in Subpart D, Appendix D, or Appendix E of 40 CFR Part 75.

**Condition 36: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 204-8.4

Item 36.1:

The Compliance Certification activity will be performed for the Facility.

Item 36.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:



Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 37: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 204-8.7

Item 37.1:

The Compliance Certification activity will be performed for the Facility.

Item 37.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring Frequency: HOURLY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 3 calendar month(s).

Condition 38: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 227-1.3(a)

Item 38.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Visible emissions at the facility are limited to 20 percent opacity , except for one six minute period per hour not to exceed 27 percent, based upon the six minute average as stated in Reference Method 9 Appendix A 40CFR60. This limit applies to every combustion unit listed in this permit. Owner or operator shall perform at least once per calendar year a Method 9 at each listed combustion unit. Readings shall be performed by a Certified Visible Emissions Evaluator. The results of each observation shall be recorded in a bound log book or other format acceptable to the Department, kept at a designated office for at least five years, and made available to NYSDEC Representatives upon request. Additional opacity readings may be required by the Department.



Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: 40CFR60 Appendix A Method 9

Monitoring Frequency: MINIMUM - ONCE PER CALENDAR YEAR

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)

Initial Report Due: 30 days after first semi-annual (6 month) period following Permit Issue Date

Condition 39: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 227-2

Item 39.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Compliance with the requirements of 6NYCRR Part 227-2 is assured on a system wide basis using a NOx RACT Compliance Plan approved by the NYS Department of Environmental Conservation.

Reference Test Method: 40CFR60 APP B

Monitoring Frequency: CONTINUOUS

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Condition 40: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 227.2(b)(1)

Item 40.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:



The two hour average emission of particulates from this stationary combustion installation shall not exceed 0.10 pounds per million Btu of heat input.

At the monitoring frequency stated below the facility shall perform the following:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emissions in a manner that will determine compliance with the limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) Submit an acceptable stack test report that outlines the results obtained from the testing done to meet the requirement of #2 above.
- 4) Facility shall keep records of all testing done at this stationary combustion installation for a period of 5 years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: 40 CFR 60 APP. A METHOD 5

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: AVERAGING METHOD - SEE MONITORING DESCRIPTION

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Condition 41: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 231-2

Item 41.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: U-GT001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 41.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING



Monitoring Description:

NOx emissions are limited to 45 tons per year. Maintaining this limit, the facility will not be subject to 6 NYCRR Part 231-2 New Source Review requirements. Data of the most recent stack test shall be used to calculate NOx annual emissions. A NOx emission test shall be performed at least once during the term of this permit. Record keeping and reporting are required.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 45 tons per year

Reference Test Method: 40CFR60 Method 7

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Condition 42: Permit Requirements
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 243-1.6(a)

Item 42.1:

The CAIR designated representative of each CAIR NOx Ozone Season source shall:

- (i) submit to the department a complete CAIR permit application under section 243-3.3 in accordance with the deadlines specified in section 243-3.2; and
- (ii) submit in a timely manner any supplemental information that the department determines is necessary in order to review a CAIR permit application and issue or deny a CAIR permit.

The owners and operators of each CAIR NOx Ozone Season source shall have a CAIR permit issued by the department under Subpart 243-3 for the source and operate the source and the unit in compliance with such CAIR permit.

Condition 43: Monitoring requirements
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 243-1.6(b)

Item 43.1:

The emissions measurements recorded and reported in accordance with Subpart 243-8 shall be used to determine compliance by each CAIR NOx Ozone Season source with the CAIR NOx Ozone Season emissions limitation under subdivision (c) of this section.

Condition 44: NOx Ozone Season Emission Requirements
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 243-1.6(c)

Item 44.1:

As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NOx Ozone Season source and each CAIR NOx Ozone Season unit at the source shall



hold, in the source's compliance account, CAIR NOx Ozone Season allowances available for compliance deductions for the control period under section 243-6.5(a) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NOx Ozone Season units at the source, as determined in accordance with Subpart 243-8. The CAIR NOx ozone season is the period beginning May 1 of a calendar year, except as provided in section 243-1.6(c)(2), and ending on September 30 of the same year, inclusive.

A CAIR NOx Ozone Season unit shall be subject to the requirements under paragraph (c)(1) of this section for the control period starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under sections 243-8.1(b)(1), (2), (3), or (7) and for each control period thereafter.

A CAIR NOx Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (c)(1) of this section, for a control period in a calendar year before the year for which the CAIR NOx Ozone Season allowance was allocated.

CAIR NOx Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NOx Ozone Season Allowance Tracking System accounts in accordance with Subparts 243-6, 243-7, and 243-9.

A CAIR NOx Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NOx Ozone Season Trading Program. No provision of the CAIR NOx Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under section 243-1.5 and no provision of law shall be construed to limit the authority of the State or the United States to terminate or limit such authorization.

A CAIR NOx Ozone Season allowance does not constitute a property right.

Upon recordation by the Administrator under Subpart 243-6, 243-7, or 243-9, every allocation, transfer, or deduction of a CAIR NOx Ozone Season allowance to or from a CAIR NOx Ozone Season source's compliance account is incorporated automatically in any CAIR permit of the source.

Condition 45: Excess emission requirements
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 243-1.6(d)

Item 45.1:

If a CAIR NOx Ozone Season source emits nitrogen oxides during any control period in excess of the CAIR NOx Ozone Season emissions limitation, then:

(1) the owners and operators of the source and each CAIR NOx Ozone Season unit at the source shall surrender the CAIR NOx Ozone Season allowances required for deduction under section 243-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law; and

(2) each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law.

Condition 46: Recordkeeping and reporting requirements
Effective for entire length of Permit



Applicable Federal Requirement:6NYCRR 243-1.6(e)

Item 46.1:

Unless otherwise provided, the owners and operators of the CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator.

(i) The certificate of representation under section 243-2.4 for the CAIR designated representative for the source and each CAIR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation under section 243-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with Subpart 243-8, provided that to the extent that Subpart 243-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Ozone Season Trading Program.

**Condition 47: Authorization and responsibilities of CAIR designated representative
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 243-2.1

Item 47.1:

Except as provided under section 243-2.2, each CAIR NO_x Ozone Season source, including all CAIR NO_x Ozone Season units at the source, shall have one and only one CAIR designated representative, with regard to all matters under the CAIR NO_x Ozone Season Trading Program concerning the source or any CAIR NO_x Ozone Season unit at the source.

The CAIR designated representative of the CAIR NO_x Ozone Season source shall be selected by an agreement binding on the owners and operators of the source and all CAIR NO_x Ozone Season units at the source and shall act in accordance with the certification statement in section 243-2.4(a)(4)(iv).

Upon receipt by the Administrator of a complete certificate of representation under section 243-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NO_x Ozone Season source represented and each CAIR NO_x Ozone Season unit at the source in all matters pertaining to the CAIR NO_x Ozone Season Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the



source or unit.

No CAIR permit will be issued, no emissions data reports will be accepted, and no CAIR NO_x Ozone Season Allowance Tracking System account will be established for a CAIR NO_x Ozone Season unit at a source, until the Administrator has received a complete certificate of representation under section 243-2.4 for a CAIR designated representative of the source and the CAIR NO_x Ozone Season units at the source.

Each submission under the CAIR NO_x Ozone Season Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NO_x Ozone Season source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

**Condition 48: Certificate of representation
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 243-2.4

Item 48.1:

Unless otherwise required by the department or the Administrator, documents of agreement referred to in the certificate of representation shall not be submitted to the department or the Administrator. Neither the department nor the Administrator shall be under any obligation to review or evaluate the sufficiency of such documents, if submitted.

**Condition 49: General requirements
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 243-8.1

Item 49.1:

The owners and operators, and to the extent applicable, the CAIR designated representative, of a CAIR NO_x Ozone Season unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this Subpart and in Subpart H of 40 CFR Part 75. For purposes of complying with such requirements, the definitions in section 243-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR NO_x Ozone Season unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 243-1.2. The owner or operator of a unit that is not a CAIR NO_x Ozone Season unit but that is monitored under 40 CFR 75.72(b)(2)(ii) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR NO_x Ozone Season unit.

'Requirements for installation, certification, and data accounting.' The owner or operator of each CAIR NO_x Ozone Season unit shall:



(1) install all monitoring systems required under this Subpart for monitoring NO_x mass emissions and individual unit heat input (including all systems required to monitor NO_x emission rate, NO_x concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.71 and 40 CFR 75.72);

(2) successfully complete all certification tests required under section 243-8.2 and meet all other requirements of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraph (a)(1) of this section; and

(3) record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section.

Condition 50: Prohibitions
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 243-8.1

Item 50.1:

No owner or operator of a CAIR NO_x Ozone Season unit shall use any alternative monitoring system, alternative reference method, or any other alternative to any requirement of this Subpart without having obtained prior written approval in accordance with section 243-8.6.

No owner or operator of a CAIR NO_x Ozone Season unit shall operate the unit so as to discharge, or allow to be discharged, NO_x emissions to the atmosphere without accounting for all such emissions in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NO_x Ozone Season unit shall disrupt the continuous emission monitoring system, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NO_x mass emissions discharged into the atmosphere or heat input, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NO_x Ozone Season unit shall retire or permanently discontinue use of the continuous emission monitoring system, any component thereof, or any other approved monitoring system under this Subpart, except under any one of the following circumstances:

- (i) during the period that the unit is covered by an exemption under section 243-1.5 that is in effect;
- (ii) the owner or operator is monitoring emissions from the unit with another certified monitoring system approved, in accordance with the applicable provisions of this Subpart and 40 CFR Part 75, by the department for use at that unit that provides emission data for the same pollutant or parameter as the retired or discontinued monitoring system; or
- (iii) the CAIR designated representative submits notification of the date of certification testing of a replacement monitoring system for the retired or discontinued monitoring system in accordance with section 243-8.2(d)(3)(i).

Condition 51: Quarterly reports
Effective for entire length of Permit

Applicable Federal Requirement:6NYCRR 243-8.5(d)



Item 51.1:

The CAIR designated representative shall submit quarterly reports, as follows:

If the CAIR NO_x Ozone Season unit is subject to an Acid Rain emissions limitation or a CAIR NO_x emissions limitation or if the owner or operator of such unit chooses to report on an annual basis under this Subpart, the CAIR designated representative shall meet the requirements of Subpart H of 40 CFR Part 75 (concerning monitoring of NO_x mass emissions) for such unit for the entire year and shall report the NO_x mass emissions data and heat input data for such unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:

(i) for a unit that commences commercial operation before July 1, 2007, the calendar quarter covering May 1, 2008 through June 30, 2008;

(ii) for a unit that commences commercial operation on or after July 1, 2007, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 243-8.1(b), unless that quarter is the third or fourth quarter of 2007 or the first quarter of 2008, in which case reporting shall commence in the quarter covering May 1, 2008 through June 30, 2008.

The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

For CAIR NO_x Ozone Season units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Annual Trading Program, CAIR SO₂ Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO_x mass emission data, heat input data, and other information required by this Subpart.

**Condition 52: Compliance certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 243-8.5(e)

Item 52.1:

The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(1) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR Part 75, including the quality assurance procedures and specifications;

(2) for a unit with add-on NO_x emission controls and for all hours where NO_x data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO_x emissions; and



(3) for a unit that is reporting on a control period basis under subparagraph (d)(2)(ii) of this section, the NO_x emission rate and NO_x concentration values substituted for missing data under Subpart D of 40 CFR Part 75 are calculated using only values from a control period and do not systematically underestimate NO_x emissions.

**Condition 53: CAIR General and Permit Requirements
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 244-1

Item 53.1:

(1) As of midnight of March 1, or midnight of the first business day thereafter if March 1 is not a business day, the owners and operators shall hold, in their compliance account, CAIR NO_x allowances available for compliance deductions for the previous control period (January 1 through December 31), in an amount not less than the total tons of nitrogen oxides emissions from all CAIR NO_x units at the source during that control period. (244-1.6(c)(1), 244-1.2(b)(5), 244-1.2(b)(36))

(2) A CAIR NO_x allowance shall not be deducted, for compliance with the requirements under paragraph (2) of this section, for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated. (244-1.6(c)(3))

(3) 'Excess emissions requirements.' If a CAIR NO_x source emits nitrogen oxides during any control period in excess of the CAIR NO_x emissions limitation, the owners and operators of the CAIR NO_x source shall surrender the CAIR NO_x allowances required for deduction under 6NYCRR Part 244-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this permit, the Act, and applicable State law. (244-1.6(d))

(4) Unless otherwise provided, the owners and operators of the CAIR NO_x source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator:

(i) The certificate of representation under 6NYCRR Part 244-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 244-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 244-8, provided that to the extent that 6NYCRR Part 244-8 provides for a three year period for recordkeeping, the three year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program. (244-1.6(e))



**Condition 54: CAIR NOx Annual Trading Program General Conditions
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 244-1

Item 54.1:

1) As of midnight of March 1, or midnight of the first business day thereafter if March 1 is not a business day, the owners and operators shall hold, in their compliance account, Clean Air Interstate Rule (CAIR) NOx allowances available for compliance deductions for the previous control period (January 1 through December 31), in an amount not less than the total tons of nitrogen oxides emissions from all CAIR NOx units at the source during that control period. A CAIR NOx allowance shall not be deducted for a control period in a calendar year before the year for which the CAIR NOx allowance was allocated. [244-1.6(c)(1), 244-1.2(b)(5), 244-1.2(b)(36), 244-1.6(c)(3)]

2) The owners and operators shall hold in their compliance account, CAIR NOx allowances available for compliance deductions for the control period starting on the later of January 1, 2009 or the deadline for meeting a CAIR NOx unit's monitor certification requirements under section 244-8.1(b)(1), (2), or (5) and for each control period thereafter. [244-1.6(c)(2)]

3) If a CAIR NOx source emits nitrogen oxides during any control period in excess of the CAIR NOx emissions limitation, the owners and operators of the CAIR NOx source shall surrender the CAIR NOx allowances required for deduction under 6NYCRR Part 244-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this permit, the Act, and applicable State law. [(244-1.6(d)]

4) Unless otherwise provided, the owners and operators of the CAIR NOx source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [244-1.6(e)]

(i) The certificate of representation under 6NYCRR Part 244-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 244-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 244-8, provided that to the extent that 6NYCRR Part 244-8 provides for a three year period for recordkeeping, the three year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NOx Annual Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NOx Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NOx Annual Trading Program.

**Condition 55: Designated CAIR Representative
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 244-2



Item 55.1:

1) Each Clean Air Interstate Rule (CAIR) NO_x source shall have one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 244-2.2, with regard to all matters under the CAIR NO_x Annual Trading Program. The CAIR designated representative shall be selected by an agreement binding on the owners and operators of the source and act in accordance with the certification statement in 6NYCRR Part 244-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 244-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NO_x source represented in all matters pertaining to the CAIR NO_x Annual Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source. [244-2.1(a), (b) & (c)]

(2) Each submission under the CAIR NO_x Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NO_x source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment." [244-2.1(e)]

**Condition 56: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 244-8

Item 56.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 56.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring and Reporting NO_x emissions

(1) The owners and operators, and to the extent applicable, the CAIR designated representative shall comply with all recordkeeping and reporting requirements in this condition, the applicable recordkeeping and reporting requirements under 40 CFR 75, and the requirements of 6NYCRR Part 244-2.1(e)(1).



(2) The CAIR designated representative shall submit quarterly reports of the the NO_x mass emissions data and heat input data for each CAIR NO_x unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under 6NYCRR Part 244-8.1(b), unless that quarter is the third or fourth quarter of 2007, in which case reporting shall commence in the quarter covering January 1, 2008 through March 31, 2008.

(3) The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

(4) For CAIR NO_x units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Ozone Season Trading Program, CAIR SO₂ Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO_x mass emission data, heat input data, and other information required by this Subpart.

(5) 'Compliance certification.' The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(i) the monitoring data submitted were recorded in accordance with the applicable requirements of 6NYCRR Part 244 and 40 CFR Part 75, including the quality assurance procedures and specifications; and

(ii) for a unit with add-on NO_x emission controls and for all hours where NO_x data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO_x emissions.

(6) Whenever any monitoring system fails to meet the



quality-assurance and quality-control requirements or data validation requirements of 40 CFR part 75, data shall be substituted using the applicable missing data procedures in Subpart D or Subpart H of, or appendix D or appendix E to 40 CFR part 75. [244-8.3(a)]

(7) Whenever the owner or operator makes a replacement, modification, or change in any certified continuous emission monitoring system under 6NYCRR Part 244-8.1(a)(1) that may significantly affect the ability of the system to accurately measure or record NOx mass emissions or heat input rate or to meet the quality-assurance and quality-control requirements of 40 CFR 75.21 or appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system in accordance with 40 CFR 75.20(b) . Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that may significantly change the stack flow or concentration profile, the owner or operator shall recertify each continuous emission monitoring system whose accuracy is potentially affected by the change, in accordance with 40 CFR 75.20(b). Examples of changes to a continuous emission monitoring system that require recertification include replacement of the analyzer, complete replacement of an existing continuous emission monitoring system, or change in location or orientation of the sampling probe or site. Any fuel flowmeter system, and any excepted NOx monitoring system under appendix E to 40 CFR part 75, under 6NYCRR Part 244-8.1(a)(1) are subject to the recertification requirements in 40 CFR 75.20(g)(6). [224-8.2(d)(2)

Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL TOTAL
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 3 calendar month(s).

**Condition 57: CAIR General and Permit Requirements
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 245-1

Item 57.1:

(1) Each CAIR SO2 source must have a permit issued by the department pursuant to 6NYCRR Parts 201 and 621 of this title; and shall have a CAIR permit issued pursuant to 6NYCRR Part 245-3 by the Department and operate the source in compliance with such CAIR permit. Each CAIR permit must contain all applicable requirements for the CAIR SO2 Trading Program and shall be a complete and separable portion of the permit. (245-1 and 245-3)

(2) As of midnight of March 1, or midnight of the first business day thereafter (if March 1 is not



a business day) for a control period, the owners and operators of each CAIR SO₂ source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO₂ allowances available for compliance deductions for the control period (January 1 through December 31) as determined in accordance with 6NYCRR Part 245-6.5(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source, as determined in accordance with 6NYCRR Part 245-8. (245-1.2(b)(5), 245-1.6(c)(1), 245-1.2(b)(36))

(3) A CAIR SO₂ allowance shall not be deducted, for compliance with the requirements under paragraph (2) of this section, for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated. (245-1.6(c)(3))

(4)'Excess emissions requirements.' If a CAIR SO₂ source emits sulfur dioxide during any control period in excess of the CAIR SO₂ emissions limitation, the owners and operators of the source shall surrender the CAIR SO₂ allowances required for deduction under 6NYCRR Part 245-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law. (245-1.6(d))

(5) Unless otherwise provided, the owners and operators of the CAIR SO₂ source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator:

(i) The certificate of representation under 6NYCRR Part 245-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 245-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 245-8, provided that to the extent that 6NYCRR Part 245-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program. (245-1.6(e))

**Condition 58: CAIR SO₂ Trading Program General Provisions
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 245-1

Item 58.1:

1) As of midnight of March 1, or midnight of the first business day thereafter (if March 1 is not a business day) for a control period, the owners and operators of each Clean Air Interstate Rule (CAIR) SO₂ source shall hold, in the source's compliance account, a tonnage equivalent in



CAIR SO₂ allowances available for compliance deductions for the control period (January 1 through December 31) not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source. A CAIR SO₂ allowance shall not be deducted, for compliance with the requirements under paragraph (2) of this section, for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.

[(245-1.2(b)(5), 245-1.6(c)(1), 245-1.2(b)(36), 245-1.6(c)(3)]

2) The owners and operators shall hold in their compliance account, CAIR SO allowances available for compliance deductions for the control period starting on the later of January 1, 2010 or the deadline for meeting a CAIR SO₂ unit's monitor certification requirements under section 245-8.1(b)(1), (2), or (5) and for each control period thereafter. [245-1.6(c)(2)]

3) If a CAIR SO₂ source emits sulfur dioxide during any control period in excess of the CAIR SO₂ emissions limitation, the owners and operators of the source shall surrender the CAIR SO₂ allowances required for deduction under 6NYCRR Part 245-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law.

[(245-1.6(d)]

4) Unless otherwise provided, the owners and operators of the CAIR SO₂ source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [245-1.6(e)]

(i) The certificate of representation under 6NYCRR Part 245-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 245-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 245-8, provided that to the extent that 6NYCRR Part 245-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program.

**Condition 59: Designated CAIR Representative
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 245-2

Item 59.1:

1) Each CAIR SO₂ source shall have one and only one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 245-2.2, with regard to all matters under the CAIR SO₂ Trading Program. The CAIR designated representative of the CAIR SO₂ source shall be selected by an agreement binding on the owners and operators of the source and all CAIR SO₂ units at the source and shall act in accordance with the certification statement in 6NYCRR Part 245-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 245-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind



each owner and operator of the CAIR SO₂ source represented and each CAIR SO₂ unit at the source in all matters pertaining to the CAIR SO₂ Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source or unit. [245-2.1(a), (b) & (c)]

(2) Each submission under the CAIR SO₂ Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR SO₂ source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment." [245-2.1(e)]

**Condition 60: Monitoring and Reporting SO₂ Emissions
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 245-8

Item 60.1:

(1) The owners and operators, and to the extent applicable, the CAIR designated representative, of a CAIR SO₂ unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this section and in 40 CFR Part 75, Subparts F and G. For purposes of complying with such requirements, the definitions in section 245-1.2 and 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR SO₂ unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 245-1.2. The owner or operator of a unit that is not a CAIR SO₂ unit but that is monitored under 40 CFR 75.16(b)(2) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR SO₂ unit. (245-8.1)

(2) 'Requirements for installation, certification, and data accounting.' The owner or operator of each CAIR SO₂ unit shall:

(i) install all monitoring systems required under this Subpart for monitoring SO₂ mass emissions and individual unit heat input (including all systems required to monitor SO₂ concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.11 and 40 CFR 75.16);

(ii) successfully complete all certification tests required under Part 245-8.2 and meet all other requirements of this section and 40 CFR Part 75 applicable to the monitoring systems under this section; and

(iii) record, report, and quality-assure the data from the monitoring systems under paragraph of this section. (245-8.1(a))

(3) 'Compliance deadlines.' The owner or operator shall meet the monitoring system



certification and other requirements of paragraphs (a)(1) and (2) of this section on or before the following dates. The owner or operator shall record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section on and after the following dates.

(i) For the owner or operator of a CAIR SO2 unit that commences commercial operation before July 1, 2008, by January 1, 2009.

(ii) For the owner or operator of a CAIR SO2 unit that commences commercial operation on or after July 1, 2008, by the later of the following dates: January 1, 2009; or 90 unit operating days or 180 calendar days, whichever occurs first, after the date on which the unit commences commercial operation. (245-8.1(b))

(4) 'Reporting data.' The owner or operator of a CAIR SO2 unit that does not meet the applicable compliance date set forth in this section for any monitoring system under paragraph 2 of this section shall, for each such monitoring system, determine, record, and report maximum potential (or, as appropriate, minimum potential) values for SO2 concentration, stack gas flow rate, stack gas moisture content, fuel flow rate, and any other parameters required to determine SO2 mass emissions and heat input in accordance with 40 CFR 75.31(b)(2) or (c)(3) or 40 CFR Part 75, appendix D, section 2.4, as applicable. (245-8.1(c))

****** Emission Unit Level ******

**Condition 61: Emission Point Definition By Emission Unit
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6

Item 61.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-GT001

Emission Point: GT001

Height (ft.): 46 Length (in.): 286 Width (in.): 168
NYTMN (km.): 4510.223 NYTME (km.): 636.033 Building: WB4

**Condition 62: Process Definition By Emission Unit
Effective for entire length of Permit**

Applicable Federal Requirement:6NYCRR 201-6

Item 62.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-GT001

Process: P28

Source Classification Code: 2-01-009-01

Process Description:

THIS PROCESS IS THE COMBUSTION OF #1
DISTILLATE OIL IN A COMBUSTION TURBINE. IN
ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE
MAY BE MIXED WITH THE DISTILLATE OIL PRIOR



TO COMBUSTION. IN ADDITION WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Emission Source/Control: ES001 - Combustion
Design Capacity: 843 million Btu per hour

Item 62.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-GT001
Process: P29
Source Classification Code: 2-01-001-01
Process Description:

THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Emission Source/Control: ES001 - Combustion
Design Capacity: 843 million Btu per hour

**Condition 63: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 225-1.2(a)(2)

Item 63.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-GT001
Process: P28
Emission Point: GT001

Regulated Contaminant(s):
CAS No: 007446-09-5
SULFUR DIOXIDE

Item 63.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

THIS UNIT IS RESTRICTED TO BURNING LOW SULFUR FUEL IN ORDER TO LIMIT SO₂ EMISSIONS. ALL FUEL IS PURCHASED ON SPECIFICATION. SOURCE TANK TO BE VERIFIED IN COMPLIANCE WITH LIMIT. DELIVERIES MAY CONTINUE UNTIL FUEL IS ADDED TO SOURCE TANK.

Work Practice Type: PARAMETER OF PROCESS MATERIAL



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

**Condition 65: Contaminant List
Effective for entire length of Permit**

Applicable State Requirement:ECL 19-0301

Item 65.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 0NY075-00-0



Name: PARTICULATES

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

**Condition 66: Unavoidable noncompliance and violations
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 201-1.4

Item 66.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.



(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

**Condition 67: Air pollution prohibited
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 211.2

Item 67.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**Condition 68: Applicable Facility, with a unit of a capacity of 25 MWe
or greater
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 237-1.4(a)

Item 68.1:

Any unit, that at any time on or after January 1, 1999, serves a generator with a nameplate capacity equal to or greater than 25 MWe and sells any amount of electricity shall be a NOx budget unit, and any source that includes one or more such units shall be a NOx budget source, subject to the requirements of NYCRR 237.

**Condition 69: Permit Requirements
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 237-1.6(a)

Item 69.1:

The NOx authorized account representative of each NOx budget unit shall: Submit to the department a complete NOx budget permit application under NYCRR 237-3.3 in accordance with the deadlines specified in NYCRR 237-3.2, which states the later of October 1, 2003 or 12 months before the date on which the NOxBU commences operation; and submit in a timely manner any supplemental information that the department determines is necessary in order to review a NOx budget permit application and issue or deny a NOx budget permit.

The owners and operators of each NOx budget unit shall have a NOx budget permit and operate the unit in compliance with such NOx budget permit.

**Condition 70: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 237-1.6(c)

Item 70.1:



The Compliance Demonstration activity will be performed for the Facility.

Item 70.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 71: Recordkeeping and Reporting Requirements
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 237-1.6(e)

Item 71.1:

Unless otherwise provided, the owners and operators of the NOx budget source and each NOx budget unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the department:

- 1) The account certificate of representation for the NOx authorized account representative for the source and each NOx budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with NYCRR 237-2.4; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new account certificate of representation changing the NOx authorized account representative.
- 2) All emissions monitoring information, in accordance with NYCRR 237-8.
- 3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the ADR NOx Budget Trading Program.
- 4) Copies of all documents used to complete a NOx budget permit application and any other submission under the ADR NOx Budget Trading Program or to demonstrate compliance with the requirements of the ADR NOx Budget Trading Program.

The NOx authorized account representative of a NOx budget source and each NOx budget unit at the source shall submit the reports and compliance certifications required under the ADR NOx Budget Trading Program, including those under NYCRR 237-4, 237-8, or 237-9.

**Condition 72: Liability- facility and units with common stacks
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 237-1.6(f)

Item 72.1:

No permit revision shall excuse any violation of the requirements of the ADR NOx Budget Trading Program that occurs prior to the date that the revision takes effect.

Any provision of the ADR NOx Budget Trading Program that applies to a NOx budget source (including a provision applicable to the NOx authorized account representative of a NOx budget source) shall also apply to the owners and operators of such source and of the NOx budget units



at the source.

Any provision of the ADR NOx Budget Trading Program that applies to a NOx budget unit (including a provision applicable to the NOx authorized account representative of a NOx budget unit) shall also apply to the owners and operators of such unit. Except with regard to the requirements applicable to units with a common stack under NYCRR 237-8, the owners and operators and the NOx authorized account representative of one NOx budget unit shall not be liable for any violation by any other NOx budget unit of which they are not owners or operators or the NOx authorized account representative and that is located at a source of which they are not owners or operators or the NOx authorized account representative.

Condition 73: Effect on other Authorities
Effective for entire length of Permit

Applicable State Requirement:6NYCRR 237-1.6(g)

Item 73.1:

No provision of the ADR NOx Budget Trading Program, a NOx budget permit application, or a NOx budget permit, shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the NOx authorized account representative of a NOx budget source or NOx budget unit from compliance with any other provisions of applicable State and federal law and regulations.

Condition 74: Authorization and responsibilities of the NOx authorized account representative
Effective for entire length of Permit

Applicable State Requirement:6NYCRR 237-2

Item 74.1:

Except as provided under NYCRR 237-2.2, each NOx budget source, including all NOx budget units at the source, shall have one and only one NOx authorized account representative, with regard to all matters under the Acid Deposition Reduction (ADR) NOx Budget Trading Program concerning the source or any NOx budget unit at the source.

The NOx authorized account representative of the NOx budget source shall be selected by an agreement binding on the owners and operators of the source and all NOx budget units at the source.

Upon receipt by the department or its agent of a complete account certificate of representation under NYCRR 237-2.4, the NOx authorized account representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the NOx budget source represented and each NOx budget unit at the source in all matters pertaining to the ADR NOx Budget Trading Program, notwithstanding any agreement between the NOx authorized account representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the NOx authorized account representative by the department or a court regarding the source or unit.

No NOx budget permit shall be issued, and no NOx Allowance Tracking System account shall be established for a NOx budget unit at a source, until the department or its agent has received a complete account certificate of representation under NYCRR 237-2.4 for a NOx authorized account representative of the source and the NOx budget units at the source.



Each submission under the ADR NOx Budget Trading Program shall be submitted, signed, and certified by the NOx authorized account representative for each NOx budget source on behalf of which the submission is made. Each such submission shall include the following certification statement by the NOx authorized account representative: "I am authorized to make this submission on behalf of the owners and operators of the NOx budget sources or NOx budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

The department or its agent will accept or act on a submission made on behalf of owners or operators of a NOx budget source or a NOx budget unit only if the submission has been made, signed, and certified in accordance with NYCRR 237-2.1(e)(1).

**Condition 75: Compliance Demonstration
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 237-4.1

Item 75.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 75.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 76: Submission of NOx allowance transfers
Effective for entire length of Permit**

Applicable State Requirement:6NYCRR 237-7.1

Item 76.1:

The NOx authorized account representatives seeking recordation of a NOx allowance transfer shall submit the transfer to the department or its agent. To be considered correctly submitted, the NOx allowance transfer shall include the following elements in a format specified by the department or its agent:

- (a) the numbers identifying both the transferor and transferee accounts;
- (b) a specification by serial number of each NOx allowance to be transferred; and
- (c) the printed name and signature of the NOx authorized account representative of the transferor account and the date signed.



Condition 77: Compliance Demonstration
Effective for entire length of Permit

Applicable State Requirement: 6NYCRR 237-8

Item 77.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 77.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

New York State Department of Environmental Conservation

Permit ID: 1-4720-01046/00004

Facility DEC ID: 1472001046

