PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 1-4722-04133/00003
Mod 0 Effective Date: 04/21/2014 Expiration Date: 04/20/2019

Mod 1 Effective Date: 08/05/2016 Expiration Date: 04/20/2019

Permit Issued To:SHOREHAM ENERGY, LLC
1900 E GOLF RD STE 1030
SCHAUMBURG, IL 60173

Contact: CHRIS GOODPASTURE
J POWER USA
1900 E GOLF RD STE 1030
SCHAUMBURG, IL 60173
(847) 908-2830

Facility: SHOREHAM ENERGY LLC
227 N COUNTRY RD
SHOREHAM, NY 11786

Description:
Modification of the DEC portion of the facility's Air Title V Facility permit. There are no changes to the Title IV Acid Rain permit. The facility consists of two (2) simple cycle combustion turbines in Shoreham, NY. The facility was previously limited to 79.9 megawatts (MW) of electrical output to the grid on a 1-hour net average basis. This limitation was imposed by the New York State Public Service Commission. In 2014, that restriction was lifted. This modification removes references to that limitation without making other changes.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: SUSAN ACKERMAN
NYSDEC - REGION 1 SUNY @ STONY BROOK
50 CIRCLE RD
STONY BROOK, NY 11790-3409

Authorized Signature: _____ Date: ___ / ___ / _____

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

LIST OF CONDITIONS

DEC GENERAL CONDITIONS
General Provisions
Facility Inspection by the Department
Relationship of this Permit to Other Department Orders and Determinations
Applications for permit renewals, modifications and transfers
Applications for permit renewals, modifications and transfers
Permit modifications, suspensions or revocations by the Department
Facility Level
Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS

DEC SPECIAL CONDITIONS
Electrical output limit

DEC GENERAL CONDITIONS
****** General Provisions ******
For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.
GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:
The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:
The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:
A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:
Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:
The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:
The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:
Permits are transferrable with the approval of the department unless specifically prohibited by

the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 1-1: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6 NYCRR 621.11

Item 1-1.1:
The permittee must submit a renewal application at least 180 days before expiration of permits for both Title V and State Facility Permits.

Item 1-1.2:
Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:
The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

a) materially false or inaccurate statements in the permit application or supporting papers;
b) failure by the permittee to comply with any terms or conditions of the permit;
c) exceeding the scope of the project as described in the permit application;
d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:
Applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409
(631) 444-0365

DEC SPECIAL CONDITIONS

Condition 6: Electrical output limit
Applicable State Requirement: 6 NYCRR 621.13

Expired by Mod No: 1

Item 6.1:
Failure to operate the approved facility in accordance with the application's commitments to monitor electrical output and to operate at a net output of no more than 79.9 megawatts is grounds for modification, suspension, or revocation of this permit. Operation above 79.9 megawatts is a violation of this permit.

The Permittee shall maintain records, at the facility, for a minimum of five years. All reports shall be submitted to both the Regional Air office and to the Public Service Commission.

Monitored Parameter:
Code: 41
Name: Electrical Output
Upper Limit: 79.9 megawatts
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: MONTHLY (CALENDAR YEAR)

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To:SHOREHAM ENERGY, LLC
1900 E GOLF RD STE 1030
SCHAUMBURG, IL 60173

Facility: SHOREHAM ENERGY LLC
227 N COUNTRY RD
SHOREHAM, NY 11786

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Mod 0 Permit Effective Date: 04/21/2014 Permit Expiration Date: 04/20/2019

Mod 1 Permit Effective Date: 08/05/2016 Permit Expiration Date: 04/20/2019

LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS
Facility Level

1 6 NYCRR 200.6: Acceptable Ambient Air Quality
2 6 NYCRR 201-6.4 (a) (7): Fees
3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
4 6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
6 6 NYCRR 201-6.4 (e): Compliance Certification
7 6 NYCRR 202-2.1: Compliance Certification
8 6 NYCRR 202-2.5: Recordkeeping requirements
9 6 NYCRR 215.2: Open Fires - Prohibitions
10 6 NYCRR 200.7: Maintenance of Equipment
11 6 NYCRR 201-1.7: Recycling and Salvage
12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
15 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
1-1 6 NYCRR 201-6.4 (a) (8): Right to Inspect
17 6 NYCRR 201-6.4 (f) (6): Off Permit Changes
18 6 NYCRR 202-1.1: Required Emissions Tests
19 40 CFR Part 68: Accidental release provisions.
20 40CFR 82, Subpart F: Recycling and Emissions Reduction
21 6 NYCRR Subpart 201-6: Emission Unit Definition
22 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
23 6 NYCRR Subpart 201-7: Facility Permissible Emissions
*24 6 NYCRR Subpart 201-7: Capping Monitoring Condition
25 6 NYCRR 211.1: Air pollution prohibited
26 6 NYCRR 225-1.2 (g): Compliance Certification
27 6 NYCRR 225-1.2 (h): Compliance Certification
49 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
50 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
51 40CFR 60.7(c), NSPS Subpart A: Compliance Certification
52 40CFR 60.7(f), NSPS Subpart A: Facility files for subject sources.
53 40CFR 60.12, NSPS Subpart A: Circumvention.
54 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
55 40CFR 60.14, NSPS Subpart A: Modifications.
56 40CFR 60.15, NSPS Subpart A: Reconstruction
57 40CFR 60.334(b), NSPS Subpart GG: CEMS
58 40 CFR Part 72: Facility Subject to Title IV Acid Rain Regulations and Permitting
1-2 40CFR 97.406, Subpart AAAAA: Compliance Certification
1-3 40CFR 97.506, Subpart BBBBB: Compliance Certification
1-4 40CFR 97.606, Subpart CCCCC: Compliance Certification

Emission Unit Level

59 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit

60 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

EU=U-00001,EP=00001

61 6 NYCRR 227-1.3 (a): Compliance Certification

EU=U-00001,EP=00002

62 6 NYCRR 227-1.3 (a): Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS
Facility Level

63 ECL 19-0301: Contaminant List
64 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
65 6 NYCRR 201-1.4: Compliance Demonstration
66 6 NYCRR Subpart 201-5: Compliance Demonstration

Emission Unit Level

EU=U-00001

67 6 NYCRR Subpart 201-5: Compliance Demonstration
68 6 NYCRR Subpart 201-5: Compliance Demonstration
69 6 NYCRR Subpart 201-5: Compliance Demonstration
70 6 NYCRR Subpart 201-5: Compliance Demonstration
71 6 NYCRR Subpart 201-5: Compliance Demonstration
72 6 NYCRR Subpart 201-5: Compliance Demonstration

NOTE: * preceding the condition number indicates capping.

FEDERALLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: **Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)**
The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: **Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)**
Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: **Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)**
Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: **Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)**
The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: **Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)**
This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and

reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: **Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: **Property Rights - 6 NYCRR 201-6.4 (a) (6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: **Severability - 6 NYCRR 201-6.4 (a) (9)**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: **Permit Shield - 6 NYCRR 201-6.4 (g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;

ii. The liability of a permittee of the Title V

facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide

a shorter time period in the case of an emergency.

Item K: **Permit Exclusion - ECL 19-0305**
The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: **Federally Enforceable Requirements - 40 CFR 70.6 (b)**
All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

Condition 1: **Acceptable Ambient Air Quality**
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 200.6

Item 1.1:
Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of

emission control required.

Condition 2: **Fees**
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (7)

Item 2.1:
The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 3: **Recordkeeping and Reporting of Compliance Monitoring**
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (c)

Item 3.1:
The following information must be included in any required compliance monitoring records and reports:

(i) The date, place, and time of sampling or measurements;

(ii) The date(s) analyses were performed;

(iii)The company or entity that performed the analyses;

(iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;

(v) The results of such analyses including quality assurance data where required; and

(vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

Condition 4: **Records of Monitoring, Sampling, and Measurement**
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (2)

Item 4.1:
Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 5: **Compliance Certification**
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (3) (ii)

Item 5.1:
The Compliance Certification activity will be performed for the Facility.

Item 5.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring

report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate

whether or not the Department or EPA has approved the results.

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (e)

Item 6.1:
The Compliance Certification activity will be performed for the Facility.

Item 6.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

i. Compliance certifications shall contain:
- the identification of each term or condition of the permit that is the basis of the certification;
- the compliance status;
- whether compliance was continuous or intermittent;
- the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
- such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;

and
- such additional requirements as may be specified elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Stationary Source Compliance Section
USEPA Region 2
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer
NYSDEC- Region 1 Headquarters
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409

The address for the BQA is as follows:

NYSDEC

Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2015.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:
The Compliance Certification activity will be performed for the Facility.

Item 7.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 8.1:
(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires - Prohibitions
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 215.2

Item 9.1:
Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 9.2
Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:
(a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
(b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
(c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
(d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
(e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
(f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
(g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
(h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
(i) Prescribed burns performed according to Part 194 of this Title.
(j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
(k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
(l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE

The following federally enforceable permit conditions are mandatory for all

Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period. [NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

Condition 10: Maintenance of Equipment
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 200.7

Item 10.1:
Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-1.7

Item 11.1:
Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 12.1:
No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 13.1:
The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Condition 14: Trivial Sources - Proof of Eligibility
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 14.1:
The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Condition 15: Requirement to Provide Information
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (4)

Item 15.1:
The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 1-1: Right to Inspect
Effective between the dates of 08/05/2016 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (8)

Replaces Condition(s) 16

Item 1-1.1:
The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Off Permit Changes

Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)

Item 17.1:
No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 18.1:
For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Accidental release provisions.
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40 CFR Part 68

Item 19.1:
If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;

b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:

1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,

2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

Condition 20: Recycling and Emissions Reduction
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 82, Subpart F

Item 20.1:
The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 21: Emission Unit Definition
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 21.1(From Mod 0):
The facility is authorized to perform regulated processes under this permit for:
Emission Unit: U-00001
Emission Unit Description:
Emission Unit U00001 represents two (2) identical GE LM6000 combustion turbines. The turbines will fire only distillate oil. The turbines will be equipped with Selective Catalytic Reduction (SCR) and water injection to control NOx emissions. Each turbine will vent to an individual 110 foot stack.

Condition 22: Progress Reports Due Semiannually
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 201-6.4 (d) (4)

Item 22.1:
Progress reports consistent with an applicable schedule of compliance are to be submitted at

least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 23: Facility Permissible Emissions
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 23.1:
The sum of emissions from the emission units specified in this permit shall not equal or exceed the following
Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 (From Mod 1) PTE: 45,000 pounds per year
Name: OXIDES OF NITROGEN

Condition 24: Capping Monitoring Condition
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 24.1:
Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 227-2
6 NYCRR Subpart 231-2

Item 24.2:
Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 24.3:
The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 24.4:
On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the

facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 24.5:
The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 24.6:
The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: U-00001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 24.7:
Compliance Certification shall include the following monitoring:

Capping: Yes
Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:
The owner or operator of the facility shall install, calibrate, maintain, and operate a continuous emissions monitor for oxides of nitrogen. The limits for emissions of oxides of nitrogen shall be based upon the higher heating value of the fuel. All required records shall be kept at the facility for a minimum of five years.

Manufacturer Name/Model Number: NOx CEM
Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 22.5 tons per year
Reference Test Method: 40 CFR 75
Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL MAXIMUM ROLLED DAILY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).

Condition 25: Air pollution prohibited
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 211.1

Item 25.1:
No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 26: Compliance Certification
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 225-1.2 (g)

Item 26.1:
The Compliance Certification activity will be performed for the Facility.

Item 26.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS
Monitoring Description:

Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.0015 percent by weight
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 27: Compliance Certification
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 225-1.2 (h)

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Item 27.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS
Monitoring Description:

Owners and/or operators of a stationary combustion installations that fire distillate oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.0015 percent by weight
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 49: EPA Region 2 address.
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A

Item 49.1:
All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2
290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC

Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Condition 50: Recordkeeping requirements.
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.7(b), NSPS Subpart A

Item 50.1:
Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

Condition 51: Compliance Certification
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.7(c), NSPS Subpart A

Item 51.1:
The Compliance Certification activity will be performed for the Facility.

Item 51.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

Affected owners or operators shall submit an excess emissions report and/or a summary report form (as defined in 40 CFR 60.7(d)) semi-annually (or more frequently as required by the applicable Subpart or the Administrator), to the Administrator. These reports shall be post marked no later than 30 days after each calendar quarter (or as appropriate), and shall contain the following information:

1) the magnitude of excess emissions computed, any conversion factors used, the date and time of each occurrence, and the process operating time during the reporting period;

2) specific identification of each period of excess emissions that occur during startup, shutdown, or malfunction, where the nature, cause, and corrective action are provided for a malfunction;

3) the date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system

repairs or adjustments; and

4) when no excess emissions have occurred or when the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be provided in the report.

Monitoring Frequency: CONTINUOUS
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 6 calendar month(s).

Condition 52: Facility files for subject sources.
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.7(f), NSPS Subpart A

Item 52.1:
The following files shall be maintained at the facility for all affected sources: all measurements, including continuous monitoring systems, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations;all continuous monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. The file shall be maintained for at least two years following the date of such measurements, reports, and records.

Condition 53: Circumvention.
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.12, NSPS Subpart A

Item 53.1:
No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

Condition 54: Monitoring requirements.
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.13, NSPS Subpart A

Item 54.1:
All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

Condition 55: Modifications.
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.14, NSPS Subpart A

Item 55.1:
Within 180 days of the completion of any physical or operational change (as defined in section 60.14), compliance with the applicable standards must be achieved.

Condition 56: Reconstruction
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.15, NSPS Subpart A

Item 56.1:
The following shall be submitted to the Administrator prior to reconstruction (as defined in section 60.15):

1) a notice of intent to reconstruct 60 days prior to the action;

2) name and address of the owner or operator;

3) the location of the existing facility;

4) a brief description of the existing facility and the components to be replaced;

5) a description of the existing air pollution control equipment and the proposed air pollution control equipment;

6) an estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility;

7) the estimated life of the facility after the replacements; and

8) a discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.

Condition 57: CEMS
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40CFR 60.334(b), NSPS Subpart GG

Item 57.1:
The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NOX emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NOX and O2 monitors. As an alternative, a CO2 monitor may be used to adjust the measured NOX concentrations to 15 percent O2 by either converting the CO2 hourly averages to equivalent O2 concentrations using Equation F–14a or F–14b in appendix F to 40 CFR Part 75 and making the adjustments to 15 percent O2, or by using the CO2 readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as specified in 40 CFR 60.334(b)(1), (2) and (3).

Condition 58: Facility Subject to Title IV Acid Rain Regulations and Permitting
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:40 CFR Part 72

Item 58.1: This facility is subject to the Title IV Acid Rain Regulations found in 40 CFR Parts 72, 73, 75, 76, 77 and 78. The Acid Rain Permit is an attachment to this permit.

Condition 1-2: Compliance Certification
Effective between the dates of 08/05/2016 and 04/20/2019

Applicable Federal Requirement:40CFR 97.406, Subpart AAAAA

Item 1-2.1:
The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 1-2.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.413 through 97.418 of Subpart AAAAA. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.

(2) The facility, and the designated representative, of each TR NOX Annual source (facility) and each TR NOx Annual Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.430 through 97.435 of Subpart AAAAA and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR NOx Annual allowances and to determine compliance with the TR NOx Annual emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NOx Annual facility and each TR NOx Annual Unit at the facility shall hold, in the facilities compliance account, TR NOx Annual allowances available for deduction for such control period under §97.424(a) in an amount not less than the tons of total NOx emissions for such control period from all TR NOX Annual Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 1-3: Compliance Certification
Effective between the dates of 08/05/2016 and 04/20/2019

Applicable Federal Requirement:40CFR 97.506, Subpart BBBBB

Item 1-3.1:
The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 1-3.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.513 through 97.518 of Subpart BBBBB. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.

(2) The facility, and the designated representative, of each TR NOx Ozone Season source (facility) and each TR NOx Ozone Season Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.530 through 97.535 of Subpart BBBBB and subpart H of part 75 of this chapter. This includes but is not limited

to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR NOx Ozone Season allowances and to determine compliance with the TR NOx Ozone Season emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NOx Ozone Season facility and each TR NOx Ozone Season Unit at the facility shall hold, in the facilities compliance account, TR NOx Ozone Season allowances available for deduction for such control period under §97.524(a) in an amount not less than the tons of total NOx emissions for such control period from all TR NOx Ozone Season Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 1-4: Compliance Certification
Effective between the dates of 08/05/2016 and 04/20/2019

Applicable Federal Requirement:40CFR 97.606, Subpart CCCCC

Item 1-4.1:
The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 1-4.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.613 through 97.618 of Subpart CCCCC. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of

this permit and when any changes are made to the representative (or alternative) or their contact information.

(2) The facility, and the designated representative, of each TR SO2 Group 1 source (facility) and each TR SO2 Group 1 Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.630 through 97.635 of Subpart CCCCC and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR SO2 Group 1 allowances and to determine compliance with the TR SO2 Group 1 emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO2 Group 1 facility and each TR SO2 Group 1 Unit at the facility shall hold, in the facilities compliance account, TR SO2 Group 1 allowances available for deduction for such control period under §97.624(a) in an amount not less than the tons of total SO2 emissions for such control period from all TR SO2 Group 1 Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

****** Emission Unit Level ******

Condition 59: Emission Point Definition By Emission Unit
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 59.1(From Mod 0):
The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001
Height (ft.): 110 Diameter (in.): 126
NYTMN (km.): 4536.237 NYTME (km.): 679.533

Emission Point: 00002
Height (ft.): 110 Diameter (in.): 126
NYTMN (km.): 4536.216 NYTME (km.): 679.525

Condition 60: Process Definition By Emission Unit
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 60.1(From Mod 0):
This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001
Process: OIL Source Classification Code: 2-01-001-01
Process Description:
Emission unit U-00001 represents two (2) identical GE LM6000 combustion turbines firing distillate oil. Water injection and selective catalytic reduction (SCR) will be employed for control of NOx emissions.

Emission Source/Control: WI001 - Combustion
Design Capacity: 421 million Btu per hour

Emission Source/Control: WI002 - Combustion
Design Capacity: 421 million Btu per hour

Emission Source/Control: SCR01 - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Emission Source/Control: SCR02 - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Condition 61: Compliance Certification
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 227-1.3 (a)

Item 61.1:
The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001

Item 61.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:
No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Reference Test Method: Method 9
Monitoring Frequency: ANNUALLY
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 6 calendar month(s).

Condition 62: Compliance Certification
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable Federal Requirement:6 NYCRR 227-1.3 (a)

Item 62.1:
The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00002

Item 62.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Reference Test Method: Method 9
Monitoring Frequency: ANNUALLY
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 6 calendar month(s).

STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: **Emergency Defense - 6 NYCRR 201-1.5**

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;
(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: **General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**
Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and

standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS
The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 63: Contaminant List
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:ECL 19-0301

Item 63.1:
Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

Condition 64: Malfunctions and start-up/shutdown activities
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR 201-1.4

Item 64.1:
(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 65: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR 201-1.4

Item 65.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 65.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
In the event that the permittee claims that an excess emission is the result of an unavoidable malfunction or upset, the permittee shall submit a quarterly Report of Malfunction and Abatement to the Department's Regional Air Pollution Control Engineer. The Report of Malfunction and Abatement shall contain the following information:

1) a description of the possible malfunction or upset;

2) the cause of the excess emission;

3) the reason(s) why it is claimed that the excess emission was the result of an unavoidable malfunction or upset;

4) the date and time of the excess emission;

5) the air contaminant(s) emitted, including the parameters of the permit exceedance;

6) the estimated emission rates of the air contaminant(s) emitted;

7) the corrective action taken to address the excess emission; and

8) any action taken to prevent such an excess emission from reoccurring.

Monitoring Frequency: CONTINUOUS
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).

Condition 66: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 66.1:
The Compliance Demonstration activity will be performed for the Facility.

Item 66.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS
Monitoring Description:

The owner or operator shall be allowed to purchase distillate oil with a sulfur content of 0.05% until June 30th 2014 and fire distillate oil with a sulfur content of 0.05% until June 30th 2016.

The owner or operator of this facility shall maintain vendor receipts of each delivery of distillate oil to determine sulfur content of the fuel. These shall be kept at the facility for a minimum of five years.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.05 percent by weight
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).

****** Emission Unit Level ******

Condition 67: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 67.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 67.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:
The owner or operator of the facility shall install, calibrate, maintain, and operate continuous emissions monitors for ammonia. All required records shall be kept at the facility for a minimum of five years.

Manufacturer Name/Model Number: Ammonia CEM
Parameter Monitored: AMMONIA
Upper Permit Limit: 10 parts per million by volume (dry, corrected to 15% O2)
Reference Test Method: Method 027
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 6 calendar month(s).

Condition 68: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 68.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Item 68.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
Start-up shall be defined as the 30 minute period of time from the point that the gas turbine begins firing fuel. The owner or operator shall record the date and time of each period of start-up. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained on-site by the applicant for a minimum of five years.

Parameter Monitored: DURATION OF START UP
Upper Permit Limit: 30 minutes
Monitoring Frequency: CONTINUOUS
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).

Condition 69: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 69.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Item 69.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
A shutdown shall be defined as the period of time when

the stop signal is initiated to when fuel is no longer being combusted in the engine or a subsequent start is initiated, not to exceed 20 minutes per occurrence. The owner or operator shall record each period of shutdown and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained on-site by the applicant for a minimum of five years.

Parameter Monitored: DURATION OF SHUTDOWN
Upper Permit Limit: 20 minutes
Monitoring Frequency: CONTINUOUS
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).

Condition 70: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 70.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 70.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:
This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall apply only during periods of start-up (30 minutes per occurrence). Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained on-site by the applicant for a minimum of five years.

Manufacturer Name/Model Number: NOx CEM
Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 35 pounds
Reference Test Method: 40 CFR 75
Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).

Condition 71: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 71.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 71.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:
This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall apply only during periods of shutdown, not to exceed 20 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained on-site by the applicant for a minimum of five years.

Manufacturer Name/Model Number: NOx CEM
Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 8 pounds
Reference Test Method: 40 CFR 75
Monitoring Frequency: CONTINUOUS
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).

Condition 72: Compliance Demonstration
Effective between the dates of 04/21/2014 and 04/20/2019

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 72.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 72.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:

The owner or operator of the facility shall install, calibrate, maintain, and operate continuous emissions monitors for oxides of nitrogen and either oxygen or carbon dioxide. All required records shall be kept at the facility for a minimum of five years.

The 9.0 ppmvd limit shall be applicable during periods of steady state operation where the facility operates 16 or more minutes consecutively in one clock hour. When a facility operates in steady state less than 16 minutes (consecutively in one clock hour, and excluding startup or shutdown) the 9.0 ppmvd limit does not apply, but a mass emission limit of 7.5 pounds applies. Emissions in excess of either the 9.0 ppmvd limit or the 7.5 pound limit shall be reported quarterly through the facility's excess emissions report.

Manufacturer Name/Model Number: NOx CEM
Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 9 parts per million by volume (dry, corrected to 15% O2)
Reference Test Method: 40 CFR 75
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2014.
Subsequent reports are due every 3 calendar month(s).