



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air State Facility
Permit ID: 2-6004-00065/00009
Effective Date: 07/28/2014 Expiration Date: 07/27/2024

Permit Issued To: U S DEPT OF VETERANS AFFAIRS
810 VERMONT AVE NW
WASHINGTON, DC 20420

Contact: MICHAEL ONG
JAMES J PETERS VA MEDICAL CTR
130 W KINGSBRIDGE RD
BRONX, NY 10468-3992
(718) 584-9000

Facility: JAMES J PETERS VA MEDICAL CENTER
130 W KINGSBRIDGE RD
BRONX, NY 10468

Contact: MICHAEL ONG
JAMES J PETERS VA MEDICAL CTR
130 W KINGSBRIDGE RD
BRONX, NY 10468-3992
(718) 584-9000

Description:
JAMES J PETERS VA MEDICAL CENTER is a hospital located at 130 W KINGSBRIDGE RD in the Bronx, New York.

The facility operates emission sources that include 3 (three) boilers, 5 (five) bi-fuel generators (600 kW), pathological waste incinerator, 4 (four) existing ethylene oxide sterilizers, and two new ethylene oxide sterilizers with one Eto abator.

Each of the two new sterilizers is a 3M Steri-Vac 8 XLI sterilizer using pure (100%) ethylene oxide as the sterilizing media. Both sterilizers are connected to a single ethylene oxide abator (3M Model 50). The abator will have destruction efficiency of 99.9%. The new sterilizers will operate on one load cycle per day with each load cycle consisting of 2 hours of sterilization and 12 hours of aeration. The load cycle for the new sterilizers is the same as the load cycle for existing sterilizers. Assuming the worst case each sterilizer including the existing sterilizers will operate for 250 cycles per year. The total ethylene oxide consumption in all six sterilizers is estimated to be 484.38 lbs per year. Pure (100%) ethylene oxide canister will be used to feed the sterilizers.

Five (5) new bi-fuel diesel generators (600 kw each).
The five new generators will be participating in the New York Independent System Operator (NYISO) Demand Response program to help the reliability of the bulk power grid during high demand or in energy shortage situation. Each of the five generators are manufactured by

New York State Department of Environmental Conservation
Facility DEC ID: 2600400065



Generac and will be bi-fuel (natural gas and diesel) fired. Under normal operation both natural gas and diesel will be fired simultaneously, with natural gas contributing 75% of the heat input and diesel contributing the 25% of the heat input. The generators were manufactured in December of 2010.

Existing boilers.

The controls and burners of existing 3 (three) boilers (emission unit 1-00002) are being renovated because the existing burners and controls are old. After renovation the heat input capacity of each boiler remain the same (38.83 mmbtu/hr) and there will not be any increase in emissions from the boilers.

Hospital pathological waste incinerator.

The incinerator is a single (1) - 1.00 mmBtu/hr pathological waste incinerator. The incinerator has a gas scrubbing system to reduce the incinerator air emissions. The incinerator has a refuse charge rate of 200 lb/hr.

The facility NOx emissions are capped at 24.9 tons per year.

The facility is subject to the provisions of state facility requirements specified under 6NYCRR 201-7.

The air state facility permit contains a listing of the applicable federal, state, and compliance monitoring requirements for the facility.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN
 NYSDEC - REGION 2
 47-40 21ST ST
 LONG ISLAND CITY, NY 11101-5407

Authorized Signature: _____ Date: ____ / ____ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department
Relationship of this Permit to Other Department Orders and
Determinations
Applications for permit renewals, modifications and transfers
Permit modifications, suspensions or revocations by the Department

Facility Level

Submission of application for permit modification or renewal -

REGION 2 HEADQUARTERS



DEC GENERAL CONDITIONS
****** General Provisions ******
GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.



Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal - REGION 2 HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Permit Under the Environmental Conservation Law (ECL)

**ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY
PERMIT**

IDENTIFICATION INFORMATION

Permit Issued To: U S DEPT OF VETERANS AFFAIRS
810 VERMONT AVE NW
WASHINGTON, DC 20420

Facility: JAMES J PETERS VA MEDICAL CENTER
130 W KINGSBRIDGE RD
BRONX, NY 10468

Authorized Activity By Standard Industrial Classification Code:
8092 - KIDNEY DIALYSIS CENTERS

Permit Effective Date: 07/28/2014

Permit Expiration Date: 07/27/2024



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 2 6 NYCRR 201-3.2 (a): Compliance Demonstration
- 3 6 NYCRR Subpart 201-7: Facility Permissible Emissions
- *4 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- 5 6 NYCRR 211.1: Air pollution prohibited
- 6 6 NYCRR 212.4 (a): Compliance Demonstration
- 7 6 NYCRR 225-1.2 (b): Compliance Demonstration
- 8 6 NYCRR 225-1.2 (f): Compliance Demonstration
- 9 6 NYCRR 225-1.2 (g): Compliance Demonstration
- 10 6 NYCRR 225-1.2 (h): Compliance Demonstration
- 11 6 NYCRR 225-1.6 (f): Compliance Demonstration
- 12 6 NYCRR 227-1.3 (a): Compliance Demonstration
- 13 40CFR 60, NSPS Subpart IIII: Applicability
- 14 40CFR 63, Subpart JJJJJ: Applicability
- 15 40CFR 63, Subpart ZZZZ: Engines at Area sources of HAP

Emission Unit Level

EU=1-00001

- 16 6 NYCRR 219-6.2: Compliance Demonstration
- 17 6 NYCRR 219-6.3: Compliance Demonstration
- 18 6 NYCRR 219-6.4: Compliance Demonstration

EU=2-00000,Proc=ETO

- 19 6 NYCRR 212.4 (a): Compliance Demonstration

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 20 ECL 19-0301: Contaminant List
- 21 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 22 6 NYCRR Subpart 201-5: Emission Unit Definition
- 23 6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits
- 24 6 NYCRR 201-5.3 (c): Compliance Demonstration
- 25 6 NYCRR 211.2: Visible Emissions Limited

Emission Unit Level

- 26 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
- 27 6 NYCRR Subpart 201-5: Process Definition By Emission Unit

NOTE: * preceding the condition number indicates capping.



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Sealing - 6 NYCRR 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6 NYCRR 200.7

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications,



required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2

If an existing emission source was subject to the permitting requirements of 6 NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

Item E: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.



(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item F: Recycling and Salvage - 6 NYCRR 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item G: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item H: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item I: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR 201-3.3 (a)

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item J: Required Emission Tests - 6 NYCRR 202-1.1

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

Item K: Open Fires Prohibitions - 6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS
The following conditions are federally enforceable.

Condition 1: Exempt Sources - Proof of Eligibility

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 1.1:

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Condition 2: Compliance Demonstration

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 2.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

Emission Unit: 1-00004

Emission Unit: 1-00006

Item 2.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

AS PROOF OF EXEMPT ELIGIBILITY FOR THE
EMERGENCY GENERATORS, THE FACILITY MUST
MAINTAIN MONTHLY RECORDS WHICH
DEMONSTRATE THAT EACH ENGINE IS OPERATED
LESS THAN 500 HOURS PER YEAR, ON A
12-MONTH ROLLING TOTAL BASIS.

Work Practice Type: HOURS PER YEAR OPERATION

Upper Permit Limit: 500.0 hours

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 3: Facility Permissible Emissions

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 3.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

PTE: 49,800 pounds per year

Condition 4: Capping Monitoring Condition
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-7

Item 4.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 201-6
6 NYCRR Subpart 231-2

Item 4.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 4.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 4.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 4.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 4.6:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 4.7:

Compliance Demonstration shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The owner or operator of combustion sources which fire multiple fuels shall maintain a record of the quantity of each fuel fired. Also, the owner or operator shall calculate NOx emissions (based on the fuel quantities) using the following formula:

$D(0.02) + G(100) + E(0.44) + N(3400) + E1(0.17) + N1(1265)$
< 49,800 lbs/yr of Oxides of Nitrogen emissions.

Where: D = 12-month rolling total of distillate oil
fired (from boilers) in gals/yr

G = 12-month rolling total of natural
gas fired (from boilers) in mmscf/yr

E = 12-month rolling total of diesel
fuel fired (from engines) in gals/yr

N = 12-month rolling total of natural
gas fired (from engines) in mmscf/yr

E1 = 12-month rolling total of diesel
fuel fired (from 5 bi-fuel engines) in gals/yr

N1 = 12-month rolling total of natural
gas fired (from 5 bi-fuel engines) in mmscf/yr

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 24.9 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2015.

Subsequent reports are due every 12 calendar month(s).

Condition 5: Air pollution prohibited
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR 211.1

Item 5.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 6: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Applicable Federal Requirement:6 NYCRR 212.4 (a)

Item 6.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000075-21-8 ETHYLENE OXIDE

Item 6.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

ETO abator is required for all sterilizers. The ETO
abator should have a destruction efficiency for ethylene
oxide of 99+%.

Parameter Monitored: ETHYLENE OXIDE

Upper Permit Limit: 99 percent degree of air cleaning or
greater

Reference Test Method: APPROVED METHOD

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: 24-HOUR AVERAGE

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 7: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:6 NYCRR 225-1.2 (b)

Item 7.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 7.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

Owners and/or operators of any stationary combustion
installation that fires either solid fuels or oil are
limited to the firing of solid fuels or oil with a sulfur
content listed in paragraph 6 NYCRR 225-1.(2)(b) through
June 30, 2014.

Data collected pursuant to this Subpart must be tabulated
and summarized in a form acceptable to the Department, and
must be retained for at least five years. The owner of a
Title V facility must furnish to the Department such
records and summaries, on a semiannual calendar basis,

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



within 30 days after the end of the semiannual period.
All other facility owners or distributors must submit
these records and summaries upon request of the
Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.2 percent by weight
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY
TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 8: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR 225-1.2 (f)

Item 8.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 8.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

Owners and/or operators of commercial, industrial, or
residential emission sources that fire number two heating
oil on or after July 1, 2012 are limited to the purchase
of number two heating oil with 0.0015 percent sulfur by
weight or less. Compliance with this limit will be based
on vendor certifications.

Data collected pursuant to this Subpart must be tabulated
and summarized in a form acceptable to the Department, and
must be retained for at least five years. The owner of a
Title V facility must furnish to the Department such
records and summaries, on a semiannual calendar basis,
within 30 days after the end of the semiannual period.
All other facility owners or distributors must submit
these records and summaries upon request of the
Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: NUMBER 2 HEATING OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.0015 percent by weight
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 9: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR 225-1.2 (g)

Item 9.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 9.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 10: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR 225-1.2 (h)

Item 10.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 10.2:

Compliance Demonstration shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installations that fire distillate oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 11: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR 225-1.6 (f)

Item 11.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 11.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Facility owners subject to this Subpart must submit a written report of the fuel sulfur content exceeding the applicable sulfur-in-fuel limitation, measured emissions exceeding the applicable sulfur-in-fuel limitation, measured emissions exceeding the applicable equivalent emission rate, and the nature and cause of such exceedances if known, for each calendar quarter, within 30 days after the end of any quarterly period in which an exceedance takes place.

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: AVERAGING METHOD - SEE MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 12: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)

Item 12.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 12.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The Department reserves the right to perform or require the performance of a Method 9 opacity evaluation at any time during facility operation.

The permittee will conduct observations of visible emissions from the emission unit, process, etc. to which this condition applies at the monitoring frequency stated below while the process is in operation. The permittee will investigate, in a timely manner, any instance where there is cause to believe that visible emissions have the potential to exceed the opacity standard.

The permittee shall investigate the cause, make any necessary corrections, and verify that the excess visible emissions problem has been corrected. If visible emissions with the potential to exceed the standard continue, the permittee will conduct a Method 9 assessment within the next operating day of the sources associated

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



with the potential noncompliance to determine the degree of opacity and will notify the NYSDEC if the Method 9 test indicates that the opacity standard is not met.

Records of visible emissions observations (or any follow-up Method 9 tests), investigations and corrective actions will be kept on-site. Should the Department determine that permittee's record keeping format is inadequate to demonstrate compliance with this condition, it shall provide written notice to the permittee stating the inadequacies, and permittee shall have 90 days to revise its prospective record keeping format in a manner acceptable to the Department.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 13: Applicability

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:40CFR 60, NSPS Subpart IIII

Item 13.1:

Facilities that have stationary compression ignition internal combustion engines must comply with applicable portions of 40 CFR 60 Subpart IIII.

Condition 14: Applicability

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:40CFR 63, Subpart JJJJJJ

Item 14.1:

This Condition applies to:

Emission Unit: 100002

Item 14.2:

Facilities that are area sources of HAP with industrial, commercial, or institutional boilers must comply with applicable portions of 40 CFR 63 JJJJJJ.

Condition 15: Engines at Area sources of HAP

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:40CFR 63, Subpart ZZZZ

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Item 15.1:

Internal combustion engines, constructed or re-constructed on or after June 12, 2006, that meet the requirements of 40 CFR 60 Subpart IIII or Subpart JJJJ meet the requirements of 40 CFR 63 Subpart ZZZZ.

****** Emission Unit Level ******

Condition 16: Compliance Demonstration

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:6 NYCRR 219-6.2

Item 16.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 16.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

No person will construct, install, use or cause to be used any incinerator whose particulate emissions exceed the permissible particulate emission shown on figure 1 or 6 NYCRR Part 219-6.2

If two or more incinerators are connected to a single stack, the total refuse charged to all incinerators connected to the same stack will be the refuse charged for the purpose of determining the permissible particulate emission.

If a single incinerator is connected to two or more stacks, the refuse charged to the single incinerator will be the refuse charged for the purpose of determining the permissible particulate emission.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.7 pounds per hour

Reference Test Method: EPA Method 5

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Condition 17: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:6 NYCRR 219-6.3

Item 17.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Item 17.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person may construct, install or operate any incinerator with visible emissions having a six-minute average opacity of twenty percent or greater except for one six minute period per hour in which the six-minute average opacity must not exceed forty percent.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: EPA Method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 18: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement:6 NYCRR 219-6.4

Item 18.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Item 18.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The gas temperature at the furnace outlet of the incinerator must be automatically maintained at not less than 1,400 °F during 90 percent of the burning period.

Parameter Monitored: TEMPERATURE

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Lower Permit Limit: 1,400 degrees Fahrenheit
Monitoring Frequency: CONTINUOUS
Averaging Method: MINIMUM - NOT TO FALL BELOW STATED
VALUE - SEE MONITORING DESCRIPTION
Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 19: Compliance Demonstration
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable Federal Requirement: 6 NYCRR 212.4 (a)

Item 19.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 2-00000
Process: ETO

Item 19.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

No person shall cause or allow emissions that exceed the applicable permissible emission rate as determined from Table 2, Table 3, or Table 4 of 6 NYCRR Part 212 for the environmental rating issued by the commissioner.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: AVERAGING METHOD - SEE MONITORING
DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)

Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Facility owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state only enforceable.

Condition 20: Contaminant List

Effective between the dates of 07/28/2014 and 07/27/2024

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Applicable State Requirement:ECL 19-0301

Item 20.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000075-21-8

Name: ETHYLENE OXIDE

CAS No: 0NY075-00-0

Name: PARTICULATES

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

Condition 21: Malfunctions and start-up/shutdown activities
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable State Requirement:6 NYCRR 201-1.4

Item 21.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 22: Emission Unit Definition
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable State Requirement: 6 NYCRR Subpart 201-5

Item 22.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00001

Emission Unit Description:

Hospital pathological waste incinerator. The incinerator is a single (1) - 1.00 mmBtu/hr pathological waste incinerator. The incinerator has a gas scrubbing system to reduce the incinerator air emissions. The incinerator has a refuse charge rate of 200 lb/hr.

Building(s): 105

Item 22.2:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00002

Emission Unit Description:

Hospital boiler plant, building number 101. This boiler plant contains three (3) - 38.83 mmBtu/hr rated boilers which can burn no. 2 fuel oil or natural gas. All three boilers are connected to a single stack. The boilers provide the heating and steam to the entire hospital complex.

Building(s): 101

Item 22.3:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00003

Emission Unit Description:


Hospital boiler plant, chiller area, building number 101. This chiller area has one (1) - 7.84 mmBtu/hr rated chiller unit which is capable to burn no. 2 fuel oil or natural gas. The chiller unit provides some of the cooling requirements for the entire hospital complex. The chiller vents to a single stack.

Building(s): 101

Item 22.4:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00004



Facility DEC ID: 2600400065

Hospital boiler plant, building number 101. Two (2) - 2,500 kW rated, diesel fired, emergency back-up generators. The generators provide emergency back-up power to the entire hospital. The two generators vent to individual stacks.

Item 22.5:

Emission Unit: 1-00006

Nursing home, building number 106. One (1) - 160 kW rated, diesel fired, emergency back-up generator. The generator provides emergency back-up power to the nursing home. The generator has a single stack.

Item 22.6:

Emission Unit: 2-00000

The unit consists of six sterilizers and three abators.

Item 22.7:

Emission Unit: E-00007

This emission unit consists of five (5) new bi-fuel (diesel fuel and natural gas) power generators. The generators will participate in Coordinated Demand Response Program.

Condition 23: Renewal deadlines for state facility permits
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable State Requirement: 6 NYCRR 201-5.2 (c)

The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Condition 24: Compliance Demonstration

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Effective between the dates of 07/28/2014 and 07/27/2024

Applicable State Requirement:6 NYCRR 201-5.3 (c)

Item 24.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 24.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Any reports or submissions required by this permit shall be submitted to the Regional Air Pollution Control Engineer (RAPCE) at the following address:

Division of Air Resources
NYS Dept. of Environmental Conservation
Region 2
47-40 21st St.
Long Island City, NY 11101

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: AVERAGING METHOD - SEE MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 25: Visible Emissions Limited

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable State Requirement:6 NYCRR 211.2

Item 25.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

****** Emission Unit Level ******

Condition 26: Emission Point Definition By Emission Unit

Effective between the dates of 07/28/2014 and 07/27/2024

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 26.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00001

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Emission Point: 00001
Height (ft.): 119 Diameter (in.): 20
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 105

Item 26.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00002

Emission Point: 00002
Height (ft.): 185 Diameter (in.): 72
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 101

Item 26.3:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00003

Emission Point: 00003
Height (ft.): 57 Diameter (in.): 24
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 101

Item 26.4:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00004

Emission Point: A0004
Height (ft.): 55 Diameter (in.): 26
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 101

Emission Point: B0004
Height (ft.): 55 Diameter (in.): 26
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 101

Item 26.5:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00006

Emission Point: 00006
Height (ft.): 16 Diameter (in.): 8
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 106

Item 26.6:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 2-00000

Emission Point: 00007
Height (ft.): 31 Diameter (in.): 37

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: MAIN
Emission Point: 00008
Height (ft.): 31 Diameter (in.): 37
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 100

Item 26.7:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: E-00007

Emission Point: A0007
Height (ft.): 13 Diameter (in.): 10
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 100

Emission Point: B0007
Height (ft.): 13 Diameter (in.): 10
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 100

Emission Point: C0007
Height (ft.): 13 Diameter (in.): 10
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 100

Emission Point: D0007
Height (ft.): 13 Diameter (in.): 10
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 100

Emission Point: E0007
Height (ft.): 13 Diameter (in.): 10
NYTMN (km.): 4524.5 NYTME (km.): 592.2 Building: 100

Condition 27: Process Definition By Emission Unit
Effective between the dates of 07/28/2014 and 07/27/2024

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 27.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001
Process: A01 Source Classification Code: 5-01-005-05
Process Description:
A SINGLE (1) PATHOLOGICAL WASTE
INCINERATOR, WHICH BURNS ONLY ANIMAL
BODIES, BODY PARTS AND ASSOCIATED BEDDING
DETERMINED NOT TO BE REGULATED MEDICAL
WASTE (AS DEFINED IN TITLE 13, SECTION
1389-aa OF THE NEW YORK PUBLIC HEALTH LAW).
THE INCINERATOR ALSO WILL BURN TYPE I
REFUSE INFREQUENTLY.

Emission Source/Control: B0001 - Control

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Control Type: GAS SCRUBBER (GENERAL, NOT CLASSIFIED)

Emission Source/Control: A0001 - Incinerator

Design Capacity: 200 pounds per hour

Waste Feed Method: MANUAL DIRECT FEED

Waste Type: CREMATORY WASTE (INCLUDING HUMAN
AND/OR ANIMAL BODY PARTS AND
ASSOCIATED ANIMAL BEDDING) ONLY

Item 27.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001

Process: B01

Source Classification Code: 5-01-005-05

Process Description:

A SINGLE (1) PATHOLOGICAL WASTE
INCINERATOR, WHICH BURNS NATURAL GAS AS A
SECONDARY FUEL.

Emission Source/Control: B0001 - Control

Control Type: GAS SCRUBBER (GENERAL, NOT CLASSIFIED)

Emission Source/Control: A0001 - Incinerator

Design Capacity: 200 pounds per hour

Waste Feed Method: MANUAL DIRECT FEED

Waste Type: CREMATORY WASTE (INCLUDING HUMAN
AND/OR ANIMAL BODY PARTS AND
ASSOCIATED ANIMAL BEDDING) ONLY

Item 27.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00002

Process: A02

Source Classification Code: 1-02-006-02

Process Description:

Firing natural gas in three (3) - 38.83 mmBtu/hr boilers.

Emission Source/Control: A0002 - Combustion

Design Capacity: 38.83 million Btu per hour

Emission Source/Control: B0002 - Combustion

Design Capacity: 38.83 million Btu per hour

Emission Source/Control: C0002 - Combustion

Design Capacity: 38.83 million Btu per hour

Item 27.4:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00002

Process: B02

Source Classification Code: 1-03-005-02

Process Description:

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Firing #2 fuel oil in three (3) - 38.83 mmBtu/hr boilers.

Emission Source/Control: A0002 - Combustion
Design Capacity: 38.83 million Btu per hour

Emission Source/Control: B0002 - Combustion
Design Capacity: 38.83 million Btu per hour

Emission Source/Control: C0002 - Combustion
Design Capacity: 38.83 million Btu per hour

Item 27.5:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00003
Process: A03 Source Classification Code: 1-05-002-06
Process Description: Firing natural gas in a chiller.

Emission Source/Control: A0003 - Combustion
Design Capacity: 7.84 million Btu per hour

Item 27.6:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00004
Process: A04 Source Classification Code: 2-02-001-02
Process Description:
Firing diesel fuel in two 2,500 kW emergency generators.

Emission Source/Control: A0004 - Combustion
Design Capacity: 2,500 kilowatts

Emission Source/Control: B0004 - Combustion
Design Capacity: 2,500 kilowatts

Item 27.7:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00006
Process: A06 Source Classification Code: 2-02-001-02
Process Description:
Firing diesel fuel in 160 kW emergency back-up power generator.

Emission Source/Control: A0006 - Combustion
Design Capacity: 160 kilowatts

Item 27.8:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 2-00000
Process: ETO Source Classification Code: 3-15-020-01

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



Process Description:

Each of the six (4 existing and 2 new) ethylene oxide sterilizers will be operated for one load cycle per day. Each load cycle consists of 2 hours of sterilization and 12 hours of aeration. A maximum of 250 load cycle per year are expected for each sterilizer. Pure ethylene oxide (100% ethylene oxide) will be used during sterilization stage. Four (4) large sterilizers including the 2 new ones will use 5.99 oz ethylene oxide canister while the two (2) small existing sterilizers will use 3.52 oz ethylene oxide canister. A maximum quantity of 484.38 lb per year of ethylene oxide is expected to be used in the process. The exhaust from each sterilizer is routed through abators. There are two existing abators serving four existing sterilizers that have destruction efficiency of 99+%. The two new sterilizers will have a common abator with destruction efficiency of 99.9%.

Emission Source/Control: ABAT1 - Control
Control Type: THERMAL OXIDATION

Emission Source/Control: ABAT2 - Control
Control Type: THERMAL OXIDATION

Emission Source/Control: ABAT3 - Control
Control Type: THERMAL OXIDATION

Emission Source/Control: 0ETO1 - Process
Design Capacity: 8 cubic feet

Emission Source/Control: 0ETO2 - Process
Design Capacity: 8 cubic feet

Emission Source/Control: 0ETO3 - Process
Design Capacity: 5 cubic feet

Emission Source/Control: 0ETO4 - Process
Design Capacity: 5 cubic feet

Emission Source/Control: 0ETO5 - Process
Design Capacity: 8 cubic feet

Emission Source/Control: 0ETO6 - Process
Design Capacity: 8 cubic feet

Item 27.9:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: E-00007

Process: GEN

Source Classification Code: 2-01-001-02

Process Description:

The process involves power generation using bi-fuel

New York State Department of Environmental Conservation

Permit ID: 2-6004-00065/00009

Facility DEC ID: 2600400065



diesel engines. The engines will be fired with natural gas and diesel fuel simultaneously. Natural gas will contribute 75% of the heat input while the remaining 25% will be supplied by the diesel fuel. The generators will use diesel fuel with sulfur content of 0.0015% by wt.

Emission Source/Control: GEN7A - Combustion
Design Capacity: 600 kilowatts

Emission Source/Control: GEN7B - Combustion
Design Capacity: 600 kilowatts

Emission Source/Control: GEN7C - Combustion
Design Capacity: 600 kilowatts

Emission Source/Control: GEN7D - Combustion
Design Capacity: 600 kilowatts

Emission Source/Control: GEN7E - Combustion
Design Capacity: 600 kilowatts

