



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 2-6007-00724/00003
Mod 0 Effective Date: 02/15/2011 Expiration Date: 02/14/2016
Mod 1 Effective Date: 05/24/2011 Expiration Date: 02/14/2016

Permit Issued To: NEW YORK POWER AUTHORITY
123 MAIN ST
WHITE PLAINS, NY 10601

Contact: JOHN KAHABKA
NY POWER AUTHORITY
123 MAIN ST
WHITE PLAINS, NY 10601
(914) 681-6308

Facility: HELL GATE
E 132ND TO E 134TH ST | LOCUST AVE TO EAST RIVER
BRONX, NY

Contact: JOHN KAHABKA
NY POWER AUTHORITY
123 MAIN ST
WHITE PLAINS, NY 10601
(914) 681-6308

Description:
The facility consists of two simple cycle combustion turbines (GE LM6000).
The turbines will employ spray intercooling systems to optimize power output.
The units are each equipped with selective catalytic reduction to control
emissions of oxides of nitrogen and catalytic oxidation to control emissions of
carbon monoxide. The stack is approximately 107 feet in height and 144 inches
in diameter. The facility can generate a maximum 79.9 megawatts of power.
Neither turbine will operate below 60 percent load (during either singular or
dual turbine operation) except during periods of start-up or shutdown.

This modification adds a special condition limiting the electrical output from
this facility to 79.9 MW.

New York State Department of Environmental Conservation
Facility DEC ID: 2600700724



By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN
 NYSDEC
 47-40 21ST ST
 LONG ISLAND CITY, NY 11101-5407

Authorized Signature: _____ Date: ___ / ___ / _____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
- Applications for permit renewals, modifications and transfers
- Permit modifications, suspensions or revocations by the Department

Facility Level

- Submission of application for permit modification or renewal -
REGION 2 HEADQUARTERS

DEC SPECIAL CONDITIONS

- Facility Output Limitation



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted to the Department for approval.



Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal - REGION 2 HEADQUARTERS

Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407

(718) 48



DEC SPECIAL CONDITIONS

2-4997

Condition 1-1: Facility Output Limitation
Applicable State Requirement: 6 NYCRR 621.13

Item 1-1.1:

Failure to operate the approved facility in accordance with the application's commitments to monitor electrical output and to operate at a net output of no more than 79.9 megawatts is grounds for modification, suspension, or revocation of this permit. Operation above 79.9 megawatts is a violation of this permit.

The Permittee shall maintain records, at the facility, for a minimum of five years. All reports shall be submitted to both the NYSDEC Regional Air office and to the Department Public Service.

Monitored Parameter:

Code: 41

Name: Electrical Output

Upper Limit: 79.9 megawatts

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: MONTHLY (CALENDAR YEAR)

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: NEW YORK POWER AUTHORITY
123 MAIN ST
WHITE PLAINS, NY 10601

Facility: HELL GATE
E 132ND TO E 134TH ST | LOCUST AVE TO EAST RIVER
BRONX, NY

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Mod 0 Permit Effective Date: 02/15/2011

Permit Expiration Date: 02/14/2016

Mod 1 Permit Effective Date: 05/24/2011

Permit Expiration Date: 02/14/2016



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 1-1 6 NYCRR 201-6.5 (a) (7): Fees
- 2 6 NYCRR 201-6.5 (a) (7): Fees
- 3 6 NYCRR 201-6.5 (c): Recordkeeping and reporting of compliance monitoring
- 4 6 NYCRR 201-6.5 (c) (2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6 NYCRR 201-6.5 (c) (3) (ii): Compliance Certification
- 6 6 NYCRR 201-6.5 (e): Compliance Certification
- 7 6 NYCRR 202-2.1: Compliance Certification
- 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 9 6 NYCRR 215.2: Open Fires - Prohibitions
- 10 6 NYCRR 200.7: Maintenance of Equipment
- 11 6 NYCRR 201-1.7: Recycling and Salvage
- 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 15 6 NYCRR 201-6.5 (a) (4): Standard Requirement - Provide Information
- 16 6 NYCRR 201-6.5 (a) (8): General Condition - Right to Inspect
- 17 6 NYCRR 201-6.5 (d) (5): Standard Requirements - Progress Reports
- 18 6 NYCRR 201-6.5 (f) (6): Off Permit Changes
- 19 6 NYCRR 202-1.1: Required Emissions Tests
- 20 6 NYCRR 211.3: Visible Emissions Limited
- 21 40 CFR Part 68: Accidental release provisions.
- 22 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 23 6 NYCRR Subpart 201-6: Emission Unit Definition
- 24 6 NYCRR 201-6.5 (g): Non Applicable requirements
- 25 6 NYCRR Subpart 201-7: Facility Permissible Emissions
- 26 6 NYCRR 243-1.6 (a): Permit Requirements
- 27 6 NYCRR 243-1.6 (b): Monitoring requirements
- 28 6 NYCRR 243-1.6 (c): NOx Ozone Season Emission Requirements
- 29 6 NYCRR 243-1.6 (d): Excess emission requirements
- 30 6 NYCRR 243-1.6 (e): Recordkeeping and reporting requirements
- 31 6 NYCRR 243-2.1: Authorization and responsibilities of CAIR designated representative
- 32 6 NYCRR 243-2.4: Certificate of representation
- 33 6 NYCRR 243-8.1: General requirements
- 34 6 NYCRR 243-8.1: Prohibitions
- 35 6 NYCRR 243-8.5 (d): Quarterly reports
- 36 6 NYCRR 243-8.5 (e): Compliance certification
- 37 6 NYCRR Subpart 244-1: CAIR NOx Annual Trading Program General Conditions
- 38 6 NYCRR Subpart 244-2: Designated CAIR Representative
- 39 6 NYCRR Subpart 244-8: Compliance Certification
- 40 6 NYCRR Subpart 245-1: CAIR SO2 Trading Program General Provisions



- 41 6 NYCRR Subpart 245-2: Designated CAIR Representative
- 42 6 NYCRR Subpart 245-8: Compliance Certification
- 43 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
- 44 40CFR 60.7(a), NSPS Subpart A: Date of construction notification -
If a COM is not used.
- 45 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
- 46 40CFR 60.7(f), NSPS Subpart A: Facility files for subject sources.
- 47 40CFR 60.12, NSPS Subpart A: Circumvention.
- 48 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
- 49 40CFR 60.14, NSPS Subpart A: Modifications.
- 50 40CFR 60.15, NSPS Subpart A: Reconstruction
- 51 40 CFR Part 72: Facility Subject to Title IV Acid Rain Regulations
and Permitting

Emission Unit Level

- 52 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 53 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

EU=1-00001

- *54 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- 55 40CFR 60.334(h)(4), NSPS Subpart GG: Custom fuel monitoring schedule

EU=1-00001,EP=00001

- 56 6 NYCRR 227-1.3 (a): Compliance Certification

EU=1-00001,EP=00002

- 57 6 NYCRR 227-1.3 (a): Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 58 ECL 19-0301: Contaminant List
- 59 6 NYCRR 201-1.4: Unavoidable noncompliance and violations
- 60 6 NYCRR 201-1.4: Unavoidable noncompliance and violations
- 61 6 NYCRR 201-1.4: Compliance Demonstration
- 62 6 NYCRR 211.2: Air pollution prohibited
- 63 6 NYCRR 211.2: Air pollution prohibited
- 1-2 6 NYCRR 211.2: Visible Emissions Limited
- 64 6 NYCRR 237-1.4 (a): Applicable Facility, with a unit of a capacity
of 25 MWe or greater
- 65 6 NYCRR 237-1.6 (c): Compliance Demonstration
- 66 6 NYCRR 237-1.6 (e): Recordkeeping and Reporting Requirements
- 67 6 NYCRR 237-1.6 (f): Liability- facility no common stacks
- 68 6 NYCRR 237-1.6 (g): Effect on other Authorities
- 69 6 NYCRR 237-4.1: Compliance Demonstration
- 70 6 NYCRR 237-7.1: Submission of NOx allowance transfers
- 71 6 NYCRR Subpart 237-8: Compliance Demonstration
- 72 6 NYCRR 238-1.6 (c): Compliance Demonstration
- 73 6 NYCRR 238-1.6 (e): Compliance Demonstration
- 74 6 NYCRR 238-1.6 (f): Liability
- 75 6 NYCRR 238-1.6 (g): Effect on Other Authorities
- 76 6 NYCRR 238-2.1: Submissions to the Department

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



- 77 6 NYCRR 238-4.1: Compliance Demonstration
- 78 6 NYCRR 238-7.1: Submission of SO2 allowance transfers
- 79 6 NYCRR Subpart 238-8: Compliance Demonstration
- 80 6 NYCRR 242-1.5: CO2 Budget Trading Program - Excess emission requirements
- 81 6 NYCRR 242-1.5: Compliance Demonstration
- 82 6 NYCRR 242-1.5: Compliance Demonstration
- 83 6 NYCRR 238-1.6 (a): Permit Requirements to be included in new permits or units.

Emission Unit Level

EU=1-00001

- 84 6 NYCRR Subpart 201-5: Compliance Demonstration
- 85 6 NYCRR Subpart 201-5: Compliance Demonstration
- 86 6 NYCRR Subpart 201-5: Compliance Demonstration
- 87 6 NYCRR Subpart 201-5: Compliance Demonstration
- 88 6 NYCRR Subpart 201-5: Compliance Demonstration
- 89 6 NYCRR Subpart 201-5: Compliance Demonstration
- 90 6 NYCRR Subpart 201-5: Compliance Demonstration
- 91 6 NYCRR Subpart 201-5: Compliance Demonstration
- 92 6 NYCRR Subpart 201-5: Compliance Demonstration
- 93 6 NYCRR Subpart 201-5: Compliance Demonstration
- 94 6 NYCRR Subpart 201-5: Compliance Demonstration
- 95 6 NYCRR Subpart 201-5: Compliance Demonstration
- 96 6 NYCRR Subpart 201-5: Compliance Demonstration
- 97 6 NYCRR Subpart 201-5: Compliance Demonstration

NOTE: * preceding the condition number indicates capping.



FEDERALLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.3 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR 201-6.3 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR 201-6.5 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.5 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.5 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR 201-6.5 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.



Item I: Severability - 6 NYCRR 201-6.5 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR 201-6.5 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR 201-6.5 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is



three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York



(NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6 (b)
All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

Condition 1: Acceptable Ambient Air Quality
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 200.6

Item 1.1:
Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 1-1: Fees
Effective between the dates of 05/24/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (7)

Item 1-1.1:
The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 2: Fees
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (7)

Item 2.1:

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

**Condition 3: Recordkeeping and reporting of compliance monitoring
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR 201-6.5 (c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

**Condition 4: Monitoring, Related Recordkeeping, and Reporting
Requirements.
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR 201-6.5 (c) (2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

**Condition 5: Compliance Certification
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR 201-6.5 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.



Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.



If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Mailing addresses for the above



referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2011.

Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement: 6 NYCRR 201-6.5 (e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions; and
 - such additional requirements as may be specified elsewhere in this permit related to compliance certification.

- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

The address for the RAPCE is as follows:

Hunters Point Plaza
47-40 21st Street
Long Island City, NY 11101-5407

The address for the BQA is as follows:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2011.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires - Prohibitions
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 215.2

Item 9.1:

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 9.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of



being fully burned within a 24-hour period.

(e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.

(f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.

(g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.

(h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.

(i) Prescribed burns performed according to Part 194 of this Title.

(j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.

(k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.

(l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 10: Maintenance of Equipment
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Condition 11: Recycling and Salvage
Effective between the dates of 02/15/2011 and 02/14/2016**



Applicable Federal Requirement:6 NYCRR 201-1.7

Item 11.1:

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air

Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility

Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 13.1:

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 14: Trivial Sources - Proof of Eligibility

Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 14.1:

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 15: Standard Requirement - Provide Information

Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (4)



Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: General Condition - Right to Inspect
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Standard Requirements - Progress Reports
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-6.5 (d) (5)

Item 17.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 18: Off Permit Changes
Effective between the dates of 02/15/2011 and 02/14/2016



Applicable Federal Requirement:6 NYCRR 201-6.5 (f) (6)

Item 18.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

**Condition 19: Required Emissions Tests
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 19.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

**Condition 20: Visible Emissions Limited
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR 211.3

Item 20.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Condition 21: Accidental release provisions.
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:40 CFR Part 68

Item 21.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

Condition 22: Recycling and Emissions Reduction
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40CFR 82, Subpart F

Item 22.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 23: Emission Unit Definition
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 23.1(From Mod 0):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-00001

Emission Unit Description:

This emission unit consists of the following:

- 1) two combustion turbines, which shall be operated in the simple cycle and fire only natural gas,
- 2) two Heatec boilers used to heat gas turbine combustion inlet air when ambient temperature and humidity could cause icing at the turbine inlet,
- 3) a 60 bhp diesel fire pump, and
- 4) a 746 bhp diesel back-up generator.

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Building(s): B1
B2
B3
B4

Condition 24: Non Applicable requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 201-6.5 (g)

Item 24.1:

This section contains a summary of those requirements that have been specifically identified as being not applicable to this facility and/or emission units, emission points, processes and/or emission sources within this facility. The summary also includes a justification for classifying any such requirements as non-applicable.

Condition 25: Facility Permissible Emissions
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 25.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 (From Mod 1) PTE: 45,000 pounds
per year

Name: OXIDES OF NITROGEN

Condition 26: Permit Requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-1.6 (a)

Item 26.1:

The CAIR designated representative of each CAIR NOx Ozone Season source shall:

- (i) submit to the department a complete CAIR permit application under section 243-3.3 in accordance with the deadlines specified in section 243-3.2; and
- (ii) submit in a timely manner any supplemental information that the department determines is necessary in order to review a CAIR permit application and issue or deny a CAIR permit.

The owners and operators of each CAIR NOx Ozone Season source shall have a CAIR permit issued by the department under Subpart 243-3 for the source and operate the source and the unit in compliance with such CAIR permit.

Condition 27: Monitoring requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-1.6 (b)



Item 27.1:

The emissions measurements recorded and reported in accordance with Subpart 243-8 shall be used to determine compliance by each CAIR NO_x Ozone Season source with the CAIR NO_x Ozone Season emissions limitation under subdivision (c) of this section.

Condition 28: NO_x Ozone Season Emission Requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-1.6 (c)

Item 28.1:

As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the control period under section 243-6.5(a) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_x Ozone Season units at the source, as determined in accordance with Subpart 243-8. The CAIR NO_x ozone season is the period beginning May 1 of a calendar year, except as provided in section 243-1.6(c)(2), and ending on September 30 of the same year, inclusive.

A CAIR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(1) of this section for the control period starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under sections 243-8.1(b)(1), (2), (3), or (7) and for each control period thereafter.

A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (c)(1) of this section, for a control period in a calendar year before the year for which the CAIR NO_x Ozone Season allowance was allocated.

CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with Subparts 243-6, 243-7, and 243-9.

A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under section 243-1.5 and no provision of law shall be construed to limit the authority of the State or the United States to terminate or limit such authorization.

A CAIR NO_x Ozone Season allowance does not constitute a property right.

Upon recordation by the Administrator under Subpart 243-6, 243-7, or 243-9, every allocation, transfer, or deduction of a CAIR NO_x Ozone Season allowance to or from a CAIR NO_x Ozone Season source's compliance account is incorporated automatically in any CAIR permit of the source.

Condition 29: Excess emission requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-1.6 (d)



Item 29.1:

If a CAIR NO_x Ozone Season source emits nitrogen oxides during any control period in excess of the CAIR NO_x Ozone Season emissions limitation, then:

(1) the owners and operators of the source and each CAIR NO_x Ozone Season unit at the source shall surrender the CAIR NO_x Ozone Season allowances required for deduction under section 243-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law; and

(2) each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law.

Condition 30: Recordkeeping and reporting requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-1.6 (e)

Item 30.1:

Unless otherwise provided, the owners and operators of the CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator.

(i) The certificate of representation under section 243-2.4 for the CAIR designated representative for the source and each CAIR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation under section 243-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with Subpart 243-8, provided that to the extent that Subpart 243-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Ozone Season Trading Program.

Condition 31: Authorization and responsibilities of CAIR designated representative
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-2.1

Item 31.1:

Except as provided under section 243-2.2, each CAIR NO_x Ozone Season source, including all CAIR NO_x Ozone Season units at the source, shall have one and only one CAIR designated

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



representative, with regard to all matters under the CAIR NOx Ozone Season Trading Program concerning the source or any CAIR NOx Ozone Season unit at the source.

The CAIR designated representative of the CAIR NOx Ozone Season source shall be selected by an agreement binding on the owners and operators of the source and all CAIR NOx Ozone Season units at the source and shall act in accordance with the certification statement in section 243-2.4(a)(4)(iv).

Upon receipt by the Administrator of a complete certificate of representation under section 243-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NOx Ozone Season source represented and each CAIR NOx Ozone Season unit at the source in all matters pertaining to the CAIR NOx Ozone Season Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source or unit.

No CAIR permit will be issued, no emissions data reports will be accepted, and no CAIR NOx Ozone Season Allowance Tracking System account will be established for a CAIR NOx Ozone Season unit at a source, until the Administrator has received a complete certificate of representation under section 243-2.4 for a CAIR designated representative of the source and the CAIR NOx Ozone Season units at the source.

Each submission under the CAIR NOx Ozone Season Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NOx Ozone Season source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

Condition 32: Certificate of representation
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-2.4

Item 32.1:

Unless otherwise required by the department or the Administrator, documents of agreement referred to in the certificate of representation shall not be submitted to the department or the Administrator. Neither the department nor the Administrator shall be under any obligation to review or evaluate the sufficiency of such documents, if submitted.

Condition 33: General requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 243-8.1



Item 33.1:

The owners and operators, and to the extent applicable, the CAIR designated representative, of a CAIR NOx Ozone Season unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this Subpart and in Subpart H of 40 CFR Part 75. For purposes of complying with such requirements, the definitions in section 243-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR NOx Ozone Season unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 243-1.2. The owner or operator of a unit that is not a CAIR NOx Ozone Season unit but that is monitored under 40 CFR 75.72(b)(2)(ii) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR NOx Ozone Season unit.

'Requirements for installation, certification, and data accounting.' The owner or operator of each CAIR NOx Ozone Season unit shall:

- (1) install all monitoring systems required under this Subpart for monitoring NOx mass emissions and individual unit heat input (including all systems required to monitor NOx emission rate, NOx concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.71 and 40 CFR 75.72);
- (2) successfully complete all certification tests required under section 243-8.2 and meet all other requirements of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraph (a)(1) of this section; and
- (3) record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section.

Condition 34: Prohibitions
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement: 6 NYCRR 243-8.1

Item 34.1:

No owner or operator of a CAIR NOx Ozone Season unit shall use any alternative monitoring system, alternative reference method, or any other alternative to any requirement of this Subpart without having obtained prior written approval in accordance with section 243-8.6.

No owner or operator of a CAIR NOx Ozone Season unit shall operate the unit so as to discharge, or allow to be discharged, NOx emissions to the atmosphere without accounting for all such emissions in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NOx Ozone Season unit shall disrupt the continuous emission monitoring system, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NOx mass emissions discharged into the atmosphere or heat input, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



No owner or operator of a CAIR NO_x Ozone Season unit shall retire or permanently discontinue use of the continuous emission monitoring system, any component thereof, or any other approved monitoring system under this Subpart, except under any one of the following circumstances:

- (i) during the period that the unit is covered by an exemption under section 243-1.5 that is in effect;
- (ii) the owner or operator is monitoring emissions from the unit with another certified monitoring system approved, in accordance with the applicable provisions of this Subpart and 40 CFR Part 75, by the department for use at that unit that provides emission data for the same pollutant or parameter as the retired or discontinued monitoring system; or
- (iii) the CAIR designated representative submits notification of the date of certification testing of a replacement monitoring system for the retired or discontinued monitoring system in accordance with section 243-8.2(d)(3)(i).

Condition 35: Quarterly reports
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement: 6 NYCRR 243-8.5 (d)

Item 35.1:

The CAIR designated representative shall submit quarterly reports, as follows:

If the CAIR NO_x Ozone Season unit is subject to an Acid Rain emissions limitation or a CAIR NO_x emissions limitation or if the owner or operator of such unit chooses to report on an annual basis under this Subpart, the CAIR designated representative shall meet the requirements of Subpart H of 40 CFR Part 75 (concerning monitoring of NO_x mass emissions) for such unit for the entire year and shall report the NO_x mass emissions data and heat input data for such unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:

- (i) for a unit that commences commercial operation before July 1, 2007, the calendar quarter covering May 1, 2008 through June 30, 2008;
- (ii) for a unit that commences commercial operation on or after July 1, 2007, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 243-8.1(b), unless that quarter is the third or fourth quarter of 2007 or the first quarter of 2008, in which case reporting shall commence in the quarter covering May 1, 2008 through June 30, 2008.

The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

For CAIR NO_x Ozone Season units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Annual Trading Program, CAIR SO₂ Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO_x mass emission data, heat input data, and other information required by this Subpart.

Condition 36: Compliance certification
Effective between the dates of 02/15/2011 and 02/14/2016



Applicable Federal Requirement:6 NYCRR 243-8.5 (e)

Item 36.1:

The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

- (1) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR Part 75, including the quality assurance procedures and specifications;
- (2) for a unit with add-on NOx emission controls and for all hours where NOx data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NOx emissions; and
- (3) for a unit that is reporting on a control period basis under subparagraph (d)(2)(ii) of this section, the NOx emission rate and NOx concentration values substituted for missing data under Subpart D of 40 CFR Part 75 are calculated using only values from a control period and do not systematically underestimate NOx emissions.

**Condition 37: CAIR NOx Annual Trading Program General Conditions
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR Subpart 244-1

Item 37.1:

- 1) As of midnight of March 1, or midnight of the first business day thereafter if March 1 is not a business day, the owners and operators shall hold, in their compliance account, Clean Air Interstate Rule (CAIR) NOx allowances available for compliance deductions for the previous control period (January 1 through December 31), in an amount not less than the total tons of nitrogen oxides emissions from all CAIR NOx units at the source during that control period. A CAIR NOx allowance shall not be deducted for a control period in a calendar year before the year for which the CAIR NOx allowance was allocated. [244-1.6(c)(1), 244-1.2(b)(5), 244-1.2(b)(36), 244-1.6(c)(3)]
- 2) The owners and operators shall hold in their compliance account, CAIR NOx allowances available for compliance deductions for the control period starting on the later of January 1, 2009 or the deadline for meeting a CAIR NOx unit's monitor certification requirements under section 244-8.1(b)(1), (2), or (5) and for each control period thereafter. [244-1.6(c)(2)]
- 3) If a CAIR NOx source emits nitrogen oxides during any control period in excess of the CAIR NOx emissions limitation, the owners and operators of the CAIR NOx source shall surrender the CAIR NOx allowances required for deduction under 6NYCRR Part 244-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this permit, the Act, and applicable State law. [(244-1.6(d)]



4) Unless otherwise provided, the owners and operators of the CAIR NO_x source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [244-1.6(e)]

(i) The certificate of representation under 6NYCRR Part 244-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 244-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 244-8, provided that to the extent that 6NYCRR Part 244-8 provides for a three year period for recordkeeping, the three year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program.

**Condition 38: Designated CAIR Representative
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement: 6 NYCRR Subpart 244-2

Item 38.1:

1) Each Clean Air Interstate Rule (CAIR) NO_x source shall have one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 244-2.2, with regard to all matters under the CAIR NO_x Annual Trading Program. The CAIR designated representative shall be selected by an agreement binding on the owners and operators of the source and act in accordance with the certification statement in 6NYCRR Part 244-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 244-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NO_x source represented in all matters pertaining to the CAIR NO_x Annual Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source. [244-2.1(a), (b) & (c)]

(2) Each submission under the CAIR NO_x Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NO_x source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment." [244-2.1(e)]



Condition 39: Compliance Certification
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement: 6 NYCRR Subpart 244-8

Item 39.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring and Reporting NOX emissions

(1) The owners and operators, and to the extent applicable, the CAIR designated representative shall comply with all recordkeeping and reporting requirements in this condition, the applicable recordkeeping and reporting requirements under 40 CFR 75, and the requirements of 6NYCRR Part 244-2.1(e)(1).

(2) The CAIR designated representative shall submit quarterly reports of the the NOx mass emissions data and heat input data for each CAIR NOx unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under 6NYCRR Part 244-8.1(b), unless that quarter is the third or fourth quarter of 2007, in which case reporting shall commence in the quarter covering January 1, 2008 through March 31, 2008.

(3) The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

(4) For CAIR NOx units that are also subject to an Acid Rain emissions limitation or the CAIR NOx Ozone Season Trading Program, CAIR SO2 Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NOx mass emission data, heat input



data, and other information required by this Subpart.

(5) 'Compliance certification.' The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(i) the monitoring data submitted were recorded in accordance with the applicable requirements of 6NYCRR Part 244 and 40 CFR Part 75, including the quality assurance procedures and specifications; and

(ii) for a unit with add-on NO_x emission controls and for all hours where NO_x data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO_x emissions.

(6) Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of 40 CFR part 75, data shall be substituted using the applicable missing data procedures in Subpart D or Subpart H of, or appendix D or appendix E to 40 CFR part 75. [244-8.3(a)]

(7) Whenever the owner or operator makes a replacement, modification, or change in any certified continuous emission monitoring system under 6NYCRR Part 244-8.1(a)(1) that may significantly affect the ability of the system to accurately measure or record NO_x mass emissions or heat input rate or to meet the quality-assurance and quality-control requirements of 40 CFR 75.21 or appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system in accordance with 40 CFR 75.20(b) . Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that may significantly change the stack flow or concentration profile, the owner or operator shall recertify each continuous emission monitoring system whose accuracy is potentially affected by the change, in accordance with 40 CFR 75.20(b). Examples of changes to a continuous emission monitoring system that require recertification include replacement of the analyzer, complete replacement of an existing continuous emission monitoring system, or change



in location or orientation of the sampling probe or site.
Any fuel flowmeter system, and any excepted NO_x monitoring system under appendix E to 40 CFR part 75, under 6NYCRR Part 244-8.1(a)(1) are subject to the recertification requirements in 40 CFR 75.20(g)(6). [224-8.2(d)(2)]

Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL TOTAL
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2011.
Subsequent reports are due every 3 calendar month(s).

Condition 40: CAIR SO₂ Trading Program General Provisions
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement: 6 NYCRR Subpart 245-1

Item 40.1:

1) As of midnight of March 1, or midnight of the first business day thereafter (if March 1 is not a business day) for a control period, the owners and operators of each Clean Air Interstate Rule (CAIR) SO₂ source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO₂ allowances available for compliance deductions for the control period (January 1 through December 31) not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO₂ units at the source. A CAIR SO₂ allowance shall not be deducted, for compliance with the requirements under paragraph (2) of this section, for a control period in a calendar year before the year for which the CAIR SO₂ allowance was allocated.
[(245-1.2(b)(5), 245-1.6(c)(1), 245-1.2(b)(36), 245-1.6(c)(3)]

2) The owners and operators shall hold in their compliance account, CAIR SO₂ allowances available for compliance deductions for the control period starting on the later of January 1, 2010 or the deadline for meeting a CAIR SO₂ unit's monitor certification requirements under section 245-8.1(b)(1), (2), or (5) and for each control period thereafter. [245-1.6(c)(2)]

3) If a CAIR SO₂ source emits sulfur dioxide during any control period in excess of the CAIR SO₂ emissions limitation, the owners and operators of the source shall surrender the CAIR SO₂ allowances required for deduction under 6NYCRR Part 245-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law.
[(245-1.6(d)]

4) Unless otherwise provided, the owners and operators of the CAIR SO₂ source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [245-1.6(e)]

(i) The certificate of representation under 6NYCRR Part 245-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the



submission of a new certificate of representation under 6NYCRR Part 245-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 245-8, provided that to the extent that 6NYCRR Part 245-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program.

Condition 41: Designated CAIR Representative
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR Subpart 245-2

Item 41.1:

1) Each CAIR SO₂ source shall have one and only one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 245-2.2, with regard to all matters under the CAIR SO₂ Trading Program. The CAIR designated representative of the CAIR SO₂ source shall be selected by an agreement binding on the owners and operators of the source and all CAIR SO₂ units at the source and shall act in accordance with the certification statement in 6NYCRR Part 245-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 245-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR SO₂ source represented and each CAIR SO₂ unit at the source in all matters pertaining to the CAIR SO₂ Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source or unit.
[245-2.1(a), (b) & (c)]

(2) Each submission under the CAIR SO₂ Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR SO₂ source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."
[245-2.1(e)]

Condition 42: Compliance Certification
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR Subpart 245-8

Item 42.1:

The Compliance Certification activity will be performed for the Facility.



Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring and Reporting SO₂ emissions:

1) The owners and operators, and to the extent applicable, the Clean Air Interstate Rule (CAIR) designated representative, of a CAIR SO₂ unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. For purposes of complying with such requirements, the definitions in section 245-1.2 and 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR SO₂ unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 245-1.2. The owner or operator of a unit that is not a CAIR SO₂ unit but that is monitored under 40 CFR 75.16(b)(2) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR SO₂ unit. [245-8.1]

2)The owner or operator of each CAIR SO₂ unit shall:
[245-8.1(a)]

(i) install all monitoring systems required under this Subpart for monitoring SO₂ mass emissions and individual unit heat input (including all systems required to monitor SO₂ concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.11 and 40 CFR 75.16);

(ii) successfully complete all certification tests required under Part 245-8.2 and meet all other requirements of this section and 40 CFR Part 75 applicable to the monitoring systems under this section; and

(iii) record, report, and quality-assure the data from the monitoring systems under paragraph of this section.

3) The owner or operator shall meet the monitoring system certification and other requirements of section 245-8.1(a)(1) and (2) on or before the following dates. The owner or operator shall record, report, and quality-assure the data from the monitoring systems under



section 245-8.1(a)(1) on and after the following dates.
[245-8.1(b)]

(i) For the CAIR SO₂ unit that commences commercial operation before July 1, 2008, by January 1, 2009.

(ii) For the CAIR SO₂ unit that commences commercial operation on or after July 1, 2008, by the later of the following dates: January 1, 2009; or 90 unit operating days or 180 calendar days, whichever occurs first, after the date on which the unit commences commercial operation.

4) Whenever the owner or operator makes a replacement, modification, or change in any certified continuous emission monitoring system under section 245-8.1(a)(1) that may significantly affect the ability of the system to accurately measure or record SO₂ mass emissions or heat input rate or to meet the quality-assurance and quality-control requirements of 40 CFR 75.21 or appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system in accordance with 40 CFR 75.20(b). Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that may significantly change the stack flow or concentration profile, the owner or operator shall recertify each continuous emission monitoring system whose accuracy is potentially affected by the change, in accordance with 40 CFR 75.20(b). Examples of changes to a continuous emission monitoring system that require recertification include: replacement of the analyzer, complete replacement of an existing continuous emission monitoring system, or change in location or orientation of the sampling probe or site. Any fuel flowmeter system under section 245-8.1(a)(1) is subject to the recertification requirements in 40 CFR 75.20(g)(6). [245-8.2(d)(2)]

5) Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of 40 CFR Part 75, data shall be substituted using the applicable missing data procedures in Subpart D of or appendix D to 40 CFR Part 75.
[245-8.3(a)]

6) The CAIR designated representative shall comply with all recordkeeping and reporting requirements in section 245-8.3, the applicable recordkeeping and reporting requirements in Subparts F and G of 40 CFR Part 75, and the requirements of section 245-2.1(e)(1).
[245-8.5(a)]

7) The owner or operator of a CAIR SO₂ unit shall comply with requirements of 40 CFR 75.62 for monitoring plans.



[245-8.5(b)]

8) The CAIR designated representative shall submit an application to the department within 45 days after completing all initial certification or recertification tests required under section 245-8.2, including the information required under 40 CFR 75.63. [245-8.5(c)]

9) The CAIR designated representative shall submit quarterly reports of the SO₂ mass emissions data and heat input data for each CAIR SO₂ unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with: [245-8.5(d)(1)]

- i) the calendar quarter covering January 1, 2009 through March 31, 2009 for a unit that commences commercial operation before July 1, 2008; or
- ii) for a unit that commences commercial operation on or after July 1, 2008, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 245-8.1(b), unless that quarter is the third or fourth quarter of 2008, in which case reporting shall commence in the quarter covering January 1, 2009 through March 31, 2009.

10) The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.64. [245-8.5(d)(2)]

11) For CAIR SO₂ units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the SO₂ mass emission data, heat input data, and other information required by this Subpart. [245-8.5(d)(3)]

12) The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that: [245-8.5(e)]

- i) the monitoring data submitted were recorded in

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



accordance with the applicable requirements of this Subpart and 40 CFR Part 75, including the quality assurance procedures and specifications; and
ii) for a unit with add-on SO₂ emission controls and for all hours where SO₂ data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate SO₂ emissions.

Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL TOTAL
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2011.
Subsequent reports are due every 3 calendar month(s).

**Condition 43: EPA Region 2 address.
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A

Item 43.1:

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2
290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

**Condition 44: Date of construction notification - If a COM is not used.
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:40CFR 60.7(a), NSPS Subpart A

Item 44.1:

Any owner or operator subject to this part shall furnish the Administrator with the following information:

1) a notification of the date construction or reconstruction commenced, post marked no later than

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



30 days after such date;

3) a notification of the actual date of initial start up, post marked within 15 days after such date;

4) a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the change is specifically exempted under this part. The notice shall be post marked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capability of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional information regarding the change;

5) a notification of the date upon which the demonstration of continuous monitoring system performance commences, post marked not less than 30 days prior to such date;

6) a notification of the anticipated date for conducting the opacity observations, post marked not less than 30 days prior to such date.

Condition 45: Recordkeeping requirements.
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40CFR 60.7(b), NSPS Subpart A

Item 45.1:

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

Condition 46: Facility files for subject sources.
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40CFR 60.7(f), NSPS Subpart A

Item 46.1:

The following files shall be maintained at the facility for all affected sources: all measurements, including continuous monitoring systems, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. The file shall be maintained for at least two years following the date of such measurements, reports, and records.

Condition 47: Circumvention.
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40CFR 60.12, NSPS Subpart A

Item 47.1:

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not



limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

Condition 48: Monitoring requirements.
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40CFR 60.13, NSPS Subpart A

Item 48.1:

All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

Condition 49: Modifications.
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40CFR 60.14, NSPS Subpart A

Item 49.1:

Within 180 days of the completion of any physical or operational change (as defined in section 60.14), compliance with the applicable standards must be achieved.

Condition 50: Reconstruction
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40CFR 60.15, NSPS Subpart A

Item 50.1:

The following shall be submitted to the Administrator prior to reconstruction (as defined in section 60.15):

- 1) a notice of intent to reconstruct 60 days prior to the action;
- 2) name and address of the owner or operator;
- 3) the location of the existing facility;
- 4) a brief description of the existing facility and the components to be replaced;
- 5) a description of the existing air pollution control equipment and the proposed air pollution control equipment;
- 6) an estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility;
- 7) the estimated life of the facility after the replacements; and
- 8) a discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.

Condition 51: Facility Subject to Title IV Acid Rain Regulations and Permitting

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:40 CFR Part 72

Item 51.1: This facility is subject to the Title IV Acid Rain Regulations found in 40 CFR Parts 72, 73, 75, 76, 77 and 78. The Acid Rain Permit is an attachment to this permit.

****** Emission Unit Level ******

**Condition 52: Emission Point Definition By Emission Unit
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 52.1(From Mod 0):

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-00001

Emission Point: 00001

Height (ft.): 107

Diameter (in.): 144

NYTMN (km.): 4517.001 NYTME (km.): 592.041

Emission Point: 00002

Height (ft.): 107

Diameter (in.): 144

NYTMN (km.): 4516.981 NYTME (km.): 592.025

Emission Point: 00003

Height (ft.): 15

Diameter (in.): 22

NYTMN (km.): 4517.012 NYTME (km.): 592.003

Emission Point: 00004

Height (ft.): 15

Diameter (in.): 22

NYTMN (km.): 4517.012 NYTME (km.): 592.003

Emission Point: 00005

Height (ft.): 13

Diameter (in.): 3

NYTMN (km.): 4517.012 NYTME (km.): 592.003

Emission Point: 00006

Height (ft.): 1 Diameter (in.): 5

NYTMN (km.): 4517.012 NYTME (km.): 592.003

**Condition 53: Process Definition By Emission Unit
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 53.1(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

New York State Department of Environmental Conservation
Permit ID: 2-6007-00724/00003 Facility DEC ID: 2600700724



Emission Unit: 1-00001
Process: 001 Source Classification Code: 2-01-002-01
Process Description:
Two combustion turbines (GE LM60000) firing natural gas.

Emission Source/Control: 00001 - Combustion
Design Capacity: 420 million Btu per hour

Emission Source/Control: 00003 - Combustion
Design Capacity: 420 million Btu per hour

Emission Source/Control: 00002 - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Emission Source/Control: 00004 - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Emission Source/Control: 00005 - Control
Control Type: CATALYTIC OXIDATION

Emission Source/Control: 00006 - Control
Control Type: CATALYTIC OXIDATION

Item 53.2(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001
Process: 002 Source Classification Code: 1-02-006-03
Process Description: Natural gas firing in two 7.4 mmBtu/hr boilers.

Emission Source/Control: 00007 - Combustion
Design Capacity: 7.4 million Btu per hour

Emission Source/Control: 00008 - Combustion
Design Capacity: 7.4 million Btu per hour

Item 53.3(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001
Process: 003 Source Classification Code: 2-02-001-02
Process Description: One 60 bhp diesel fire pump.

Emission Source/Control: 00009 - Combustion
Design Capacity: 60 horsepower (mechanical)

Item 53.4(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-00001
Process: 004 Source Classification Code: 2-02-001-02
Process Description: One 746 bhp diesel back-up generator.

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Emission Source/Control: 00010 - Combustion
Design Capacity: 746 horsepower (mechanical)

Condition 54: Capping Monitoring Condition
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement: 6 NYCRR Subpart 201-7

Item 54.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 227-2
6 NYCRR Subpart 231-2

Item 54.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 54.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 54.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 54.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 54.6:

The Compliance Certification activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 54.7:

Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall calculate the tons per year of oxides of nitrogen emissions based on a twelve month rolling average using the following equation:

$$(GTACTION + (0.0364 \text{ lbs/mmBtu})(BATHI) + (10.23 \text{ lbs/hr})(BETAHO) + (0.80 \text{ lbs/hr})(FPTAHO)) / 2000 \text{ lbs/ton} \leq 22.5 \text{ tpy}$$

where:

GTACTION = gas turbine actual NOx emissions in pounds per year from the CEM reports,

BATHI = boiler annual total heat input in mmBtu/yr,

BETAHO = back-up engine total annual hours of operation in hr/yr, and

FPTAHO = fire pump total annual hours of operation in hr/yr.

All records shall be maintained by the applicant at their Poletti facility for a minimum of five year

Manufacturer Name/Model Number: NOx ANALYSER

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 22.5 tons per year

Reference Test Method: 40 CFR 75

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

**Condition 55: Custom fuel monitoring schedule
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable Federal Requirement:40CFR 60.334(h)(4), NSPS Subpart GG

Item 55.1:

This Condition applies to Emission Unit: 1-00001

Item 55.2:

For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.



Condition 56: Compliance Certification
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 227-1.3 (a)

Item 56.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-00001

Emission Point: 00001

Item 56.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: ANNUALLY

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2011.

Subsequent reports are due every 6 calendar month(s).

Condition 57: Compliance Certification
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable Federal Requirement:6 NYCRR 227-1.3 (a)

Item 57.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-00001

Emission Point: 00002

Item 57.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: ANNUALLY

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2011.

Subsequent reports are due every 6 calendar month(s).



STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS
The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 58: Contaminant List
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:ECL 19-0301

Item 58.1:
Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0
Name: CARBON MONOXIDE



CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

Condition 59: Unavoidable noncompliance and violations
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement: 6 NYCRR 201-1.4

Item 59.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which



result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 60: Unavoidable noncompliance and violations
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 201-1.4

Item 60.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.



(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 61: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 201-1.4

Item 61.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 61.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

In the event that the permittee claims that an excess emission is the result of an unavoidable malfunction or upset, the permittee shall submit a Report of Malfunction and Abatement to the Department's Regional Air pollution Control Engineer within 30 days from the date that the excess emission occurred. The Report of Malfunction and Abatement shall contain the following information:

- 1) a description of the possible malfunction or upset;
- 2) the cause of the excess emission;
- 3) the reason(s) why it is claimed that the excess emission was the result of an unavoidable malfunction or upset;
- 4) the date and time of the excess emission;
- 5) the air contaminant(s) emitted, including the parameters of the permit exceedance;
- 6) the estimated emission rates of the air contaminant(s) emitted;
- 7) the corrective action taken to address the excess



emission; and

8) any action taken to prevent such an excess emission from reoccurring.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 62: Air pollution prohibited
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 211.2

Item 62.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 63: Air pollution prohibited
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 211.2

Item 63.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 1-2: Visible Emissions Limited
Effective between the dates of 05/24/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 211.2

Item 1-2.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 64: Applicable Facility, with a unit of a capacity of 25 MWe or greater
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 237-1.4 (a)

Item 64.1:



Any unit, that at any time on or after January 1, 1999, serves a generator with a nameplate capacity equal to or greater than 25 MWe and sells any amount of electricity shall be a NOx budget unit, and any source that includes one or more such units shall be a NOx budget source, subject to the requirements of NYCRR 237.

Condition 65: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 237-1.6 (c)

Item 65.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 65.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators of each NOx budget source and each NOx budget unit at the source shall hold NOx allowances available for compliance deductions under NYCRR 237-6.5, as of the NOx allowance transfer deadline, in the unit's compliance account and the source's overdraft account in an amount not less than the total NOx emissions for the control period from the unit, as determined in accordance with NYCRR 237-8.

Each ton of NOx emitted in excess of the NOx budget emissions limitation shall constitute a separate violation of applicable State law.

A NOx budget unit shall be subject to the requirements under NYCRR 237-1.6(c)(1) starting when the unit commences operation.

NOx allowances shall be held in, deducted from, or transferred among NOx Allowance Tracking System accounts in accordance with NYCRR 237-5, 237-6, 237-7, and 237-9.

Except for future control period NOx allowances which may be deducted pursuant to NYCRR 237-6.5(f), a NOx allowance shall not be deducted, in order to comply with the requirements under NYCRR 237-1.6(c)(1), for a control period in a year prior to the year for which the NOx allowance was allocated.

A NOx allowance allocated by the department under the Acid Deposition Reduction (ADR) NOx Budget Trading Program is a limited authorization to emit one ton of NOx in accordance with the ADR NOx Budget Trading Program. No provision of the ADR NOx Budget Trading Program, the NOx budget permit



application, or the NOx budget permit or any provision of law shall be construed to limit the authority of the State to terminate or limit such authorization.

A NOx allowance allocated by the department under the ADR NOx Budget Trading Program does not constitute a property right.

The owners and operators of a NOx budget unit that has excess emissions in any control period shall: Forfeit the NOx allowances required for deduction under NYCRR 237-6.5(d)(1); and pay any fine, penalty, or assessment or comply with any other remedy imposed under NYCRR 237-6.5(d)(3).

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 66: Recordkeeping and Reporting Requirements
Effective between the dates of 02/15/2011 and 02/14/2016**

Applicable State Requirement:6 NYCRR 237-1.6 (e)

Item 66.1:

Unless otherwise provided, the owners and operators of the NOx budget source and each NOx budget unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the department:

- 1) The account certificate of representation for the NOx authorized account representative for the source and each NOx budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with NYCRR 237-2.4; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new account certificate of representation changing the NOx authorized account representative.
- 2) All emissions monitoring information, in accordance with NYCRR 237-8.
- 3) Copies of all reports, compliance certifications, and other submissions and all records made or required under the ADR NOx Budget Trading Program.
- 4) Copies of all documents used to complete a NOx budget permit application and any other submission under the ADR NOx Budget Trading Program or to demonstrate compliance with the requirements of the ADR NOx Budget Trading Program.

The NOx authorized account representative of a NOx budget source and each NOx budget unit at the source shall submit the reports and compliance certifications required under the ADR NOx Budget Trading Program, including those under NYCRR 237-4, 237-8, or 237-9.

**Condition 67: Liability- facility no common stacks
Effective between the dates of 02/15/2011 and 02/14/2016**



Applicable State Requirement:6 NYCRR 237-1.6 (f)

Item 67.1:

No permit revision shall excuse any violation of the requirements of the ADR NOx Budget Trading Program that occurs prior to the date that the revision takes effect.

Any provision of the ADR NOx Budget Trading Program that applies to a NOx budget source (including a provision applicable to the NOx authorized account representative of a NOx budget source) shall also apply to the owners and operators of such source and of the NOx budget units at the source.

Condition 68: Effect on other Authorities
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 237-1.6 (g)

Item 68.1:

No provision of the ADR NOx Budget Trading Program, a NOx budget permit application, or a NOx budget permit, shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the NOx authorized account representative of a NOx budget source or NOx budget unit from compliance with any other provisions of applicable State and federal law and regulations.

Condition 69: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 237-4.1

Item 69.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 69.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

For each control period in which one or more NOx budget units at a source are subject to the NOx budget emissions limitation, the NOx authorized account representative of the source shall submit to the department by the September 30 following the relevant control period, a compliance certification report for each source covering all such units.

The NOx authorized account representative shall include in the compliance certification report the following elements, in a format prescribed by the department, concerning each unit at the source and subject to the NOx budget emissions limitation for the control period covered by the report:



- (1) identification of each NO_x budget unit;
- (2) except in instances when the NO_x budget unit seeks to use future control period NO_x allowances which may be deducted pursuant to NYCRR 237-6.5(f), at the NO_x authorized account representative's option, the serial numbers of the NO_x allowances that are to be deducted from each unit's compliance account under NYCRR 237-6.5 for the control period;
- (3) at the NO_x authorized account representative's option, for units sharing a common stack and having NO_x emissions that are not monitored separately or apportioned in accordance with NYCRR 237-8, the percentage of NO_x allowances that is to be deducted from each unit's compliance account under NYCRR 237-6.5(e);
- (4) for units using future control period allowances for compliance purposes pursuant to NYCRR 237-6.5(f), the statement of intent and report required under NYCRR 237-6.5(f)(2); and
- (5) the compliance certification under NYCRR 237-4(c).

In the compliance certification report the NO_x authorized account representative shall certify, based on reasonable inquiry of those persons with primary responsibility for operating the source and the NO_x budget units at the source in compliance with the Acid Deposition Reduction (ADR) NO_x Budget Trading Program, whether each NO_x budget unit for which the compliance certification is submitted was operated during the calendar year covered by the report in compliance with the requirements of the ADR NO_x Budget Trading Program applicable to the unit, including:

- (a) whether the unit was operated in compliance with the NO_x budget emissions limitation;
- (b) whether the monitoring plan that governs the unit has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute NO_x emissions to the unit, in accordance with NYCRR 237-8;
- (c) whether all the NO_x emissions from the unit, or a group of units (including the unit) using a common stack, were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with NYCRR 237-8. If conditional data were reported, the owner or operator



shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;

(d) whether the facts that form the basis for certification under NYCRR 237-8 of each monitor at the unit or a group of units (including the unit) using a common stack, or for using an excepted monitoring method or alternative monitoring method approved under NYCRR 237-8, if any, has changed; and

(e) if a change is required to be reported in (4) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor recertification.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 70: Submission of NO_x allowance transfers
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 237-7.1

Item 70.1:

The NO_x authorized account representatives seeking recordation of a NO_x allowance transfer shall submit the transfer to the department or its agent. To be considered correctly submitted, the NO_x allowance transfer shall include the following elements in a format specified by the department or its agent:

- (a) the numbers identifying both the transferor and transferee accounts;
- (b) a specification by serial number of each NO_x allowance to be transferred; and
- (c) the printed name and signature of the NO_x authorized account representative of the transferor account and the date signed.

Condition 71: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 237-8

Item 71.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 71.2:

Compliance Demonstration shall include the following monitoring:



Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators, and to the extent applicable, the NOx authorized account representative of a NOx budget unit, shall comply with the monitoring and reporting requirements as provided in this NYCRR 237-8 and in Subpart H of 40 CFR part 75. For purposes of complying with such requirements, the definitions in NYCRR 237-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," and "designated representative" in 40 CFR part 75 shall be replaced by the terms "NOx budget unit," and "NOx authorized account representative," respectively, as defined in section 237-1.2.

For any NOx budget unit which is also a NOx budget unit under Part 204 of this title, prior or contemporaneous timely submissions in compliance with the requirements of Subpart 204-8 may, when appropriate, be summarily referenced by the owners and operators of the NOx budget unit in order to demonstrate compliance with the requirements of this Subpart:

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 72: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-1.6 (c)

Item 72.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 72.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners and operators of each SO2 budget source and each SO2 budget unit at the source shall hold SO2 allowances available for compliance deductions under NYCRR 238-6.5, as of the SO2 allowance transfer deadline, in the unit's compliance account and the source's overdraft account in an amount not less than the total SO2 emissions for the control period from the unit, as determined in accordance with NYCRR 238-8.

Each ton of sulfur dioxide emitted in excess of the SO2 budget emissions limitation shall constitute a separate violation of this Part, the Act, and applicable State



law.

An SO₂ budget unit shall be subject to the requirements under NYCRR 1.6 (c)(1) on the date on which the unit commences operation.

SO₂ allowances shall be held in, deducted from, or transferred among SO₂ Allowance Tracking System accounts in accordance with NYCRR 238-5, 238-6, and 238-7.

Except for future control period SO₂ allowances which may be deducted pursuant to NYCRR 238-6.5(f), an SO₂ allowance shall not be deducted, in order to comply with the requirements under NYCRR 238-1.6(c)(1) for a control period in a year prior to the year for which the SO₂ allowance was allocated.

An SO₂ allowance allocated by the department under the ADR SO₂ budget Trading Program is a limited authorization to emit one ton of sulfur dioxide in accordance with the Acid Deposition Reduction (ADR) SO₂ Budget Trading Program. No provision of the ADR SO₂ Budget Trading Program, the SO₂ budget permit application, or the SO₂ budget permit or any provision of law shall be construed to limit the authority of the United States or the State to terminate or limit such authorization.

An SO₂ allowance allocated by the department under the ADR SO₂ Budget Trading Program does not constitute a property right.

The owners and operators of an SO₂ budget unit that has excess emissions in any control period shall: Forfeit the SO₂ allowances required for deduction under NYCRR 238-6.5(d)(1); and Pay any fine, penalty, or assessment or comply with any other remedy imposed under NYCRR 238-6.5(d)(3).

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2011.

Subsequent reports are due every 12 calendar month(s).

Condition 73: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-1.6 (e)

Item 73.1:

The Compliance Demonstration activity will be performed for the Facility.

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Item 73.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Unless otherwise provided, the owners and operators of the SO₂ budget source and each SO₂ budget unit at the source shall keep on site or at a site approved by the Department each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the department.

The account certificate of representation for the SO₂ authorized account representative for the source and each SO₂ budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with NYCRR 238-2.4; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new account certificate of representation changing the SO₂ authorized account representative;

All emissions monitoring information, in accordance with NYCRR 238-8;

Copies of all reports, compliance certifications, and other submissions and all records made or required under the ADR SO₂ Budget Trading Program;

Copies of all documents used to complete an SO₂ budget permit application and any other submission under the ADR SO₂ Budget Trading Program or to demonstrate compliance with the requirements of the ADR SO₂ Budget Trading Program;

The SO₂ authorized account representative of an SO₂ budget source and each SO₂ budget unit at the source shall submit the reports and compliance certifications required under the ADR SO₂ Budget Trading Program, including those under NYCRR 238-4, or 238-8.

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2011.

Subsequent reports are due every 12 calendar month(s).

Condition 74: Liability

Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-1.6 (f)



Item 74.1:

No permit revision shall excuse any violation of the requirements of the ADR SO₂ Budget Trading Program that occurs prior to the date that the revision takes effect.

Any provision of the ADR SO₂ Budget Trading Program that applies to an SO₂ budget source (including a provision applicable to the SO₂ authorized account representative of an SO₂ budget source) shall also apply to the owners and operators of such source and of the SO₂ budget units at the source;

Any provision of the ADR SO₂ Budget Trading Program that applies to an SO₂ budget unit (including a provision applicable to the SO₂ authorized account representative of an SO₂ budget unit) shall also apply to the owners and operators of such unit. Except with regard to the requirements applicable to units with a common stack under Subpart 238-8, the owners and operators and the SO₂ authorized account representative of one SO₂ budget unit shall not be liable for any violation by any other SO₂ budget unit of which they are not owners or operators or the SO₂ authorized account representative and that is located at a source of which they are not owners or operators or the SO₂ authorized account representative.

Condition 75: Effect on Other Authorities
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-1.6 (g)

Item 75.1:

No provision of the ADR SO₂ Budget Trading Program, an SO₂ budget permit application, or an SO₂ budget permit, shall be construed as exempting or excluding the owners and operators and, to the extent applicable, the SO₂ authorized account representative of an SO₂ budget source or SO₂ budget unit from compliance with any other provisions of applicable State and federal law and regulation.

Condition 76: Submissions to the Department
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-2.1

Item 76.1:

Each submission under the Acid Deposition Reduction (ADR) SO₂ Budget Trading Program shall be submitted, signed, and certified by the SO₂ authorized account representative for each SO₂ budget source on behalf of which the submission is made. Each such submission shall include the following certification statement by the SO₂ authorized account representative:

"I am authorized to make this submission on behalf of the owners and operators of the SO₂ budget sources or SO₂ budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."



Condition 77: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-4.1

Item 77.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 77.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

For each control period in which one or more SO₂ budget units at a source are subject to the SO₂ budget emissions limitation, the SO₂ authorized account representative of the source shall submit to the Department by the March 1 following the relevant control period, a compliance certification report for each source covering all such units; as per NYCRR 238-4.

The SO₂ authorized account representative shall include in the compliance certification the following elements, in a format prescribed by the department, concerning each unit at the source and subject to the SO₂ budget emissions limitation for the control period covered by the report:

- (1) identification of each SO₂ budget unit;
- (2) except in instances when the SO₂ budget unit seeks to use future control period SO₂ allowances which may be deducted pursuant to NYCRR 238-6.5(f), at the SO₂ authorized account representative's option, the serial numbers of the SO₂ allowances that are to be deducted from each unit's compliance account under NYCRR 238-6.5 for the control period;
- (3) at the SO₂ authorized account representative's option, for units sharing a common stack and having SO₂ emissions that are not monitored separately or apportioned in accordance with NYCRR 238-8, the percentage of SO₂ allowances that is to be deducted from each unit's compliance account under NYCRR 238-6.5(e);
- (4) for units using future control period allowances for compliance purposes pursuant to NYCRR 238-6.5(f), the statement of intent and report required under NYCRR 238-6.5(f)(2); and
- (5) the compliance certification under NYCRR



238-4.1(c).

In the compliance certification report, the SO₂ authorized account representative shall certify, based on reasonable inquiry of those persons with primary responsibility for operating the source and the SO₂ budget units at the source in compliance with the ADR SO₂ Budget Trading Program, whether each SO₂ budget unit for which the compliance certification is submitted was operated during the calendar year covered by the report in compliance with the requirements of the ADR SO₂ Budget Trading Program applicable to the unit, including:

(a) whether the unit was operated in compliance with the SO₂ budget emissions limitation;

(b) whether the monitoring plan that governs the unit has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute SO₂ emissions to the unit, in accordance with Subpart 238-8;

(c) whether all the SO₂ emissions from the unit, or a group of units (including the unit) using a common stack, were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with Subpart 238-8. If conditional data were reported, the owner or operator shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;

(d) whether the facts that form the basis for certification under Subpart 238-8 of each monitor at the unit or a group of units (including the unit) using a common stack, or for using an excepted monitoring method or alternative monitoring method approved under Subpart 238-8, if any, has changed; and

(e) if a change is required to be reported under (4) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor recertification.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Reporting Requirements: ANNUALLY (CALENDAR)
Reports due by March 1st

Condition 78: Submission of SO2 allowance transfers
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-7.1

Item 78.1:

The SO2 authorized account representatives seeking recordation of an SO2 allowance transfer shall submit the transfer to the department or its agent. To be considered correctly submitted, the SO2 allowance transfer shall include the following elements in a format specified by the department or its agent:

- (a) the numbers identifying both the transferor and transferee accounts;
- (b) a specification by serial number of each SO2 allowance to be transferred; and
- (c) the printed name and signature of the SO2 authorized account representative of the transferor account and the date signed.

Condition 79: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 238-8

Item 79.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 79.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators, and to the extent applicable, the SO2 authorized account representative of an SO2 budget unit, shall comply with the monitoring and reporting requirements as provided for in all applicable sections of 40 CFR part 75. For purposes of complying with such requirements, the definitions in NYCRR 238-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," and "designated representative" in 40 CFR part 75 shall be replaced by the terms "SO2 budget unit," and "SO2 authorized account representative," respectively, as defined in NYCRR 238-1.2.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.



The initial report is due 7/30/2011.
Subsequent reports are due every 12 calendar month(s).

Condition 80: CO2 Budget Trading Program - Excess emission requirements
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 242-1.5

Item 80.1:

The owners and operators of a CO2 budget source that has excess emissions in any control period shall:

- (1) forfeit the CO2 allowances required for deduction under 6 NYCRR Part 242-6.5(d)(1), provided CO2 offset allowances may not be used to cover any part of such excess emissions; and
- (2) pay any fine, penalty, or assessment or comply with any other remedy imposed under 6 NYCRR Part 242-6.5(d)(2).

Condition 81: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 242-1.5

Item 81.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 81.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators and, to the extent applicable, the CO2 authorized account representative of each CO2 budget source and each CO2 budget unit at the source shall comply with the monitoring requirements of Subpart 242-8. The emissions measurements recorded and reported in accordance with Subpart 242-8 of this Part shall be used to determine compliance by the unit with the following CO2 requirements:

- (1) The owners and operators of each CO2 budget source and each CO2 budget unit at the source shall hold CO2 allowances available for compliance deductions under Section 242-6.5, as of the CO2 allowance transfer deadline, in the source's compliance account in an amount not less than the total CO2 emissions for the control period from all CO2 budget units at the source, as determined in accordance with Subparts 242-6 and 242-8.
- (2) Each ton of CO2 emitted in excess of the CO2 budget emissions limitation shall constitute a separate violation of this Part and applicable state law.

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



(3) A CO2 budget unit shall be subject to the requirements specified in item 1 starting on the later, of January 1, 2009 or the date on which the unit commences operation.

(4) CO2 allowances shall be held in, deducted from, or transferred among CO2 Allowance Tracking System accounts in accordance with Subparts 242-5, 242-6, and 242-7, and Section 242-10.7.

(5) A CO2 allowance shall not be deducted, in order to comply with the requirements specified in item 1, for a control period that ends prior to the allocation year for which the CO2 allowance was allocated. A CO2 offset allowance shall not be deducted, in order to comply with the requirements under item 1, beyond the applicable percent limitations set out in 6NYCRR Part 242-6.5(a)(3).

(6) A CO2 allowance under the CO2 Budget Trading Program is a limited authorization by the Department or a participating state to emit one ton of CO2 in accordance with the CO2 Budget Trading Program. No provision of the CO2 Budget Trading Program, the CO2 budget permit application, or the CO2 budget permit or any provision of law shall be construed to limit the authority of the Department or a participating state to terminate or limit such authorization.

(7) A CO2 allowance under the CO2 Budget Trading Program does not constitute a property right.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2011.

Subsequent reports are due every 6 calendar month(s).

Condition 82: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 242-1.5

Item 82.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 82.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:



The owners and operators of the CO2 budget source and each CO2 budget unit at the source shall keep on site at the source each of the following documents for a period of 10 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 10 years, in writing by the department.

(i) The account certificate of representation for the CO2 authorized account representative for the source and each CO2 budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 6 NYCRR Part 242-2.4, provided that the certificate and documents shall be retained on site at the source beyond such 10-year period until such documents are superseded because of the submission of a new account certificate of representation.

(ii) All emissions monitoring information, in accordance with Subpart 242-8 and 40 CFR 75.57.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CO2 Budget Trading Program.

(iv) Copies of all documents used to complete a CO2 budget permit application and any other submission under the CO2 Budget Trading Program or to demonstrate compliance with the requirements of the CO2 Budget Trading Program.

The CO2 authorized account representative of a CO2 budget source and each CO2 budget unit at the source shall submit the reports and compliance certifications required under the CO2 Budget Trading Program, including those under Subpart 242-4.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2011.

Subsequent reports are due every 6 calendar month(s).

Condition 83: Permit Requirements to be included in new permits or units. Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR 238-1.6 (a)

Item 83.1:

(this space used for Emission Unit)

Item 83.2:

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



The SO2 authorized account representative of each SO2 budget unit shall:

(i) submit to the department a complete SO2 budget permit application under section 238-3.3 in accordance with the deadlines specified in NYCRR 238-3.2; which states the later of October 1, 2004 or 12 months before the date on which the SO2 budget unit commences operation;

(ii) submit in a timely manner any supplemental information that the department determines is necessary in order to review an SO2 budget permit application and issue or deny an SO2 budget permit.

The owners and operators of each SO2 budget unit shall have an SO2 budget permit and operate the unit in compliance with such SO2 budget permit.

****** Emission Unit Level ******

Condition 84: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 84.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Item 84.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of this facility shall not operate the combustion turbines below 60 percent load (28.2 MW per turbine), except during periods of startup or shutdown.

The owner or operator shall monitor and record the megawatt output of each combustion turbine continuously.

All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

Condition 85: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 85.1:

The Compliance Demonstration activity will be performed for:

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Emission Unit: 1-00001

Item 85.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A shutdown shall be defined as the period of time when the stop signal is initiated to when fuel is no longer being combusted in the engine or a subsequent start is initiated, not to exceed 20 minutes per occurrence. The owner or operator shall record each period of shutdown and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Parameter Monitored: DURATION OF SHUTDOWN

Upper Permit Limit: 20 minutes

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER
OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

Condition 86: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 86.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 86.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for carbon monoxide. This limit shall apply during periods of

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



start-up or shutdown. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Manufacturer Name/Model Number: CO Analyzer
Parameter Monitored: CARBON MONOXIDE
Upper Permit Limit: 8.0 pounds
Reference Test Method: 40 CFR 60 Appendix F
Monitoring Frequency: CONTINUOUS
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2011.
Subsequent reports are due every 3 calendar month(s).

Condition 87: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 87.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 87.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:

The two Heatec boilers are each limited to 30 ppm of NO_x emissions. The owner or operator shall conduct compliance testing once during the term of the permit. The owner or operator shall submit a test protocol for Department approval. Testing shall be scheduled no sooner than 30 days of test protocol approval. The test results shall be submitted to the Department within 60 days of test completion. Test results shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 30 parts per million by volume (dry, corrected to 3% oxygen)
Reference Test Method: 40 CFR 60 Appendix B & F
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT



Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 88: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 88.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 88.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for carbon monoxide. This limit shall apply at all times except during periods of start-up or shutdown. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Manufacturer Name/Model Number: CO Analyzer
Parameter Monitored: CARBON MONOXIDE
Upper Permit Limit: 0.013 pounds per million Btus
Reference Test Method: 40 CFR 60 Appendix F
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2011.
Subsequent reports are due every 3 calendar month(s).

Condition 89: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 89.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 89.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The back-up engine shall meet a limit of 10.23 pounds per hour of NOx emissions. The owner or operator shall conduct compliance testing once during the term of the permit. The owner or operator shall submit a test protocol for Department approval. Testing shall be scheduled no sooner than 30 days of test protocol approval. The test results shall be submitted to the Department within 60 days of test completion. Test results shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 10.23 pounds per hour

Reference Test Method: 40 CFR 60 Appendix B & F

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 90: Compliance Demonstration

Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement: 6 NYCRR Subpart 201-5

Item 90.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Item 90.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

The diesel fire pump and back-up engines shall each be limited to 500 hours per year of operation. These engines shall install non resettable hour meters to record their hours of operation. The records for number of hours per year fired shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Work Practice Type: HOURS PER YEAR OPERATION

Upper Permit Limit: 500 hours

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2011.
Subsequent reports are due every 6 calendar month(s).

Condition 91: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 91.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 91.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous emissions monitor for ammonia slip, in accordance with the manufacturer's specifications. This limit shall apply during periods of start-up or shutdown. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Manufacturer Name/Model Number: Ammonia Analyzer

Parameter Monitored: AMMONIA

Upper Permit Limit: 7.4 pounds

Reference Test Method: 40 CFR 60 Appendix A Conditional Method 203

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

Condition 92: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 92.1:

The Compliance Demonstration activity will be performed for:



Emission Unit: 1-00001

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 92.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous emissions monitor for ammonia slip, in accordance with the manufacturer's specifications. This limit shall apply at all times except during periods of start-up or shutdown. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Manufacturer Name/Model Number: Ammonia Analyzer

Parameter Monitored: AMMONIA

Upper Permit Limit: 10.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 60 Appendix A Conditional Method 203

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

Condition 93: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 93.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 93.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain, and



operate a continuous 40 CFR Part 75 emissions monitor for measuring and recording oxides of nitrogen. The facility shall also install either a continuous monitor for oxygen or carbon dioxide. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

The 2.5 ppmvd limit shall be applicable during periods of steady state operation where the facility operates 16 or more minutes consecutively in one clock hour. When a facility operates in steady state less than 16 minutes (consecutively in one clock hour, and excluding startup or shutdown) the 2.5 ppmvd limit does not apply, but a mass emission limit of 2.5 pounds applies. Emissions in excess of either the 2.5 ppmvd limit or the 2.5 pound limit shall be reported quarterly through the facility's excess emissions report.

Manufacturer Name/Model Number: NOx Analyzer
Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 2.5 parts per million by volume
(dry, corrected to 15% O₂)
Reference Test Method: 40 CFR 75
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2011.
Subsequent reports are due every 3 calendar month(s).

Condition 94: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement: 6 NYCRR Subpart 201-5

Item 94.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 94.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain, and operate a continuous emissions monitor for oxides of nitrogen. The 5.0 pounds per hour limit shall apply during steady state operations where the turbine operates

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



for the full 60 minutes of the hour. The following limits shall apply during steady state partial hours (less than the full 60 minutes) of operation:

Time Period (minutes) NOx Mass Limit (pounds)

1 - 15 2.5

16 - 30 3.0

31 - 45 3.75

46 - 59 5.0

Emissions in excess of the steady state limits for full 60 minute hours and steady state partial hours shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer
Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 5.0 pounds per hour
Reference Test Method: 40 CFR 75
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2011.
Subsequent reports are due every 3 calendar month(s).

Condition 95: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 95.1:
The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Item 95.2:
Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:
Start-up shall be defined as the 30 minute period of time from the point that the gas turbine begins firing fuel.

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



The owner or operator shall record the date and time of each period of start-up. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Parameter Monitored: DURATION OF START UP

Upper Permit Limit: 30 minutes

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

Condition 96: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 96.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 96.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall apply only during periods of start-up (30 minutes per occurrence). Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 15 pounds

Reference Test Method: None

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

New York State Department of Environmental Conservation

Permit ID: 2-6007-00724/00003

Facility DEC ID: 2600700724



Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

Condition 97: Compliance Demonstration
Effective between the dates of 02/15/2011 and 02/14/2016

Applicable State Requirement:6 NYCRR Subpart 201-5

Item 97.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 97.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall apply only during periods of shutdown, not to exceed 20 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their Poletti facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 5.0 pounds

Reference Test Method: None

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2011.

Subsequent reports are due every 3 calendar month(s).

