

New York State Department of Environmental Conservation
Facility DEC ID: 2610200116



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 2-6102-00116/00021
Mod 0 Effective Date: 07/31/2002 Expiration Date: 07/30/2007
Mod 1 Effective Date: 10/07/2002 Expiration Date: 07/30/2007

Permit Issued To: ASTORIA GENERATING COMPANY LP
18-01 20TH AVE
LONG ISLAND CITY, NY 11105-4271

Contact: ANDREW W OLIVER
ASTORIA GENERATING COMPANY LP
3650 JAMES ST STE 206
SYRACUSE, NY 13206
(315) 433-1371

Facility: GOWANUS GENERATING STATION
27TH ST & THIRD AVE
BROOKLYN, NY 11232

Contact: JAMES N GREGORY, JR
ASTORIA GEN CO
PO BOX 658
BROOKLYN, NY 11232-0658
(718) 832-3926

Description:
THE MOD 1 WAS DONE TO REFLECT LATEST EMISSION FACTORS, BASED ON JULY-
AUGUST 2001 STACK TEST.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN
DIVISION OF ENVIRONMENTAL PERMITS
ONE HUNTERS POINT PLAZA, 47-40 21ST STREET
LONG ISLAND CITY, NY 11101-5407

Authorized Signature: _____ Date: ___ / ___ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Applications for Permit Renewals and Modifications

Permit Modifications, Suspensions and Revocations by the Department

Facility Level

Submission of Applications for Permit Modification or Renewal-REGION 2

HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301.2(m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for Permit Renewals and Modifications
Applicable State Requirement: 6NYCRR 621.13

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

New York State Department of Environmental Conservation
Facility DEC ID: 2610200116



Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Permit Modifications, Suspensions and Revocations by the Department
Applicable State Requirement: 6NYCRR 621.14

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of Applications for Permit Modification or Renewal-REGION 2 HEADQUARTERS
Applicable State Requirement: 6NYCRR 621.5(a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: ASTORIA GENERATING COMPANY LP
18-01 20TH AVE
LONG ISLAND CITY, NY 11105-4271

Facility: GOWANUS GENERATING STATION
27TH ST & THIRD AVE
BROOKLYN, NY 11232

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Mod 0 Permit Effective Date: 07/31/2002

Permit Expiration Date: 07/30/2007

Mod 1 Permit Effective Date: 10/07/2002

Permit Expiration Date: 07/30/2007



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6NYCRR 201-6: Emission Unit Definition
- 2 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 3 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 4 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 5 6NYCRR 201-6.5(e): Compliance Certification
- 6 6NYCRR 202-2.1: Compliance Certification
- 7 6NYCRR 202-2.5: Recordkeeping requirements
- 8 6NYCRR 204-2.1: Submissions to the Department.
- 9 6NYCRR 204-4.1: Contents of reports and compliance certifications.
- 10 6NYCRR 204-4.1: Discretionary report contents.
- 11 6NYCRR 204-4.1: Compliance Certification
- 12 6NYCRR 204-7.1: Submission of NO_x allowance transfers.
- 13 6NYCRR 204-8.1: General provisions.
- 14 6NYCRR 204-8.1: Prohibitions.
- 15 6NYCRR 204-8.1: Requirements for installation, certification, and data accounting.
- 16 6NYCRR 204-8.2: Requirements for recertification of monitoring systems.
- 17 6NYCRR 204-8.2: Compliance Certification
- 18 6NYCRR 204-8.3: Out of control periods.
- 19 6NYCRR 204-8.4: Compliance Certification
- 20 6NYCRR 204-8.7: Compliance Certification
- 21 6NYCRR 207: Submittal of Episode Action Plans
- 22 6NYCRR 225-1.8(d): Sampling, compositing, and analysis of fuel samples
- 23 6NYCRR 225.1(a)(3): Compliance Certification
- 24 6NYCRR 227-1.3(a): Compliance Certification
- 25 6NYCRR 227-2.1: This condition states the facility is applicable to NO_x RACT.
- 26 6NYCRR 227-2.3(g): Contents of operating plans.
- 27 6NYCRR 227-2.5(b): Compliance Certification
- 28 6NYCRR 227-2.6: Compliance Certification
- 29 6NYCRR 227-2.6: Compliance Certification
- 30 6NYCRR 227-3.12: Authorized Account Representatives (AARs)
- 31 6NYCRR 227-3.13: Compliance Certification
- 32 6NYCRR 227-3.15: Compliance Certification
- 33 6NYCRR 227-3.16: Compliance Certification
- 34 6NYCRR 227-3.17: Compliance Certification
- 1-1 40CFR 68: Accidental release provisions.
- 36 40CFR 82, Subpart F: Recycling and Emissions Reduction

Emission Unit Level

- 37 6NYCRR 201-6: Emission Point Definition By Emission Unit



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

- 38 6NYCRR 201-6: Process Definition By Emission Unit
- 39 6NYCRR 231-2: Process Permissible Emissions
- 40 40CFR 52.21, Subpart A: Process Permissible Emissions

EU=G-W0005

- 41 6NYCRR 225-1.7: Compliance Certification
- 42 6NYCRR 227.2(b)(1): Compliance Certification

EU=G-W0006

- 43 6NYCRR 225-1.7: Compliance Certification
- 44 6NYCRR 227.2(b)(1): Compliance Certification
- *1-2 6NYCRR 231-2: Compliance Certification
- *1-3 6NYCRR 231-2: Compliance Certification
- *1-4 6NYCRR 231-2: Compliance Certification
- *1-5 40CFR 52.21, Subpart A: Compliance Certification
- *1-6 40CFR 52.21, Subpart A: Compliance Certification
- *1-7 40CFR 52.21, Subpart A: Compliance Certification
- *1-8 40CFR 52.21, Subpart A: Compliance Certification
- *48 40CFR 52.21, Subpart A: Compliance Certification
- *49 40CFR 52.21, Subpart A: Compliance Certification
- *50 40CFR 52.21, Subpart A: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 55 ECL 19-0301: Contaminant List
- 56 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 57 6NYCRR 211.2: Air pollution prohibited

NOTE: * preceding the condition number indicates capping.



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Sealing - 6NYCRR Part 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6NYCRR Part 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6NYCRR Part 200.7

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6NYCRR Part 201-1.2

If an existing emission source was subject to the permitting requirements of 6NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

Item E: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item F: Recycling and Salvage - 6NYCRR Part 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item G: Prohibition of Reintroduction of Collected Contaminants to the Air - 6NYCRR Part 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item H: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item I: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR Part 201-3.2(a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item J: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR Part 201-3.3(a)

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item K: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item L: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item M: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



renewal application.

Item N: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item O: Providing Information Upon Request - 6 NYCRR Part 201-6.5(a)(4)

The permittee shall furnish to the Department, within a reasonable time, any information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The permittee shall also, on request, furnish the Department with copies of records required to be kept by the permit. Where information is claimed to be confidential, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

Item P: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item Q: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item R: Fees - 6 NYCRR Part 201-6.5(a)(7)

The owner and/or operator of a stationary source shall pay fees to the department consistent with the fee schedule authorized by 6 NYCRR Subpart 482-2.

Item S: Right to Inspect - 6 NYCRR Part 201-6.5(a)(8)

Upon presentation of credentials and other documents, as

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



may be required by law, the permittee shall allow the Department or an authorized representative to perform the following:

- i. Enter upon the permittee's premises where the permitted facility is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- iii. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
- iv. As authorized by the Act, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Item T: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item U: Progress Reports and Compliance Schedules - 6 NYCRR Part 201-6.5(d)(5)

Progress reports consistent with an applicable schedule of compliance must be submitted at least semiannually on a calendar year basis, or at a more frequent period if specified in the applicable requirement or by the Department elsewhere in this permit. These reports shall be submitted to the Department within 30 days after the end of a reporting period. Such progress reports shall contain the following:

- i. Dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- ii. An explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive



or corrective measures adopted.

Item V: Off Permit Changes - 6 NYCRR Part 201-6.5(f)(6)

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the Administrator and the Department with written notification in advance of the proposed changes within a minimum of 7 days as required by 6 NYCRR §201-6.5(f)(6).

Item W: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

contributing to such pollution;

ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item X: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item Y: Required Emission Tests - 6 NYCRR Part 202-1.1

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6NYCRR Part 202-1.

Item Z: Visible Emissions Limited - 6 NYCRR Part 211.3

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Item AA: Open Fires - 6 NYCRR Part 215

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, rubbish for salvage, or rubbish generated by industrial or commercial activities.

Item BB: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item CC: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

**Condition 1: Emission Unit Definition
Effective between the dates of 07/31/2002 and 07/30/2007**

Applicable Federal Requirement: 6NYCRR 201-6

Item 1.1(From Mod 1):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: G-W0006

Emission Unit Description:

Sixteen combustion turbines each rated at 299 MMBTU/hr.
Each combustion turbine has the capability to burn natural gas and distillate oil and has a diesel starter engine.

Building(s): PIER 1

Item 1.2(From Mod 0):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: G-W0005

Emission Unit Description:

Sixteen combustion turbines each rated at 299 MMBTU/hr.
Each combustion turbine has the capability to burn distillate oil and has a diesel starter engine.

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Building(s): PIER 1

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT
TO ANNUAL CERTIFICATIONS AT ALL TIMES**

**The following federally enforceable permit conditions are mandatory for all Title V permits
and are subject to annual compliance certification requirements at all times.**

**Condition 2: Recordkeeping and reporting of compliance monitoring
Effective between the dates of 07/31/2002 and 07/30/2007**

Applicable Federal Requirement: 6NYCRR 201-6.5(c)

Item 2.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

**Condition 3: Monitoring, Related Recordkeeping, and Reporting
Requirements.
Effective between the dates of 07/31/2002 and 07/30/2007**

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)

Item 3.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 4: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)

Item 4.1:

The Compliance Certification activity will be performed for the Facility.

Item 4.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant or a toxic air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section,

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If any of the above conditions are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) through (4) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraph (1) through (4) of this section must also be identified in the 6 month monitoring report required above.

If the permittee seeks to have a violation excused as provided in 201-1.4, the permittee shall report such violations as required under 201-1.4(b). However, in no case may reports of any deviation be on a less frequent basis than those described in paragraphs (1) through (4) above. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2002.
Subsequent reports are due every 6 calendar month(s).

Condition 5: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 201-6.5(e)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



permit that is the basis of the certification;

- the compliance status;
- whether compliance was continuous or intermittent;
- the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
- such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;

and

- such additional requirements as may be specified elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



The address for the RAPCE is as follows:

Hunters Point Plaza
47-40 21st Street
Long Island City, NY 11101-5407

The address for the BCME is as follows:

NYSDEC
Bureau of Compliance Monitoring
and Enforcement
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2003.
Subsequent reports are due on the same day each year

Condition 6: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 202-2.1

Item 6.1:
The Compliance Certification activity will be performed for the Facility.

Item 6.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

Emission statements shall be submitted on or before April
15th each year for emissions of the previous calendar
year.

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due by April 15th for previous calendar year

Condition 7: Recordkeeping requirements
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 202-2.5

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Item 7.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 8: Submissions to the Department.
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-2.1

Item 8.1: Each submission under the NOx Budget Trading Program shall be submitted, signed and certified by the NOx authorized account representative for each NOx Budget source on behalf of which the submission is made. Each submission shall include a certification statement (as stated in paragraph 204-2.1(e)(1)) by the NOx authorized account representative.

Condition 9: Contents of reports and compliance certifications.
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-4.1

Item 9.1: The NOx authorized account representative shall include in the compliance certification report the following elements, in a format prescribed by the Administrator, concerning each unit at the source and subject to the NOx Budget emissions limitation for the control period covered by the report:

- (1) Identification of each NOx Budget unit; and
- (2) In the compliance certification report the NOx authorized account representative shall certify, based on reasonable inquiry of those persons with primary responsibility for operating the source and the NOx Budget units at the source in compliance with the NOx Budget Trading Program, whether each NOx Budget unit for which the compliance certification is submitted was operated during the calendar year covered by the report in compliance with the requirements of the NOx Budget Trading Program applicable to the unit, including:
 - (i) Whether the unit was operated in compliance with the NOx Budget emissions limitation;



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

(ii) Whether the monitoring plan that governs the unit has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute NOx emissions to the unit, in accordance with Subpart 204-8;

(iii) Whether all the NOx emissions from the unit, or a group of units (including the unit) using a common stack, were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with Subpart 204-8. If conditional data were reported, the owner or operator shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions has been made;

(iv) Whether the facts that form the basis for certification under Subpart 204-8 of each monitor at the unit or a group of units (including the unit) using a common stack, or for using an excepted monitoring method or alternative monitoring method approved under Subpart 204-8, if any, has changed; and

(v) If a change is required to be reported under item (iv) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor recertification.

Condition 10: Discretionary report contents.

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-4.1

Item 10.1: At the NOx authorized account representative's option the following may be included in the compliance certification report:

(1) The serial numbers of the NOx allowances that are to be deducted from each unit's compliance account under Section 204-6.5 for the control period; and

(2) For units sharing a common stack and having NOx emissions that are not monitored separately or apportioned in accordance with Subpart 204-8, the percentage of NOx allowances that is to be deducted from each unit's compliance account under Subdivision 204-6.5(e).

Condition 11: Compliance Certification

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-4.1

Item 11.1:

The Compliance Certification activity will be performed for the Facility.

Item 11.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

For each control period in which one or more NOx Budget units at a source are subject to the NOx Budget emissions limitation, the NOx authorized account representative of



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

the source shall submit to the Department and the Administrator by November 30 of that year, a compliance certification report for each source covering all such units.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 12: Submission of NOx allowance transfers.
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-7.1

Item 12.1: The NOx authorized account representatives seeking recordation of a NOx allowance transfer shall submit the transfer to the Administrator. To be considered correctly submitted, the NOx allowance transfer shall include the following elements in a format specified by the Administrator:

- (a) The numbers identifying both the transferor and transferee accounts;
- (b) A specification by serial number of each NOx allowance to be transferred; and
- (c) The printed name and signature of the NOx authorized account representative of the transferor account and the date signed.

Condition 13: General provisions.
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.1

Item 13.1: The owners and operators, and to the extent applicable, the NOx authorized account representative of a NOx Budget unit, shall comply with the monitoring and reporting requirements as provided in this Subpart and in Subpart H of 40 CFR Part 75. For purposes of complying with such requirements, the definitions in Section 204-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be replaced by the terms "NOx Budget unit," "NOx authorized account representative," and "continuous emission monitoring system" (or "CEMS"), respectively, as defined in Section 204-1.2.

Condition 14: Prohibitions.
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.1

Item 14.1: No owner or operator of a NOx Budget unit or a non-NOx Budget unit monitored under 40 CFR 75.72(b)(2)(ii) shall:

- (1) use any alternative monitoring system, alternative reference method, or any other alternative for the required continuous emission monitoring system without having obtained prior written approval in accordance with Section 204-8.6;
- (2) operate the unit so as to discharge, or allow to be discharged, NOx emissions to the atmosphere without accounting for all such emissions in accordance with the applicable provisions of this Subpart



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

and 40 CFR Part 75 except as provided for in 40 CFR 75.74;

(3) disrupt the continuous emission monitoring system, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NO_x mass emissions discharged into the atmosphere, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the applicable provisions of this Subpart and 40 CFR Part 75 except as provided for in 40 CFR 75.74; and

(4) permanently discontinue use of the continuous emission monitoring system, any component thereof, or any other approved emission monitoring system under this Subpart, except under any one of the following circumstances:

(i) The owner or operator is monitoring emissions from the unit with another certified monitoring system approved, in accordance with the applicable provisions of this Subpart and 40 CFR Part 75, by the Department for use at that unit that provides emission data for the same pollutant or parameter as the discontinued monitoring system; or

(ii) The NO_x authorized account representative submits notification of the date of certification testing of a replacement monitoring system in accordance with Paragraph 204-8.2(b)(2).

Condition 15: Requirements for installation, certification, and data accounting.

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.1

Item 15.1: The owner or operator of each NO_x Budget unit must meet the following requirements. These provisions also apply to a unit for which an application for a NO_x Budget opt-in permit is submitted and not denied or withdrawn, as provided in Subpart 204-9:

(1) Install all monitoring systems required under this Subpart for monitoring NO_x mass. This includes all systems required to monitor NO_x emission rate, NO_x concentration, heat input, and air or fuel flow, in accordance with 40 CFR 75.71 and 75.72.

(2) Install all monitoring systems for monitoring heat input, if required under Section 204-8.7 for developing NO_x allowance allocations.

(3) Successfully complete all certification tests required under Section 204-8.2 and meet all other provisions of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraphs (a)(1) and (2) of this section.

(4) Record and report data from the monitoring systems under paragraphs (a)(1) and (2) of this section.

Condition 16: Requirements for recertification of monitoring systems.

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.2

Item 16.1: Whenever the owner or operator makes a replacement, modification, or change in a certified monitoring system that the Administrator or the Department determines significantly affects the ability of the system to accurately measure or record NO_x mass emissions or heat input or to meet the requirements of 40 CFR 75.21 or Appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system according to 40 CFR 75.20(b). Furthermore, whenever the owner or operator



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

makes a replacement, modification, or change to the flue gas handling system or the unit's operation that the Administrator or the Department determines to significantly change the flow or concentration profile, the owner or operator shall recertify the continuous emissions monitoring system according to 40 CFR 75.20(b). Examples of changes which require recertification include: replacement of the analyzer, change in location or orientation of the sampling probe or site, or changing of flow rate monitor polynomial coefficients.

Condition 17: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.2

Item 17.1:

The Compliance Certification activity will be performed for the Facility.

Item 17.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of a NO_x Budget unit under paragraphs (b)(2) or (b)(3) of this section must determine, record and report NO_x mass, heat input (if required for purposes of allocations) and any other values required to determine NO_x Mass (e.g. NO_x emission rate and heat input or NO_x concentration and stack flow) using the provisions of 40 CFR 75.70(g), from the date and hour that the unit starts operating until all required certification tests are successfully completed.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 18: Out of control periods.
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.3

Item 18.1: Whenever any monitoring system fails to meet the quality assurance requirements of Appendix B of 40 CFR Part 75, data shall be substituted using the applicable procedures in Subpart D, Appendix D, or Appendix E of 40 CFR Part 75.

Condition 19: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.4

Item 19.1:

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



The Compliance Certification activity will be performed for the Facility.

Item 19.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The Authorized Account Representative for a NO_x Budget unit shall submit written notice to the Department and the USEPA Administrator in accordance with the requirements of this subpart as follows:

All monitoring plans or monitoring plan modifications; compliance certifications, recertifications and quarterly QA/QC reports; and, petitions for alternative monitoring, shall be submitted to the USEPA Administrator (or his/her representatives) as well as two copies to the Department (one copy to the Regional Air Pollution Control Engineer (RAPCES) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office. All Authorized Account Representative changes shall be sent to the NYSDEC central office.

All quarterly emission data shall be electronically filed with the USEPA Clean Air Markets Division with a copy (disc or hard copy) to the NYSDEC offices.

The address for the USEPA Administrator is as follows:

USEPA Clean Air Markets Division
401 M Street SW (6204J)
Washington D.C. 20460

CEM Coordinator
USEPA-Region 2
2890 Woodbridge Avenue
Edison, N.J. 08837

The address for the BCME is as follows:

NYSDEC
Bureau of Compliance Monitoring and Enforcement
625 Broadway, 2nd Floor
Albany N.Y. 12233-3258

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



AAR changes should be sent to the attention of:

NYSDEC
Stationary Source Planning Section
Bureau of Air Quality Planning
625 Broadway, 2nd Floor
Albany NY 12233-3251

The address for the RAPCE is as follows:

Hunters Point Plaza
47-20 21st Street
Long Island City, NY 11101-5407

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 20: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 204-8.7

Item 20.1:
The Compliance Certification activity will be performed for the Facility.

Item 20.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of a unit that elects to monitor and report NO_x Mass emissions using a NO_x concentration system and a flow system shall also monitor and report heat input at the unit level using the procedures set forth in 40 CFR Part 75.

Monitoring Frequency: HOURLY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2002.

Subsequent reports are due every 3 calendar month(s).

Condition 21: Submittal of Episode Action Plans
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 207



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Item 21.1:

An episode action plan must be submitted for approval by the Department in accordance with the requirements of 6NYCRR Part 207. The plan shall contain detailed steps which will be taken by the facility to reduce air contaminant emissions during each stage of an air pollution episode. Once approved, the facility shall take whatever actions are prescribed by the episode action plan when an air pollution episode is in effect.

Condition 22: Sampling, compositing, and analysis of fuel samples
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 225-1.8(d)

Item 22.1:

All sampling, compositing, and analysis of fuel samples, taken to determine compliance with 6 NYCRR Part 225-1, must be done in accordance with methods acceptable to the commissioner.

Condition 23: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 225.1(a)(3)

Item 23.1:

The Compliance Certification activity will be performed for the Facility.

Item 23.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

No person shall sell, offer for sale, purchase or use any distillate oil which has sulfur content greater than 0.20 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site for a minimum of five years after the date of the last entry.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.20 percent by weight

Monitoring Frequency: PER DELIVERY

Reporting Requirements: MONTHLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 8/30/2002.

Subsequent reports are due every 1 calendar month(s).

Condition 24: Compliance Certification



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-1.3(a)

Item 24.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 24.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity (on a six minute block period) except for one six minute block period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition
- was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

- 3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then the Method 9 analysis (based upon a 6-minute mean) of the



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY

Upper Permit Limit: 27 percent

Reference Test Method: method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2002.

Subsequent reports are due every 3 calendar month(s).

Condition 25: This condition states the facility is applicable to NOx RACT.

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-2.1

Item 25.1:

This facility is subject to NOx RACT.

Condition 26: Contents of operating plans.

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-2.3(g)

Item 26.1:



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Operating Plan: any owner or operator of a facility subject to this section must submit to the department, with the application(s) for certificate(s) to operate submitted according to subdivision (d) of this section, an operating plan, including an operating manual, acceptable to the department. This should at a minimum include:

- (1) A summary of the applicable standards and requirements of this Subpart and how this facility will comply, including any system averaging and any higher specific unit emission rates that may apply;
- (2) A description of the combustion process, including the procedures for the control of NO_x emissions;
- (3) Procedures for monitoring unit operating parameters;
- (4) Procedures for ash handling;
- (5) Procedures for monitoring emissions;
- (6) Reporting and recordkeeping procedures; and,
- (7) The name and title of operating personnel and, if applicable, their qualifications (e.g., licenses, certificates, education, training courses completed).

Condition 27: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-2.5(b)

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 27.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Astoria Generating Company's system-wide averaging of NO_x emissions from its Astoria, Gowanus, and Narrows Generating Stations must be performed in accordance with the most current version of the NO_x RACT Compliance and Operating Plan approved by the Department.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

The initial report is due 10/30/2002.

Subsequent reports are due every 3 calendar month(s).

Condition 28: Compliance Certification

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-2.6

Item 28.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 28.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

In lieu of performing a stack test on the Starter Engines associated with the Combustion Turbines, a log must be kept which lists the dates of operation of the Starter Engines and the duration of each occurrence. The log must be maintained at the facility and submitted, semiannually to the Department, at the following address:

Hunters Point Plaza
47-40 21st Street
Long Island City, NY, 11101-5407
Att: Regional Air Pollution Control

Engineer

The information on the Starter Engines, provided to the applicant by the engine manufacturer, is attached to this permit and constitutes an enforceable part of the permit.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2002.

Subsequent reports are due every 6 calendar month(s).

Condition 29: Compliance Certification

Effective between the dates of 07/31/2002 and 07/30/2007



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Applicable Federal Requirement: 6NYCRR 227-2.6

Item 29.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 29.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Stack testing shall be performed to verify compliance of NOx emissions from the Combustion Turbines with the most current version of the system-wide averaging plan (NOx RACT Compliance and Operating Plan), submitted by Astoria Generating Company. All stack testing shall be done in accordance with 6NYCRR 227-2.6(c).

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 30: Authorized Account Representatives (AARs)
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-3.12

Item 30.1: Each budget source must designate an AAR, and may designate an alternate AAR, for each compliance account and compliance overdraft account.

Condition 31: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-3.13

Item 31.1:

The Compliance Certification activity will be performed for the Facility.

Item 31.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner and/or operator of a budget source which is not subject to 40 CFR Part 75 shall meet the monitoring requirements of this Subpart by:

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



(1) Submitting to the Department and the Administrator a monitoring plan as specified in paragraph 227-3.13(a)(2) which must include the following information, as appropriate:

(i) A description of the monitoring approach to be used;

(ii) A description of the major components of the monitoring system including the manufacturer, serial numbers of the component, the measurement span(s) of the components and documentation to demonstrate that the measurement span of each component is appropriate to measure all of the expected values. This requirement applies to all monitoring systems including CEMS which have not been certified pursuant to 40 CFR Part 75;

(iii) An estimate of the accuracy of the system and documentation to demonstrate how the estimate of accuracy was determined;

(iv) A description of the tests that will be used for initial certification, initial quality assurance, periodic quality assurance, and relative accuracy;

(v) If the monitoring system uses a default emission rate or unit specific emission factor, the monitoring plan shall include the following:

(a) All information necessary to support the emission rate including historical monitoring data and historical fuel usage data. If the source plans to conduct emission testing to determine emission rate, the plan must include a test protocol explaining the testing to be conducted;

(b) Procedures which will be utilized to demonstrate that any control equipment in operation during the testing to develop source specific emission factors or during development of load-based emissions curves are in use when those factors or emission curves are applied to calculate NO_x emissions; and

(c) Alternative uncontrolled emission rates to be used to calculate NO_x emissions during periods when control equipment is not being used or is inoperable.

(vi) The following documentation regarding heat input determination, as appropriate:

(a) If the method for determining heat input involves

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



boiler efficiency testing, a description of the test to determine boiler efficiency;

(b) If the method for determining heat input uses fuel sampling, a description of the test to be used in the fuel sampling program; and

(c) If the method for determining heat input uses fuel flow meters, the meters shall be certified pursuant to 40 CFR Part 75 Appendix D, or equivalent certification methodology.

(vii) As described in the Guidance Document, schematics for the sources, data flow diagrams, and a list of the Electronic Report Record Types used to report quarterly data.

(2) Determining NO_x emission rate in lbs/mmBtu using one of the following methods:

(i) Implementing monitoring in accordance with 40 CFR Part 75;

(ii) If the budget source is required to have and operate a CEMS to meet the requirements of 40 CFR Part 60 or other state requirements or permits, the CEMS must be used to meet the requirements of this paragraph. 40 CFR Part 60 monitors used for this purpose shall meet quality assurance criteria as described in the Guidance Document. Any time that a 40 CFR Part 60 CEMS cannot be used to report data for this program because it does not meet the requirements of the Guidance Document, missing data shall be substituted using the procedures in 40 CFR Part 75 Subpart D. In addition, a CEMS that has not undergone initial certification testing to meet the requirements of 40 CFR Part 75 or 40 CFR Part 60 shall meet the initial certification requirements contained in the Guidance Document;

(iii) If the budget source is an oil or gas fired source with a maximum heat input capacity of less than 250 mmBtu/hr or an oil or gas fired peaking source of any size and does not have a CEMS, any of the following methodologies may be used to measure NO_x, consistent with the Guidance Document:

(a) For a boiler or a turbine, the procedures contained in 40 CFR Part 75 Appendix E;

(b) For a combustion turbine, a default emission factor as follows:

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



- (1) 0.7 lb/mmBtu if gas fired;
- (2) 1.2 lbs/mmBtu if oil fired; or
- (3) the source specific maximum potential NO_x emission rate determined through testing performed in accordance with a protocol approved by the Department.

(c) For a boiler, a default emission factor as follows:

- (1) 2 lbs/mmBtu if oil fired,
- (2) 1.5 lbs/mmBtu if gas fired; or
- (3) the source specific maximum potential NO_x emission rate determined through testing performed in accordance with a protocol approved by the Department.

(iv) any other method authorized in the Guidance Document and approved by the Department.

(3) Determining heat input rate using one of the following methods:

(i) If the budget source does not have a flue gas flow monitor, any of the following methods may be used upon Department approval:

(a) Use of a flow monitor and a diluent monitor meeting the requirements of 40 CFR Part 75 and the procedures set forth in 40 CFR Part 75 Appendix F Section 5;

(b) For a budget source that combusts only oil or natural gas, use of a fuel flow monitor meeting the requirements of 40 CFR Part 75 Appendix D and the procedures set forth in 40 CFR Part 75 Appendix F Section 5;

(c) For a budget source having a rated capacity with a rated output of less than 25 megawatts or that operates as a peaking unit only, that combusts only oil or natural gas, measuring fuel use over a representative period and calculating the heat input on an hourly basis by apportioning the fuel based on electrical load in accordance with the following formula:

$$\text{Hourly heat input} = (\text{Hourly electrical load} \times \text{Total heat input}) / \text{Total electrical load}$$

(d) For a budget source that combusts any fuel other than oil or natural gas, one of the following



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

alternative
methods:

- (1) Conducting fuel sampling and analysis and monitoring fuel usage;
- (2) Using boiler efficiency curves and other monitored information such as boiler steam output; and
- (3) Any other methods approved by the Department.

(ii) Alternative methods specified in the Guidance Document and approved by the Department, which may be subject to both initial and periodic relative accuracy, and quality assurance testing as accepted by the Department.

(4) Determining the NOx emissions in lbs/hr by multiplying the NOx emission rate and heat input rate figures together.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 32: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-3.15

Item 32.1:

The Compliance Certification activity will be performed for the Facility.

Item 32.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

This budget source must submit to the Administrator, in a format which meets the requirements of the Administrator's Electronic Data Reporting convention, information regarding emissions and operations during each calendar quarter of each year in accordance with the procedures specified in the Guidance Document.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Reports due 30 days after the reporting period.
The initial report is due 10/30/2002.
Subsequent reports are due every 3 calendar month(s).

Condition 33: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-3.16

Item 33.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 33.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

(a) Each year during the period extending from November 1 through the allowance transfer deadline, December 31, this budget source may request the Administrator to deduct a number of allowances from the budget source's compliance account equal to the current year control period NO_x emissions from the budget source. The request must include identification of the compliance account from which the deductions should be made. The request may include the serial numbers of the particular allowances to be deducted. If no serial numbers are included, the Administrator will first deduct allowances allocated for the current year control period. If the Administrator exhausts all allowances allocated for the current year control period, the Administrator will next deduct banked allowances in the compliance account in the order in which they were deposited. The request may only involve allowances placed in the budget source's compliance account; allowances in a compliance overdraft account or general account may not be deducted pursuant to the request.

(b) If, by November 1 of the current year, the total number of allowances in the budget source's compliance account and compliance overdraft account, including allowance transfer requests properly submitted to the Administrator, is less than the current year control period NO_x emissions from the budget source, the budget

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



source must obtain additional allowances by the allowance transfer deadline so that the total number of allowances in the compliance account and compliance overdraft account, including allowance transfer requests properly submitted to the Administrator by the allowance transfer deadline, at least equals the current year control period NOx emissions rounded to the nearest whole ton. The Administrator will not consider for compliance purposes allowances contained in any general account held by the owner and/or operator of the budget source.

(c) If, by the allowance transfer deadline, this budget source either makes no allowance deduction request or makes a request that is insufficient to meet the requirements of Subdivision 227-3.16(a), the Administrator will deduct a number of allowances from the budget source's compliance account and compliance overdraft account that equals the current year control period NOx emissions from the budget source. Under this Subdivision, the Administrator will deduct allowances in the following order:

- (1) Current year allowances from the compliance account in the order in which they were deposited.
- (2) Banked allowances in the compliance account in the order in which they were deposited.
- (3) Current year allowances from the compliance overdraft account in the order in which they were deposited.
- (4) Banked allowances from the compliance overdraft account in the order in which they were deposited.

(d) Any banked allowances deducted pursuant to this Section shall be deducted in accordance with the provisions of Section 227-3.9.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 34: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227-3.17

Item 34.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 34.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

- (a) By December 31 of each year, this budget source must submit a compliance certification to the Department relating to the budget source's activities during the current year.
- (b) The compliance certification shall contain, at a minimum:
 - (1) identification of the budget source, including address of the budget source, name and address of the owner and/or operator, account numbers of the relevant compliance account and compliance overdraft account and the name of the AAR;
 - (2) a statement indicating whether NO_x emissions data have been reported to the NETS in accordance with the procedures set forth in Section 227-3.15 and any additional procedures established by the Administrator;
 - (3) a statement indicating whether the budget source has a number of allowances in its compliance account or compliance overdraft account equal to or greater than the budget source's NO_x emissions for the current year control period;
 - (4) a statement indicating whether the monitoring data reflected the actual operation of the budget source;
 - (5) a statement indicating whether all NO_x emissions from the budget source were accounted for, either through the relevant monitoring or application of the appropriate missing data procedures; and
 - (6) a statement indicating whether there were any changes in the method of operation of the budget source or the method of monitoring the budget source during the current year.
- (c) The Department may verify compliance by whatever means necessary, including, but not limited to, the following:
 - (1) inspection of budget source operating records;
 - (2) examining information contained in the NATS (NO_x Allowance Tracking System) regarding allowance deductions and transfers for the budget source;



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

- (3) examining information contained in the NETS (NO_x Emission Tracking System) regarding NO_x emissions from the budget source;
- (4) testing emission monitoring devices; and,
- (5) testing conducted pursuant to 6 NYCRR Part 202.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period. [NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 1-1: Accidental release provisions.
Effective between the dates of 10/07/2002 and 07/30/2007**

Applicable Federal Requirement: 40CFR 68

Replaces Condition(s) 35

Item 1-1.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Table 1, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit (if not previously submitted) one of the following if such quantities are present at the time of permit issuance:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

USEPA Region 2
Air Compliance Branch
290 Broadway
New York, NY 10007-1866
ATTN: Accidental Release Program contact



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Condition 36: Recycling and Emissions Reduction
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 82, Subpart F

Item 36.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

****** Emission Unit Level ******

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 37: Emission Point Definition By Emission Unit
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 201-6

Item 37.1(From Mod 0):

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: G-W0005

Emission Point: 0GT11
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT12
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT13
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT14
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT15
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Emission Point: 0GT16 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT17 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT18 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT41 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT42 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT43 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT44 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT45 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT46 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT47 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1
Emission Point: 0GT48 Height (ft.): 57	Length (in.): 240	Width (in.): 154 Building: PIER 1

Item 37.2(From Mod 0):

The following emission points are included in this permit for the cited Emission Unit:

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Emission Unit: G-W0006

Emission Point: 0GT21
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT22
Height (ft.): 57 Length (in.): 240 Width (in.): 154
NYTMN (km.): 4501.523 NYTME (km.): 584.333 Building: PIER 1

Emission Point: 0GT23
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT24
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT25
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT26
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT27
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT28
Height (ft.): 57 Length (in.): 240 Width (in.): 154
NYTMN (km.): 4501.523 NYTME (km.): 584.333 Building: PIER 1

Emission Point: 0GT31
Height (ft.): 57 Length (in.): 240 Width (in.): 154
NYTMN (km.): 4501.523 NYTME (km.): 584.333 Building: PIER 1

Emission Point: 0GT32
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: 0GT33
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Emission Point: OGT34
Height (ft.): 57 Length (in.): 240 Width (in.): 154
NYTMN (km.): 4501.523 NYTME (km.): 584.333 Building: PIER 1

Emission Point: OGT35
Height (ft.): 57 Length (in.): 240 Width (in.): 154
NYTMN (km.): 4501.523 NYTME (km.): 584.333 Building: PIER 1

Emission Point: OGT36
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Emission Point: OGT37
Height (ft.): 57 Length (in.): 240 Width (in.): 154
NYTMN (km.): 4501.523 NYTME (km.): 584.333 Building: PIER 1

Emission Point: OGT38
Height (ft.): 57 Length (in.): 240 Width (in.): 154
Building: PIER 1

Condition 38: Process Definition By Emission Unit
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 201-6

Item 38.1(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: G-W0005
Process: D01 Source Classification Code: 2-01-001-09
Process Description:
THIS PROCESS INCLUDES: 16 COMBUSTION
TURBINES RATED AT 299 MMBTU/HR EACH. THIS
PROCESS COVERS THE COMBUSTION OF DISTILLATE
OIL IN THESE TURBINES.

Emission Source/Control: OGT11 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: OGT12 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: OGT13 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: OGT14 - Combustion
Design Capacity: 299 million Btu per hour



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Emission Source/Control: 0GT15 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT16 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT17 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT18 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT41 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT42 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT43 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT44 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT45 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT46 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT47 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT48 - Combustion
Design Capacity: 299 million Btu per hour

Item 38.2(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: G-W0005

Process: SD1

Source Classification Code: 2-01-001-02

Process Description:

This process is for 16 diesel starter engines each rated at 600 hp. Each combustion turbine has a starter engine.

Emission Source/Control: 0GT11 - Combustion



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT12 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT13 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT14 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT15 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT16 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT17 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT18 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT41 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT42 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT43 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT44 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT45 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT46 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT47 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT48 - Combustion
Design Capacity: 299 million Btu per hour

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Item 38.3(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: G-W0006

Process: D02

Source Classification Code: 2-01-001-09

Process Description:

THIS PROCESS INCLUDES: 16 COMBUSTION
TURBINES RATED AT 299 MMBTU/HR EACH,
CONVERTED TO DUAL FUEL CAPABILITY. THIS
PROCESS COVERS THE COMBUSTION OF DISTILLATE
OIL IN THESE TURBINES.

Emission Source/Control: 0GT21 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT22 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT23 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT24 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT25 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT26 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT27 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT28 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT31 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT32 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT33 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT34 - Combustion
Design Capacity: 299 million Btu per hour



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Emission Source/Control: 0GT35 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT36 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT37 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT38 - Combustion
Design Capacity: 299 million Btu per hour

Item 38.4(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: G-W0006

Process: NG1

Source Classification Code: 2-01-002-01

Process Description:

THIS PROCESS INCLUDES: 16 COMBUSTION
TURBINES RATED AT 299 MMBTU/HR EACH,
CONVERTED TO DUAL FUEL CAPABILITY. THIS
PROCESS COVERS THE COMBUSTION OF NATURAL
GAS IN THESE TURBINES.

Emission Source/Control: 0GT21 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT22 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT23 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT24 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT25 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT26 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT27 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT28 - Combustion



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT31 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT32 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT33 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT34 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT35 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT36 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT37 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT38 - Combustion
Design Capacity: 299 million Btu per hour

Item 38.5(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: G-W0006

Process: SD2

Source Classification Code: 2-01-001-02

Process Description:

This process is for 16 diesel starter engines each rated at 600 hp. Each combustion turbine has a starter engine.

Emission Source/Control: 0GT21 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT22 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT23 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT24 - Combustion
Design Capacity: 299 million Btu per hour



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Emission Source/Control: 0GT25 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT26 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT27 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT28 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT31 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT32 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT33 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT34 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT35 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT36 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT37 - Combustion
Design Capacity: 299 million Btu per hour

Emission Source/Control: 0GT38 - Combustion
Design Capacity: 299 million Btu per hour

Condition 39: Process Permissible Emissions
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 231-2

Item 39.1:

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: G-W0005

Process: D01

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



CAS No: 000630-08-0 (From Mod 0)

Name: CARBON MONOXIDE

PTE(s): 16 pounds per hour
0.0033 pounds per million Btus
138,296 pounds per year

CAS No: 0NY210-00-0 (From Mod 0)

Name: OXIDES OF NITROGEN

PTE(s): 2,928 pounds per hour
0.612 pounds per million Btus
25,647,600 pounds per year

CAS No: 0NY998-00-0 (From Mod 0)

Name: VOC

PTE(s): 2 pounds per hour
0.00041 pounds per million Btus
17,182 pounds per year

Emission Unit: G-W0005

Process: SD1

CAS No: 000630-08-0 (From Mod 0)

Name: CARBON MONOXIDE

PTE(s): 6.5 pounds per hour
0.1 pounds per million Btus
560 pounds per year

CAS No: 0NY210-00-0 (From Mod 0)

Name: OXIDES OF NITROGEN

PTE(s): 297.5 pounds per hour
4.41 pounds per million Btus
27,156 pounds per year

CAS No: 0NY998-00-0 (From Mod 0)

Name: VOC

PTE(s): 48 pounds per hour
0.36 pounds per million Btus
4,398 pounds per year

Condition 40: Process Permissible Emissions
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 40.1:

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:



Emission Unit: G-W0005 Process: D01

CAS No: 007446-09-5 (From Mod 0)
Name: SULFUR DIOXIDE
PTE(s): 966.5 pounds per hour
 0.202 pounds per million Btus
 8,465,383 pounds per year

CAS No: 0NY075-00-0 (From Mod 0)
Name: PARTICULATES
PTE(s): 57 pounds per hour
 0.012 pounds per million Btus
 502,900 pounds per year

CAS No: 0NY075-00-5 (From Mod 0)
Name: PM-10
PTE(s): 57 pounds per hour
 0.012 pounds per million Btus
 502,900 pounds per year

CAS No: 0NY210-00-0 (From Mod 0)
Name: OXIDES OF NITROGEN
PTE(s): 2,928 pounds per hour
 0.612 pounds per million Btus
 25,647,600 pounds per year

Emission Unit: G-W0005 Process: SD1

CAS No: 007446-09-5 (From Mod 0)
Name: SULFUR DIOXIDE
PTE(s): 19.5 pounds per hour
 0.29 pounds per million Btus
 1,796 pounds per year

CAS No: 0NY075-00-0 (From Mod 0)
Name: PARTICULATES
PTE(s): 21 pounds per hour
 0.31 pounds per million Btus
 1,927 pounds per year

CAS No: 0NY075-00-5 (From Mod 0)
Name: PM-10
PTE(s): 21 pounds per hour
 0.31 pounds per million Btus
 1,927 pounds per year



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

CAS No: 0NY210-00-0 (From Mod 0)

Name: OXIDES OF NITROGEN

PTE(s): 297.5 pounds per hour

4.41 pounds per million Btus

27,156 pounds per year

Condition 41: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 225-1.7

Item 41.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0005

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 41.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

DAILY FUEL USAGE IS DETERMINED. AVG
ELECTRICAL OUTPUT & HRLY GENERATION RATE
ARE MEASURED. HEAT CONTENT, SULFUR
CONTENT & ASH CONTENT ARE DETERMINED FOR
EA SHIPMENT. QUARTERLY REPORTS OF
EXCEEDANCES ARE FILED.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 42: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 42.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0005

Regulated Contaminant(s):



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

CAS No: 0NY075-00-0 PARTICULATES

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,
- 2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and
- 3) all records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2002.

Subsequent reports are due every 6 calendar month(s).

Condition 43: Compliance Certification

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 225-1.7

Item 43.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 43.2:

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

DAILY FUEL USAGE IS DETERMINED. AVG ELECTRICAL OUTPUT & HRLY GENERATION RATE ARE MEASURED. HEAT CONTENT, SULFUR CONTENT & ASH CONTENT ARE DETERMINED FOR EA SHIPMENT. QUARTERLY REPORTS OF EXCEEDANCES ARE FILED.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 44: Compliance Certification
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 44.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 44.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,
- 2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and
- 3) all records shall be maintained at the facility for a minimum of five years.



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

Parameter Monitored: PARTICULATES
Upper Permit Limit: 0.10 pounds per million Btus
Reference Test Method: Method 5
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2002.
Subsequent reports are due every 6 calendar month(s).

Condition 1-2: Compliance Certification
Effective between the dates of 10/07/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 231-2

Item 1-2.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 1-2.2:

Compliance Certification shall include the following monitoring:

Capping: Yes
Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
FUEL USAGE IS DETERMINED AND USED IN
CONJUNCTION WITH RELEVANT EMISSION FACTOR
TO VERIFY THAT ANNUAL EMISSIONS ARE LESS
THAN OR EQUAL TO THE CAP.

EMISSION FACTORS USED: 0.00959 LB/MMBTU
FOR OIL FIRE AND 0.00354 LB/MMBTU FOR
NATURAL GAS FIRE, BASED ON JULY-AUGUST
2001 STACK TEST.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO
FOLLOWING TONS PER YEAR. THE FACILITY
MUST MAINTAIN RECORDS ON A DAILY BASIS IN
ORDER TO DEMONSTRATE COMPLIANCE.

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



THE REGIONAL AIR POLLUTION CONTROL
ENGINEER MUST BE NOTIFIED IN WRITING
WITHIN 10 WORKING DAYS OF ANY
CONTRAVENTION OF THE EMISSION
LIMIT.

Parameter Monitored: VOC

Upper Permit Limit: 8.6 tons per year

Reference Test Method: EPA approved

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2003.

Subsequent reports are due every 6 calendar month(s).

Condition 1-3: Compliance Certification

Effective between the dates of 10/07/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 231-2

Item 1-3.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 1-3.2:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

FUEL USAGE IS DETERMINED AND USED IN
CONJUNCTION WITH RELEVANT EMISSION FACTOR
TO VERIFY THAT ANNUAL EMISSIONS ARE LESS
THAN OR EQUAL TO THE CAP.

EMISSION FACTORS USED: 0.440 LB/MMBTU FOR
OIL FIRE AND 0.261 LB/MMBTU FOR NATURAL
GAS FIRE, BASED ON JULY-AUGUST 2001 STACK

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



TEST.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO FOLLOWING TONS PER YEAR. THE FACILITY MUST MAINTAIN RECORDS ON A DAILY BASIS IN ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL ENGINEER MUST BE NOTIFIED IN WRITING WITHIN 10 WORKING DAYS OF ANY CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 382 tons per year
Reference Test Method: EPA approved
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)
Initial Report Due: 03/01/2003 for the period 10/07/2002 through 01/30/2003

Condition 1-4: Compliance Certification
Effective between the dates of 10/07/2002 and 07/30/2007

Applicable Federal Requirement: 6NYCRR 231-2

Item 1-4.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 1-4.2:

Compliance Certification shall include the following monitoring:

Capping: Yes
Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
FUEL USAGE IS DETERMINED AND USED IN
CONJUNCTION WITH RELEVANT EMISSION FACTOR
TO VERIFY THAT ANNUAL EMISSIONS ARE LESS
THAN OR EQUAL TO THE CAP.

EMISSION FACTORS USED: 0.0315 LB/MMBTU



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

FOR OIL FIRE AND 0.00627 LB/MMBTU FOR
NATURAL GAS FIRE, BASED ON JULY-AUGUST
2001 STACK TEST.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO
FOLLOWING TONS PER YEAR. THE FACILITY
MUST MAINTAIN RECORDS ON A DAILY BASIS IN
ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL
ENGINEER MUST BE NOTIFIED IN WRITING
WITHIN 10 WORKING DAYS OF ANY
CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: CARBON MONOXIDE
Upper Permit Limit: 69 tons per year
Reference Test Method: EPA approved
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)
Initial Report Due: 03/01/2003 for the period 10/07/2002 through 01/30/2003

Condition 1-5: Compliance Certification
Effective between the dates of 10/07/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 1-5.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):
CAS No: 0NY075-00-5 PM-10

Item 1-5.2:

Compliance Certification shall include the following monitoring:

Capping: Yes
Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE
Monitoring Description:
FUEL USAGE IS DETERMINED AND USED IN
CONJUNCTION WITH RELEVANT EMISSION FACTOR
TO VERIFY THAT ANNUAL EMISSIONS ARE LESS
THAN OR EQUAL TO THE CAP.

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



EMISSION FACTORS USED: 0.012 LB/MMBTU FOR OIL FIRE AND 0.0066 LB/MMBTU FOR NATURAL GAS FIRE, BASED ON AP-42.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO FOLLOWING TONS PER YEAR. THE FACILITY MUST MAINTAIN RECORDS ON A DAILY BASIS IN ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL ENGINEER MUST BE NOTIFIED IN WRITING WITHIN 10 WORKING DAYS OF ANY CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: PM-10
Upper Permit Limit: 21.3 tons per year
Reference Test Method: EPA approved
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2003.
Subsequent reports are due every 6 calendar month(s).

Condition 1-6: Compliance Certification
Effective between the dates of 10/07/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 1-6.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 1-6.2:

Compliance Certification shall include the following monitoring:

Capping: Yes
Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:
FUEL USAGE IS DETERMINED AND USED IN

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



CONJUNCTION WITH RELEVANT EMISSION FACTOR TO VERIFY THAT ANNUAL EMISSIONS ARE LESS THAN OR EQUAL TO THE CAP.

EMISSION FACTORS USED: 0.202 LB/MMBTU FOR OIL FIRE AND 0.0034 LB/MMBTU FOR NATURAL GAS FIRE, BASED ON AP-42.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO FOLLOWING TONS PER YEAR. THE FACILITY MUST MAINTAIN RECORDS ON A DAILY BASIS IN ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL ENGINEER MUST BE NOTIFIED IN WRITING WITHIN 10 WORKING DAYS OF ANY CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: SULFUR DIOXIDE

Upper Permit Limit: 117 tons per year

Reference Test Method: EPA approved

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)

Initial Report Due: 03/01/2003 for the period 10/07/2002 through 01/30/2003

Condition 1-7: Compliance Certification

Effective between the dates of 10/07/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 1-7.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 1-7.2:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



FUEL USAGE IS DETERMINED AND USED IN CONJUNCTION WITH RELEVANT EMISSION FACTOR TO VERIFY THAT ANNUAL EMISSIONS ARE LESS THAN OR EQUAL TO THE CAP.

EMISSION FACTORS USED: 0.012 LB/MMBTU FOR OIL FIRE AND 0.0066 LB/MMBTU FOR NATURAL GAS FIRE, BASED ON AP-42.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO FOLLOWING TONS PER YEAR. THE FACILITY MUST MAINTAIN RECORDS ON A DAILY BASIS IN ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL ENGINEER MUST BE NOTIFIED IN WRITING WITHIN 10 WORKING DAYS OF ANY CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 30.8 tons per year

Reference Test Method: EPA approved

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)

Initial Report Due: 03/01/2003 for the period 10/07/2002 through 01/30/2003

Condition 1-8: Compliance Certification

Effective between the dates of 10/07/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 1-8.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 1-8.2:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Monitoring Description:

FUEL USAGE IS DETERMINED AND USED IN CONJUNCTION WITH RELEVANT EMISSION FACTOR TO VERIFY THAT ANNUAL EMISSIONS ARE LESS THAN OR EQUAL TO THE CAP.

EMISSION FACTORS USED: 0.440 LB/MMBTU FOR OIL FIRE AND 0.261 LB/MMBTU FOR NATURAL GAS FIRE, BASED ON JULY-AUGUST 2001 STACK TEST.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO FOLLOWING TONS PER YEAR. THE FACILITY MUST MAINTAIN RECORDS ON A DAILY BASIS IN ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL ENGINEER MUST BE NOTIFIED IN WRITING WITHIN 10 WORKING DAYS OF ANY CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 382 tons per year

Reference Test Method: EPA approved

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)

Initial Report Due: 03/01/2003 for the period 10/07/2002 through 01/30/2003

Condition 48: Compliance Certification

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 48.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 007439-97-6 MERCURY

Item 48.2:

Compliance Certification shall include the following monitoring:

Capping: Yes

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

FUEL USAGE IS DETERMINED AND USED IN
CONJUNCTION WITH RELEVANT EMISSION FACTOR
TO VERIFY THAT ANNUAL EMISSIONS ARE LESS
THAN OR EQUAL TO THE CAP.

Emission factor used for Mercury is
1.2E-06 lb/MmBtu.

EMISSION UNIT GW 0006 SHALL BE LIMITED TO
FOLLOWING TONS PER YEAR. THE FACILITY
MUST MAINTAIN RECORDS ON A DAILY BASIS IN
ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL
ENGINEER MUST BE NOTIFIED IN WRITING
WITHIN 10 WORKING DAYS OF ANY
CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: MERCURY

Upper Permit Limit: 0.05 tons per year

Reference Test Method: EPA approved

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)

Initial Report Due: 03/01/2003 for the period 07/31/2002 through 01/30/2003

Condition 49: Compliance Certification

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 49.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 007440-41-7 BERYLLIUM

Item 49.2:

Compliance Certification shall include the following monitoring:

Capping: Yes

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

FUEL USAGE IS DETERMINED AND USED IN
CONJUNCTION WITH RELEVANT EMISSION FACTOR
TO VERIFY THAT ANNUAL EMISSIONS ARE LESS
THAN OR EQUAL TO THE CAP.

Emission Factor used for Beryllium is
3.1E-07 lb/MMBtu

EMISSION UNIT GW 0006 SHALL BE LIMITED TO
FOLLOWING TONS PER YEAR. THE FACILITY
MUST MAINTAIN RECORDS ON A DAILY BASIS IN
ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL
ENGINEER MUST BE NOTIFIED IN WRITING
WITHIN 10 WORKING DAYS OF ANY
CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: BERYLLIUM

Upper Permit Limit: 0.00058 tons per year

Reference Test Method: EPA approved method

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)

Initial Report Due: 03/01/2003 for the period 07/31/2002 through 01/30/2003

Condition 50: Compliance Certification

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 50.1:

The Compliance Certification activity will be performed for:

Emission Unit: G-W0006

Regulated Contaminant(s):

CAS No: 007439-92-1 LEAD

Item 50.2:

Compliance Certification shall include the following monitoring:

Capping: Yes

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

FUEL USAGE IS DETERMINED AND USED IN
CONJUNCTION WITH RELEVANT EMISSION FACTOR
TO VERIFY THAT ANNUAL EMISSIONS ARE LESS
THAN OR EQUAL TO THE CAP.

Emission factor for Lead used is 1.4 E
-05 lb/MMBtu

EMISSION UNIT GW 0006 SHALL BE LIMITED TO
FOLLOWING TONS PER YEAR. THE FACILITY
MUST MAINTAIN RECORDS ON A DAILY BASIS IN
ORDER TO DEMONSTRATE COMPLIANCE.

THE REGIONAL AIR POLLUTION CONTROL
ENGINEER MUST BE NOTIFIED IN WRITING
WITHIN 10 WORKING DAYS OF ANY
CONTRAVENTION OF THE EMISSION LIMIT.

Parameter Monitored: LEAD

Upper Permit Limit: 0.56 tons per year

Reference Test Method: EPA approved

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)

Initial Report Due: 03/01/2003 for the period 07/31/2002 through 01/30/2003



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 55: Contaminant List
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable State Requirement: ECL 19-0301

Item 55.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this

New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116



permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 007440-41-7

Name: BERYLLIUM

CAS No: 000630-08-0

Name: CARBON MONOXIDE

CAS No: 007439-92-1

Name: LEAD

CAS No: 007439-97-6

Name: MERCURY

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

CAS No: 0NY075-00-0

Name: PARTICULATES

CAS No: 0NY075-00-5

Name: PM-10

CAS No: 007446-09-5

Name: SULFUR DIOXIDE

CAS No: 0NY998-00-0

Name: VOC

Condition 56: Unavoidable noncompliance and violations
Effective between the dates of 07/31/2002 and 07/30/2007

Applicable State Requirement: 6NYCRR 201-1.4

Item 56.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

- (a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall



New York State Department of Environmental Conservation

Permit ID: 2-6102-00116/00021

Facility DEC ID: 2610200116

include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 57: Air pollution prohibited

Effective between the dates of 07/31/2002 and 07/30/2007

Applicable State Requirement: 6NYCRR 211.2

Item 57.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.