



**PERMIT**  
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air Title V Facility  
Permit ID: 2-6104-00249/00004  
Mod 0 Effective Date: 05/30/2013 Expiration Date: 05/29/2018  
Mod 1 Effective Date: 08/22/2013 Expiration Date: 05/29/2018  
Mod 2 Effective Date: 11/17/2015 Expiration Date: 05/29/2018  
Mod 3 Effective Date: 11/02/2016 Expiration Date: 05/29/2018

Permit Issued To: NYC HEALTH & HOSPITALS CORP  
125 WORTH ST  
NEW YORK, NY 10013-4006

Contact: JOSEPH MULCHAN  
KINGS COUNTY HOSPITAL CENTER  
451 CLARKSON AVE BLDG E, RM E2218  
BROOKLYN, NY 11203  
(718) 245-2945

Facility: NYC-HH - KINGS COUNTY HOSPITAL CENTER  
451 CLARKSON AVE  
BROOKLYN, NY 11203

Description:  
NYC HH - Kings County Hospital Center, located at 451 Clarkson Avenue in Brooklyn, New York, is an 800 bed hospital which provides emergency and in-patient care. The hospital center also serves as a research center and nursing school. The Standard Industrial Classification Code (SIC) is 8062 - General Medical and Surgical Hospitals.

NYC HH - Kings County Hospital Center operates five boilers, each rated at 49.9mmBtu/hr which supply steam for the space heating of the building. Facility also has sixteen diesel-fired emergency generators which are exempt (limited to operating below 500 hours per year).

With this modification facility plans to add two electrical and hot water arrays: a C1000S which has five (5) C200 HRM Microturbines; and a C600s which has three (3) C200 HRM Microturbines. Each C200 HRM Microturbine will be independently exhausted to the atmosphere and will have a rated 190 KW power output. Each qualifies for exemption from permit requirements under section 201-3.2(c)5 gas turbines with a heat input peak load less than 10 mmBtu/hr.

Annual potential emissions from these new eight microturbines are calculated to be 2.37 TPY (with the manufacturer guaranteed emission factor 0.356/bs NOx/MWhe), which is less than the

**New York State Department of Environmental Conservation**  
**Facility DEC ID: 2610400249**



6 NYCRR Part 231 NOx Significant Project Threshold 2.5 TPY. Therefore, this project is exempt from permitting as per 6 NYCRR Part 201.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator:           STEPHEN A WATTS  
  47-40 21ST ST  
  LONG ISLAND CITY, NY 11101-5401

Authorized Signature: \_\_\_\_\_ Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_



**Notification of Other State Permittee Obligations**

**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



**LIST OF CONDITIONS**

**DEC GENERAL CONDITIONS**

**General Provisions**

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
  - Applications for permit renewals, modifications and transfers
  - Applications for permit renewals, modifications and transfers
  - Permit modifications, suspensions or revocations by the Department

**Facility Level**

- Submission of application for permit modification or renewal -  
REGION 2 HEADQUARTERS



**DEC GENERAL CONDITIONS**

**\*\*\*\* General Provisions \*\*\*\***

**For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.**

**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**

**Applicable State Requirement: ECL 19-0305**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**

**Applicable State Requirement: ECL 3-0301 (2) (m)**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 3-1: Applications for permit renewals, modifications and transfers**

**Applicable State Requirement: 6 NYCRR 621.11**

**Item 3-1.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item3-1.2:**

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

**Item 3-1.3**

Permits are transferrable with the approval of the department unless specifically prohibited by



the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 3: Applications for permit renewals, modifications and transfers**  
**Applicable State Requirement: 6 NYCRR 621.11**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 3.3:**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 4: Permit modifications, suspensions or revocations by the Department**  
**Applicable State Requirement: 6 NYCRR 621.13**

**Item 4.1:**

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 5: Submission of application for permit modification or renewal - REGION 2 HEADQUARTERS**  
**Applicable State Requirement: 6 NYCRR 621.6 (a)**

**Item 5.1:**

Submission of applications for permit modification or renewal are to be submitted to:  
NYSDEC Regional Permit Administrator

**New York State Department of Environmental Conservation**  
**Facility DEC ID: 2610400249**



Region 2 Headquarters  
Division of Environmental Permits  
1 Hunters Point Plaza, 4740 21st Street  
Long Island City, NY 11101-5407  
(718) 482-4997

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: NYC HEALTH & HOSPITALS CORP  
125 WORTH ST  
NEW YORK, NY 10013-4006

Facility: NYC-HH - KINGS COUNTY HOSPITAL CENTER  
451 CLARKSON AVE  
BROOKLYN, NY 11203

Authorized Activity By Standard Industrial Classification Code:  
8062 - GENERAL MEDICAL & SURGICAL HOSPITALS

Mod 0 Permit Effective Date: 05/30/2013

Permit Expiration Date: 05/29/2018

Mod 1 Permit Effective Date: 08/22/2013

Permit Expiration Date: 05/29/2018

Mod 2 Permit Effective Date: 11/17/2015

Permit Expiration Date: 05/29/2018

Mod 3 Permit Effective Date: 11/02/2016

Permit Expiration Date: 05/29/2018



## LIST OF CONDITIONS

### FEDERALLY ENFORCEABLE CONDITIONS

#### Facility Level

- 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6 NYCRR 201-6.4 (a) (7): Fees
- 3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
- 4 6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
- 5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
- 6 6 NYCRR 201-6.4 (e): Compliance Certification
- 7 6 NYCRR 202-2.1: Compliance Certification
- 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 9 6 NYCRR 215.2: Open Fires - Prohibitions
- 10 6 NYCRR 200.7: Maintenance of Equipment
- 11 6 NYCRR 201-1.7: Recycling and Salvage
- 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 15 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
- 3-1 6 NYCRR 201-6.4 (a) (8): Right to Inspect
- 17 6 NYCRR 201-6.4 (f) (6): Off Permit Changes
- 18 6 NYCRR 202-1.1: Required Emissions Tests
- 19 40 CFR Part 68: Accidental release provisions.
- 20 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 21 6 NYCRR Subpart 201-6: Emission Unit Definition
- 22 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
- 23 6 NYCRR Subpart 201-7: Facility Permissible Emissions
- \*2-1 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- \*2-2 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- \*24 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- 29 6 NYCRR 211.1: Air pollution prohibited
- 3-2 6 NYCRR 225-1.2 (d): Compliance Certification
- 2-3 6 NYCRR 225-1.2 (g): Compliance Certification
- 31 6 NYCRR 225-1.2 (g): Compliance Certification
- 2-4 6 NYCRR 225-1.2 (h): Compliance Certification
- 32 6 NYCRR 225-1.2 (h): Compliance Certification
- 34 6 NYCRR 225.1 (a) (3): Compliance Certification
- 35 6 NYCRR 225.7 (a): Compliance Certification
- 36 6 NYCRR 227-1.3 (a): Compliance Certification
- 2-5 6 NYCRR 227-2.4 (c) (1) (ii): Compliance Certification
- 37 6 NYCRR 227.2 (b) (1): Compliance Certification
- 2-6 40CFR 52.21, Subpart A: Compliance Certification

#### Emission Unit Level

- 39 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 40 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

**EU=U-00001**

**New York State Department of Environmental Conservation**

**Permit ID: 2-6104-00249/00004**

**Facility DEC ID: 2610400249**



- 1-1 6 NYCRR 227-2.4 (c) (1) (ii): Compliance Certification
- 2-7 6 NYCRR 227-2.4 (c) (1) (ii): Compliance Certification
- 1-2 6 NYCRR 227-2.5 (a): Compliance Certification

**EU=U-00002**

- 1-3 6 NYCRR 227-2.4 (c) (1) (ii): Compliance Certification
- 2-8 6 NYCRR 227-2.4 (c) (1) (ii): Compliance Certification
- 1-4 6 NYCRR 227-2.5 (a): Compliance Certification

**STATE ONLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 45 ECL 19-0301: Contaminant List
- 46 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities

NOTE: \* preceding the condition number indicates capping.



**FEDERALLY ENFORCEABLE CONDITIONS**  
**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**  
**The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.**

**Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

**Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)**

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)**

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

**Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)**

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)**

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and



reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

**Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

**Item H: Severability - 6 NYCRR 201-6.4 (a) (9)**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item I: Permit Shield - 6 NYCRR 201-6.4 (g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;

ii. The liability of a permittee of the Title V



facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide



a shorter time period in the case of an emergency.

**Item K: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS  
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

**The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.**

**Condition 1: Acceptable Ambient Air Quality  
Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 200.6**

**Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



emission control required.

**Condition 2: Fees**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (7)**

**Item 2.1:**

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

**Condition 3: Recordkeeping and Reporting of Compliance Monitoring**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (c)**

**Item 3.1:**

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

**Condition 4: Records of Monitoring, Sampling, and Measurement**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (2)**

**Item 4.1:**

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.



**Condition 5: Compliance Certification**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (3) (ii)**

**Item 5.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 5.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.
- (2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.
- (3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring



report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate



whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 6: Compliance Certification**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (e)**

**Item 6.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 6.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
  - the identification of each term or condition of the permit that is the basis of the certification;
  - the compliance status;
  - whether compliance was continuous or intermittent;
  - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related record keeping and reporting requirements of this permit;
  - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;and
  - such additional requirements as may be specified elsewhere in this permit related to compliance certification.
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2  
Air Compliance Branch  
290 Broadway  
New York, NY 10007-1866

The address for the RAPCE is as follows:

Hunters Point Plaza  
47-40 21st Street  
Long Island City, NY 11101-5407

The address for the BQA is as follows:

NYSDEC  
Bureau of Quality Assurance  
625 Broadway  
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 1/30/2014.  
Subsequent reports are due on the same day each year

**Condition 7: Compliance Certification**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 202-2.1**

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



**Item 7.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 7.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

**Condition 8: Recordkeeping requirements**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 202-2.5**

**Item 8.1:**

(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

**Condition 9: Open Fires - Prohibitions**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 215.2**

**Item 9.1:**

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

**Item 9.2**

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

(a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or



- portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
  - (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
  - (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
  - (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
  - (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
  - (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
  - (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
  - (i) Prescribed burns performed according to Part 194 of this Title.
  - (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
  - (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
  - (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS  
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

**The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.**

**[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]**

**Condition 10: Maintenance of Equipment  
Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 200.7**



**Item 10.1:**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Condition 11: Recycling and Salvage**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-1.7**

**Item 11.1:**

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

**Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-1.8**

**Item 12.1:**

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 13: Exempt Sources - Proof of Eligibility**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-3.2 (a)**

**Item 13.1:**

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

**Condition 14: Trivial Sources - Proof of Eligibility**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-3.3 (a)**

**Item 14.1:**

The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

**Condition 15: Requirement to Provide Information**



**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (4)**

**Item 15.1:**

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

**Condition 3-1: Right to Inspect**

**Effective between the dates of 11/02/2016 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (8)**

**Item 3-1.1:**

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

**Condition 17: Off Permit Changes**

**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)**

**Item 17.1:**

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



(whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

**Condition 18: Required Emissions Tests**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 202-1.1**

**Item 18.1:**

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

**Condition 19: Accidental release provisions.**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:40 CFR Part 68**

**Item 19.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;

b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:

1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,

2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center  
C/O CSC  
8400 Corporate Dr  
Carrollton, Md. 20785



**Condition 20: Recycling and Emissions Reduction**  
Effective between the dates of 05/30/2013 and 05/29/2018

**Applicable Federal Requirement:40CFR 82, Subpart F**

**Item 20.1:**

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**The following conditions are subject to annual compliance certification requirements for Title V permits only.**

**Condition 21: Emission Unit Definition**  
Effective between the dates of 05/30/2013 and 05/29/2018

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 21.1(From Mod 2):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

Emission Unit U-00001 consists of two Cleaver Brooks boilers (Emission Sources 00001 & 00002), rated at 49.9 MM Btu/hr each, capable of burning natural gas (Process 001); and # 6 residual fuel oil (Process 002) or #2 distillate fuel oil (Process 003). The flue gases from these two boilers exit through a common stack, identified as Emission point 00001. These two boilers are located in Building Z (Boiler House). NYC-HH - Kings County Hospital Center's boilers currently burn # 6 fuel oil as a secondary fuel to natural gas. After burners replacement, # 2 distillate fuel oil will be used instead of #6 residual fuel oil.

Building(s): BLDG Z

**Item 21.2(From Mod 2):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00002

Emission Unit Description:

Emission Unit U-00002 consists of three Cleaver Brooks boilers (Emission Sources 00003, 00004 & 00005), rated at 49.9 MM Btu/hr each, capable of burning natural gas (Process 010); and # 6 residual fuel oil (Process 020) or #2 distillate fuel oil (Process 032). The flue gases from these three boilers exit through a common stack, identified as Emission point 00002. These three boilers are located in Building Z (Boiler House). NYC-HH - Kings

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



County Hospital Center's boilers currently burn # 6 fuel oil as a secondary fuel to natural gas. After burners replacement, # 2 distillate fuel oil will be used instead of #6 residual fuel oil.

Building(s): BLDG Z

Condition 22: Progress Reports Due Semiannually
Effective between the dates of 05/30/2013 and 05/29/2018

Applicable Federal Requirement:6 NYCRR 201-6.4 (d) (4)

Item 22.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 23: Facility Permissible Emissions
Effective between the dates of 05/30/2013 and 05/29/2018

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 23.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

Table with 2 rows of contaminant data: SULFUR DIOXIDE and OXIDES OF NITROGEN, including CAS numbers, PTE rates, and names.

Condition 2-1: Capping Monitoring Condition
Effective between the dates of 11/17/2015 and 05/29/2018

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 2-1.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



otherwise be subject to:

40 CFR 52.21 (j)

**Item 2-1.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 2-1.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 2-1.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 2-1.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 2-1.6:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 2-1.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The facility wide emissions of NOx and SO2 continue to be limited to 99.99 tons per year. At the beginning of each month, the facility shall calculate total SO2 emissions for the previous month and the total SO2 emissions for the previous consecutive 12-month period. Monthly SO2 emissions are determined as follows:

$SO_2 \text{ (lb/month)} = SO_{2ng} + SO_{2(6)oil} + SO_{2(2)oil} + SO_{2(diesel)}$ ; where

$SO_{2ng}$  = Monthly SO2 emissions based on Natural gas usage



(MMcf net natural gas burned/month, multiplied by 0.6 lb/MMcf);

SO<sub>2</sub>(6)oil = Monthly SO<sub>2</sub> emissions based on #6 fuel oil usage (Gallons of #6 oil burned/month, multiplied by 157S lb/1000gal); where S = % Sulfur content of the #6 fuel oil;

SO<sub>2</sub>(2)oil = Monthly SO<sub>2</sub> emissions based on #2 fuel oil usage (Gallons of #2 oil burned/month, multiplied by 142S lb/1000gal); where S = % Sulfur content of the #2 fuel oil;

SO<sub>2</sub>diesel = Monthly SO<sub>2</sub> emissions based on diesel fuel usage (Gallons of diesel burned/month, multiplied by 37.5 lb/1000gal).

The emission factors used in the above-mentioned equation, (0.6 lbSO<sub>2</sub>/MMcf natural gas), (157S lbSO<sub>2</sub>/1000gal#6oil) and (142S lbSO<sub>2</sub>/1000 gal#2 oil), are taken from the USEPA Compilation of Air Pollution Emission Factors (AP-42), Volume I, January 1995, Tables 1.4-2 and 1.3-2, respectively.

It is also understood that the after the fuel switching transition period is over by eliminating use of #6 fuel oil, the facility will determine the annual upper limit of the usage amount for each fuel kind to demonstrate compliance with the total facility-wide emissions.

Parameter Monitored: SULFUR DIOXIDE

Upper Permit Limit: 99.99 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2016.

Subsequent reports are due every 12 calendar month(s).

**Condition 2-2: Capping Monitoring Condition**  
**Effective between the dates of 11/17/2015 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR Subpart 201-7**

**Item 2-2.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 231-2

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



**Item 2-2.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 2-2.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 2-2.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 2-2.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 2-2.6:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 2-2.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The facility wide emissions of NO<sub>x</sub> and SO<sub>2</sub> continue to be limited to 99.99 tons per year. At the beginning of each month, the facility shall calculate total NO<sub>x</sub> emissions for the previous month and the total NO<sub>x</sub> emissions for the previous consecutive 12-month period. Monthly NO<sub>x</sub> emissions are determined as follows:

NO<sub>x</sub> (lb/month) = NO<sub>x</sub>ng + NO<sub>x</sub>(6)oil + NO<sub>x</sub>(2)oil + NO<sub>x</sub>(diesel); where

NO<sub>x</sub>ng = Monthly NO<sub>x</sub> emissions based on Natural gas usage (MMcf net natural gas burned/month, multiplied by 2.2 lb/MMcf);

NO<sub>x</sub>(6)oil = Monthly NO<sub>x</sub> emissions based on #6 fuel oil

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



usage (Gallons of #6 oil burned/month, multiplied by 55lb/1000gal);

NO<sub>x</sub>(2)oil = Monthly NO<sub>x</sub> emissions based on #2 fuel oil usage (Gallons of #2 oil burned/month, multiplied by 20lb/1000gal);

NO<sub>x</sub>diesel = Monthly NO<sub>x</sub> emissions based on diesel fuel usage (Gallons of diesel burned/month, multiplied by 1.32lb/gal).

The emission factors used in the above-mentioned equation, (2.2 lbNO<sub>x</sub>/MMcf natural gas), (55 lbNO<sub>x</sub>/1000gal#6oil) and (20 lbNO<sub>x</sub>/1000 gal#2 oil), are taken from the USEPA Compilation of Air Pollution Emission Factors (AP-42), Volume I, January 1995, Tables 1.4-2 and 1.3-2.

It is also understood that the after the fuel switching transition period is over by eliminating use of #6 fuel oil, the facility will determine the annual upper limit of the usage amount for each fuel kind to demonstrate compliance with the total facility-wide emissions.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 99.99 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2016.

Subsequent reports are due every 12 calendar month(s).

**Condition 24: Capping Monitoring Condition**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR Subpart 201-7**

**Item 24.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40 CFR 52.21 (j)

**Item 24.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 24.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request.

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 24.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 24.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 24.6:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5      SULFUR DIOXIDE

**Item 24.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

The facility wide use of Diesel Fuel for Generators is limited to 120,000 gallons per year.

Work Practice Type: PROCESS MATERIAL THRUPUT

Process Material: DIESEL OIL

Upper Permit Limit: 120,000 gallons per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL TOTAL ROLLED MONTHLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2013.

Subsequent reports are due every 6 calendar month(s).

**Condition 29:      Air pollution prohibited**

**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 211.1**

**Item 29.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**Condition 3-2: Compliance Certification**  
**Effective between the dates of 11/02/2016 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 225-1.2 (d)**

**Item 3-2.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 3-2.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of any stationary combustion installation that fires residual oil are limited to the firing of residual oil with a sulfur content of 0.30% sulfur.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: RESIDUAL FUEL (#4, #5 AND/OR #6 FUEL OIL)

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.30 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 2-3: Compliance Certification**  
**Effective between the dates of 11/17/2015 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 225-1.2 (g)**

**Item 2-3.1:**

The Compliance Certification activity will be performed for the Facility.

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



**Item 2-3.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 31: Compliance Certification**

**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 225-1.2 (g)**

**Item 31.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 31.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014. Compliance with this limit will be based on vendor certifications.

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL  
Parameter Monitored: SULFUR CONTENT  
Upper Permit Limit: 0.0015 percent by weight  
Monitoring Frequency: PER DELIVERY  
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)  
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 2-4: Compliance Certification**  
**Effective between the dates of 11/17/2015 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 225-1.2 (h)**

**Item 2-4.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 2-4.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installations that fire distillate oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL



**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 32: Compliance Certification**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 225-1.2 (h)**

**Item 32.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 32.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC  
OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installations that fire distillate oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.0015 percent by weight

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 34: Compliance Certification**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 225.1 (a) (3)**

**Item 34.1:**

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



The Compliance Certification activity will be performed for the Facility.

**Item 34.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

No person shall sell, offer for sale, purchase or use any residual oil which has sulfur content greater than 0.30 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site for a minimum of five years after the date of the last entry.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: NUMBER 6 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.30 percent by weight

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2013.

Subsequent reports are due every 6 calendar month(s).

**Condition 35: Compliance Certification**

**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 225.7 (a)**

**Item 35.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 35.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The permittee shall retain fuel oil supplier certifications for each shipment of oil received. Such certifications shall contain, as a minimum, supplier name, date of shipment, quantity shipped, heating value of the oil, oil sulfur content, and the method used to determine the sulfur content. Such certifications shall be available for inspection by, or submitted to, the NYSDEC as per the stated reporting requirement.

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2013.

Subsequent reports are due every 6 calendar month(s).

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



**Condition 36: Compliance Certification**  
Effective between the dates of 05/30/2013 and 05/29/2018

**Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)**

**Item 36.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 36.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (six minute average), except for one-six-minute period per hour of not more than 27 percent opacity.

The Department reserves the right to perform or require the performance of a Method 9 opacity evaluation at any time during facility operation.

The permittee will conduct observations of visible emissions from the emission unit, process, etc. to which this condition applies at the monitoring frequency stated below while the process is in operation. The permittee will investigate, in a timely manner, any instance where there is cause to believe that visible emissions have the potential to exceed the opacity standard.

The permittee shall investigate the cause, make any necessary corrections, and verify that the excess visible emissions problem has been corrected. If visible emissions with the potential to exceed the standard continue, the permittee will conduct a Method 9 assessment within the next operating day of the sources associated with the potential noncompliance to determine the degree of opacity and will notify the NYSDEC if the method 9 test indicates that the opacity standard is not met.

Records of visible emissions observations (or any follow-up method 9 tests), investigations and corrective actions will be kept on-site. Should the Department determine that permittee's record keeping format is inadequate to demonstrate compliance with this condition, it shall provide written notice to the permittee stating the inadequacies, and permittee shall have 90 days to revise its prospective record keeping format in a manner acceptable to the Department.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



Reference Test Method: Method 9  
Monitoring Frequency: DAILY  
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2013.  
Subsequent reports are due every 6 calendar month(s).

**Condition 2-5: Compliance Certification**  
**Effective between the dates of 11/17/2015 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 227-2.4 (c) (1) (ii)**

**Item 2-5.1:**

The Compliance Certification activity will be performed for the facility:  
The Compliance Certification applies to:

Emission Unit: U-00001

Emission Unit: U-00002

Regulated Contaminant(s):  
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 2-5.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

This condition applies to oil/gas fired mid-size boilers. By switching from fuel oil to Natural Gas, the facility chooses the fuel switching option under 6NYCRR 227-2.5(a), that states that the owner or operator of an emission source subject to this Subpart may commit to burning a cleaner fuel between May 1st and September 30th of each year. Fuel switching must result in quantifiable annual NOx emissions equal to or less than the NOx emissions expected if the emission source complied with the applicable presumptive RACT emission limits set forth in section 227-2.4 of this Subpart.

The facility is subject to an upper NOx RACT emission limit of 0.08 pounds per million Btus. The owner or operator shall submit a testing protocol to the Department for approval a maximum of 30 days prior to any stack testing. The facility must maintain records of its total NOx emissions on daily basis and quantity of annual NOx emissions rolled daily on-site for a period of minimum five years.

NOx emissions would be calculated based on the following formula:

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



$$\text{NOx (lbs/mmBtu)} = ((A*(B) + C*(D) = E*(F)) / ((A*(G) + C*(H) + E*(I))); \text{ where}$$

A = MGal of #6 fuel oil burned;

B = NOx Emission factor for burning #6 fuel oil in lbs/MGal (based on the latest facility stack test. A March 26, 2012 stack test noted an emission factor of 42.3 lbs/MGal);

C = MGal of #2 fuel oil burned;

D = NOx Emission factor for burning #2 fuel oil in lbs/MGal

E = MMcf of natural Gas burned;

F = NOx Emission factor for burning Natural Gas in lbs/MMcf (based on the latest facility stack test. A March 26, 2012 stack test noted an emission factor of 114.3 lbs/MMcf);

G = 152 MMBtu/Gal; Heating value of one MGal of #6 fuel oil burned (Based on AP-42);

H = 138 MMBtu/Gal; Heating value of one MGal of #2 fuel oil burned (Based on AP-42);

I = 1020 MMBtu/MMcf; Heating value of one MMcf of Natural Gas burned (Based on AP-42).

Upper Permit Limit: 0.08 pounds per million Btus

Reference Test Method: 40 CFR 60 Appendix A Method 7, 7E, or 19

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2016.

Subsequent reports are due every 6 calendar month(s).

**Condition 37: Compliance Certification**

**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 227.2 (b) (1)**

**Item 37.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 37.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,
- 2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and
- 3) all records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2013.

Subsequent reports are due every 6 calendar month(s).

**Condition 2-6: Compliance Certification**  
**Effective between the dates of 11/17/2015 and 05/29/2018**

**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 2-6.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 2-6.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The facility wide SO<sub>2</sub> emission total is restricted to 199,999 pounds or less as determined by summing the individual monthly emissions during any consecutive 12 month period. At the beginning of each month, the facility shall calculate total SO<sub>2</sub> emissions for the previous month and total SO<sub>2</sub> emissions for the previous consecutive 12 month period. Monthly SO<sub>2</sub> emissions are determined as follows:

$$\text{SO}_2 \text{ (lb/month)} = \text{SO}_2\text{ng} + \text{SO}_2(6)\text{oil} + \text{SO}_2(2)\text{oil} +$$

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



SO<sub>2</sub>(diesel); where

SO<sub>2</sub>ng = Monthly SO<sub>2</sub> emissions based on Natural gas usage (MMcf net natural gas burned/month, multiplied by 0.6 lb/MMcf);

SO<sub>2</sub>(6)oil = Monthly SO<sub>2</sub> emissions based on #6 fuel oil usage (Gallons of #6 oil burned/month, multiplied by 157Slb/1000gal); where S = % Sulfur content of the #6 fuel oil;

SO<sub>2</sub>(2)oil = Monthly SO<sub>2</sub> emissions based on #2 fuel oil usage (Gallons of #2 oil burned/month, multiplied by 142Slb/1000gal); where S = % Sulfur content of the #2 fuel oil;

SO<sub>2</sub>diesel = Monthly SO<sub>2</sub> emissions based on diesel fuel usage (Gallons of diesel burned/month, multiplied by 37.5 lb/1000gal).

The emission factors used in the above-mentioned equation, (0.6 lbSO<sub>2</sub>/MMcf natural gas), (157S lbSO<sub>2</sub>/1000gal#6oil) and (142S lbSO<sub>2</sub>/1000 gal#2 oil), are taken from the USEPA Compilation of Air Pollution Emission Factors (AP-42), Volume I, January 1995, Tables 1.4-2 and 1.3-2, respectively.

The facility shall maintain records showing the quantity of fuel burned on a monthly basis. Records shall be based on verifiable data such as fuel metering data or fuel purchase records to confirm the general accuracy of the monthly fuel usage amounts. All fuel use records and corresponding emission calculations shall be kept on site for a minimum of five (5) years. This information shall be made available to the department upon request.

The facility shall submit to the department an annual inventory listing monthly SO<sub>2</sub> emissions and total SO<sub>2</sub> emissions for the previous year due by the 15th of April.

Monitoring Frequency: MONTHLY  
Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 1/30/2016.  
Subsequent reports are due every 12 calendar month(s).

\*\*\*\* Emission Unit Level \*\*\*\*



**Condition 39: Emission Point Definition By Emission Unit**  
Effective between the dates of 05/30/2013 and 05/29/2018

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 39.1(From Mod 0):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001

Height (ft.): 225

Diameter (in.): 120

NYTMN (km.): 4501.123 NYTME (km.): 589.333 Building: BLDG Z

**Item 39.2(From Mod 0):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00002

Emission Point: 00002

Height (ft.): 225

Diameter (in.): 120

NYTMN (km.): 4501.123 NYTME (km.): 589.333 Building: BLDG Z

**Condition 40: Process Definition By Emission Unit**  
Effective between the dates of 05/30/2013 and 05/29/2018

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 40.1(From Mod 2):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 001

Source Classification Code: 1-03-006-02

Process Description:

Process 001 consists of the burning of natural gas in two of the Cleaver Brooks boilers (Emission Sources 00001 & 00002), rated at 49.9 MM Btu/hr each, in Emission Unit U-00001, and are located in Building Z (Boiler House). The flue gases from these two boilers exit through a common stack, identified as Emission point 00001.

Emission Source/Control: 00001 - Combustion

Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00002 - Combustion

Design Capacity: 49.9 million Btu per hour

**Item 40.2(From Mod 2):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001



Process: 002 Source Classification Code: 1-03-004-02

Process Description:

Process 002 consists of the burning of # 6 residual oil in two of the Cleaver Brooks boilers (Emission Sources 00001 & 00002), rated at 49.9 MM Btu/hr each, in Emission Unit U-00001, and are located in Building Z (Power House). The flue gases from these two boilers exit through a common stack, identified as Emission point 00001.

Emission Source/Control: 00001 - Combustion  
Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00002 - Combustion  
Design Capacity: 49.9 million Btu per hour

**Item 40.3(From Mod 2):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 003 Source Classification Code: 1-03-006-02

Process Description:

Process 003 consists of the burning of # 2 distillate fuel oil in two of the Cleaver Brooks boilers (Emission Sources 00001 & 00002), rated at 49.9 MM Btu/hr each, in Emission Unit U-00001, and are located in Building Z (Power House). The flue gases from these two boilers exit through a common stack, identified as Emission point 00001.

Emission Source/Control: 00001 - Combustion  
Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00002 - Combustion  
Design Capacity: 49.9 million Btu per hour

**Item 40.4(From Mod 2):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002

Process: 010 Source Classification Code: 1-03-006-02

Process Description:

Process 010 consists of the burning of natural gas in three of the Cleaver Brooks boilers (Emission Sources 00003, 00004 & 00005), rated at 49.9 MM Btu/hr each, in Emission Unit U-00002, and are located in Building Z (Power House). The flue gases from these three boilers exit through a common stack, identified as Emission point 00002.

Emission Source/Control: 00003 - Combustion  
Design Capacity: 49.9 million Btu per hour



Emission Source/Control: 00004 - Combustion  
Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00005 - Combustion  
Design Capacity: 49.9 million Btu per hour

**Item 40.5(From Mod 2):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002  
Process: 020 Source Classification Code: 1-03-004-02  
Process Description:

Process 020 consists of the burning of # 6 residual oil in three of the Cleaver Brooks boilers (Emission Sources 00003, 00004 & 00005), rated at 49.9 MM Btu/hr each, in Emission Unit U-00002, and are located in Building Z (Power House). The flue gases from these three boilers exit through a common stack, identified as Emission point 00002.

Emission Source/Control: 00003 - Combustion  
Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00004 - Combustion  
Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00005 - Combustion  
Design Capacity: 49.9 million Btu per hour

**Item 40.6(From Mod 2):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002  
Process: 032 Source Classification Code: 1-03-006-02  
Process Description:

Process 030 consists of the burning of # 2 residual oil in three of the Cleaver Brooks boilers (Emission Sources 00003, 00004 & 00005), rated at 49.9 MM Btu/hr each, in Emission Unit U-00002, and are located in Building Z (Power House). The flue gases from these three boilers exit through a common stack, identified as Emission point 00002.

Emission Source/Control: 00003 - Combustion  
Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00004 - Combustion  
Design Capacity: 49.9 million Btu per hour

Emission Source/Control: 00005 - Combustion  
Design Capacity: 49.9 million Btu per hour



**Condition 1-1: Compliance Certification**  
Effective between the dates of 08/22/2013 and 05/29/2018

**Applicable Federal Requirement: 6 NYCRR 227-2.4 (c) (1) (ii)**

**Item 1-1.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 1-1.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

This condition applies to oil/gas fired mid-size boilers.

By switching from residual oil # 6 to Natural Gas, the facility chooses the fuel switching option under 6 NYCRR 227-2.5(a), that states that the owner or operator of an emission source subject to this Subpart may commit to burning a cleaner fuel between May 1st and September 30th of each year. Fuel switching must result in quantifiable annual NOx emissions equal to or less than the NOx emissions expected if the emission source complied with the applicable presumptive RACT emission limits set forth in section 227-2.4 of this Subpart.

The facility is subject to an upper NOx RACT emission limit of 0.20 pounds per million Btus. The owner or operator shall submit a testing protocol to the Department for approval a minimum of 30 days prior to any stack testing.

The compliance deadline, with the emission limitation listed in this condition, is July, 1 2014. Compliance with the monitoring, record keeping, or reporting requirements listed in this condition begins on July, 1 2014.

Upper Permit Limit: 0.20 pounds per million Btus

Reference Test Method: 40 CFR 60 Appendix A Method 7, 7E, or 19

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2014.

Subsequent reports are due every 6 calendar month(s).



**Condition 2-7: Compliance Certification**  
Effective between the dates of 11/17/2015 and 05/29/2018

**Applicable Federal Requirement: 6 NYCRR 227-2.4 (c) (1) (ii)**

**Item 2-7.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 2-7.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Emission Unit U-00001 consists of two Cleaver Brooks boilers (Emission Sources 00001 & 00002), rated at 49.9 MM Btu/hr each, capable of burning natural gas (Process 001); and # 6 residual fuel oil (Process 002) or #2 distillate fuel oil (Process 003). The flue gases from these two boilers exit through a common stack, identified as Emission point 00001. These two boilers are located in Building Z (Boiler House). NYC-HH - Kings County Hospital Center's boilers currently burn # 6 fuel oil as a secondary fuel to natural gas. After burners replacement, # 2 distillate fuel oil will be used instead of #6 residual fuel oil.

The owner or operator of a mid-size boiler must comply with the relevant presumptive RACT emission limit of 0.08 pounds per million Btus.

To meet this limitation, the facility chooses the fuel switching option under 6NYCRR 227-2.5(a), that states that the owner or operator of an emission source subject to this Subpart may commit to burning a cleaner fuel between May 1st and September 30th of each year. Fuel switching must result in quantifiable annual NOx emissions equal to or less than the NOx emissions expected if the emission source complied with the applicable presumptive RACT emission limits set forth in section 227-2.4 of this Subpart.

In order to comply with the NOx RACT, the facility will only burn Natural Gas during the period of May 1st to September 30th. Therefore, the facility will meet the RACT emission limit of 0.08 lbs of NOx per million Btus by taking the annual average of NOx emissions per million Btus.

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



The owner or operator shall submit a testing protocol to the Department for approval a maximum of 30 days prior to any stack testing. The facility must maintain records of its total NOx emissions on daily basis and quantity of annual NOx emissions rolled daily on-site for a period of minimum five years.

The facility will comply with this requirement when it transitions to the combustion of #2 fuel oil.

Upper Permit Limit: 0.08 pounds per million Btus  
Reference Test Method: 40 CFR 60 Appendix A Method 7, 7E, or 19  
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT  
Averaging Method: 1-HOUR AVERAGE  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 1/30/2016.  
Subsequent reports are due every 6 calendar month(s).

**Condition 1-2: Compliance Certification**  
**Effective between the dates of 08/22/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 227-2.5 (a)**

**Item 1-2.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 1-2.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

This condition applies to oil/gas fired mid-size boilers. By switching from residual oil # 6 to distillate oil # 2, the facility chooses the fuel switching option under 6 NYCRR 227-2.5(a), that states that the owner or operator of an emission source subject to this Subpart may commit to burning a cleaner fuel between May 1st and September 30th of each year. Fuel switching must result in quantifiable annual NOx emissions equal to or less than the NOx emissions expected if the emission source complied with the applicable presumptive RACT emission limits set forth in section 227-2.4 of this Subpart.

The facility is subject to a NOx limit is 0.20 pounds per million Btus due to fuel switching option. The owner or

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



operator shall submit a testing protocol to the Department for approval a minimum of 30 days prior to any stack testing. The facility must maintain records of its total NOx emissions and quantify of annual NOx emission rolled monthly on-site for a period of minimum five years.

NOx emissions would be calculated based on the following formula:

$$\text{NOx (lbs/mmBtu)} = ((A*(B) + C*(D)) / ((A*(E)+C*(F)));$$

where,

A = MGal of #6 Fuel Oil burned,

B = NOx Emission Factor for burning # 6 Fuel Oil in lbs/MGal (based on the latest facility stack test. A March 26, 2012 stack test noted an emission factor of 42.3 lbs/MGal.),

C = MMcf of Natural Gas burned,

D = NOx Emission factor for burning Natural Gas in lbs/MMcf (based on the latest facility stack test. A March 26, 2012 stack test noted an emission factor of 114.3 lbs/MMcf.),

E = 152 MMBtu/MGal; value for one MGal of #6 Fuel Oil burned (based on AP-42 value of 152,000 Btu/gal # 6 fuel oil burned)

F = 1020 MMBtu/MMcf; value for one MMcf Natural gas burned (based on AP-42 value of 1020 Btu/scf Natural Gas burned).

Upper Permit Limit: 0.20 pounds per million Btus  
Reference Test Method: 40 CFR 60 Appendix A Method 7, 7E, or 19  
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT  
Averaging Method: 1-HOUR AVERAGE  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 1/30/2014.  
Subsequent reports are due every 6 calendar month(s).

**Condition 1-3: Compliance Certification**  
**Effective between the dates of 08/22/2013 and 05/29/2018**

**Applicable Federal Requirement:6 NYCRR 227-2.4 (c) (1) (ii)**

**Item 1-3.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

New York State Department of Environmental Conservation

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 1-3.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

This condition applies to oil/gas fired mid-size boilers.

By switching from residual oil # 6 to Natural Gas, the facility chooses the fuel switching option under 6 NYCRR 227-2.5(a), that states that the owner or operator of an emission source subject to this Subpart may commit to burning a cleaner fuel between May 1st and September 30th of each year. Fuel switching must result in quantifiable annual NOx emissions equal to or less than the NOx emissions expected if the emission source complied with the applicable presumptive RACT emission limits set forth in section 227-2.4 of this Subpart.

The facility is subject to an upper NOx RACT emission limit of 0.20 pounds per million Btus. The owner or operator shall submit a testing protocol to the Department for approval a minimum of 30 days prior to any stack testing.

The compliance deadline, with the emission limitation listed in this condition, is July, 1 2014. Compliance with the monitoring, record keeping, or reporting requirements listed in this condition begins on July, 1 2014.

Upper Permit Limit: 0.20 pounds per million Btus

Reference Test Method: 40 CFR 60 Appendix A Method 7, 7E, or 19

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2014.

Subsequent reports are due every 6 calendar month(s).

**Condition 2-8: Compliance Certification**

**Effective between the dates of 11/17/2015 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 227-2.4 (c) (1) (ii)**

**Item 2-8.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):



CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 2-8.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Emission Unit U-00002 consists of three Cleaver Brooks boilers (Emission Sources 00003, 00004 & 00005), rated at 49.9 MM Btu/hr each, capable of burning natural gas (Process 010); and # 6 residual fuel oil (Process 020) or #2 distillate fuel oil (Process 032). The flue gases from these three boilers exit through a common stack, identified as Emission point 00002. These three boilers are located in Building Z (Boiler House). NYC-HH - Kings County Hospital Center's boilers currently burn # 6 fuel oil as a secondary fuel to natural gas. After burners replacement, # 2 distillate fuel oil will be used instead of #6 residual fuel oil.

The owner or operator of a mid-size boiler must comply with the relevant presumptive RACT emission limit of 0.08 pounds per million Btus.

To meet this limitation, the facility chooses the fuel switching option under 6NYCRR 227-2.5(a), that states that the owner or operator of an emission source subject to this Subpart may commit to burning a cleaner fuel between May 1st and September 30th of each year. Fuel switching must result in quantifiable annual NOx emissions equal to or less than the NOx emissions expected if the emission source complied with the applicable presumptive RACT emission limits set forth in section 227-2.4 of this Subpart.

In order to comply with the NOx RACT, the facility will only burn Natural Gas during the period of May 1st to September 30th. Therefore, the facility will meet the RACT emission limit of 0.08 lbs of NOx per million Btus by taking the annual average of NOx emissions per million Btus.

The owner or operator shall submit a testing protocol to the Department for approval a maximum of 30 days prior to any stack testing. The facility must maintain records of its total NOx emissions on daily basis and quantity of annual NOx emissions rolled daily on-site for a period of minimum five years.

The facility will comply with this requirement when it transitions to the combustion of #2 fuel oil.

**New York State Department of Environmental Conservation**

Permit ID: 2-6104-00249/00004

Facility DEC ID: 2610400249



Upper Permit Limit: 0.08 pounds per million Btus  
Reference Test Method: 40 CFR 60 Appendix A Method 7, 7E, or 19  
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT  
Averaging Method: 1-HOUR AVERAGE  
Reporting Requirements: SEMI-ANNUALLY (ANNIVERSARY)  
Initial Report Due: 12/29/2015 for the period 11/17/2015 through 11/29/2015

**Condition 1-4: Compliance Certification**  
**Effective between the dates of 08/22/2013 and 05/29/2018**

**Applicable Federal Requirement: 6 NYCRR 227-2.5 (a)**

**Item 1-4.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 1-4.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

This condition applies to oil/gas fired mid-size boilers. By switching from residual oil # 6 to distillate oil # 2, the facility chooses the fuel switching option under 6 NYCRR 227-2.5(a), that states that the owner or operator of an emission source subject to this Subpart may commit to burning a cleaner fuel between May 1st and September 30th of each year. Fuel switching must result in quantifiable annual NOx emissions equal to or less than the NOx emissions expected if the emission source complied with the applicable presumptive RACT emission limits set forth in section 227-2.4 of this Subpart.

The facility is subject to a NOx limit is 0.20 pounds per million Btus due to fuel switching option. The owner or operator shall submit a testing protocol to the Department for approval a minimum of 30 days prior to any stack testing. The facility must maintain records of its total NOx emissions and quantify of annual NOx emission rolled monthly on-site for a period of minimum five years.

NOx emissions would be calculated based on the following formula:

$$\text{NOx (lbs/mmBtu)} = ((A*(B) + C*(D)) / ((A*(E)+C*(F)));$$

where,

A = MGal of #6 Fuel Oil burned,

**New York State Department of Environmental Conservation**

**Permit ID: 2-6104-00249/00004**

**Facility DEC ID: 2610400249**



B = NO<sub>x</sub> Emission Factor for burning # 6 Fuel Oil in lbs/MGal (based on the latest facility stack test. A March 26, 2012 stack test noted an emission factor of 42.3 lbs/MGal.),

C = MMcf of Natural Gas burned,

D = NO<sub>x</sub> Emission factor for burning Natural Gas in lbs/MMcf (based on the latest facility stack test. A March 26, 2012 stack test noted an emission factor of 114.3 lbs/MMcf.),

E = 152 MMBtu/MGal; value for one MGal of #6 Fuel Oil burned (based on AP-42 value of 152,000 Btu/gal # 6 fuel oil burned)

F = 1020 MMBtu/MMcf; value for one MMcf Natural gas burned (based on AP-42 value of 1020 Btu/scf Natural Gas burned).

Upper Permit Limit: 0.20 pounds per million Btus  
Reference Test Method: 40 CFR 60 Appendix A Method 7, 7E, or 19  
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT  
Averaging Method: 1-HOUR AVERAGE  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 1/30/2014.  
Subsequent reports are due every 6 calendar month(s).



**STATE ONLY ENFORCEABLE CONDITIONS**  
**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**  
**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Emergency Defense - 6 NYCRR 201-1.5**

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;

(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and



standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.**

**Condition 45: Contaminant List**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable State Requirement:ECL 19-0301**

**Item 45.1:**  
Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 007446-09-5  
Name: SULFUR DIOXIDE

CAS No: 0NY075-00-0  
Name: PARTICULATES

CAS No: 0NY210-00-0  
Name: OXIDES OF NITROGEN

**Condition 46: Malfunctions and start-up/shutdown activities**  
**Effective between the dates of 05/30/2013 and 05/29/2018**

**Applicable State Requirement:6 NYCRR 201-1.4**

**Item 46.1:**  
(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.



(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.