



**New York State Department of Environmental Conservation**  
**Facility DEC ID: 2610500262**



By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator:            JOHN F CRYAN  
   DIVISION OF ENVIRONMENTAL PERMITS  
   ONE HUNTERS POINT PLAZA, 47-40 21ST STREET  
   LONG ISLAND CITY, NY 11101-5407

Authorized Signature: \_\_\_\_\_ Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_



**Notification of Other State Permittee Obligations**

**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



**LIST OF CONDITIONS**

**DEC GENERAL CONDITIONS**

**General Provisions**

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Applications for permit renewals, modifications and transfers

Applications for Permit Renewals and Modifications

Permit modifications, suspensions or revocations by the Department

Permit Modifications, Suspensions and Revocations by the Department

**Facility Level**

Submission of application for permit modification or renewal-REGION 2  
HEADQUARTERS



**DEC GENERAL CONDITIONS**

**\*\*\*\* General Provisions \*\*\*\***

**For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions**

**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**  
**Applicable State Requirement: ECL 19-0305**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**  
**Applicable State Requirement: ECL 3-0301.2(m)**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 3: Applications for permit renewals, modifications and transfers**  
**Applicable State Requirement: 6NYCRR 621.11**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 3.3:**



**New York State Department of Environmental Conservation**  
**Facility DEC ID: 2610500262**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 4: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 4.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 4.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 4.3:**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 5: Permit modifications, suspensions or revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 5.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**Condition 6: Permit Modifications, Suspensions and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Item 6.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;

**New York State Department of Environmental Conservation**  
**Facility DEC ID: 2610500262**



- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 7: Submission of application for permit modification or renewal-REGION 2 HEADQUARTERS**  
**Applicable State Requirement: 6NYCRR 621.6(a)**

**Item 7.1:**

Submission of applications for permit modification or renewal are to be submitted to:  
NYSDEC Regional Permit Administrator  
Region 2 Headquarters  
Division of Environmental Permits  
1 Hunters Point Plaza, 4740 21st Street  
Long Island City, NY 11101-5407  
(718) 482-4997



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: NYC TRANSIT AUTHORITY

2 BROADWAY  
NEW YORK, NY 10004

METROPOLITAN TRANSPORTATION AUTHORITY

347 MADISON AVE  
NEW YORK, NY 10017

Facility: NYC-TA EAST NY BUS DEPOT & SHOPS

1 JAMAICA AVE  
BROOKLYN, NY 11207

Authorized Activity By Standard Industrial Classification Code:

4111 - LOCAL AND SUBURBAN TRANSIT  
4119 - LOCAL PASSENGER TRANSPORTATION

Permit Effective Date:

Permit Expiration Date:



**LIST OF CONDITIONS**

**FEDERALLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 1 6NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6NYCRR 201-6.5(a)(7): Fees
- 3 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 4 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 6 6NYCRR 201-6.5(e): Compliance Certification
- 7 6NYCRR 202-2.1: Compliance Certification
- 8 6NYCRR 202-2.5: Recordkeeping requirements
- 9 6NYCRR 215: Open Fires Prohibited at Industrial and Commercial Sites
- 10 6NYCRR 200.7: Maintenance of Equipment
- 11 6NYCRR 201-1.7: Recycling and Salvage
- 12 6NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6NYCRR 201-3.2(a): Exempt Sources - Proof of Eligibility
- 14 6NYCRR 201-3.3(a): Trivial Sources - Proof of Eligibility
- 15 6NYCRR 201-6.5(a)(4): Standard Requirement - Provide Information
- 16 6NYCRR 201-6.5(a)(8): General Condition - Right to Inspect
- 17 6NYCRR 201-6.5(d)(5): Standard Requirements - Progress Reports
- 18 6NYCRR 201-6.5(f)(6): Off Permit Changes
- 19 6NYCRR 202-1.1: Required Emissions Tests
- 20 6NYCRR 211.3: Visible Emissions Limited
- 21 40CFR 68: Accidental release provisions.
- 22 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 23 6NYCRR 201-6: Emission Unit Definition
- 24 6NYCRR 201-6: Compliance Plan
- 25 6NYCRR 211.4: VOC prohibited
- 26 6NYCRR 225.1(a)(3): Compliance Certification
- 27 6NYCRR 226: Compliance Certification
- 28 6NYCRR 228.1(a): Permit Requirements
- 29 6NYCRR 228.6: Prohibition of sale
- 30 6NYCRR 228.10: Compliance Certification
- 31 6NYCRR 230.2(b): Gasoline Tanks  $\geq$  250 Gallons Installed after 1/1/79 Required Stage 1 in NYCMA
- 32 6NYCRR 230.2(k): Compliance Certification
- 33 40CFR 82, Subpart B: Servicing of Motor Vehicle Air Conditioners (MVAC)

**Emission Unit Level**

- 34 6NYCRR 201-6: Emission Point Definition By Emission Unit
- 35 6NYCRR 201-6: Process Definition By Emission Unit

**EU=B-00001**



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

- 36 6NYCRR 227-1.3: Compliance Certification
- 37 6NYCRR 227.2(b)(1): Compliance Certification
- 38 40CFR 60.40c, NSPS Subpart Dc: Applicability of this Subpart to this emission source
- 39 40CFR 60.43c(c), NSPS Subpart Dc: Compliance Certification
- 40 40CFR 60.47c, NSPS Subpart Dc: Opacity monitoring requirements.
- 41 40CFR 60.47c, NSPS Subpart Dc: Opacity monitoring requirements.
- 42 40CFR 60.48c(i), NSPS Subpart Dc: Compliance Certification

**EU=B-00001,Proc=B01,ES=0BLR1**

- 43 6NYCRR 227-2.4(d): Compliance Certification

**EU=B-00001,Proc=B01,ES=0BLR2**

- 44 6NYCRR 227-2.4(d): Compliance Certification

**EU=B-00001,Proc=B01,ES=0BLR3**

- 45 6NYCRR 227-2.4(d): Compliance Certification

**EU=B-00001,Proc=B02,ES=0BLR1**

- 46 6NYCRR 227-2.4(d): Compliance Certification

**EU=B-00001,Proc=B02,ES=0BLR2**

- 47 6NYCRR 227-2.4(d): Compliance Certification

**EU=B-00001,Proc=B02,ES=0BLR3**

- 48 6NYCRR 227-2.4(d): Compliance Certification

**EU=E-I0001**

- 49 6NYCRR 227-1.3(a): Compliance Certification
- 50 6NYCRR 227.2(b)(1): Compliance Certification

**EU=G-AS001**

- 51 6NYCRR 230.2(d)(1): Stage I and II requirements for tanks constructed, replaced, or substantially modified after June 27, 1987
- 52 6NYCRR 230.2(f): Requirements for gasoline transport vehicles delivering to Stage I controlled dispensing sites.
- 53 6NYCRR 230.2(g): Compliance Certification
- 54 6NYCRR 230.2(k): Compliance Certification
- 55 6NYCRR 230.2(k): Compliance Certification
- 56 6NYCRR 230.5(d): Compliance Certification

**EU=P-B0001**

- 57 6NYCRR 228.2: Compliance Certification
- 58 6NYCRR 228.3(a): Recordkeeping, Reports of VOCs - EU Level
- 59 6NYCRR 228.4: Compliance Certification
- 60 6NYCRR 228.5(a): Compliance Certification
- 61 6NYCRR 228.5(b): Use of Methods 311 or 24.

**New York State Department of Environmental Conservation**  
**Permit ID: 2-6105-00262/00009      Facility DEC ID: 2610500262**



- 62 6NYCRR 228.5(d): Department access to obtain samples.
- 63 6NYCRR 228.8: Compliance Certification
- 64 6NYCRR 228.8: Compliance Certification
- 65 6NYCRR 228.8: Compliance Certification
- 66 6NYCRR 228.8: Compliance Certification

**STATE ONLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 67 ECL 19-0301: Contaminant List
- 68 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 69 6NYCRR 211.2: Air pollution prohibited



**FEDERALLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.**

**Item A: Emergency Defense - 6NYCRR Part 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

**Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)**

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)**

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

**Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6NYCRR Part 201-6.5(a)(5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



order to maintain compliance with the conditions of this permit.

**Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

**Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item L: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

**The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.**

**Condition 1: Acceptable Ambient Air Quality  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 200.6**

**Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Condition 2: Fees**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(a)(7)**

**Item 2.1:**

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

**Condition 3: Recordkeeping and reporting of compliance monitoring**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(c)**

**Item 3.1:**

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

**Condition 4: Monitoring, Related Recordkeeping, and Reporting Requirements.**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)**

**Item 4.1:**

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

**Condition 5: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)**

**Item 5.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 5.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant or a toxic air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If any of the above conditions are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) through (4) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraph (1) through (4) of this section must also be identified in the 6 month monitoring report required above.

If the permittee seeks to have a violation excused as provided in 201-1.4, the permittee shall report such violations as required under 201-1.4(b). However, in no case may reports of any deviation be on a less frequent basis than those described in paragraphs (1) through (4) above. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
Subsequent reports are due every 6 calendar month(s).

**Condition 6: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(e)**

**Item 6.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 6.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



- i. Compliance certifications shall contain:
  - the identification of each term or condition of the permit that is the basis of the certification;
  - the compliance status;
  - whether compliance was continuous or intermittent;
  - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
  - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;
  - and
  - such additional requirements as may be specified elsewhere in this permit related to compliance certification.
  
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.
  
- iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.
  
- iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2  
Air Compliance Branch  
290 Broadway

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



New York, NY 10007-1866

The address for the RAPCE is as follows:

Hunters Point Plaza  
47-40 21st Street  
Long Island City, NY 11101-5407

The address for the BQA is as follows:

NYSDEC  
Bureau of Quality Assurance  
625 Broadway  
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 45 days after the reporting period.  
The initial report is due 8/14/2008.  
Subsequent reports are due on the same day each year

**Condition 7: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 202-2.1**

**Item 7.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 7.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

**Condition 8: Recordkeeping requirements  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 202-2.5**



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Item 8.1:**

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

**Condition 9: Open Fires Prohibited at Industrial and Commercial Sites  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 215**

**Item 9.1:**

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, refuse, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT  
TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

**The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period. [NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]**

**Condition 10: Maintenance of Equipment  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 200.7**

**Item 10.1:**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Condition 11: Recycling and Salvage  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-1.7**



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Item 11.1:**

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

**Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-1.8**

**Item 12.1:**

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 13: Exempt Sources - Proof of Eligibility**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-3.2(a)**

**Item 13.1:**

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

**Condition 14: Trivial Sources - Proof of Eligibility**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-3.3(a)**

**Item 14.1:**

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

**Condition 15: Standard Requirement - Provide Information**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(a)(4)**



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Item 15.1:**

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

**Condition 16: General Condition - Right to Inspect  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(a)(8)**

**Item 16.1:**

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

**Condition 17: Standard Requirements - Progress Reports  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(d)(5)**

**Item 17.1:**

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

**New York State Department of Environmental Conservation**

Permit ID: 2-6105-00262/00009

Facility DEC ID: 2610500262



**Condition 18: Off Permit Changes**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6.5(f)(6)**

**Item 18.1:**

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

**Condition 19: Required Emissions Tests**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 202-1.1**

**Item 19.1:**

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time. Such person shall bear the cost of measurement and preparing the report of measured emissions. Failure of such person to submit a report acceptable to the commissioner within the time stated shall be sufficient reason for the commissioner to suspend or deny a certificate to operate.

**Condition 20: Visible Emissions Limited**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 211.3**

**Item 20.1:**

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



minute period per hour of not more than 57 percent opacity.

**Condition 21: Accidental release provisions.  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 68**

**Item 21.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
  - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
  - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center  
C/O CSC  
8400 Corporate Dr  
Carrollton, Md. 20785

**Condition 22: Recycling and Emissions Reduction  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 82, Subpart F**

**Item 22.1:**

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**The following conditions are subject to annual compliance certification requirements  
for Title V permits only.**

**Condition 23: Emission Unit Definition  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6**

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



**Item 23.1:**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: B-00001

Emission Unit Description:

THREE BOILERS VENTING TO INDIVIDUAL STACKS COMPRISE THIS EMISSION UNIT. EACH BOILER IS CAPABLE OF FIRING #6 FUEL OIL AND NATURAL GAS AND IS RATED AT 47.263 MMBTU/HR. THE BOILERS AND EMISSION POINTS ARE LOCATED IN THE BOILER HOUSE.

Building(s): BH

**Item 23.2:**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: E-I0001

Emission Unit Description:

Emergency Generators

2007 renewal, 2 more added.

Also, there are 2 more exempt generators, which were participating in CDRP Program before. So all together, they have 5 exempt generators.

No emissions change than original emissions indicated.

Building(s): MAINT

**Item 23.3:**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: G-AS001

Emission Unit Description:

GASOLINE DISPENSING STATION CONSISTING OF TWO DISPENSERS EQUIPPED WITH STAGE-I AND STAGE-II CONTROLS (EMISSION UNIT ID STAG11 AND STAG2); TWO DISPENSING PUMPS (EMISSION UNIT ID PUMP1 AND PUMP2); AND ONE GASOLINE STORAGE TANK (EMISSION UNIT ID TANK1). THE GASOLINE DISPENSING STATION WAS INSTALLED DECEMBER 1993.

Building(s): DEPOT

**Item 23.4:**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: P-B0001

Emission Unit Description:

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



THERE ARE THREE PAINT BOOTHS WHICH COMPRISE THIS EMISSION UNIT. HOWEVER, DUE TO A LIMITED AIR SUPPLY, ONLY TWO BOOTHS ARE CAPABLE OF OPERATING AT ANY ONE TIME. EACH BOOTH HAS TWO WATER CURTAINS FOR CONTROL OF PARTICULATE EMISSIONS. THE BOOTHS ARE USED FOR PAINTING BUSES.

Building(s): PB

**Condition 24: Compliance Plan**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6**

**Item 24.1:**

Compliance will be achieved according to the following schedule for the Facility:

Consent Order: 070614-256

Progress Report Begin Date: 12/01/2007

**Item 24.2:**

Remedial Measure:

Schedule Date: 12/01/2007

Adhere to compliance schedule of the consent order

**Condition 25: VOC prohibited**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 211.4**

**Item 25.1:**

The use of Volatile Organic Compounds to liquefy asphalt used for paving is prohibited, except for:

- (1) asphalt used in the production of long-life stockpile material for pavement patching and repair;
- (2) asphalt applied at low ambient temperature from October 16th to May 1st; and
- (3) asphalt used as a penetrating prime coat for the purpose of preparing an untreated absorbent surface to receive an asphalt surface.

**Condition 26: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 225.1(a)(3)**

**Item 26.1:**



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

The Compliance Certification activity will be performed for the Facility.

**Item 26.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

No person shall sell, offer for sale, purchase or use any residual oil which has sulfur content greater than 0.30 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site for a minimum of five years after the date of the last entry.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: NUMBER 6 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.30 percent by weight

Reference Test Method: EPA approved

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 27: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 226**

**Item 27.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

**Item 27.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

6NYCRR 226. Requirements for Cold Cleaning Degreasers  
(For Title V after 12/31/2003)

A. Equipment Specifications

The following types of control equipment must be used when conducting cold cleaning degreasing, solvent metal

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



cleaning:

- (1) A cover which can be operated easily.
- (2) An internal drainage facility (under cover), if practical.
- (3) A control system that limits VOC emissions to those achievable with equipment having a freeboard ratio greater than or equal to 0.5, or a water cover when the solvent is insoluble in and heavier than water. This does not apply to remote reservoir degreasers.
- (4) Solvent with a vapor pressure of 1.0 mm Hg, or less, at 20 C.

**B. Operating Requirements:**

When cold cleaning, the clean parts must be drained at least 15 seconds or until dripping ceases.

**C. General Requirements:**

A Person conducting solvent metal cleaning must:

- (1) Store solvent in covered containers and transfer or dispose of waste solvent in such a manner that less than 20 percent of the waste solvent (by weight) can evaporate into the atmosphere.
- (2) Maintain equipment to minimize leaks and fugitive emissions.
- (3) Display at the equipment location a conspicuous summary of proper operating procedures consistent with minimizing emissions of VOCs.
- (4) Keep the degreaser cover closed except when:
  - (a) parts are being placed into or being removed from the degreaser;
  - (b) adding or removing solvent from the degreaser;
  - (c) no solvent is in the degreaser; or
  - (d) when manually cleaning metal parts in the cold cleaning degreaser.
- (5) Create and retain a record of solvent consumption for five years. This record must be made available to the Department upon request.
- (6) Not clean sponges, fabric, wood, leather, paper products and other absorbent materials in a degreaser.
- (7) If using a cold cleaning degreaser that is subject to paragraph 226.3(a)(4), retain a record of the following three items for five years and provide these records to the Department upon request. An invoice, a bill of sale, a



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

certificate covering multiple sales, a Material Safety Data Sheet (MSDS), or other appropriate documentation acceptable to the Department may be used to comply with this requirement.

(a) the name and address of the solvent supplier;

(b) the type of solvent including the product or vendor identification number; and

(c) the vapor pressure of the solvent measured in mm Hg at 20 °C (68 °F).

(8) Include in the semiannual monitoring report and annual compliance certifications (required of all permittees subject to Title V) the solvent consumption required under

(5) above, as well as a statement that the permittee's obligations under items (1) through (7) above have been met for the period of the report or certification.. This statement must be based on the permittees observations on a daily basis that the operation of the solvent metal cleaning process has met the above criteria. The permittee must maintain a log of instances when the above have not been met, and such statement must summarize these instances.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 28: Permit Requirements**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.1(a)**

**Item 28.1:**

**Every owner or operator of a facility applying for a Title V facility permit or State facility permit, including modifications, must:**

**(1) identify the method(s) (e.g., sampling, testing, etc.), if any, that will be used to comply with the requirements of this Part;**

**(2) where applicable, provide a process specific reasonably available control technology (RACT) determination under subdivision 228.3(e) unless the RACT demonstration has already been approved by the Department and the Administrator and a reevaluation frequency for the RACT determination is included in the facility's existing Title V facility permit or State facility permit; and**

**(3) where applicable, submit evidence to demonstrate that the shut down of a natural gas fired VOC incinerator pursuant to subdivision 228.3(b) will not jeopardize air quality.**



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Condition 29: Prohibition of sale  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.6**

**Item 29.1:**

(A) No person shall sell, specify, or require for use the application of a coating on a part or product at a facility with a coating line described in table 1 or 2 in section 228.7 or 228.8 of 6 NYCRR 228 if such use is prohibited by any of the provisions of this Part. The prohibition shall apply to all written or oral contracts under the terms of which any coating is to be applied to any part or product at this facility. This prohibition shall not apply to the following:

- (1) coatings utilized at surface coating lines where control equipment has been installed to meet the maximum permitted VOC content limitations specified in tables 1 and 2 of sections 228.7 or 228.8 of 6 NYCRR Part 228;
- (2) coatings utilized at surface coating lines where a coating system is used which meets the requirements specified in section 228.3(d) of 6 NYCRR Part 228; and
- (3) coatings utilized at surface coating lines that have been granted variances for reasons of technological and economic feasibility per section 228.3(e) of 6 NYCRR Part 228.

(B) Any person selling a coating for use in a coating line subject to this Part must, upon request, provide the user with certification of the VOC content of the coating supplied.

**Condition 30: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.10**

**Item 30.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
CAS No: 0NY998-00-0 VOC

**Item 30.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES  
Monitoring Description:  
Within the work area(s) associated with a coating line,  
the owner or operator of this facility subject to 6NYCRR  
Part 228 must:



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

- (a) use closed, non-leaking containers to store or dispose of cloth or other absorbent applicators impregnated with VOC solvents that are used for surface preparation, cleanup or coating removal;
- (b) store in closed, non-leaking containers spent or fresh VOC solvents to be used for surface preparation, cleanup or coating removal;
- (c) not use VOC solvents to cleanup spray equipment unless equipment is used to collect the cleaning compounds and to minimize VOC evaporation;
- (d) not use open containers to store or dispense surface coatings and/or inks unless production, sampling, maintenance or inspection procedures require operational access. This provision does not apply to the actual device or equipment designed for the purpose of applying a coating material to a substrate. These devices may include, but are not limited to spray guns, flow coaters, dip tanks, rollers, knife coaters, and extrusion coaters;
- (e) not use open containers to store or dispose of spent surface coatings, or spent VOC solvents.
- (f) minimize spills during the handling and transfer of coatings and VOC solvents; and

All associated coating line work area(s) within the facility shall be inspected daily to determine if there are any open containers present, and that only acceptable spray gun cleaning methods were utilized. A log book shall be maintained to record these inspections and their results. The log book shall include the following information:

- date and time of inspection
- items or areas observed
- corrective measures taken, if necessary

Monitoring Frequency: DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Condition 31: Gasoline Tanks  $\geq$  250 Gallons Installed after 1/1/79  
Required Stage 1 in NYCMA  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 230.2(b)**

**Item 31.1:**

Gasoline tanks greater than or equal to 250 gallons and installed after January 1, 1979 are required to install Stage I vapor collection systems in NYCMA.

**Condition 32: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 230.2(k)**

**Item 32.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 32.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners and/or operators of stage II systems must perform dynamic pressure tests at 5 year intervals after commencing operations. The back pressure during the dynamic back pressure tests must not exceed 0.45 inches of water column gauge at a flow rate of 60 cubic feet per hour or 0.95 inches of water column gauge at a flow rate of 100 cubic feet per hour.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 33: Servicing of Motor Vehicle Air Conditioners (MVAC)  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 82, Subpart B**

**Item 33.1:**

If the permittee performs a service on motor (fleet) vehicles when this service involves ozone-depleting substance refrigerant (or regulated substitute substance) in the motor vehicle air conditioner (MVAC), the permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include the air-tight sealed refrigeration system used as refrigerated cargo, or system used on passenger buses using HCFC-22 refrigerant.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 34: Emission Point Definition By Emission Unit  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6**

**Item 34.1:**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: B-00001

Emission Point: BH001

Height (ft.): 67                      Diameter (in.): 36  
NYTMN (km.): 4503.623    NYTME (km.): 593.133    Building: BH

Emission Point: BH002

Height (ft.): 67                      Diameter (in.): 36  
NYTMN (km.): 4503.323    NYTME (km.): 593.133    Building: BH

Emission Point: BH003

Height (ft.): 67                      Diameter (in.): 36  
NYTMN (km.): 4503.323    NYTME (km.): 593.133    Building: BH

**Item 34.2:**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: G-AS001

Emission Point: GAS01

Height (ft.): 3                      Diameter (in.): 3  
NYTMN (km.): 4503.1    NYTME (km.): 593.1    Building: DEPOT

Emission Point: GAS02

Height (ft.): 3                      Diameter (in.): 3  
NYTMN (km.): 4503.1    NYTME (km.): 593.1    Building: DEPOT

Emission Point: GAS03

Height (ft.): 76                      Diameter (in.): 3  
NYTMN (km.): 4503.1    NYTME (km.): 593.1    Building: DEPOT

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



**Item 34.3:**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: P-B0001

Emission Point: PB001

Height (ft.): 60 Diameter (in.): 24  
NYTMN (km.): 4504.623 NYTME (km.): 593.133 Building: PB

Emission Point: PB002

Height (ft.): 60 Diameter (in.): 24  
NYTMN (km.): 4503.623 NYTME (km.): 593.133 Building: PB

Emission Point: PB003

Height (ft.): 60 Diameter (in.): 24  
NYTMN (km.): 4503.623 NYTME (km.): 593.133 Building: PB

Emission Point: PB004

Height (ft.): 60 Diameter (in.): 24  
NYTMN (km.): 4503.623 NYTME (km.): 593.133 Building: PB

Emission Point: PB005

Height (ft.): 60 Diameter (in.): 24  
NYTMN (km.): 4503.623 NYTME (km.): 593.133 Building: PB

Emission Point: PB006

Height (ft.): 60 Diameter (in.): 24  
NYTMN (km.): 4503.623 NYTME (km.): 593.133 Building: PB

**Condition 35: Process Definition By Emission Unit  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 201-6**

**Item 35.1:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: B-00001

Process: B01

Source Classification Code: 1-03-004-01

Process Description: FIRING #6 FUEL OIL IN THE THREE BOILERS.

Emission Source/Control: 0BLR1 - Combustion

Design Capacity: 47.263 million Btu per hour

Emission Source/Control: 0BLR2 - Combustion

Design Capacity: 47.263 million Btu per hour

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



Emission Source/Control: 0BLR3 - Combustion

Design Capacity: 47.263 million Btu per hour

**Item 35.2:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: B-00001

Process: B02

Source Classification Code: 1-03-006-02

Process Description: FIRING NATURAL GAS IN THE THREE BOILERS.

Emission Source/Control: 0BLR1 - Combustion

Design Capacity: 47.263 million Btu per hour

Emission Source/Control: 0BLR2 - Combustion

Design Capacity: 47.263 million Btu per hour

Emission Source/Control: 0BLR3 - Combustion

Design Capacity: 47.263 million Btu per hour

**Item 35.3:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: E-I0001

Process: EG1

Source Classification Code: 1-03-004-01

Process Description: Emergency Generators burning distillate oil

Emission Source/Control: 1EG01 - Combustion

Design Capacity: 125 kilowatts

**Item 35.4:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: G-AS001

Process: ST1

Source Classification Code: 4-06-004-01

Process Description:

FILLING UNDERGROUND GASOLINE STORAGE TANK  
EQUIPPED WITH STAGE I VAPOR CONTROL.

Emission Source/Control: STAG1 - Control

Control Type: VAPOR LOCK BALANCE RECOVERY SYSTEM

Emission Source/Control: TANK1 - Process

Design Capacity: 4,000 barrel year

**Item 35.5:**

This permit authorizes the following regulated processes for the cited Emission Unit:

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



Emission Unit: G-AS001

Process: ST2

Source Classification Code: 4-06-006-03

Process Description:

GASOLINE REFUELING OF VEHICLES WITH STAGE  
II VAPOR CONTROL.

Emission Source/Control: STAG2 - Control

Control Type: VAPOR RECOVERY SYS(INCL.  
CONDENSERS,HOODING, OTHER ENCLOSURES)

Emission Source/Control: PUMP1 - Process

Emission Source/Control: PUMP2 - Process

**Item 35.6:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: G-AS001

Process: ST3

Source Classification Code: 4-06-006-02

Process Description:

VEHICLE FUELING SPILL LOSSES ASSOCIATED  
WITH GASOLINE DISPENSING.

Emission Source/Control: PUMP1 - Process

Emission Source/Control: PUMP2 - Process

**Item 35.7:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: P-B0001

Process: PB1

Source Classification Code: 4-02-016-01

Process Description: SPRAY PAINTING OF BUSES.

Emission Source/Control: BTH01 - Control

Control Type: WATER CURTAIN

Emission Source/Control: BTH02 - Control

Control Type: WATER CURTAIN

Emission Source/Control: BTH03 - Control

Control Type: WATER CURTAIN

Emission Source/Control: BTH04 - Control

Control Type: WATER CURTAIN



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Emission Source/Control: BTH05 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: BTH06 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: PSB01 - Process

**Item 35.8:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: P-B0001  
Process: PB2  
Source Classification Code: 3-14-015-62  
Process Description: PAINT GUN AND LINE SOLVENT CLEANING.

Emission Source/Control: BTH01 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: BTH02 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: BTH03 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: BTH04 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: BTH05 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: BTH06 - Control  
Control Type: WATER CURTAIN

Emission Source/Control: PSB01 - Process

**Condition 36: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-1.3**

**Item 36.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

**Item 36.2:**

Compliance Certification shall include the following monitoring:

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired boilers which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack for each boiler which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- date and time of day
- observer's name
- identity of emission point
- weather condition
- was a plume observed?

Inclement weather conditions shall be recorded for those days when observations are prohibited. This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

\*\* NOTE \*\* Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 37: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227.2(b)(1)**

**Item 37.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 37.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Parameter Monitored: PARTICULATES  
Upper Permit Limit: 0.10 pounds per million Btus  
Reference Test Method: Method 5  
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT  
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST  
METHOD INDICATED  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
Subsequent reports are due every 6 calendar month(s).

**Condition 38: Applicability of this Subpart to this emission source  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 60.40c, NSPS Subpart Dc**

**Item 38.1:**

This Condition applies to Emission Unit: B-00001

**Item 38.2:**

This emission source is subject to the applicable General Provisions of 40 CFR 60 Subpart Dc. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements.

**Condition 39: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 60.43c(c), NSPS Subpart Dc**

**Item 39.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 39.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

On and after the date on which the initial performance test is completed or required to be completed under §60.8 of this part, whichever date comes first, no owner or operator of an affected facility that combusts coal, wood or oil and has a heat input capacity of 30 million BTU per

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



hour or greater shall cause to be discharged into the atmosphere from an affected facility any gases that exhibit greater than 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity.

Parameter Monitored: OPACITY  
Upper Permit Limit: 20.0 percent  
Monitoring Frequency: CONTINUOUS  
Averaging Method: 6 MINUTE AVERAGE  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
Subsequent reports are due every 6 calendar month(s).

**Condition 40: Opacity monitoring requirements.  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 60.47c, NSPS Subpart Dc**

**Item 40.1:**

This Condition applies to Emission Unit: B-00001

**Item 40.2:**

All CEMs measuring opacity shall be operated in accordance with Appendix B of this part 40 CFR 60. The span value shall be between 60% and 80%.

**Condition 41: Opacity monitoring requirements.  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 60.47c, NSPS Subpart Dc**

**Item 41.1:**

This Condition applies to Emission Unit: B-00001

**Item 41.2:**

Facilities combusting coal, residual oil, and wood, subject to section 40 CFR 60-Dc.43c shall install, calibrate, maintain, and operate CEMs for opacity.

**Condition 42: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 60.48c(i), NSPS Subpart Dc**

**Item 42.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



**Item 42.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record, for determining compliance with the NSPS requirements.

**\*\* NOTE\*\*** Records shall be maintained for a minimum of five years to achieve compliance with the requirements of Title V.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 43: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-2.4(d)**

**Item 43.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

Process: B01

Emission Source: OBLR1

**Item 43.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Reports due 30 days after the reporting period.  
Subsequent reports are due every 12 calendar month(s).

**Condition 44: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-2.4(d)**

**Item 44.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

Process: B01

Emission Source: 0BLR2

**Item 44.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

**Condition 45: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-2.4(d)**

**Item 45.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

Process: B01

Emission Source: 0BLR3

**Item 45.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
Subsequent reports are due every 12 calendar month(s).

**Condition 46: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-2.4(d)**

**Item 46.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001  
Process: B02                      Emission Source: 0BLR1

**Item 46.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
Subsequent reports are due every 12 calendar month(s).

**Condition 47: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-2.4(d)**

**Item 47.1:**

The Compliance Certification activity will be performed for:



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Emission Unit: B-00001

Process: B02

Emission Source: 0BLR2

**Item 47.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

**Condition 48: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-2.4(d)**

**Item 48.1:**

The Compliance Certification activity will be performed for:

Emission Unit: B-00001

Process: B02

Emission Source: 0BLR3

**Item 48.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Subsequent reports are due every 12 calendar month(s).

**Condition 49: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227-1.3(a)**

**Item 49.1:**

The Compliance Certification activity will be performed for:

Emission Unit: E-I0001

**Item 49.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: DAILY

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 50: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 227.2(b)(1)**

**Item 50.1:**

The Compliance Certification activity will be performed for:

Emission Unit: E-I0001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



**Item 50.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 51: Stage I and II requirements for tanks constructed, replaced, or substantially modified after June 27, 1987 Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 230.2(d)(1)**

**Item 51.1:**

This Condition applies to Emission Unit: G-AS001

**Item 51.2:**

Stage I and Stage II vapor collection systems are required at any gasoline dispensing site located in the New York City Metropolitan Area which is constructed, replaced, or substantially modified after June 27, 1987, regardless of the annual gasoline throughput at the site.

This requirement does not apply for gasoline tanks with a capacity less than 550 gallons which are used exclusively for farm tractors used for agricultural purposes or for snowplowing.



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Condition 52: Requirements for gasoline transport vehicles delivering to Stage I controlled dispensing sites.  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 230.2(f)**

**Item 52.1:**

This Condition applies to Emission Unit: G-AS001

**Item 52.2:**

Owners and/or operators of gasoline transport vehicles and gasoline dispensing sites subject to stage I vapor collection or vapor control requirements must:

1. install all necessary stage I vapor collection and control systems, and make any modifications necessary to comply with the requirements;
2. provide adequate training and written instructions to the operator of the affected gasoline transport vehicle;
3. replace, repair, or modify any worn or ineffective component or design element to ensure the vapor-tight integrity of the stage I vapor collection and vapor control systems;
4. connect and ensure proper operation of the stage I vapor collection and control systems whenever gasoline is being loaded, unloaded or dispensed; and
5. connect the Stage I vapor collection hose before connecting the gasoline delivery hose to the gasoline transport vehicle, and disconnect the gasoline delivery hose before disconnecting the Stage I vapor collection hose from the gasoline transport vehicle.

**Condition 53: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 230.2(g)**

**Item 53.1:**

The Compliance Certification activity will be performed for:

Emission Unit: G-AS001

**Item 53.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

1. DAILY VISUAL INSPECTIONS OF COMPONENTS OF STAGE II VAPOR COLLECTION SYSTEMS MUST BE PERFORMED TO ENSURE THE

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



INTEGRITY AND EFFICIENCY OF THE SYSTEM.

THIS SHOULD BE RECORDED DAILY IN A LOG BOOK. THE LOG SHOULD CONTAIN THE FOLLOWING INFORMATION: (A) INSPECTOR'S NAME; (B) INSPECTION DATE; (C) RESULTS - IS IT IN COMPLIANCE OR IS THERE A DEFICIENCY AND IF SO, WHAT IS IT; (D) REMEDIAL MEASURES IF A DEFICIENCY WAS NOTED.

THE RECORDS MUST BE MAINTAINED FOR AT LEAST FIVE YEARS, AND SHOULD BE MADE AVAILABLE TO THE DEPARTMENT UPON REQUEST.

2. DISPENSERS WITH DEFECTIVE STAGE II COMPONENTS MUST BE REMOVED FROM SERVICE, LOCKED AND SEALED TO PREVENT VAPOR LOSS FROM OPERATIONAL DISPENSERS UNTIL APPROVED REPLACEMENT PARTS ARE INSTALLED.

Monitoring Frequency: DAILY  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
Subsequent reports are due every 6 calendar month(s).

**Condition 54: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 230.2(k)**

**Item 54.1:**

The Compliance Certification activity will be performed for:

Emission Unit: G-AS001

**Item 54.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners and/or operators of stage II systems must perform leak tests at 5 year intervals after commencing operations. The pressure in gasoline storage tanks must



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

not fall below the values in Table 1 of Part 230.2(k)(2)(iii) after 5 minutes from an initial pressure of 10.0 inches of water column during a leak test.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: AVERAGING METHOD - SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 55: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 230.2(k)**

**Item 55.1:**

The Compliance Certification activity will be performed for:

Emission Unit: G-AS001

**Item 55.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Owners and/or operators of stage II systems must perform liquid blockage tests at 5 year intervals after commencing operations. The back pressure during the liquid blockage tests must not exceed 0.03 inches of water column gauge above the dynamic back pressure test results for the system for flow rates of 60 and 100 cubic feet per hour.

Parameter Monitored: PRESSURE

Upper Permit Limit: 0.03 inches of water

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE - SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 56: Compliance Certification**  
**Effective for entire length of Permit**



**Applicable Federal Requirement: 6NYCRR 230.5(d)**

**Item 56.1:**

The Compliance Certification activity will be performed for:

Emission Unit: G-AS001

**Item 56.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners and / or Operators of gasoline dispensing sites required to perform tests of Stage II systems pursuant to Section 230.2(k) of this Part must submit a notarized report of test results to the Department within 30 days of the test. These test results must also be retained at the gasoline dispensing site for five years following the test, and must be made available for inspection by the commissioner's representative during normal business hours.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 57: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.2**

**Item 57.1:**

The Compliance Certification activity will be performed for:

Emission Unit: P-B0001

Regulated Contaminant(s):

CAS No: 0NY998-00-0    VOC

**Item 57.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**



For all surface coatings subject to 6NYCRR Part 228, the VOC content (as applied, minus water and exempt VOC), must be less than or equal to the limit specified in Table 1 or Table 2 for the respective surface that is coated.

The VOC content of a coating, as applied, shall be calculated as follows:

$$(VOC)_a = [ (Wv)_a - (Ww)_a - (We)_a ] / [ 1 - \{ (Vw)_a + (Ve)_a \} ]$$

Where:

(VOC)<sub>a</sub> = VOC content of a coating, as applied, expressed as pounds of VOC per gallon of coating minus water and excluded VOC

(Wv)<sub>a</sub> = The pounds of total volatiles per gallon of an as applied coating

(Ww)<sub>a</sub> = The pounds of water per gallon of an as applied coating

(We)<sub>a</sub> = The pounds of excluded VOC per gallon of an as applied coating

(Vw)<sub>a</sub> = The gallons of water per gallon of an as applied coating

(Ve)<sub>a</sub> = The gallons of excluded VOC per gallon of an as applied coating

Reference Test Method: EPA RM 24

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 58: Recordkeeping, Reports of VOCs - EU Level  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.3(a)**

**Item 58.1:**

This Condition applies to Emission Unit: P-B0001

**Item 58.2:** Use of coatings that exceed the maximum permitted pounds of VOC per gallon, minus water and excluded VOC at application specified in table 1 of section 228.7 or table 2 of section 228.8 of 6 NYCRR Part 228 is prohibited.



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

**Condition 59: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.4**

**Item 59.1:**

The Compliance Certification activity will be performed for:

Emission Unit: P-B0001

**Item 59.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The permittee will conduct observations of visible emissions from the emission unit, process, etc. to which this condition applies daily while the process is in operation. The permittee will immediately investigate any instance where there is cause to believe that visible emissions above those that are normal and in compliance are occurring or have occurred from a process source.

If visible emissions above those that are normal and in compliance with section 212.6(a) are detected (this may be zero percent opacity for many or all emission sources), the permittee shall determine the cause, make the necessary correction, and verify that the excess visible emissions problem has been corrected. If the permittee expects the excess visible emissions to occur in excess of 1 hour after discovery, the Department will be notified immediately.

If visible emissions above those that are normal and in compliance continue to be present after corrections are made, the permittee will immediately notify The Department and conduct a Method 9 assessment within 24 hours to determine the degree of opacity.

If the opacity is determined to exceed the limits of section 212.6(a), the facility will be determined to be in violation, the permittee will remedy the problem, and will contact the Department. The provisions of Part 201-1.4 shall apply.

The semiannual monitoring report and annual compliance



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

certifications required of all permittees subject to Title V must include a summary of these observations.

Reference Test Method: EPA Method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 60: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.5(a)**

**Item 60.1:**

The Compliance Certification activity will be performed for:

Emission Unit: P-B0001

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

**Item 60.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of any emission source subject to 6NYCRR Part 228 must maintain and, upon request, provide the Department with a certification from the coating supplier/manufacturer which verifies the parameters used to determine the actual VOC content of each as applied coating, (VOC)a, used at the facility. In addition, purchase, usage and/or production records of the coating material, including solvents, must be maintained in a format acceptable to the Department and, upon request, these records must be submitted to the Department. Any facility required to perform the overall removal efficiency calculation, must maintain records to verify the parameters used in the calculation. A facility owner or operator must maintain a record that identifies each air cleaning device that has an overall removal efficiency of at least 85 percent. Any additional information required to determine compliance must be provided to the Department in a format acceptable to the Department.



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 61: Use of Methods 311 or 24.**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.5(b)**

**Item 61.1:**

This Condition applies to Emission Unit: P-B0001

**Item 61.2:**

Upon request by the Department, the owner and operator of any emission source subject to 6NYCRR Part 228, must use Method 311 or Method 24 as presented in Appendices A of both 40 CFR Parts 63 and 60, respectively (see table 1, section 200.9 of Title 6), to measure the volatile content, water content, density, volume of solids, and weight of solids in order to determine the actual VOC content of an as applied coating during a compliance demonstration.

**Condition 62: Department access to obtain samples.**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.5(d)**

**Item 62.1:**

This Condition applies to Emission Unit: P-B0001

**Item 62.2:**

Representatives of the Department must be permitted during reasonable business hours, to obtain coating samples for the purpose of determining compliance with 6NYCRR Part 228.

**Condition 63: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.8**

**Item 63.1:**

The Compliance Certification activity will be performed for:

Emission Unit: P-B0001

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

**Item 63.2:**



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Motor vehicle refinish coatings used for coating entire vehicles may contain a maximum of 5.0 pound of VOC per gallon of coating (minus water and excluded VOC) as applied.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: VOC's

Parameter Monitored: VOC CONTENT

Upper Permit Limit: 5.0 pounds per gallon

Reference Test Method: 40 cfr 60, method 24

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL CHANGE

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE - SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 60 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 64: Compliance Certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.8**

**Item 64.1:**

The Compliance Certification activity will be performed for:

Emission Unit: P-B0001

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

**Item 64.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Motor Vehicle refinish coatings used for repair and/or touch-up may contain a maximum of 6.2 pound of VOC per gallon of coating (minus water and excluded VOC) as applied.



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: VOC's

Parameter Monitored: VOC CONTENT

Upper Permit Limit: 6.2 pounds per gallon

Reference Test Method: 40 cfr 60, method 24

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL  
CHANGE

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -  
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 65: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.8**

**Item 65.1:**

The Compliance Certification activity will be performed for:

Emission Unit: P-B0001

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

**Item 65.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC  
OPERATIONS

Monitoring Description:

The maximum permitted pounds of VOC per gallon (minus  
water and excluded VOC) of coating at application, for  
miscellaneous plastic clear coating lines is 4.8

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: COATING LINES

Parameter Monitored: VOC CONTENT

Upper Permit Limit: 4.8 pounds per gallon

Reference Test Method: 40 cfr 60, method 24

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL  
CHANGE

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.



Subsequent reports are due every 6 calendar month(s).

**Condition 66: Compliance Certification**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 228.8**

**Item 66.1:**

The Compliance Certification activity will be performed for:

Emission Unit: P-B0001

Regulated Contaminant(s):  
CAS No: 0NY998-00-0    VOC

**Item 66.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC  
OPERATIONS

Monitoring Description:

The maximum permitted pounds of VOC per gallon (minus  
water and excluded VOC) of coating at application, for  
miscellaneous plastic color topcoat coating lines is 3.8

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: COATING LINES

Parameter Monitored: VOC CONTENT

Upper Permit Limit: 3.8 pounds per gallon

Reference Test Method: 40 cfr 60, method 24

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL  
CHANGE

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).



**STATE ONLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.**

**Condition 67: Contaminant List  
Effective for entire length of Permit**

**Applicable State Requirement: ECL 19-0301**

**Item 67.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY075-00-0

Name: PARTICULATES

CAS No: 0NY998-00-0

Name: VOC

**Condition 68: Unavoidable noncompliance and violations  
Effective for entire length of Permit**

**Applicable State Requirement: 6NYCRR 201-1.4**

**Item 68.1:**

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superseded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.



**New York State Department of Environmental Conservation**

**Permit ID: 2-6105-00262/00009**

**Facility DEC ID: 2610500262**

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

**Condition 69: Air pollution prohibited**  
**Effective for entire length of Permit**

**Applicable State Requirement: 6NYCRR 211.2**

**Item 69.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.