



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 2-6202-00674/00001
Mod 0 Effective Date: 11/21/2003 Expiration Date: 11/20/2008
Mod 1 Effective Date: 02/22/2005 Expiration Date: 11/20/2008

Permit Issued To: ST LUKE'S ROOSEVELT HOSPITAL
419 WEST 114TH ST
NEW YORK, NY 10025

Contact: LEONARD MELLUSI
ST LUKE'S ROOSEVELT HOSPITAL
1111 AMSTERDAM AVENUE
NEW YORK, NY 10025
(212) 420-5677

Facility: ST LUKE'S ROOSEVELT HOSPITAL
1111 AMSTERDAM AVE
NEW YORK, NY 10025

Description:

This modification involves the removal of the thylene oxide sterilizer.

St Luke's Roosevelt Hospital Center is an existing major facility and has four boilers (installed before the year 1972) for heating and four emergency generators.

The emission unit U00001 has four boilers: S0001, S0002, S0003 and S0004. Boilers S0001 and S0004 are venting to emission point E0002 and S0002 and S0003 are venting to E0002. The boiler S0001 of 164 mmbtu/hr heat input capacity burns only #6 fuel oil. The other three boilers, S0002 of 38 mmbtu/hr heat input capacity, S0003 and S0004 of 49 mmbtu/hr heat input capacities, are capable of burning natural gas or #6 residual oil.

Facility's yearly nitrogen oxides, particulates and sulfur dioxide emissions from the combustion units exceed the major source threshold for Title V applicability. As such, the facility is subject to the permitting requirements of NYCRR Part 201-6.

Boilers are subject to reasonably available control technology (RACT) for oxides of nitrogen (NO_x). Oxides of nitrogen are limited to 0.3 lbs/mmbtu for large boiler (S0001). Particulate emissions from boilers are limited 0.1 pounds per million btu. Facility is required to perform stack test, once during the permit term to demonstrate compliance with NO_x and particulate limits. Sulfur emissions from the

New York State Department of Environmental Conservation
Facility DEC ID: 2620200674



boilers and engines are controlled by limiting sulfur content in the residual oil to 0.3% by weight.

The hospital's current primary sterilizer is a low-temperature hydrogen peroxide plasma unit which emits no air pollutants.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN
 DIVISION OF ENVIRONMENTAL PERMITS
 ONE HUNTERS POINT PLAZA, 47-40 21ST STREET
 LONG ISLAND CITY, NY 11101-5407

Authorized Signature: _____ Date: ___ / ___ / _____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Applications for Permit Renewals and Modifications

Permit Modifications, Suspensions and Revocations by the Department

Facility Level

Submission of Applications for Permit Modification or Renewal-REGION 2

HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301.2(m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for Permit Renewals and Modifications
Applicable State Requirement: 6NYCRR 621.13

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:



New York State Department of Environmental Conservation
Facility DEC ID: 2620200674

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Permit Modifications, Suspensions and Revocations by the Department
Applicable State Requirement: 6NYCRR 621.14

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of Applications for Permit Modification or Renewal-REGION 2 HEADQUARTERS
Applicable State Requirement: 6NYCRR 621.5(a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: ST LUKE'S ROOSEVELT HOSPITAL
419 WEST 114TH ST
NEW YORK, NY 10025

Facility: ST LUKE'S ROOSEVELT HOSPITAL
1111 AMSTERDAM AVE
NEW YORK, NY 10025

Authorized Activity By Standard Industrial Classification Code:
8062 - GENERAL MEDICAL & SURGICAL HOSPITALS

Mod 0 Permit Effective Date: 11/21/2003

Permit Expiration Date: 11/20/2008

Mod 1 Permit Effective Date: 02/22/2005

Permit Expiration Date: 11/20/2008



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6NYCRR 201-6: Emission Unit Definition
- 2 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 3 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 4 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 5 6NYCRR 201-6.5(e): Compliance Certification
- 6 6NYCRR 202-1.2: Notification
- 7 6NYCRR 202-1.3: Acceptable procedures - Stack test report submittal
- 8 6NYCRR 202-2.1: Compliance Certification
- 9 6NYCRR 202-2.5: Recordkeeping requirements
- 10 6NYCRR 225.1(a)(3): Compliance Certification
- 11 6NYCRR 225.7(a): Compliance Certification
- 1-1 40CFR 68: Accidental release provisions.
- 13 40CFR 82, Subpart F: Recycling and Emissions Reduction

Emission Unit Level

- 14 6NYCRR 201-6: Emission Point Definition By Emission Unit
- 15 6NYCRR 201-6: Process Definition By Emission Unit

EU=U-00001

- 17 6NYCRR 201-6.5(e): Compliance Certification
- 18 6NYCRR 227-2.4(d): Compliance Certification

EU=U-00001,Proc=001,ES=S0001

- 19 6NYCRR 227-2.4(b)(1): Compliance Certification

EU=U-00001,EP=E0001

- 20 6NYCRR 227-1.3(a): Compliance Certification

EU=U-00001,EP=E0001,Proc=001

- 21 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,Proc=001,ES=S0001

- 22 6NYCRR 227-2.4(b): Compliance Plan

EU=U-00001,EP=E0002

- 23 6NYCRR 227-1.3(a): Compliance Certification

EU=U-00001,EP=E0002,Proc=001

- 24 6NYCRR 227.2(b)(1): Compliance Certification



STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 27 ECL 19-0301: Contaminant List
- 28 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 29 6NYCRR 211.2: Air pollution prohibited

Emission Unit Level

EU=U-00001,EP=E0001,Proc=001

- 30 6NYCRR 227-1.2(a)(2): Compliance Demonstration

EU=U-00001,EP=E0002,Proc=001

- 31 6NYCRR 227-1.2(a)(2): Compliance Demonstration



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Sealing - 6NYCRR Part 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6NYCRR Part 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6NYCRR Part 200.7

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6NYCRR Part 201-1.2

If an existing emission source was subject to the permitting requirements of 6NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

Item E: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item F: Recycling and Salvage - 6NYCRR Part 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item G: Prohibition of Reintroduction of Collected Contaminants to the Air - 6NYCRR Part 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item H: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item I: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR Part 201-3.2(a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item J: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR Part 201-3.3(a)

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item K: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item L: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item M: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



renewal application.

Item N: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item O: Providing Information Upon Request - 6 NYCRR Part 201-6.5(a)(4)

The permittee shall furnish to the Department, within a reasonable time, any information that the Department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The permittee shall also, on request, furnish the Department with copies of records required to be kept by the permit. Where information is claimed to be confidential, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

Item P: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item Q: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item R: Fees - 6 NYCRR Part 201-6.5(a)(7)

The owner and/or operator of a stationary source shall pay fees to the department consistent with the fee schedule authorized by 6 NYCRR Subpart 482-2.

Item S: Right to Inspect - 6 NYCRR Part 201-6.5(a)(8)

Upon presentation of credentials and other documents, as

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



may be required by law, the permittee shall allow the Department or an authorized representative to perform the following:

- i. Enter upon the permittee's premises where the permitted facility is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- iii. Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
- iv. As authorized by the Act, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Item T: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item U: Progress Reports and Compliance Schedules - 6 NYCRR Part 201-6.5(d)(5)

Progress reports consistent with an applicable schedule of compliance must be submitted at least semiannually on a calendar year basis, or at a more frequent period if specified in the applicable requirement or by the Department elsewhere in this permit. These reports shall be submitted to the Department within 30 days after the end of a reporting period. Such progress reports shall contain the following:

- i. Dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- ii. An explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



or corrective measures adopted.

Item V: Off Permit Changes - 6 NYCRR Part 201-6.5(f)(6)

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provisions of Title I of the Act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the Administrator and the Department with written notification in advance of the proposed changes within a minimum of 7 days as required by 6 NYCRR §201-6.5(f)(6).

Item W: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

contributing to such pollution;

ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item X: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item Y: Required Emission Tests - 6 NYCRR Part 202-1.1

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6NYCRR Part 202-1.

Item Z: Visible Emissions Limited - 6 NYCRR Part 211.3

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Item AA: Open Fires - 6 NYCRR Part 215

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, rubbish for salvage, or rubbish generated by industrial or commercial activities.

Item BB: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item CC: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS

The following conditions are subject to annual compliance certification requirements for Title V permits only.

**Condition 1: Emission Unit Definition
Effective between the dates of 11/21/2003 and 11/20/2008**

Applicable Federal Requirement: 6NYCRR 201-6

Item 1.1(From Mod 1):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

This unit consists of four (4) boilers. The large boiler (S0001) has capacity to burn No.6 fuel only. The other three boilers (S0002, S0003 & S0004) have dual -fuel capabilities, burning no.6 oil and natural gas. Boilers S0001 and S0004 (total of 213 mmbtu/hr) exhaust to common stack E0002 and boilers S0002 and S0003 (total of 87mmbtu/hr) exhaust to common stack E0001.

Building(s): CHAPEL
TRAVERS

Item 1.2(From Mod 0):



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00002 End Date: 10/15/2003

Emission Unit Description:

This unit consists of one (1) ethylene oxide sterilizer equipped with an aerator. This unit is currently operated with Oxyfume 2000 which consists of 8.6% of ETO and 91.4% HCFCs. The unit could also be operated with Oxyfume 2002 (10%EtO).

Building(s): BABCOCK

**Condition 2: Recordkeeping and reporting of compliance monitoring
Effective between the dates of 11/21/2003 and 11/20/2008**

Applicable Federal Requirement: 6NYCRR 201-6.5(c)

Item 2.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

**Condition 3: Monitoring, Related Recordkeeping, and Reporting
Requirements.
Effective between the dates of 11/21/2003 and 11/20/2008**

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)

Item 3.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 4: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)

Item 4.1:

The Compliance Certification activity will be performed for the Facility.

Item 4.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section,

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2004.

Subsequent reports are due every 6 calendar month(s).

Condition 5: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 201-6.5(e)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



- the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;
- and
- such additional requirements as may be specified elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2
Air Compliance Branch
290 Broadway

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



New York, NY 10007-1866

The address for the RAPCE is as follows:

Hunters Point Plaza
47-40 21st Street
Long Island City, NY 11101-5407

The address for the BCME is as follows:

NYSDEC
Bureau of Compliance Monitoring
and Enforcement
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2004.

Subsequent reports are due on the same day each year

Condition 6: Notification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 202-1.2

Item 6.1:

A person who is required by the commissioner to submit a stack test report shall notify the commissioner, in writing, not less than 30 days prior to the test, of the time and date of the test. Such notification shall also include the acceptable procedures to be used to stack test including sampling and analytical procedures. Such person shall allow the commissioner, or his representative, free access to observe stack testing being conducted by such person.

Condition 7: Acceptable procedures - Stack test report submittal
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 202-1.3

Item 7.1:

Emission test reports must be submitted in triplicate to the commissioner within 60 days after the completion of the tests, unless additional time is requested in writing.

Condition 8: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 202-2.1



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

Item 8.1:

The Compliance Certification activity will be performed for the Facility.

Item 8.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

**Condition 9: Recordkeeping requirements
Effective between the dates of 11/21/2003 and 11/20/2008**

Applicable Federal Requirement: 6NYCRR 202-2.5

Item 9.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

**Condition 10: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008**

Applicable Federal Requirement: 6NYCRR 225.1(a)(3)

Item 10.1:

The Compliance Certification activity will be performed for the Facility.

Item 10.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

No person shall sell, offer for sale, purchase or use any residual oil which has sulfur content greater than 0.30 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site for a minimum of five years after the date of the last entry.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: NUMBER 6 OIL
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.30 percent by weight
Monitoring Frequency: PER DELIVERY
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2004.
Subsequent reports are due every 6 calendar month(s).

Condition 11: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 225.7(a)

Item 11.1:

The Compliance Certification activity will be performed for the Facility.

Item 11.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The permittee shall retain fuel oil supplier certifications for each shipment of oil received. Such certifications shall contain, as a minimum, supplier name, date of shipment, quantity shipped, heating value of the oil, oil sulfur content, and the method used to determine the sulfur content. Such certifications shall be available for inspection by, or submitted to, the NYSDEC as per the stated reporting requirement.

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2004.

Subsequent reports are due every 6 calendar month(s).

Condition 1-1: Accidental release provisions.
Effective between the dates of 02/22/2005 and 11/20/2008



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

Applicable Federal Requirement: 40CFR 68

Replaces Condition(s) 12

Item 1-1.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

Condition 13: Recycling and Emissions Reduction
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 40CFR 82, Subpart F

Item 13.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

****** Emission Unit Level ******

Condition 14: Emission Point Definition By Emission Unit
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 201-6

Item 14.1(From Mod 1):

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: E0001

Height (ft.): 130

Length (in.): 48

Width (in.): 96

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



Building: TRAVERS

Emission Point: E0002
Height (ft.): 140

Diameter (in.): 96

Building: CHAPEL

Item 14.2(From Mod 0):

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00002

Emission Point: E0003
Height (ft.): 120

Removal Date: 10/15/2003
Diameter (in.): 34

Building: BABCOCK

**Condition 15: Process Definition By Emission Unit
Effective between the dates of 11/21/2003 and 11/20/2008**

Applicable Federal Requirement: 6NYCRR 201-6

Item 15.1(From Mod 1):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 001

Source Classification Code: 1-02-004-02

Process Description: Four boilers burning No. 6 fuel oil.

Emission Source/Control: S0001 - Combustion
Design Capacity: 164 million Btu per hour

Emission Source/Control: S0002 - Combustion
Design Capacity: 38 million Btu per hour

Emission Source/Control: S0003 - Combustion
Design Capacity: 49 million Btu per hour

Emission Source/Control: S0004 - Combustion
Design Capacity: 49 million Btu per hour

Item 15.2(From Mod 1):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 002

Source Classification Code: 1-01-006-02

Process Description:

Three small boilers burning natural gas fuel. Note that large boiler is not capable of burning natural gas fuel.



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

Emission Source/Control: S0002 - Combustion
Design Capacity: 38 million Btu per hour

Emission Source/Control: S0003 - Combustion
Design Capacity: 49 million Btu per hour

Emission Source/Control: S0004 - Combustion
Design Capacity: 49 million Btu per hour

Item 15.3(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002

Process: 003

Source Classification Code: 3-99-999-94

Process End Date: 10/15/2003

Process Description:

The emission unit consists of one ethylene oxide(ETO) sterilization.The unit operates as a backup without an abator. The duration of the sterilization /aeration cycle time is 14.5 hours. Each sterilization cycle consumes 11.5 lbs of oxyfume 2000 or 0.989 lbs ETO. Most of the 0.989 lbs of ETO is emitted during the first three hours of the cycle. Thus the maximum hourly emission rate is 0.33 lbs conservatively, if one assumes that 100% of the ETO used in a cycle is emitted in one hour, then the worst case emission is 0.989 lbs ETO per hour. The hospital's primary sterilizer is a new low-temperature hydrogen peroxide plasma. The ETO backup unit is used only once per week (52 weeks per year) thus the maximum ETO emissions are 51.43 pounds per year.

Emission Source/Control: S0005 - Process Removal Date: 10/15/2003

Condition 17: Compliance Certification

Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 201-6.5(e)

Item 17.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

Item 17.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Boiler tune-up shall be performed annually for the boiler (S0001) listed in this emission unit. The owner or operator shall maintain a log (in a format acceptable to the Department) containing the following information:

- (1) The date when the tune-up was performed;
- (2) A summary list of the items adjusted as part of the tune-up;

and,

- (3) The name, title and affiliation of the person(s) who performed the adjustments.

Monitoring Frequency: ANNUALLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2004.

Subsequent reports are due every 6 calendar month(s).

Condition 18: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 227-2.4(d)

Item 18.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Item 18.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Reference Test Method: Air Guide 33

Monitoring Frequency: ANNUALLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

Reports due 30 days after the reporting period.
The initial report is due 4/30/2004.
Subsequent reports are due every 6 calendar month(s).

Condition 19: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 227-2.4(b)(1)

Item 19.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 001 Emission Source: S0001

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 19.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:

NOx emission limits for large boilers, where compliance
with the specific emission limit is verified through stack
testing.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 0.30 pounds per million Btus
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2004.
Subsequent reports are due every 6 calendar month(s).

Condition 20: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 227-1.3(a)

Item 20.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: E0001

Regulated Contaminant(s):

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



CAS No: 0NY075-00-0 PARTICULATES

Item 20.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity (on a six minute block period) except for one six minute block period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - weather condition
 - was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

- 3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then the Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: DAILY

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2004.

Subsequent reports are due every 6 calendar month(s).

Condition 21: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 21.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: E0001
Process: 001

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 21.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

1) submit, to the Department, an acceptable protocol for



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

the testing of particulate emission limit cited in this condition,

2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and

3) all records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2004.

Subsequent reports are due every 6 calendar month(s).

Condition 22: Compliance Plan

Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 227-2.4(b)

Item 22.1:

Compliance will be achieved according to the following schedule for the emission units, processes, sources or emission points specified in this permit:

Emission Unit: U-00001 Emission Point: E0001

Process: 001 Emission Source: S0001

Consent Order: pending

Progress Report Begin Date: 12/06/1997

Item 22.2:

Remedial Measure:

Schedule Date:

Within 60 days after the completion of the stack tests, facility must submit the stack test report to the Department for review and approval.

Item 22.3:

Remedial Measure:

Schedule Date:

Within 30 days of Department's approval of the stack test



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

protocol, St Luke's Roosevelt Hospital must perform NO_x emission stack testing. The Department received the stack test protocol on August 8, 2003.

Condition 23: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 227-1.3(a)

Item 23.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: E0002

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 23.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity (on a six minute block period) except for one six minute block period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition
- was a plume observed?

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then the Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Reference Test Method: Method 9
Monitoring Frequency: DAILY
Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2004.
Subsequent reports are due every 6 calendar month(s).

Condition 24: Compliance Certification
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 24.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: E0002

New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674



Process: 001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 24.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,
- 2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and
- 3) all records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2004.

Subsequent reports are due every 6 calendar month(s).



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

**Condition 27: Contaminant List
Effective between the dates of 11/21/2003 and 11/20/2008**

Applicable State Requirement: ECL 19-0301

Item 27.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

CAS No: 0NY075-00-0

Name: PARTICULATES

Condition 28: Unavoidable noncompliance and violations
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable State Requirement: 6NYCRR 201-1.4

Item 28.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superseded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 29: Air pollution prohibited
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable State Requirement: 6NYCRR 211.2

Item 29.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

****** Emission Unit Level ******

Condition 30: Compliance Demonstration
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable State Requirement: 6NYCRR 227-1.2(a)(2)

Item 30.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001 Emission Point: E0001
Process: 001

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 30.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:
Particulate emission limit for a boiler or combination of



New York State Department of Environmental Conservation

Permit ID: 2-6202-00674/00001

Facility DEC ID: 2620200674

boilers (connected to the same emission point) with a maximum heat input exceeding 50 mmBtu per hour but no greater than 250 mmBtu per hour firing oil, other than distillate oil.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.20 pounds per million Btus

Reference Test Method: Method 5 / Method 17

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2004.

Subsequent reports are due every 6 calendar month(s).

Condition 31: Compliance Demonstration
Effective between the dates of 11/21/2003 and 11/20/2008

Applicable State Requirement: 6NYCRR 227-1.2(a)(2)

Item 31.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001 Emission Point: E0002
Process: 001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 31.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a boiler or combination of boilers (connected to the same emission point) with a maximum heat input exceeding 50 mmBtu per hour but no greater than 250 mmBtu per hour firing oil, other than distillate oil.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.20 pounds per million Btus

Reference Test Method: Method 5 / Method 17

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

New York State Department of Environmental Conservation
Permit ID: 2-6202-00674/00001 Facility DEC ID: 2620200674



The initial report is due 4/30/2004.
Subsequent reports are due every 6 calendar month(s).