



New York State Department of Environmental Conservation
Facility DEC ID: 2620500182

This variance was granted by DEC, pending EPA's final approval.

The other four (4) gas engines meet the Subpart 227-2 NOx RACT limit of 1.5 gr/bhp-hr.

This facility emits oxides of nitrogen in excess of 25 tons per year and is subject to Title V permitting requirements, Part 201. The Title V permit contains a complete listing of the applicable Federal, State and compliance monitoring requirements for this facility, its emission unit and emission point.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN
 DIVISION OF ENVIRONMENTAL PERMITS
 ONE HUNTERS POINT PLAZA, 47-40 21ST STREET
 LONG ISLAND CITY, NY 11101-5407

Authorized Signature: _____ Date: ____ / ____ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Applications for permit renewals, modifications and transfers

Renewals and Modifications

Permit modifications, suspensions or revocations by the Department

Permit Modifications, Suspensions and Revocations by the Department

Facility Level

Submission of Applications for Permit Modification or Renewal-REGION 2

HEADQUARTERS

Submission of application for permit modification or renewal-REGION 2

HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301.2(m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:



New York State Department of Environmental Conservation
Facility DEC ID: 2620500182

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Applications for Permit Renewals and Modifications
Applicable State Requirement: 6NYCRR 621.13

Item 4.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 4.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 4.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 5: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6NYCRR 621.13

Item 5.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

Condition 6: Permit Modifications, Suspensions and Revocations by the Department
Applicable State Requirement: 6NYCRR 621.14

Item 6.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;

New York State Department of Environmental Conservation
Facility DEC ID: 2620500182



- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 7: Submission of Applications for Permit Modification or Renewal-REGION 2 HEADQUARTERS

Applicable State Requirement: 6NYCRR 621.5(a)

Item 7.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997

Condition 8: Submission of application for permit modification or renewal-REGION 2 HEADQUARTERS

Applicable State Requirement: 6NYCRR 621.6(a)

Item 8.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: MUTUAL REDEVELOPMENT HOUSES INC
321 EIGHTH AVE
NEW YORK, NY 10001-4818

Facility: MUTUAL REDEVELOPMENT HOUSES
315 WEST 25TH ST
NEW YORK, NY 10001

Authorized Activity By Standard Industrial Classification Code:
6513 - APARTMENT BUILDING OPERATORS

Permit Effective Date:

Permit Expiration Date:



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6NYCRR 201-6.5(a)(7): Fees
- 3 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 4 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 6 6NYCRR 201-6.5(e): Compliance Certification
- 7 6NYCRR 202-2.1: Compliance Certification
- 8 6NYCRR 202-2.5: Recordkeeping requirements
- 9 6NYCRR 215: Open Fires Prohibited at Industrial and Commercial Sites
- 10 6NYCRR 200.7: Maintenance of Equipment
- 11 6NYCRR 201-1.7: Recycling and Salvage
- 12 6NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6NYCRR 201-3.2(a): Exempt Sources - Proof of Eligibility
- 14 6NYCRR 201-3.3(a): Trivial Sources - Proof of Eligibility
- 15 6NYCRR 201-6.5(a)(4): Standard Requirement - Provide Information
- 16 6NYCRR 201-6.5(a)(8): General Condition - Right to Inspect
- 17 6NYCRR 201-6.5(d)(5): Standard Requirements - Progress Reports
- 18 6NYCRR 201-6.5(f)(6): Off Permit Changes
- 19 6NYCRR 202-1.1: Required Emissions Tests
- 20 6NYCRR 211.3: Visible Emissions Limited
- 21 40CFR 68: Accidental release provisions.
- 22 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 23 6NYCRR 201-6: Emission Unit Definition
- 24 6NYCRR 225.1(a)(3): Compliance Certification
- 25 6NYCRR 225.7(a): Compliance Certification
- 27 6NYCRR 227-1.3: Compliance Certification
- 26 6NYCRR 227-1.3(a): Compliance Certification
- 28 6NYCRR 227-2.5(c): Compliance Certification

Emission Unit Level

- 29 6NYCRR 201-6: Emission Point Definition By Emission Unit
- 30 6NYCRR 201-6: Process Definition By Emission Unit

EU=U-00001

- 31 6NYCRR 227-2.6: Compliance Certification

EU=U-00001,Proc=001,ES=00003

- 32 6NYCRR 227-2.4(d): Compliance Certification

EU=U-00001,Proc=001,ES=00004



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

33 6NYCRR 227-2.4(d): Compliance Certification

EU=U-00001,Proc=002,ES=00005

34 6NYCRR 227-2.5(c): Compliance Certification

EU=U-00001,Proc=002,ES=00006

35 6NYCRR 227-2.5(c): Compliance Certification

EU=U-00001,Proc=002,ES=00007

36 6NYCRR 227-2.5(c): Compliance Certification

EU=U-00001,Proc=002,ES=00008

37 6NYCRR 227-2.5(c): Compliance Certification

EU=U-00001,Proc=002,ES=00009

38 6NYCRR 227-2.5(c): Compliance Certification

EU=U-00001,Proc=002,ES=00010

39 6NYCRR 227-2.5(c): Compliance Certification

EU=U-00001,Proc=003,ES=00011

40 6NYCRR 227-2.4(f)(2): Compliance Certification

EU=U-00001,Proc=003,ES=00012

): Compliance Certification

EU=U-00001,Proc=003,ES=00013

42 6NYCRR 227-2.4(f)(2): Compliance Certification

EU=U-00001,Proc=003,ES=00014

): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00003

44 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00004

45 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00005

46 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00006

47 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00007

48 6NYCRR 227.2(b)(1): Compliance Certification



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

EU=U-00001,EP=00001,Proc=002,ES=00008

49 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00009

50 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00010

51 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00015

52 6NYCRR 227.2(b)(1): Compliance Certification

EU=U-00001,EP=00001,Proc=002,ES=00016

53 6NYCRR 227.2(b)(1): Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

54 ECL 19-0301: Contaminant List

55 6NYCRR 201-1.4: Unavoidable noncompliance and violations

56 6NYCRR 211.2: Air pollution prohibited



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

s at the time being properly operated;

(2) The equipment at the permitted facility causing the

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

hin two working days after the event

(4) The facility owner and/or operator notified the

occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification e submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

ust comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the

this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment

emission of air pollutants causing or

contributing to such pollution;

ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



Act;

- iv. The ability of the Department or the Administrator to ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

Additional applicable requirements under the Act

become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original

of its terms and conditions has been

extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

made in establishing the emissions

- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate standards or other terms or conditions of the permit.

- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

If the permitted facility is an "affected source"

subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

The same procedures as apply to initial

Proceedings to reopen and issue Title V facility permits permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



is to be reopened, except that the Department may provide a period in the case of an emergency.

Item L:

Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Other Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable regulations.

as being enforceable under only state

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

**Condition 1: Acceptable Ambient Air Quality
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

Condition 3: Recordkeeping and reporting of compliance monitoring
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

Condition 4: Monitoring, Related Recordkeeping, and Reporting Requirements.
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 5: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

For emissions of a hazardous air pollutant (as

identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official

YCCR Part 201-6.3(d)(12), must be

submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

visions of 6 NYCRR 201-1.4 shall apply if the

permittee seeks to have a violation excused unless

ted by regulation. In order to have a

violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Monitoring Frequency: DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 6: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



following:

i. Compliance certifications shall contain:

- the identification of each term or condition of the permit that is the basis of the certification;
- the compliance status;

Compliance was continuous or intermittent;

- the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
- such other facts as the Department may require to

to determine compliance status of the facility as

specified in any special permit terms or conditions;
and

additional requirements as may be specified

elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions

for which an annual certification is

required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date,

for each quarter has been acceptable by the

Department.

iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Air Compliance Branch
290 Broadway
New York, NY 10007-1866

The address for the RAPCE is as follows:

Hunters Point Plaza
47-40 21st Street
Long Island City, NY 11101-5407

The address for the BQA is as follows:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2008.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)

April 15th for previous calendar year



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Condition 8: Recordkeeping requirements
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires Prohibited at Industrial and Commercial Sites
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 215

Item 9.1:

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, refuse, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT
TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period. [NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

Condition 10: Maintenance of Equipment
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Condition 11: Recycling and Salvage
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-1.7

Item 11.1:

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-3.2(a)

Item 13.1:

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 14: Trivial Sources - Proof of Eligibility
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-3.3(a)

Item 14.1:

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



Condition 15: Standard Requirement - Provide Information
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: General Condition - Right to Inspect
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Standard Requirements - Progress Reports
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(d)(5)

Item 17.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 18: Off Permit Changes
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(f)(6)

Item 18.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

Condition 19: Required Emissions Tests
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 202-1.1

Item 19.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time. Such person shall bear the cost of measurement and preparing the report of measured emissions. Failure of such person to submit a report acceptable to the commissioner within the time stated shall be sufficient reason for the commissioner to suspend or deny a certificate to operate.

Condition 20: Visible Emissions Limited
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 211.3

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



Item 20.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Condition 21: Accidental release provisions.
Effective for entire length of Permit**

Applicable Federal Requirement: 40CFR 68

Item 21.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

**Condition 22: Recycling and Emissions Reduction
Effective for entire length of Permit**

Applicable Federal Requirement: 40CFR 82, Subpart F

Item 22.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**The following conditions are subject to annual compliance certification requirements
for Title V permits only.**

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



Condition 23: Emission Unit Definition
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6

Item 23.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

The emission unit is comprised of six (6) diesel engine generators (emission sources 00005, 00006, 00007, 00008,

), two (2) Kewanee dual fuel boilers

(emission sources 00003 & 00004) and two (2) Trane dual fuel chillers/heaters (emission sources 00015 & 00016), four 812 kwh engine driven generators (emission sources 00011, 00012, 00013 & 00014). All discharging through one common stack . The gas fired units are lean burn low emission engines.

Building(s): PPLANT

Condition 24: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 225.1(a)(3)

Item 24.1:

The Compliance Certification activity will be performed for the Facility.

Item 24.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

No person shall sell, offer for sale, purchase or use any distillate oil which has sulfur content greater than 0.20 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site for a minimum of five years after the date of the last entry.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.20 percent by weight

Monitoring Frequency: PER DELIVERY



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 25: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 225.7(a)

Item 25.1:

The Compliance Certification activity will be performed for the Facility.

Item 25.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The permittee shall retain fuel oil supplier certifications for each shipment of oil received. Such certifications shall contain, as a minimum, supplier name, date of shipment, quantity shipped, heating value of the oil, oil sulfur content, and the method used to determine

content. Such certifications shall be

available for inspection by, or submitted to, the NYSDEC as per the stated reporting requirement.

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 27: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-1.3

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Item 27.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired boilers which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



to perform the following:

1) Observe the stack for each boiler which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- date and time of day
- observer's name
- identity of emission point
- weather condition
- was a plume observed?

Inclement weather conditions shall be recorded for those days when observations are prohibited. This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The

en the stack and the beginning of the

detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

stack.

Monitoring Frequency: DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 26: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-1.3(a)

Item 26.1:

The Compliance Certification activity will be performed for the Facility.

Item 26.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 28: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.5(c)

Item 28.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: U-00001 Emission Point: 00001

Process: 002 Emission Source: 00005

Emission Unit: U-00001 Emission Point: 00001



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Process: 002 Emission Source: 00006

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00007

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00008

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00009

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00010

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 28.2:

Compliance Certification shall include the following monitoring:

PROCESS OR CONTROL

DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The alternate NOx emission standard for emission sources 00005, 00006, 00007, 00008, 00009, 00010 is 6.0 g/bhp-hour. As a result the 12-month average - rolled monthly NOx emissions are capped to 98.3 tons. This capping is to support the alternate emission NOx standard of 6.0 grams per brake horsepower-hour.

The alternate emission standard is based on the September 29, 2006 NOx Ract Determination and the 10/26/2005 stack test. The 820 KW and 1150 KW engines were tested at 65% and 85% load.

For the 820 KW engine at 65% load, the fuel feed rate was 42 gallons/hr and at 85% load the fuel feed rate was 55 gallons/hr.

For the 1150 KW engine at 65% load, the fuel feed rate was 48 gallons/hr and at 85% load the fuel feed rate was 65 gallons/hr.

The owner shall submit, to the Regional Air Pollution

eer, within thirty (30) days of permit

issuance a plan for his review and acceptance how the NOx emissions will be monitored for compliance with this

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



capping condition.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 98.3 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

****** Emission Unit Level ******

**Condition 29: Emission Point Definition By Emission Unit
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 201-6

Item 29.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001

Height (ft.): 220

Diameter (in.): 84

NYTMN (km.): 4511.

NYTME (km.): 584.7

Building: PPLANT

**Condition 30: Process Definition By Emission Unit
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 201-6

Item 30.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 001

Source Classification Code: 1-03-006-02

Process Description:

Firing natural gas in heaters/chillers 00015 and 00016,
and boilers 00003 and 00004.

Emission Source/Control: 00003 - Combustion

Design Capacity: 31 million Btu per hour

Emission Source/Control: 00004 - Combustion

Design Capacity: 31 million Btu per hour

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



Emission Source/Control: 00015 - Combustion
Design Capacity: 10.4 British thermal units per hour

Emission Source/Control: 00016 - Combustion
Design Capacity: 10.4 British thermal units per hour

Item 30.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 002

Source Classification Code: 2-03-001-01

Process Description:

Firing no 2 fuel oil in engine driven generators
(emission sources 00005, 00006, 00007, 00008, 00009 &
00010). No 2 fuel oil used as standby during periods of
gas interruption for the heater/chillers (emission sources

1 boilers (emission sources 00003 &

00004).

Emission Source/Control: 00003 - Combustion
Design Capacity: 31 million Btu per hour

Emission Source/Control: 00004 - Combustion
Design Capacity: 31 million Btu per hour

Emission Source/Control: 00005 - Combustion
Design Capacity: 8.5 million Btu per hour

Emission Source/Control: 00006 - Combustion
Design Capacity: 8.5 million Btu per hour

Emission Source/Control: 00007 - Combustion
Design Capacity: 8.5 million Btu per hour

Emission Source/Control: 00008 - Combustion
Design Capacity: 11.9 million Btu per hour

Emission Source/Control: 00009 - Combustion
Design Capacity: 11.9 million Btu per hour

Emission Source/Control: 00010 - Combustion
Design Capacity: 11.9 million Btu per hour

Emission Source/Control: 00015 - Combustion
Design Capacity: 10.4 British thermal units per hour



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Emission Source/Control: 00016 - Combustion
Design Capacity: 10.4 British thermal units per hour

Item 30.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 003

Source Classification Code: 2-03-002-01

Process Description:

Firing natural gas in engine driven generators (emission sources 00011, 00012, 00013 & 00014).

Emission Source/Control: 00011 - Combustion
Design Capacity: 7.6 million Btu per hour

Emission Source/Control: 00012 - Combustion
Design Capacity: 7.6 million Btu per hour

Emission Source/Control: 00013 - Combustion
Design Capacity: 7.6 million Btu per hour

Emission Source/Control: 00014 - Combustion
Design Capacity: 7.6 million Btu per hour

**Condition 31: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 227-2.6

Item 31.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 31.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The alternate NO_x emission limit of 6.0 grams per brake horsepower-hour for each engine must be verified by conducting an emissions test for three different loads (low, medium and high).

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



The emissions testing must be performed by:

(1) submitting a compliance test protocol to the department for approval at least 30 days prior to emission testing. The conditions of the testing and the locations of the sampling devices must be specified and be acceptable to the department;

(2) utilizing the following procedures set forth in 40 CFR part 60, Appendix A or any other method acceptable to the department for determining compliance with NOx limit of 6.0 grams per brake horsepower per hour, as specified in the 9/29/2006 NOx RACT Variance and must, in addition, follow the procedures set forth in Part 202 of this Title and utilize Method 7, 7E, or 19

reference method approved by the department; and

(3) submitting a compliance test report containing the results of the emissions test to the department no later than 60 days after completion of the emission test.

Upper Permit Limit: 6.0 grams per brake horsepower-hour
Reference Test Method: SEE DESCRIPTION ABOVE
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.

part 60, Appendix A or another

every 6 calendar month(s).

Condition 32: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.4(d)

Item 32.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 001 Emission Source: 00003

Item 32.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

Condition 33: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.4(d)

Item 33.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 001 Emission Source: 00004

Item 33.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

Condition 34: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.5(c)

Item 34.1:

The Compliance Certification activity will be performed for:



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Emission Unit: U-00001
Process: 002 Emission Source: 00005

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 34.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

6.0 gram/brake horsepower-hour (g/bhp-hr) is the
alternative NOx emissions standard as demonstrated by the
NOx RACT Economic and Technological Analysis of September
29, 2006 submission.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 6.0 grams per brake horsepower-hour
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 35: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.5(c)

Item 35.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 002 Emission Source: 00006

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 35.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



6.0 gram/brake horsepower-hour (g/bhp-hr) is the alternative NO_x emissions standard as demonstrated by the NO_x RACT Economic and Technological Analysis of September 29, 2006 submission.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 6.0 grams per brake horsepower-hour
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 36: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.5(c)

Item 36.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 002 Emission Source: 00007

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 36.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:
6.0 gram/brake horsepower-hour (g/bhp-hr) is the alternative NO_x emissions standard as demonstrated by the NO_x RACT Economic and Technological Analysis of September 29, 2006 submission.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 6.0 grams per brake horsepower-hour
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.

every 6 calendar month(s).



Condition 37: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.5(c)

Item 37.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 002 Emission Source: 00008

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 37.2:

Compliance Certification shall include the following monitoring:

PROCESS OR CONTROL

DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

6.0 gram/brake horsepower-hour (g/bhp-hr) is the alternative NO_x emissions standard as demonstrated by the NO_x RACT Economic and Technological Analysis of September 29, 2006 submission.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 6.0 grams per brake horsepower-hour
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 38: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.5(c)

Item 38.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 002 Emission Source: 00009

Regulated Contaminant(s):



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

6.0 gram/brake horsepower-hour (g/bhp-hr) is the
alternative NOx emissions standard as demonstrated by the
NOx RACT Economic and Technological Analysis of September
29, 2006 submission.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 6.0 grams per brake horsepower-hour

Monitoring Frequency: DAILY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 39: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.5(c)

Item 39.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: 002

Emission Source: 00010

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

6.0 gram/brake horsepower-hour (g/bhp-hr) is the
alternative NOx emissions standard as demonstrated by the
NOx RACT Economic and Technological Analysis of September
29, 2006 submission.



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 6.0 grams per brake horsepower-hour
Monitoring Frequency: DAILY
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 40: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.4(f)(2)

Item 40.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001
Process: 003 Emission Source: 00011

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

NOx emission limit for a lean burn spark ignited natural gas fired stationary internal combustion engine. Stack testing will be required in order to demonstrate compliance with the regulatory standard. The owner or operator must submit a stack test protocol to the Department for approval prior to testing. The owner or operator shall submit stack test results, to the Department for approval, within 60 days of stack test completion.

Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 1.5 grams per brake horsepower-hour
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 41: Compliance Certification
Effective for entire length of Permit



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Applicable Federal Requirement: 6NYCRR 227-2.4(f)(2)

Item 41.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: 003

Emission Source: 00012

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 41.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

NOx emission limit for a lean burn spark ignited natural gas fired stationary internal combustion engine. Stack testing will be required in order to demonstrate compliance with the regulatory standard. The owner or

operator shall submit a stack test protocol to the

Department for approval prior to testing. The owner or operator shall submit stack test results, to the Department for approval, within 60 days of stack test completion.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 1.5 grams per brake horsepower-hour

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 42: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 227-2.4(f)(2)

Item 42.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: 003

Emission Source: 00013

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 42.2:



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

NOx emission limit for a lean burn spark ignited natural gas fired stationary internal combustion engine. Stack testing will be required in order to demonstrate compliance with the regulatory standard. The owner or

operator must submit a stack test protocol to the

Department for approval prior to testing. The owner or operator shall submit stack test results, to the Department for approval, within 60 days of stack test completion.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 1.5 grams per brake horsepower-hour

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 43: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 227-2.4(f)(2)

Item 43.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: 003

Emission Source: 00014

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 43.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

NOx emission limit for a lean burn spark ignited natural gas fired stationary internal combustion engine. Stack testing will be required in order to demonstrate compliance with the regulatory standard. The owner or operator must submit a stack test protocol to the Department for approval prior to testing. The owner or operator shall submit stack test results, to the Department for approval, within 60 days of stack test

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



completion.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 1.5 grams per brake horsepower-hour

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 44: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 44.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001

Process: 002 Emission Source: 00003

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 44.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion
installation firing oil. The owner or operator shall

allowing once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

**Condition 45: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 45.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00004

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 45.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion
installation firing oil. The owner or operator shall

monitoring once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST

METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

every 6 calendar month(s).

Condition 46: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 46.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00005

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 46.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion
installation firing oil. The owner or operator shall

allowing once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 47: Compliance Certification



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 47.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00006

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 47.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:

0.05 pounds per million Btus

installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 48: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Item 48.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00007

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 48.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall

allowing once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

**Condition 49: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 49.1:

The Compliance Certification activity will be performed for:



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00008

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 49.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:

emission limit for stationary combustion

installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

0.0 pounds per million Btus

Reference Test Method: Method 5
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 50: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 50.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00009



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 50.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall

allowing once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

**Condition 51: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 51.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00010

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



Item 51.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

emission limit for stationary combustion

installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 52: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 52.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001

Process: 002 Emission Source: 00015

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 52.2:

Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall

allowing once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

every 6 calendar month(s).

Condition 53: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 53.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001
Process: 002 Emission Source: 00016

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 53.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:

New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182



emission limit for stationary combustion

at the installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all

emission limits, terms, conditions, and

standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such

and emission control devices may be

sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must

access to any facility regulated by this

Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

**Condition 54: Contaminant List
Effective for entire length of Permit**

Applicable State Requirement: ECL 19-0301

Item 54.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

CAS No: 0NY075-00-0

Name: PARTICULATES

**Condition 55: Unavoidable noncompliance and violations
Effective for entire length of Permit**

Applicable State Requirement: 6NYCRR 201-1.4

Item 55.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superseded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.



New York State Department of Environmental Conservation

Permit ID: 2-6205-00182/00001

Facility DEC ID: 2620500182

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 56: Air pollution prohibited
Effective for entire length of Permit

Applicable State Requirement: 6NYCRR 211.2

Item 56.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.