

New York State Department of Environmental Conservation
Facility DEC ID: 2630100065



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 2-6301-00065/00002
Effective Date: _____ Expiration Date: _____

Permit Issued To: NYC HEALTH & HOSPITALS CORP
125 WORTH STREET
NEW YORK, NY 10013-4006

Contact: ROLAND NG
ELMHURST HOSPITAL CENTER
79-01 BROADWAY
ELMHURST, NY 11373
(718) 334-5252

Facility: ELMHURST HOSP-79-01 BROADWAY
79-01 BROADWAY
ELMHURST, NY 11373

Contact: ROLAND NG
ELMHURST HOSPITAL CENTER
79-01 BROADWAY
ELMHURST, NY 11373
(718) 334-5252

Description:
Elmhurst Hospital Center is a large 615 bed New York City hospital which operates four (4) boilers, six (6) emergency generators, an ethylene oxide (ETO) sterilization facility (two ETO sterilizers, one aerator, and an ETO abatement system), and twelve (12) fuel oil storage tanks.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN
DIVISION OF ENVIRONMENTAL PERMITS
ONE HUNTERS POINT PLAZA, 47-40 21ST STREET
LONG ISLAND CITY, NY 11101-5407

Authorized Signature: _____ Date: ____ / ____ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department
Relationship of this Permit to Other Department Orders and Determinations
Applications for permit renewals, modifications and transfers
Applications for Permit Renewals and Modifications
Permit modifications, suspensions or revocations by the Department
Permit Modifications, Suspensions and Revocations by the Department

Facility Level

Submission of Applications for Permit Modification or Renewal-REGION 2
HEADQUARTERS
Submission of application for permit modification or renewal-REGION 2
HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301.2(m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:



New York State Department of Environmental Conservation
Facility DEC ID: 2630100065

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Applications for Permit Renewals and Modifications
Applicable State Requirement: 6NYCRR 621.13

Item 4.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 4.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 4.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 5: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6NYCRR 621.13

Item 5.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

Condition 6: Permit Modifications, Suspensions and Revocations by the Department
Applicable State Requirement: 6NYCRR 621.14

Item 6.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;

New York State Department of Environmental Conservation
Facility DEC ID: 2630100065



- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 7: Submission of Applications for Permit Modification or Renewal-REGION 2 HEADQUARTERS
Applicable State Requirement: 6NYCRR 621.5(a)

Item 7.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997

Condition 8: Submission of application for permit modification or renewal-REGION 2 HEADQUARTERS
Applicable State Requirement: 6NYCRR 621.6(a)

Item 8.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: NYC HEALTH & HOSPITALS CORP
125 WORTH STREET
NEW YORK, NY 10013-4006

Facility: ELMHURST HOSP-79-01 BROADWAY
79-01 BROADWAY
ELMHURST, NY 11373

Authorized Activity By Standard Industrial Classification Code:
8062 - GENERAL MEDICAL & SURGICAL HOSPITALS

Permit Effective Date:

Permit Expiration Date:



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6NYCRR 201-6.5(a)(7): Fees
- 3 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 4 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 6 6NYCRR 201-6.5(e): Compliance Certification
- 7 6NYCRR 202-2.1: Compliance Certification
- 8 6NYCRR 202-2.5: Recordkeeping requirements
- 9 6NYCRR 215: Open Fires Prohibited at Industrial and Commercial Sites
- 10 6NYCRR 200.7: Maintenance of Equipment
- 11 6NYCRR 201-1.7: Recycling and Salvage
- 12 6NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6NYCRR 201-3.2(a): Exempt Sources - Proof of Eligibility
- 14 6NYCRR 201-3.3(a): Trivial Sources - Proof of Eligibility
- 15 6NYCRR 201-6.5(a)(4): Standard Requirement - Provide Information
- 16 6NYCRR 201-6.5(a)(8): General Condition - Right to Inspect
- 17 6NYCRR 201-6.5(d)(5): Standard Requirements - Progress Reports
- 18 6NYCRR 201-6.5(f)(6): Off Permit Changes
- 19 6NYCRR 202-1.1: Required Emissions Tests
- 20 6NYCRR 211.3: Visible Emissions Limited
- 21 6NYCRR 211.3: Compliance Certification
- 22 40CFR 68: Accidental release provisions.
- 23 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 24 6NYCRR 201-6: Emission Unit Definition
- 25 6NYCRR 201-7.1: Facility Permissible Emissions
- 26 6NYCRR 225.1(a)(3): Compliance Certification
- 27 6NYCRR 225.1(a)(3): Compliance Certification
- 28 6NYCRR 225.7(a): Compliance Certification

Emission Unit Level

- 29 6NYCRR 201-6: Emission Point Definition By Emission Unit
- 30 6NYCRR 201-6: Process Definition By Emission Unit
- 31 6NYCRR 201-7.1: Emission Unit Permissible Emissions
- 32 6NYCRR 201-7.1: Process Permissible Emissions

EU=0-U0001

- 33 6NYCRR 227-1.2(b): Multiple combustion sources.
- 34 6NYCRR 227-1.3(a): Compliance Certification
- 35 6NYCRR 227-2.4(d): Compliance Certification



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

EU=0-U0001,Proc=002,ES=S0001

36 6NYCRR 227.2(b)(1): Compliance Certification

EU=0-U0001,Proc=002,ES=S0002

37 6NYCRR 227.2(b)(1): Compliance Certification

EU=0-U0001,Proc=002,ES=S0003

38 6NYCRR 227.2(b)(1): Compliance Certification

EU=0-U0001,Proc=002,ES=S0004

39 6NYCRR 227.2(b)(1): Compliance Certification

EU=0-U0001,EP=E0001,Proc=002

40 6NYCRR 227-1.3: Compliance Certification

EU=0-U0002

41 6NYCRR 212.4(a): Compliance Certification

42 6NYCRR 212.6(a): Compliance Certification

EU=0-U0003

*43 6NYCRR 201-7.1: Capping Monitoring Condition

44 6NYCRR 227.2(b)(1): Compliance Certification

EU=0-U0003,Proc=001

45 6NYCRR 227-1.3: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

46 ECL 19-0301: Contaminant List

47 6NYCRR 201-1.4: Unavoidable noncompliance and violations

48 6NYCRR 211.2: Air pollution prohibited

NOTE: * preceding the condition number indicates capping.



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

**Condition 1: Acceptable Ambient Air Quality
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

Condition 3: Recordkeeping and reporting of compliance monitoring
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

Condition 4: Monitoring, Related Recordkeeping, and Reporting Requirements.
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 5: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.



(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;and
 - such additional requirements as may be specified elsewhere in this permit related to compliance certification.
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.
- iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.
- iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

USEPA Region 2
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

The address for the RAPCE is as follows:

Hunters Point Plaza
47-40 21st Street
Long Island City, NY 11101-5407

The address for the BQA is as follows:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2006.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April
15th each year for emissions of the previous calendar
year.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective for entire length of Permit



Applicable Federal Requirement: 6NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires Prohibited at Industrial and Commercial Sites
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 215

Item 9.1:

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, refuse, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT
TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period. [NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

Condition 10: Maintenance of Equipment
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage
Effective for entire length of Permit



Applicable Federal Requirement: 6NYCRR 201-1.7

Item 11.1:

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-3.2(a)

Item 13.1:

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 14: Trivial Sources - Proof of Eligibility
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-3.3(a)

Item 14.1:

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 15: Standard Requirement - Provide Information



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: General Condition - Right to Inspect
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Standard Requirements - Progress Reports
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(d)(5)

Item 17.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 18: Off Permit Changes
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6.5(f)(6)

Item 18.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

Condition 19: Required Emissions Tests
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 202-1.1

Item 19.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time. Such person shall bear the cost of measurement and preparing the report of measured emissions. Failure of such person to submit a report acceptable to the commissioner within the time stated shall be sufficient reason for the commissioner to suspend or deny a certificate to operate.

Condition 20: Visible Emissions Limited
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 211.3

Item 20.1:



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 21: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 211.3

Item 21.1:

The Compliance Certification activity will be performed for the Facility.

Item 21.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Except as permitted by a specific part of Title 6 of the NYCRR, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - weather condition
 - was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 22: Accidental release provisions.
Effective for entire length of Permit**

Applicable Federal Requirement: 40CFR 68

Item 22.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

- 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
- 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

Condition 23: Recycling and Emissions Reduction
Effective for entire length of Permit

Applicable Federal Requirement: 40CFR 82, Subpart F

Item 23.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 24: Emission Unit Definition
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6

Item 24.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 0-U0001

Emission Unit Description:

Four (4) identical union iron works boilers, each with a maximum heat input of 25.4 mmbtu/hr. The flue gas from these boilers exit through a common stack. These boilers were installed in 1954 and are not subject to NSPS regulations (applicability date 1989).

Building(s): 1

Item 24.2:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 0-U0002



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Emission Unit Description:

One (1) Ethylene Oxide (ETO) sterilization facility which consists of two (2) AMSCO ETO sterilizers and one (1) aerator hooked up to an ETO abatement system. The emissions from the ETO abatement system exit through a stack. There is no NSPS standards for this ETO sterilization facility.

Building(s): 2

Item 24.3:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 0-U0003

Emission Unit Description:

Three emergency generators burning number 2 fuel oil will be operated besides testing. Each of these generators has a heat input of 6.7 mmbtu/hr and are not subject to NSPS regulations (applies to generators above 10 mmbtu/hr).

There is also additional exempt emergency generators, burning #2 fuel oil at the facility, under this emission unit.

Building(s): 1

**Condition 25: Facility Permissible Emissions
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 201-7.1

Item 25.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0

PTE: 390,000 pounds per year

Name: OXIDES OF NITROGEN

**Condition 26: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 225.1(a)(3)

Item 26.1:

The Compliance Certification activity will be performed for the Facility.



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Item 26.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

No person shall sell, offer for sale, purchase or use any distillate oil which has sulfur content greater than 0.20 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site for a minimum of five years after the date of the last entry.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.20 percent by weight

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 27: Compliance Certification
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 225.1(a)(3)

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Item 27.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

No person shall sell, offer for sale, purchase or use any residual oil which has sulfur content greater than 0.30 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site for a minimum of five years after the date of the last entry.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: NUMBER 6 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.30 percent by weight

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Reports due 30 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 28: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 225.7(a)

Item 28.1:

The Compliance Certification activity will be performed for the Facility.

Item 28.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The permittee shall retain fuel oil supplier certifications for each shipment of oil received. Such certifications shall contain, as a minimum, supplier name, date of shipment, quantity shipped, heating value of the oil, oil sulfur content, and the method used to determine the sulfur content. Such certifications shall be available for inspection by, or submitted to, the NYSDEC as per the stated reporting requirement.

Monitoring Frequency: PER DELIVERY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

****** Emission Unit Level ******

Condition 29: Emission Point Definition By Emission Unit
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 201-6

Item 29.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 0-U0001

Emission Point: E0001

Height (ft.): 162

Diameter (in.): 84

Building: 1



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Item 29.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 0-U0002

Emission Point: E0002

Height (ft.): 175

Diameter (in.): 16

Building: 2

Item 29.3:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 0-U0003

Emission Point: E0003

Height (ft.): 18

Diameter (in.): 14

NYTMN (km.): 4511.

NYTME (km.): 594.

Building: 1

Emission Point: E0004

Height (ft.): 18

Diameter (in.): 14

NYTMN (km.): 4511.

NYTME (km.): 594.

Building: 1

Emission Point: E0005

Height (ft.): 18

Diameter (in.): 14

NYTMN (km.): 4511.

NYTME (km.): 594.

Building: 1

**Condition 30: Process Definition By Emission Unit
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 201-6

Item 30.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-U0001

Process: 002

Source Classification Code: 1-03-006-02

Process Description:

Three (3) dual-fuel combustion boilers burning number 6 fuel oil and one single fuel boiler burning number 6 fuel(emission source S0001). The flue gases from the four (4) boilers exit through a common stack.

Emission Source/Control: S0001 - Combustion

Design Capacity: 25.4 million Btu per hour

Emission Source/Control: S0002 - Combustion



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Design Capacity: 25.4 million Btu per hour

Emission Source/Control: S0003 - Combustion
Design Capacity: 25.4 million Btu per hour

Emission Source/Control: S0004 - Combustion
Design Capacity: 25.4 million Btu per hour

Item 30.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-U0001

Process: 006

Source Classification Code: 1-01-006-02

Process Description:

Three boilers burning natural gas. The flue gases from the boilers exit through a common stack.

Emission Source/Control: S0002 - Combustion
Design Capacity: 25.4 million Btu per hour

Emission Source/Control: S0003 - Combustion
Design Capacity: 25.4 million Btu per hour

Emission Source/Control: S0004 - Combustion
Design Capacity: 25.4 million Btu per hour

Item 30.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-U0002

Process: 003

Source Classification Code: 3-15-020-01

Process Description:

The ETO sterilizers utilize a 10/90 mixture of ETO and HCFC-124 to sterilize surgical equipment. The length of the sterilization cycle is two hours, while the length of the aeration cycle is 12 hours for each sterilizer. The aerator can be utilized for the aeration cycle in conjunction with either sterilizer. Emissions from the EtO sterilizer and aerators are controlled by the EtO Abatement system. The system converts EtO into carbon dioxide and water vapor through an exothermic reaction by passing the gas stream through a catalyst bed.

An electric heater heats the air and catalyst to a minimum of 320 degrees F, at which temperature the catalytic reaction is 99.9% efficient. The maximum operating temperature is 500 degrees F. If temperatures



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

exceed 500 degrees F, the system will prevent introduction of additional EtO until the proper operating temp is reached. In addition, the sterilizer units will not exhaust to the abator simultaneously. If the temperature is below the minimum 320 degrees F, then an outside contractor will be contacted to inspect the unit for malfunctions.

Twice per year, an efficiency test is conducted on the disposer unit by an outside contractor. A demonstrated efficiency less than the manufacturer's guarantee of 99.9% will result in the unit being shut down until the disposer can be repaired and a satisfactory efficiency test conducted.

Emission Source/Control: S0008 - Control
Control Type: CATALYTIC OXIDATION

Emission Source/Control: S0005 - Process
Design Capacity: 27 cubic feet

Emission Source/Control: S0006 - Process
Design Capacity: 34 cubic feet

Emission Source/Control: S0007 - Process
Design Capacity: 34 cubic feet

Item 30.4:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-U0003

Process: 001

Source Classification Code: 2-02-001-01

Process Description:

THREE EMERGENCY GENERATORS, BURNING NUMBER
2 FUEL OIL, WILL BE OPERATED DURING PEAK
LOAD CONDITIONS FOR A MAXIMUM OF 90 HOURS
IN ADDITION TO REGULAR TESTING HOURS.

Emission Source/Control: S0009 - Combustion
Design Capacity: 600 kilowatts

Emission Source/Control: S0010 - Combustion
Design Capacity: 600 kilowatts

Emission Source/Control: S0011 - Combustion
Design Capacity: 600 kilowatts



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

**Condition 31: Emission Unit Permissible Emissions
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 201-7.1

Item 31.1:

The sum of emissions from all regulated processes specified in this permit for the emission unit cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: 0-U0003

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 87.3 pounds per hour

45,000 pounds per year

**Condition 32: Process Permissible Emissions
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 201-7.1

Item 32.1:

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: 0-U0003 Process: 001

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 87.3 pounds per hour

45,000 pounds per year

**Condition 33: Multiple combustion sources.
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 227-1.2(b)

Item 33.1:

This Condition applies to Emission Unit: 0-U0001

Item 33.2:

The total heat input of all furnaces connected to the same stack or pollution control device shall be used to calculate the permissible particulate emission rate.

**Condition 34: Compliance Certification
Effective for entire length of Permit**



Applicable Federal Requirement: 6NYCRR 227-1.3(a)

Item 34.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0001

Item 34.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 35: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-2.4(d)

Item 35.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0001

Item 35.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

A boiler tune-up shall be performed annually. The owner



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

or operator of a small boiler shall maintain a log (in the format acceptable to the Department) containing the following information: (1) The date which the equipment was adjusted; and (2) The name, title, and affiliation of the person who adjusted the equipment.

Reference Test Method: Air Guide 33
Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 12 calendar month(s).

Condition 36: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 36.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0001
Process: 002 Emission Source: S0001

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 36.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Upper Permit Limit: 0.10 pounds per million Btus
Reference Test Method: Method 5
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 37: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 37.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0001
Process: 002 Emission Source: S0002

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 37.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES
Upper Permit Limit: 0.10 pounds per million Btus
Reference Test Method: Method 5
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 38: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 38.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0001

Process: 002

Emission Source: S0003

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Reports due 30 days after the reporting period.
Subsequent reports are due every 6 calendar month(s).

Condition 39: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 39.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0001
Process: 002 Emission Source: S0004

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Condition 40: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-1.3

Item 40.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0001 Emission Point: E0001
Process: 002

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired boilers which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack for each boiler which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - date and time of day
 - observer's name
 - identity of emission point
 - weather condition
 - was a plume observed?

Inclement weather conditions shall be recorded for those days when observations are prohibited. This logbook must be retained at the facility for five (5) years after the date of the last entry.

- 3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 41: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 212.4(a)

Item 41.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0002

Regulated Contaminant(s):

CAS No: 000075-21-8 ETHYLENE OXIDE

Item 41.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Emissions of EtO, a hazardous air pollutant, are

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



regulated by 6NYCRR, Part 212.4(a) which requires a minimum 99% control efficiency for "A" rated contaminants.

1. Compliance will be demonstrated by maintaining the temperature of the catalyst bed during the purge cycle at a minimum of 320 degrees F, at which temperature the catalytic reaction is 99.9% efficient. If the temperature falls below the minimum 320 degrees F, an alarm will sound and the unit will be taken out of service until an outside contractor is contacted to inspect the unit for malfunctions and the appropriate repairs made.
2. The sterilizer units will not be operated until the minimum operating temperature of 320 degrees F for the catalyst bed is reached.
3. The maximum operating temperature of the catalyst bed is 500 degrees F. If temperatures exceed 500 degrees F, the system will prevent introduction of additional EtO until the proper operating temperature is reached.
4. The sterilizer units will not exhaust to the disposer unit simultaneously.
5. Twice per year, an efficiency test will be conducted on the disposer unit by an outside contractor. A demonstrated efficiency less than the manufacturer's guarantee of 99.9% will result in the unit being shut down until the disposer can be repaired and a satisfactory efficiency test conducted.
6. The catalyst bed is to be inspected at least four times per year. The catalyst shall be inspected for thermal aging, masking, contamination, and burnout.
7. Records of all equipment inspection, repairs, preventative maintenance, efficiency testing, and follow-up activity are to be maintained on-site for the most recent five years in an accessible format and made available to Department representatives on request. Emissions from this source will be tested at least once during the term of this permit.
8. The ethylene oxide abator must be in operation whenever ethylene oxide sterilization is conducted. The operation of the ethylene oxide abator is monitored for compliance

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



in accordance with the manufacturer's instructions. The owner/operator shall maintain a log containing the following information:

- a) Date and number of sterilization loads;
- b) Quantity of Ethylene Oxides used in pounds per hour, per day and per year.
- c) Date and time of sterilizer and/or abator malfunction and maintenance performed;
- d) Records must be maintained on site for a period of five years.

9. Facility must promptly report to the Department (Region 2 RAPCE, Hunters Point Plaza, 47-40 21 Street, Long Island City, NY 11101) any abatement system deviations as indicated by the temperature of the catalyst bed being recorded as out of range (less than 320 degree Fahrenheit or more than 500 degree Fahrenheit) for an hour or more.

10. The Department must be notified within one business day of Elmhurst Hospital becoming aware of the temperature excursion.

11. Elmhurst Hospital shall submit to the Department, within 30 days of its notification to the Department, a written report on the temperature excursion, describing the nature of the malfunction, the corrective action taken and the estimated EtO emission rates.

Process Material: ETHYLENE OXIDE

Parameter Monitored: TEMPERATURE

Lower Permit Limit: 320 degrees Fahrenheit

Upper Permit Limit: 500 degrees Fahrenheit

Monitoring Frequency: CONTINUOUS

Averaging Method: RANGE - NOT TO FALL OUTSIDE OF STATED RANGE AT ANY TIME

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 42: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 212.6(a)

Item 42.1:

The Compliance Certification activity will be performed for:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



Emission Unit: 0-U0002

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

No person shall cause or allow emissions having an average opacity during any six consecutive minutes of 20 percent or greater from any process emission source, except only the emission of uncombined water. The Department reserves the right to perform or require the performance of a Method 9 opacity evaluation at any time during facility operation.

The permittee will conduct observations of visible emissions from the emission unit, process, etc. to which this condition applies at the monitoring frequency stated below while the process is in operation. The permittee will immediately investigate any instance where there is cause to believe that visible emissions above those that are normal and in compliance are occurring or have occurred from a process source.

If visible emissions above those that are normal (this may be zero percent opacity for many or all emission sources) and in compliance with section 212.6(a) are detected, the permittee shall determine the cause, make the necessary correction, and verify that the excess visible emissions problem has been corrected.

If visible emissions above those that are normal and in compliance continue to be present after corrections are made, the permittee will immediately notify The Department and conduct a Method 9 assessment within 24 hours to determine the degree of opacity.

Records of these observations, investigations and corrective actions will be kept on-site in a format acceptable to the Department and the semiannual progress report and annual compliance certifications required of all permittees subject to Title V must include a summary of these instances.

Reference Test Method: EPA Approved

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 43: Capping Monitoring Condition
Effective for entire length of Permit**

Applicable Federal Requirement: 6NYCRR 201-7.1

Item 43.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6NYCRR 231-2

Item 43.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 43.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 43.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 43.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 43.6:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0003

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



Item 43.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The emissions of oxides of nitrogen from this emission unit is limited to 22.5 tons per year. This limit will be met by restricting the number of gallons of #2 fuel oil burned annually by all six diesel generators in this emission unit to a total of 100,000 gallons. Only #2 fuel oil (i.e., diesel fuel) shall be burned in these diesel generators.

The permittee must maintain a log of the number of gallons of oil fired in each of the three diesel engines along with an annual rolling daily total of the number of gallons burned by the engines in this emission unit. This log will be available to the Department for inspection upon request during normal business hours.

The permittee's compliance with this condition must be summarized in the semiannual report and annual compliance certification required under this permit.

Work Practice Type: PROCESS MATERIAL THRUPUT

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Upper Permit Limit: 100000 gallons per year

Reference Test Method: EPA approved

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 44: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227.2(b)(1)

Item 44.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0003



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 44.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emission of particulates from each of the diesel engines in this emission unit is limited to 0.10 pounds per million Btu on a two hour average basis. To demonstrate compliance with this limit, the owner or operator shall, within 180 days of the issuance of this permit, submit to the Department an acceptable protocol for the testing of the particulates limit cited in this condition. Upon approval of this protocol by the Department, the permittee must:

- 1) Perform a stack test within 30 days of the approval of the protocol to determine compliance with the Particulates limit cited in this condition, as per the approved protocol.
- 2) Submit the stack test results to the Department within 30 days of the performance of the test, and
- 3) Maintain all records at the facility for a minimum of five years.

The results of any testing must be included in the semiannual report and annual compliance certification required under this permit.

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: AVERAGING METHOD - SEE MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

Condition 45: Compliance Certification
Effective for entire length of Permit

Applicable Federal Requirement: 6NYCRR 227-1.3



Item 45.1:

The Compliance Certification activity will be performed for:

Emission Unit: 0-U0003
Process: 001

Item 45.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired internal combustion engines which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack for each internal combustion engine which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - weather condition
 - was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

- 3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions

New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065



or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

**Condition 46: Contaminant List
Effective for entire length of Permit**

Applicable State Requirement: ECL 19-0301

Item 46.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000075-21-8

Name: ETHYLENE OXIDE

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

CAS No: 0NY075-00-0

Name: PARTICULATES

**Condition 47: Unavoidable noncompliance and violations
Effective for entire length of Permit**

Applicable State Requirement: 6NYCRR 201-1.4

Item 47.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant



New York State Department of Environmental Conservation

Permit ID: 2-6301-00065/00002

Facility DEC ID: 2630100065

emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 48: Air pollution prohibited
Effective for entire length of Permit

Applicable State Requirement: 6NYCRR 211.2

Item 48.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.