



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 2-6301-00084/00015
Mod 0 Effective Date: 03/17/2008 Expiration Date: 03/16/2013
Mod 1 Effective Date: 07/02/2009 Expiration Date: 03/16/2013
Mod 2 Effective Date: 01/19/2012 Expiration Date: 03/16/2013

Permit Issued To: NEW YORK POWER AUTHORITY
123 MAIN ST
WHITE PLAINS, NY 10601

Contact: KOLLI M RAO
NEW YORK POWER AUTHORITY
123 MAIN STREET
WHITE PLAINS, NY 10601
(914) 681-6387

Facility: POLETTI POWER PROJECT
31-03 20TH AVE
ASTORIA, NY 11105

Description:

This modification is just for records that facility's plant with DEC Id # 2-6301-00084/00010 consisting of Emission Unit # U-00001 was closed on January 30, 2010. The facility submitted an application, dated July 21, 2010 for Emission Reduction Credits (ERCs) for the Nitrogen Oxides (NOx), Volatile Organic Compounds (VOCs) and Particulate Matter (PM 2.5). The Department (NYSDEC) reviewed the ERC application and agreed to approve the ERCs listed in condition under 6 NYCRR part 231-10.2. This approval of credits does not affect the functioning of the facility's plant with DEC Id # 2-6301-00084/00015, which has its own Title V Air permit.

New York State Department of Environmental Conservation
Facility DEC ID: 2630100084



By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN
 NYSDEC
 47-40 21ST ST
 LONG ISLAND CITY, NY 11101-5407

Authorized Signature: _____ Date: ____ / ____ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
 - Applications for permit renewals, modifications and transfers
 - Permit modifications, suspensions or revocations by the Department
 - Permit modifications, suspensions or revocations by the Department
 - Permit modifications, suspensions or revocations by the Department

Facility Level

- Submission of application for permit modification or renewal -
REGION 2 HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted to the Department for approval.



Condition 1-1: Permit modifications, suspensions or revocations by the Department

Applicable State Requirement: 6 NYCRR 621.13

Item 1-1.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

Condition 4: Permit modifications, suspensions or revocations by the Department

Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

Condition 2-1: Permit modifications, suspensions or revocations by the Department

Applicable State Requirement: 6 NYCRR 621.13

Item 2-1.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.



****** Facility Level ******

**Condition 5: Submission of application for permit modification or renewal - REGION 2
HEADQUARTERS**

Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 2 Headquarters
Division of Environmental Permits
1 Hunters Point Plaza, 4740 21st Street
Long Island City, NY 11101-5407
(718) 482-4997



Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: NEW YORK POWER AUTHORITY
123 MAIN ST
WHITE PLAINS, NY 10601

Facility: POLETTI POWER PROJECT
31-03 20TH AVE
ASTORIA, NY 11105

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Mod 0 Permit Effective Date: 03/17/2008

Permit Expiration Date: 03/16/2013

Mod 1 Permit Effective Date: 07/02/2009

Permit Expiration Date: 03/16/2013

Mod 2 Permit Effective Date: 01/19/2012

Permit Expiration Date: 03/16/2013



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 2-1 6 NYCRR 201-6.5 (a) (7): Fees
- 2 6 NYCRR 201-6.5 (a) (7): Fees
- 3 6 NYCRR 201-6.5 (c): Recordkeeping and reporting of compliance monitoring
- 4 6 NYCRR 201-6.5 (c) (2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6 NYCRR 201-6.5 (c) (3) (ii): Compliance Certification
- 6 6 NYCRR 201-6.5 (e): Compliance Certification
- 7 6 NYCRR 202-2.1: Compliance Certification
- 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 9 6 NYCRR Part 215: Open Fires Prohibited at Industrial and Commercial Sites
- 2-2 6 NYCRR 215.2: Open Fires - Prohibitions
- 10 6 NYCRR 200.7: Maintenance of Equipment
- 11 6 NYCRR 201-1.7: Recycling and Salvage
- 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 15 6 NYCRR 201-6.5 (a) (4): Standard Requirement - Provide Information
- 16 6 NYCRR 201-6.5 (a) (8): General Condition - Right to Inspect
- 17 6 NYCRR 201-6.5 (d) (5): Standard Requirements - Progress Reports
- 18 6 NYCRR 201-6.5 (f) (6): Off Permit Changes
- 2-3 6 NYCRR 202-1.1: Required Emissions Tests
- 19 6 NYCRR 202-1.1: Required Emissions Tests
- 20 6 NYCRR 211.3: Visible Emissions Limited
- 21 6 NYCRR 211.3: Compliance Certification
- 22 6 NYCRR 211.3: Compliance Certification
- 23 40 CFR Part 68: Accidental release provisions.
- 24 40 CFR 82, Subpart F: Recycling and Emissions Reduction
- 25 6 NYCRR Subpart 201-6: Steady state and fuel switching emission limit applicability.
- 26 6 NYCRR Subpart 201-6: Emission Unit Definition
- 27 6 NYCRR Subpart 201-6: Compliance Certification
- 28 6 NYCRR 202-1.5: Prohibitions
- 29 6 NYCRR 204-1.6: Permit requirements (To be included only in new permits or units).
- 30 6 NYCRR 204-2.1: Submissions to the Department.
- 31 6 NYCRR 204-4.1: Compliance Certification
- 32 6 NYCRR 204-7.1: Submission of NOx allowance transfers.
- 33 6 NYCRR 204-8.1: Requirements for installation, certification, and data accounting.
- 34 6 NYCRR 204-8.2: Requirements for recertification of monitoring systems.
- 35 6 NYCRR 204-8.2: Compliance Certification
- 36 6 NYCRR 204-8.3: Out of control periods.



- 37 6 NYCRR 204-8.4: Compliance Certification
 - 38 6 NYCRR 204-8.7: Compliance Certification
 - 39 6 NYCRR Part 207: Submittal of Episode Action Plans
 - 2-4 6 NYCRR 211.1: Air pollution prohibited
 - 40 6 NYCRR 225-1.2 (d): Compliance Certification
 - 2-5 6 NYCRR 231-10.2: Compliance Certification
 - 1-1 6 NYCRR 243-1.6 (a): Permit Requirements
 - 1-2 6 NYCRR 243-1.6 (b): Monitoring requirements
 - 1-3 6 NYCRR 243-1.6 (c): NOx Ozone Season Emission Requirements
 - 1-4 6 NYCRR 243-1.6 (d): Excess emission requirements
 - 1-5 6 NYCRR 243-1.6 (e): Recordkeeping and reporting requirements
 - 1-6 6 NYCRR 243-2.1: Authorization and responsibilities of CAIR
designated representative
 - 1-7 6 NYCRR 243-2.4: Certificate of representation
 - 1-8 6 NYCRR 243-8.1: General requirements
 - 1-9 6 NYCRR 243-8.1: Prohibitions
 - 1-10 6 NYCRR 243-8.5 (d): Quarterly reports
 - 1-11 6 NYCRR 243-8.5 (e): Compliance certification
 - 1-12 6 NYCRR Subpart 244-1: CAIR NOx Annual Trading Program General
Conditions
 - 1-13 6 NYCRR Subpart 244-2: Designated CAIR Representative
 - 1-14 6 NYCRR Subpart 244-8: Compliance Certification
 - 1-15 6 NYCRR Subpart 245-1: CAIR SO2 Trading Program General Provisions
 - 1-16 6 NYCRR Subpart 245-2: Designated CAIR Representative
 - 1-17 6 NYCRR Subpart 245-8: Compliance Certification
 - 41 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
 - 42 40CFR 60.7(a), NSPS Subpart A: Date of construction notification -
If a COM is not used.
 - 43 40CFR 60.7(a), NSPS Subpart A: Date of Construction Notification -
if a COM is used
 - 44 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
 - 45 40CFR 60.7(d), NSPS Subpart A: Excess emissions report.
 - 46 40CFR 60.7(f), NSPS Subpart A: Facility files for subject sources.
 - 47 40CFR 60.8(a), NSPS Subpart A: Performance testing timeline.
 - 48 40CFR 60.8(b), NSPS Subpart A: Performance test methods.
 - 49 40CFR 60.8(c), NSPS Subpart A: Required performance test information.
 - 50 40CFR 60.8(d), NSPS Subpart A: Prior notice.
 - 51 40CFR 60.8(e), NSPS Subpart A: Performance testing facilities.
 - 52 40CFR 60.8(f), NSPS Subpart A: Number of required tests.
 - 53 40CFR 60.9, NSPS Subpart A: Availability of information.
 - 54 40CFR 60.11, NSPS Subpart A: Opacity standard compliance testing.
 - 55 40CFR 60.12, NSPS Subpart A: Circumvention.
 - 56 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
 - 57 40CFR 60.14, NSPS Subpart A: Modifications.
 - 58 40CFR 60.15, NSPS Subpart A: Reconstruction
 - 59 40 CFR Part 72: Facility Subject to Title IV Acid Rain Regulations
and Permitting
- Emission Unit Level**
- 60 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
 - 61 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

EU=U-00003



- 62 6 NYCRR 227-1.3 (a): Compliance Certification
- 63 6 NYCRR 231-2.6: Compliance Certification
- 64 6 NYCRR 231-2.6: Compliance Certification
- 65 6 NYCRR 231-2.6: Compliance Certification
- 66 6 NYCRR 231-2.9: Compliance Certification
- 67 40CFR 52.21, Subpart A: Compliance Certification
- 68 40CFR 52.21, Subpart A: Compliance Certification
- 69 40CFR 60.334(b), NSPS Subpart GG: Compliance Certification

EU=U-00003,Proc=PC1

- 70 6 NYCRR 227-2.4 (e) (2) (i): Compliance Certification
- 71 6 NYCRR 231-2.5 (a): Compliance Certification
- 72 6 NYCRR 231-2.5 (a): Compliance Certification
- 73 6 NYCRR 231-2.5 (a): Compliance Certification
- 74 6 NYCRR 231-2.5 (a): Compliance Certification
- 75 6 NYCRR 231-2.5 (a): Compliance Certification
- 76 6 NYCRR 231-2.5 (a): Compliance Certification
- 77 40CFR 52.21(j), Subpart A: Compliance Certification
- 78 40CFR 52.21(j), Subpart A: Compliance Certification
- 79 40CFR 52.21(j), Subpart A: Compliance Certification
- 80 40CFR 52.21(j), Subpart A: Compliance Certification
- 81 40CFR 52.21(j), Subpart A: Compliance Certification

EU=U-00003,Proc=PC2

- 82 6 NYCRR 201-6.1: Compliance Certification
- 83 6 NYCRR 227-2.4 (e) (2) (ii): Compliance Certification
- 84 6 NYCRR 231-2.5 (a): Compliance Certification
- 85 6 NYCRR 231-2.5 (a): Compliance Certification
- 86 6 NYCRR 231-2.5 (a): Compliance Certification
- 87 6 NYCRR 231-2.5 (a): Compliance Certification
- 88 6 NYCRR 231-2.5 (a): Compliance Certification
- 89 6 NYCRR 231-2.5 (a): Compliance Certification
- 90 40CFR 52.21(j), Subpart A: Compliance Certification
- 91 40CFR 52.21(j), Subpart A: Compliance Certification
- 92 40CFR 52.21(j), Subpart A: Compliance Certification
- 93 40CFR 52.21(j), Subpart A: Compliance Certification
- 94 40CFR 52.21(j), Subpart A: Compliance Certification
- 95 40CFR 52.21(j), Subpart A: Compliance Certification
- 96 40CFR 60.333(b), NSPS Subpart GG: Compliance Certification

EU=U-00003,Proc=PC3

- 97 6 NYCRR 227.2 (b) (1): Compliance Certification

EU=U-00003,EP=0003A,Proc=PC1,ES=CC03A

- 98 6 NYCRR 231-2.5 (a): Compliance Certification
- 99 6 NYCRR 231-2.5 (a): Compliance Certification
- 100 6 NYCRR 231-2.5 (a): Compliance Certification
- 101 40CFR 52.21(j), Subpart A: Compliance Certification
- 102 40CFR 52.21(j), Subpart A: Compliance Certification
- 103 40CFR 52.21(j), Subpart A: Compliance Certification

EU=U-00003,EP=0003A,Proc=PC2,ES=CC03A



- 104 6 NYCRR 231-2.5 (a): Compliance Certification
- 105 6 NYCRR 231-2.5 (a): Compliance Certification
- 106 6 NYCRR 231-2.5 (a): Compliance Certification
- 107 40CFR 52.21(j), Subpart A: Compliance Certification
- 108 40CFR 52.21(j), Subpart A: Compliance Certification
- 109 40CFR 52.21(j), Subpart A: Compliance Certification

EU=U-00003,EP=0003B,Proc=PC1,ES=CC03B

- 110 6 NYCRR 231-2.5 (a): Compliance Certification
- 111 6 NYCRR 231-2.5 (a): Compliance Certification
- 112 6 NYCRR 231-2.5 (a): Compliance Certification
- 113 40CFR 52.21(j), Subpart A: Compliance Certification
- 114 40CFR 52.21(j), Subpart A: Compliance Certification
- 115 40CFR 52.21(j), Subpart A: Compliance Certification

EU=U-00003,EP=0003B,Proc=PC2,ES=CC03B

- 116 6 NYCRR 231-2.5 (a): Compliance Certification
- 117 6 NYCRR 231-2.5 (a): Compliance Certification
- 118 6 NYCRR 231-2.5 (a): Compliance Certification
- 119 40CFR 52.21(j), Subpart A: Compliance Certification
- 120 40CFR 52.21(j), Subpart A: Compliance Certification
- 121 40CFR 52.21(j), Subpart A: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 122 ECL 19-0301: Contaminant List
- 1-18 6 NYCRR 201-1.4: Unavoidable noncompliance and violations
- 1-19 6 NYCRR 211.2: Air pollution prohibited
- 2-6 6 NYCRR 211.2: Visible Emissions Limited



FEDERALLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.3 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR 201-6.3 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR 201-6.5 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.5 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.5 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR 201-6.5 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.



Item I: Severability - 6 NYCRR 201-6.5 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR 201-6.5 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR 201-6.5 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is



three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York



(NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

Condition 1: Acceptable Ambient Air Quality
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2-1: Fees
Effective between the dates of 01/19/2012 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (7)

Item 2-1.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 2: Fees
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (7)

Item 2.1:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

**Condition 3: Recordkeeping and reporting of compliance monitoring
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR 201-6.5 (c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

**Condition 4: Monitoring, Related Recordkeeping, and Reporting
Requirements.
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR 201-6.5 (c) (2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

**Condition 5: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR 201-6.5 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.



Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant or a toxic air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.



If any of the above conditions are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) through (4) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraph (1) through (4) of this section must also be identified in the 6 month monitoring report required above.

If the permittee seeks to have a violation excused as provided in 201-1.4, the permittee shall report such violations as required under 201-1.4(b). However, in no case may reports of any deviation be on a less frequent basis than those described in paragraphs (1) through (4) above. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office). Mailing addresses for the above referenced persons are contained



in the monitoring condition for 6 NYCRR Part 201-6.5(e),
contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement: 6 NYCRR 201-6.5 (e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

i. Compliance certifications shall contain:

- the identification of each term or condition of the permit that is the basis of the certification;
- the compliance status;
- whether compliance was continuous or intermittent;
- the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
- such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions; and
- such additional requirements as may be specified elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

The address for the RAPCE is as follows:

Hunters Point Plaza
47-40 21st Street
Long Island City, NY 11101-5407

The address for the BCME is as follows:

NYSDEC
Bureau of Compliance Monitoring
and Enforcement
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires Prohibited at Industrial and Commercial Sites
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Part 215

Item 9.1:

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, refuse, rubbish for salvage, or rubbish generated by industrial or commercial activities.

Condition 2-2: Open Fires - Prohibitions
Effective between the dates of 01/19/2012 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 215.2

Item 2-2.1:

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 2-2.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of



this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.

- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 10: Maintenance of Equipment
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement: 6 NYCRR 200.7



Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-1.7

Item 11.1:

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 13.1:

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 14: Trivial Sources - Proof of Eligibility
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 14.1:

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for



a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 15: Standard Requirement - Provide Information
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: General Condition - Right to Inspect
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-6.5 (a) (8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Standard Requirements - Progress Reports
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-6.5 (d) (5)

Item 17.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:



(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 18: Off Permit Changes
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 201-6.5 (f) (6)

Item 18.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

Condition 2-3: Required Emissions Tests
Effective between the dates of 01/19/2012 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 2-3.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Required Emissions Tests
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 19.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Such person shall bear the cost of measurement and preparing the report of measured emissions. Failure of such person to submit a report acceptable to the commissioner within the time stated shall be sufficient reason for the commissioner to suspend or deny a certificate to operate.

Condition 20: Visible Emissions Limited
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 211.3

Item 20.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 21: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 211.3

Item 21.1:

The Compliance Certification activity will be performed for the Facility.

Item 21.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Except as permitted by a specific part of Title 6 of the NYCRR, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition



- was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY
Upper Permit Limit: 57 percent
Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Averaging Method: ONE CONTINUOUS 6-MINUTE PERIOD PER HOUR
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 22: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 211.3

Item 22.1:
The Compliance Certification activity will be performed for the Facility.

Item 22.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL



DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Except as permitted by a specific part of Title 6 of the NYCRR, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - weather condition
 - was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



stack.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

**Condition 23: Accidental release provisions.
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:40 CFR Part 68

Item 23.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

**Condition 24: Recycling and Emissions Reduction
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:40CFR 82, Subpart F

Item 24.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.



Condition 25: Steady state and fuel switching emission limit applicability.

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 25.1: The emission limits for NOx, CO, and ammonia are monitored by continuous emissions monitors (CEMs), and apply only during periods of steady state operation of the turbines. The owner or operator is required to develop emission limits for these pollutants during periods of start-up, shutdown, and fuel switching for both natural gas and distillate oil firing modes of operation.

Condition 26: Emission Unit Definition

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 26.1(From Mod 0):

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00003

Emission Unit Description:

EMISSION UNIT U00003 REPRESENTS TWO GE S207FA COMBUSTION TURBINES RATED AT 1779 MMBTU/HR WHEN FIRING NATURAL GAS (THE PRIMARY FUEL) AT 54.6 D F AND 2,041 MMBTU/HR WHEN FIRING KEROSENE (BACK-UP FUEL) AT -5 D F. THE TWO TURBINES WILL EACH VENT TO SEPARATE FLUE (EP0003A AND EP0003B) . THE "COMBINED CYCLE FACILITY" WILL GENERATE APPROXIMATELY 500 MW OF POWER.

Building(s): CCNYPA1

Condition 27: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Item 27.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator shall, within one year following the commencement of commercial operation, submit start-up, shutdown, and fuel switching data with an application for



permit modification to establish enforceable combustion turbine start-up, shutdown, and fuel switching emission rates for NO_x, CO, and NH₃, and confirm that such established rates would not result in a violation of applicable NAAQS. In the event that a minimum of 15 start-ups and 15 shutdowns, while firing distillate oil, does not occur within the one year period defined above, the owner or operator will be required to submit start-up and shutdown data with an application for permit modification once the 15 start-ups and shutdowns when firing distillate oil occur. Also, if a minimum of 15 fuel switches do not occur within the one year period defined above, the owner or operator will be required to submit fuel switching data with an application for permit modification once the 15 fuel switches occur.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 28: Prohibitions
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 202-1.5

Item 28.1:

No person shall conceal an emission by the use of air or other gaseous diluents to achieve compliance with an emission standard which is based on the concentration of a contaminant in the gases emitted through a stack.

Condition 29: Permit requirements (To be included only in new permits or units).

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 204-1.6

Item 29.1: The NO_x authorized account representative of each NO_x budget unit shall submit to the Department a complete NO_x Budget permit application (as defined under Section 204-3.3) no later than 12 months before the date on which the NO_x Budget unit commences operation.

Condition 30: Submissions to the Department.

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 204-2.1

Item 30.1: Each submission under the NO_x Budget Trading Program shall be submitted, signed and certified by the NO_x authorized account representative for each NO_x Budget source on behalf of which the submission is made. Each submission shall include a certification statement (as stated in paragraph 204-2.4(a)(4)) by the NO_x authorized account representative.

Condition 31: Compliance Certification



Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 204-4.1

Item 31.1:

The Compliance Certification activity will be performed for the Facility.

Item 31.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

For each control period in which one or more NOx Budget units at a source are subject to the NOx Budget emissions limitation, the NOx authorized account representative of the source shall submit to the Department and the Administrator by November 30 of that year, a compliance certification report for each source covering all such units.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 32: Submission of NOx allowance transfers.

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 204-7.1

Item 32.1: The NOx authorized account representatives seeking recordation of a NOx allowance transfer shall submit the transfer to the Administrator. To be considered correctly submitted, the NOx allowance transfer shall include the following elements in a format specified by the Administrator:

- (a) The numbers identifying both the transferor and transferee accounts;
- (b) A specification by serial number of each NOx allowance to be transferred; and
- (c) The printed name and signature of the NOx authorized account representative of the transferor account and the date signed.

Condition 33: Requirements for installation, certification, and data accounting.

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 204-8.1

Item 33.1: The owner or operator of each NOx Budget unit must meet the following requirements. These provisions also apply to a unit for which an application for a NOx Budget opt-in permit is submitted and not denied or withdrawn, as provided in Subpart 204-9:

- (1) Install all monitoring systems required under this Subpart for monitoring NOx mass. This includes all systems required to monitor NOx emission rate, NOx concentration, heat input, and flow, in accordance with 40 CFR 75.71 and 75.72.
- (2) Install all monitoring systems for monitoring heat input, if required under Section 204-8.7 for developing NOx allowance allocations.



(3) Successfully complete all certification tests required under Section 204-8.2 and meet all other provisions of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraphs (a)(1) and (2) of this section.

(4) Record and report data from the monitoring systems under paragraphs (a)(1) and (2) of this section.

**Condition 34: Requirements for recertification of monitoring systems.
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR 204-8.2

Item 34.1: Whenever the owner or operator makes a replacement, modification, or change in a certified monitoring system that the Administrator or the Department determines significantly affects the ability of the system to accurately measure or record NO_x mass emissions or heat input or to meet the requirements of 40 CFR 75.21 or Appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system according to 40 CFR 75.20(b). Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that the Administrator or the Department determines to significantly change the flow or concentration profile, the owner or operator shall recertify the continuous emissions monitoring system according to 40 CFR 75.20(b). Examples of changes which require recertification include: replacement of the analyzer, change in location or orientation of the sampling probe or site, or changing of flow rate monitor polynomial coefficients.

**Condition 35: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR 204-8.2

Item 35.1:
The Compliance Certification activity will be performed for the Facility.

Item 35.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of a NO_x Budget unit under paragraphs (b)(2) or (b)(3) of this section must determine, record and report NO_x mass, heat input (if required for purposes of allocations) and any other values required to determine NO_x Mass (e.g. NO_x emission rate and heat input or NO_x concentration and stack flow) using the provisions of 40 CFR 75.70(g), from the date and hour that the unit starts operating until all required certification tests are successfully completed.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 36: Out of control periods.
Effective between the dates of 03/17/2008 and 03/16/2013**



Applicable Federal Requirement:6 NYCRR 204-8.3

Item 36.1: Whenever any monitoring system fails to meet the quality assurance requirements of Appendix B of 40 CFR Part 75, data shall be substituted using the applicable procedures in Subpart D, Appendix D, or Appendix E of 40 CFR Part 75.

**Condition 37: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR 204-8.4

Item 37.1:

The Compliance Certification activity will be performed for the Facility.

Item 37.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The Authorized Account Representative for a NOx Budget unit shall submit written notice to the Department and the USEPA Administrator in accordance with the requirements of this subpart as follows:

All monitoring plans or monitoring plan modifications; compliance certifications, recertifications and quarterly QA/QC reports; and, petitions for alternative monitoring, shall be submitted to the USEPA Administrator (or his/her representatives) as well as two copies to the Department (one copy to the Regional Air Pollution Control Engineer (RAPCES) in the regional office and one copy to the Bureau of Compliance Monitoring and Enforcement (BCME) in the DEC central office. All Authorized Account Representative changes shall be sent to the NYSDEC central office.

All quarterly emission data shall be electronically filed with the USEPA Clean Air Markets Division with a copy (disc or hard copy) to the NYSDEC offices.

The address for the USEPA Administrator is as follows:

USEPA Clean Air Markets Division
401 M Street SW (6204J)
Washington D.C. 20460

CEM Coordinator
USEPA-Region 2
2890 Woodbridge Avenue
Edison, N.J. 08837

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



The address for the BCME is as follows:

NYSDEC
Bureau of Compliance Monitoring and Enforcement
625 Broadway, 2nd Floor
Albany N.Y. 12233-3258

AAR changes should be sent to the attention of:

NYSDEC
Stationary Source Planning Section
Bureau of Air Quality Planning
625 Broadway, 2nd Floor
Albany NY 12233-3251

The address for the RAPCE is as follows:

Hunters Point Plaza
47-20 21st Street
Long Island City, NY 11101-5407

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 38: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 204-8.7

Item 38.1:

The Compliance Certification activity will be performed for the Facility.

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of a unit that elects to monitor and report NOx Mass emissions using a NOx concentration system and a flow system shall also monitor and report heat input at the unit level using the procedures set forth in 40 CFR Part 75.

Monitoring Frequency: HOURLY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 39: Submittal of Episode Action Plans
Effective between the dates of 03/17/2008 and 03/16/2013



Applicable Federal Requirement:6 NYCRR Part 207

Item 39.1:

An episode action plan must be submitted for approval by the Department in accordance with the requirements of 6NYCRR Part 207. The plan shall contain detailed steps which will be taken by the facility to reduce air contaminant emissions during each stage of an air pollution episode. Once approved, the facility shall take whatever actions are prescribed by the episode action plan when an air pollution episode is in effect.

Condition 2-4: Air pollution prohibited
Effective between the dates of 01/19/2012 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 211.1

Item 2-4.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 40: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 225-1.2 (d)

Item 40.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

NYP&A WILL UTILIZE KEROSENE FUEL OIL CONTAINING A MAXIMUM 0.04% SULFUR BY WEIGHT AT THE FACILITY. NYP&A IS PROPOSING COMPLIANCE BY TAKING A SAMPLE OF KEROSENE FUEL OIL FROM THE BULK STORAGE TANK AFTER EACH OIL DELIVERY AND TESTING THE SAMPLE FOR SULFUR CONTENT. A LOG OF THE SULFUR CONTENT IN OIL PER DELIVERY MUST BE MAINTAINED ON SITE FOR A MINIMUM OF FIVE YEARS AFTER THE DATE OF LAST ENTRY.



Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: OIL (NOT ELSEWHERE CLASSIFIED)
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.04 percent by weight
Reference Test Method: ASTM METH D4294
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY
TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 2-5: Compliance Certification
Effective between the dates of 01/19/2012 and 03/16/2013

Applicable Federal Requirement: 6 NYCRR 231-10.2

Item 2-5.1:

The Compliance Certification activity will be performed for the Facility.

Item 2-5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

This plant with the DEC id # 2-6301-00084/00010 consisting of Emission Unit # U-00001 was closed on January 30, 2010. The facility submitted an application, dated July 21, 2010 for Emission Reduction Credits (ERCs) for the Nitrogen Oxides (NOx), Volatile Organic Compounds (VOCs) and Particulate Matter (PM 2.5). The Department (NYSDEC) reviewed the ERC application and agreed to approve the ERCs as follows:

		NOx	VOCs	PM 2.5
ERCs approved (tons)	1,554.0	48.60		
	93.60			

The quantity of approved VOC and PM2.5 is slightly less than requested to reflect the quantities reported in the Unit's emission inventories for 2007 and 2008.

These ERCs were noticed in ENB on October 26, 2011 under DEC id # 2-6301-00084/00020. This is just for records and does not require further monitoring or reporting. This approval of credits does not affect the functioning of the facility's other plant with DEC Id # 2-6301-00084/00015, which has its own Title V Air permit. This is for records and does not require reporting

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 1-1: Permit Requirements
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-1.6 (a)

Item 1-1.1:

The CAIR designated representative of each CAIR NO_x Ozone Season source shall:

- (i) submit to the department a complete CAIR permit application under section 243-3.3 in accordance with the deadlines specified in section 243-3.2; and
- (ii) submit in a timely manner any supplemental information that the department determines is necessary in order to review a CAIR permit application and issue or deny a CAIR permit.

The owners and operators of each CAIR NO_x Ozone Season source shall have a CAIR permit issued by the department under Subpart 243-3 for the source and operate the source and the unit in compliance with such CAIR permit.

Condition 1-2: Monitoring requirements
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-1.6 (b)

Item 1-2.1:

The emissions measurements recorded and reported in accordance with Subpart 243-8 shall be used to determine compliance by each CAIR NO_x Ozone Season source with the CAIR NO_x Ozone Season emissions limitation under subdivision (c) of this section.

Condition 1-3: NO_x Ozone Season Emission Requirements
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-1.6 (c)

Item 1-3.1:

As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO_x Ozone Season allowances available for compliance deductions for the control period under section 243-6.5(a) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NO_x Ozone Season units at the source, as determined in accordance with Subpart 243-8. The CAIR NO_x ozone season is the period beginning May 1 of a calendar year, except as provided in section 243-1.6(c)(2), and ending on September 30 of the same year, inclusive.

A CAIR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(1) of this section for the control period starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under sections 243-8.1(b)(1), (2), (3), or (7) and for each control period thereafter.

A CAIR NO_x Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (c)(1) of this section, for a control period in a calendar year before



the year for which the CAIR NO_x Ozone Season allowance was allocated.

CAIR NO_x Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO_x Ozone Season Allowance Tracking System accounts in accordance with Subparts 243-6, 243-7, and 243-9.

A CAIR NO_x Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NO_x Ozone Season Trading Program. No provision of the CAIR NO_x Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under section 243-1.5 and no provision of law shall be construed to limit the authority of the State or the United States to terminate or limit such authorization.

A CAIR NO_x Ozone Season allowance does not constitute a property right.

Upon recordation by the Administrator under Subpart 243-6, 243-7, or 243-9, every allocation, transfer, or deduction of a CAIR NO_x Ozone Season allowance to or from a CAIR NO_x Ozone Season source's compliance account is incorporated automatically in any CAIR permit of the source.

Condition 1-4: Excess emission requirements
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-1.6 (d)

Item 1-4.1:

If a CAIR NO_x Ozone Season source emits nitrogen oxides during any control period in excess of the CAIR NO_x Ozone Season emissions limitation, then:

(1) the owners and operators of the source and each CAIR NO_x Ozone Season unit at the source shall surrender the CAIR NO_x Ozone Season allowances required for deduction under section 243-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law; and

(2) each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law.

Condition 1-5: Recordkeeping and reporting requirements
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-1.6 (e)

Item 1-5.1:

Unless otherwise provided, the owners and operators of the CAIR NO_x Ozone Season source and each CAIR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator.

(i) The certificate of representation under section 243-2.4 for the CAIR designated representative for the source and each CAIR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such



five-year period until such documents are superseded because of the submission of a new certificate of representation under section 243-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with Subpart 243-8, provided that to the extent that Subpart 243-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NOx Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NOx Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NOx Ozone Season Trading Program.

Condition 1-6: Authorization and responsibilities of CAIR designated representative

Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-2.1

Item 1-6.1:

Except as provided under section 243-2.2, each CAIR NOx Ozone Season source, including all CAIR NOx Ozone Season units at the source, shall have one and only one CAIR designated representative, with regard to all matters under the CAIR NOx Ozone Season Trading Program concerning the source or any CAIR NOx Ozone Season unit at the source.

The CAIR designated representative of the CAIR NOx Ozone Season source shall be selected by an agreement binding on the owners and operators of the source and all CAIR NOx Ozone Season units at the source and shall act in accordance with the certification statement in section 243-2.4(a)(4)(iv).

Upon receipt by the Administrator of a complete certificate of representation under section 243-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NOx Ozone Season source represented and each CAIR NOx Ozone Season unit at the source in all matters pertaining to the CAIR NOx Ozone Season Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source or unit.

No CAIR permit will be issued, no emissions data reports will be accepted, and no CAIR NOx Ozone Season Allowance Tracking System account will be established for a CAIR NOx Ozone Season unit at a source, until the Administrator has received a complete certificate of representation under section 243-2.4 for a CAIR designated representative of the source and the CAIR NOx Ozone Season units at the source.

Each submission under the CAIR NOx Ozone Season Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NOx Ozone Season source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the



submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

Condition 1-7: Certificate of representation
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-2.4

Item 1-7.1:

Unless otherwise required by the department or the Administrator, documents of agreement referred to in the certificate of representation shall not be submitted to the department or the Administrator. Neither the department nor the Administrator shall be under any obligation to review or evaluate the sufficiency of such documents, if submitted.

Condition 1-8: General requirements
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-8.1

Item 1-8.1:

The owners and operators, and to the extent applicable, the CAIR designated representative, of a CAIR NOx Ozone Season unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this Subpart and in Subpart H of 40 CFR Part 75. For purposes of complying with such requirements, the definitions in section 243-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR NOx Ozone Season unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 243-1.2. The owner or operator of a unit that is not a CAIR NOx Ozone Season unit but that is monitored under 40 CFR 75.72(b)(2)(ii) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR NOx Ozone Season unit.

'Requirements for installation, certification, and data accounting.' The owner or operator of each CAIR NOx Ozone Season unit shall:

- (1) install all monitoring systems required under this Subpart for monitoring NOx mass emissions and individual unit heat input (including all systems required to monitor NOx emission rate, NOx concentration, stack gas moisture content, stack gas flow rate, CO2 or O2 concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.71 and 40 CFR 75.72);
- (2) successfully complete all certification tests required under section 243-8.2 and meet all other requirements of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraph (a)(1) of this section; and
- (3) record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section.



Condition 1-9: Prohibitions
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-8.1

Item 1-9.1:

No owner or operator of a CAIR NO_x Ozone Season unit shall use any alternative monitoring system, alternative reference method, or any other alternative to any requirement of this Subpart without having obtained prior written approval in accordance with section 243-8.6.

No owner or operator of a CAIR NO_x Ozone Season unit shall operate the unit so as to discharge, or allow to be discharged, NO_x emissions to the atmosphere without accounting for all such emissions in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NO_x Ozone Season unit shall disrupt the continuous emission monitoring system, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NO_x mass emissions discharged into the atmosphere or heat input, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NO_x Ozone Season unit shall retire or permanently discontinue use of the continuous emission monitoring system, any component thereof, or any other approved monitoring system under this Subpart, except under any one of the following circumstances:

- (i) during the period that the unit is covered by an exemption under section 243-1.5 that is in effect;
- (ii) the owner or operator is monitoring emissions from the unit with another certified monitoring system approved, in accordance with the applicable provisions of this Subpart and 40 CFR Part 75, by the department for use at that unit that provides emission data for the same pollutant or parameter as the retired or discontinued monitoring system; or
- (iii) the CAIR designated representative submits notification of the date of certification testing of a replacement monitoring system for the retired or discontinued monitoring system in accordance with section 243-8.2(d)(3)(i).

Condition 1-10: Quarterly reports
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-8.5 (d)

Item 1-10.1:

The CAIR designated representative shall submit quarterly reports, as follows:

If the CAIR NO_x Ozone Season unit is subject to an Acid Rain emissions limitation or a CAIR NO_x emissions limitation or if the owner or operator of such unit chooses to report on an annual basis under this Subpart, the CAIR designated representative shall meet the requirements of Subpart H of 40 CFR Part 75 (concerning monitoring of NO_x mass emissions) for such unit for the entire year and shall report the NO_x mass emissions data and heat input data for such unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



(i) for a unit that commences commercial operation before July 1, 2007, the calendar quarter covering May 1, 2008 through June 30, 2008;

(ii) for a unit that commences commercial operation on or after July 1, 2007, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 243-8.1(b), unless that quarter is the third or fourth quarter of 2007 or the first quarter of 2008, in which case reporting shall commence in the quarter covering May 1, 2008 through June 30, 2008.

The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

For CAIR NO_x Ozone Season units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Annual Trading Program, CAIR SO₂ Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO_x mass emission data, heat input data, and other information required by this Subpart.

Condition 1-11: Compliance certification
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 243-8.5 (e)

Item 1-11.1:

The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(1) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR Part 75, including the quality assurance procedures and specifications;

(2) for a unit with add-on NO_x emission controls and for all hours where NO_x data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO_x emissions; and

(3) for a unit that is reporting on a control period basis under subparagraph (d)(2)(ii) of this section, the NO_x emission rate and NO_x concentration values substituted for missing data under Subpart D of 40 CFR Part 75 are calculated using only values from a control period and do not systematically underestimate NO_x emissions.

Condition 1-12: CAIR NO_x Annual Trading Program General Conditions
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Subpart 244-1



Item 1-12.1:

1) As of midnight of March 1, or midnight of the first business day thereafter if March 1 is not a business day, the owners and operators shall hold, in their compliance account, Clean Air Interstate Rule (CAIR) NO_x allowances available for compliance deductions for the previous control period (January 1 through December 31), in an amount not less than the total tons of nitrogen oxides emissions from all CAIR NO_x units at the source during that control period. A CAIR NO_x allowance shall not be deducted for a control period in a calendar year before the year for which the CAIR NO_x allowance was allocated. [244-1.6(c)(1), 244-1.2(b)(5), 244-1.2(b)(36), 244-1.6(c)(3)]

2) The owners and operators shall hold in their compliance account, CAIR NO_x allowances available for compliance deductions for the control period starting on the later of January 1, 2009 or the deadline for meeting a CAIR NO_x unit's monitor certification requirements under section 244-8.1(b)(1), (2), or (5) and for each control period thereafter. [244-1.6(c)(2)]

3) If a CAIR NO_x source emits nitrogen oxides during any control period in excess of the CAIR NO_x emissions limitation, the owners and operators of the CAIR NO_x source shall surrender the CAIR NO_x allowances required for deduction under 6NYCRR Part 244-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this permit, the Act, and applicable State law. [(244-1.6(d)]

4) Unless otherwise provided, the owners and operators of the CAIR NO_x source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [244-1.6(e)]

(i) The certificate of representation under 6NYCRR Part 244-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 244-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 244-8, provided that to the extent that 6NYCRR Part 244-8 provides for a three year period for recordkeeping, the three year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO_x Annual Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO_x Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NO_x Annual Trading Program.

Condition 1-13: Designated CAIR Representative
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Subpart 244-2

Item 1-13.1:

1) Each Clean Air Interstate Rule (CAIR) NO_x source shall have one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 244-2.2, with regard to all matters under the CAIR NO_x Annual Trading Program. The CAIR designated representative shall be selected by an agreement binding on the owners and operators of the



source and act in accordance with the certification statement in 6NYCRR Part 244-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 244-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR NOx source represented in all matters pertaining to the CAIR NOx Annual Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated representative by the department, the Administrator, or a court regarding the source. [244-2.1(a), (b) & (c)]

(2) Each submission under the CAIR NOx Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR NOx source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment." [244-2.1(e)]

Condition 1-14: Compliance Certification
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement: 6 NYCRR Subpart 244-8

Item 1-14.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 1-14.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring and Reporting NOX emissions

(1) The owners and operators, and to the extent applicable, the CAIR designated representative shall comply with all recordkeeping and reporting requirements in this condition, the applicable recordkeeping and reporting requirements under 40 CFR 75, and the requirements of 6NYCRR Part 244-2.1(e)(1).

(2) The CAIR designated representative shall submit quarterly reports of the the NOx mass emissions data and heat input data for each CAIR NOx unit, in an electronic quarterly report in a format prescribed by the



Administrator, for each calendar quarter beginning with the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under 6NYCRR Part 244-8.1(b), unless that quarter is the third or fourth quarter of 2007, in which case reporting shall commence in the quarter covering January 1, 2008 through March 31, 2008.

(3) The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

(4) For CAIR NO_x units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Ozone Season Trading Program, CAIR SO₂ Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO_x mass emission data, heat input data, and other information required by this Subpart.

(5) 'Compliance certification.' The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(i) the monitoring data submitted were recorded in accordance with the applicable requirements of 6NYCRR Part 244 and 40 CFR Part 75, including the quality assurance procedures and specifications; and

(ii) for a unit with add-on NO_x emission controls and for all hours where NO_x data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO_x emissions.

(6) Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of 40 CFR part 75, data shall be substituted using the applicable missing data procedures



in Subpart D or Subpart H of, or appendix D or appendix E to 40 CFR part 75. [244-8.3(a)]

(7) Whenever the owner or operator makes a replacement, modification, or change in any certified continuous emission monitoring system under 6NYCRR Part 244-8.1(a)(1) that may significantly affect the ability of the system to accurately measure or record NOx mass emissions or heat input rate or to meet the quality-assurance and quality-control requirements of 40 CFR 75.21 or appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system in accordance with 40 CFR 75.20(b) . Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that may significantly change the stack flow or concentration profile, the owner or operator shall recertify each continuous emission monitoring system whose accuracy is potentially affected by the change, in accordance with 40 CFR 75.20(b). Examples of changes to a continuous emission monitoring system that require recertification include replacement of the analyzer, complete replacement of an existing continuous emission monitoring system, or change in location or orientation of the sampling probe or site. Any fuel flowmeter system, and any excepted NOx monitoring system under appendix E to 40 CFR part 75, under 6NYCRR Part 244-8.1(a)(1) are subject to the recertification requirements in 40 CFR 75.20(g)(6). [224-8.2(d)(2)

Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL TOTAL
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2009.
Subsequent reports are due every 3 calendar month(s).

**Condition 1-15: CAIR SO2 Trading Program General Provisions
Effective between the dates of 07/02/2009 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR Subpart 245-1

Item 1-15.1:

1) As of midnight of March 1, or midnight of the first business day thereafter (if March 1 is not a business day) for a control period, the owners and operators of each Clean Air Interstate Rule (CAIR) SO2 source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO2 allowances available for compliance deductions for the control period (January 1 through December 31) not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO2 units at the source. A CAIR SO2 allowance shall not be deducted, for compliance with the requirements under paragraph (2) of this section, for a control period in a calendar year before the year for which the CAIR SO2 allowance was allocated.



[(245-1.2(b)(5), 245-1.6(c)(1), 245-1.2(b)(36), 245-1.6(c)(3)]

2) The owners and operators shall hold in their compliance account, CAIR SO allowances available for compliance deductions for the control period starting on the later of January 1, 2010 or the deadline for meeting a CAIR SO₂ unit's monitor certification requirements under section 245-8.1(b)(1), (2), or (5) and for each control period thereafter. [245-1.6(c)(2)]

3) If a CAIR SO₂ source emits sulfur dioxide during any control period in excess of the CAIR SO₂ emissions limitation, the owners and operators of the source shall surrender the CAIR SO₂ allowances required for deduction under 6NYCRR Part 245-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law. Each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law. [(245-1.6(d)]

4) Unless otherwise provided, the owners and operators of the CAIR SO₂ source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator: [245-1.6(e)]

(i) The certificate of representation under 6NYCRR Part 245-2.4 for the CAIR designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation under 6NYCRR Part 245-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with 6NYCRR Part 245-8, provided that to the extent that 6NYCRR Part 245-8 provides for a three-year period for recordkeeping, the three-year period shall apply.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO₂ Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR SO₂ Trading Program or to demonstrate compliance with the requirements of the CAIR SO₂ Trading Program.

Condition 1-16: Designated CAIR Representative
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Subpart 245-2

Item 1-16.1:

1) Each CAIR SO₂ source shall have one and only one CAIR designated representative and may have one alternate representative, as per 6NYCRR Part 245-2.2, with regard to all matters under the CAIR SO₂ Trading Program. The CAIR designated representative of the CAIR SO₂ source shall be selected by an agreement binding on the owners and operators of the source and all CAIR SO₂ units at the source and shall act in accordance with the certification statement in 6NYCRR Part 245-2.4(a)(4)(iv). Upon receipt by the Administrator of a complete certificate of representation under 6NYCRR Part 245-2.4, the CAIR designated representative of the source shall represent and, by his or her representations, actions, inactions, or submissions, legally bind each owner and operator of the CAIR SO₂ source represented and each CAIR SO₂ unit at the source in all matters pertaining to the CAIR SO₂ Trading Program, notwithstanding any agreement between the CAIR designated representative and such owners and operators. The owners and operators shall be bound by any decision or order issued to the CAIR designated



representative by the department, the Administrator, or a court regarding the source or unit.
[245-2.1(a), (b) & (c)]

(2) Each submission under the CAIR SO₂ Trading Program shall be submitted, signed, and certified by the CAIR designated representative for each CAIR SO₂ source on behalf of which the submission is made. Each such submission shall include the following certification statement by the CAIR designated representative: "I am authorized to make this submission on behalf of the owners and operators of the source or units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."
[245-2.1(e)]

Condition 1-17: Compliance Certification
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable Federal Requirement:6 NYCRR Subpart 245-8

Item 1-17.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 1-17.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Monitoring and Reporting SO₂ emissions:

1) The owners and operators, and to the extent applicable, the Clean Air Interstate Rule (CAIR) designated representative, of a CAIR SO₂ unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. For purposes of complying with such requirements, the definitions in section 245-1.2 and 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR SO₂ unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 245-1.2. The owner or operator of a unit that is not a CAIR SO₂ unit but that is monitored under 40 CFR 75.16(b)(2) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR SO₂ unit. [245-8.1]



2)The owner or operator of each CAIR SO₂ unit shall:
[245-8.1(a)]

(i) install all monitoring systems required under this Subpart for monitoring SO₂ mass emissions and individual unit heat input (including all systems required to monitor SO₂ concentration, stack gas moisture content, stack gas flow rate, CO₂ or O₂ concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.11 and 40 CFR 75.16);

(ii) successfully complete all certification tests required under Part 245-8.2 and meet all other requirements of this section and 40 CFR Part 75 applicable to the monitoring systems under this section; and

(iii) record, report, and quality-assure the data from the monitoring systems under paragraph of this section.

3) The owner or operator shall meet the monitoring system certification and other requirements of section 245-8.1(a)(1) and (2) on or before the following dates. The owner or operator shall record, report, and quality-assure the data from the monitoring systems under section 245-8.1(a)(1) on and after the following dates.
[245-8.1(b)]

(i) For the CAIR SO₂ unit that commences commercial operation before July 1, 2008, by January 1, 2009.

(ii) For the CAIR SO₂ unit that commences commercial operation on or after July 1, 2008, by the later of the following dates: January 1, 2009; or 90 unit operating days or 180 calendar days, whichever occurs first, after the date on which the unit commences commercial operation.

4) Whenever the owner or operator makes a replacement, modification, or change in any certified continuous emission monitoring system under section 245-8.1(a)(1) that may significantly affect the ability of the system to accurately measure or record SO₂ mass emissions or heat input rate or to meet the quality-assurance and quality-control requirements of 40 CFR 75.21 or appendix B to 40 CFR Part 75, the owner or operator shall recertify the monitoring system in accordance with 40 CFR 75.20(b). Furthermore, whenever the owner or operator makes a replacement, modification, or change to the flue gas handling system or the unit's operation that may significantly change the stack flow or concentration profile, the owner or operator shall recertify each continuous emission monitoring system whose accuracy is potentially affected by the change, in accordance with 40 CFR 75.20(b). Examples of changes to a continuous emission monitoring system that require recertification include:



replacement of the analyzer, complete replacement of an existing continuous emission monitoring system, or change in location or orientation of the sampling probe or site. Any fuel flowmeter system under section 245-8.1(a)(1) is subject to the recertification requirements in 40 CFR 75.20(g)(6). [245-8.2(d)(2)]

5) Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of 40 CFR Part 75, data shall be substituted using the applicable missing data procedures in Subpart D of or appendix D to 40 CFR Part 75. [245-8.3(a)]

6) The CAIR designated representative shall comply with all recordkeeping and reporting requirements in section 245-8.3, the applicable recordkeeping and reporting requirements in Subparts F and G of 40 CFR Part 75, and the requirements of section 245-2.1(e)(1). [245-8.5(a)]

7) The owner or operator of a CAIR SO₂ unit shall comply with requirements of 40 CFR 75.62 for monitoring plans. [245-8.5(b)]

8) The CAIR designated representative shall submit an application to the department within 45 days after completing all initial certification or recertification tests required under section 245-8.2, including the information required under 40 CFR 75.63. [245-8.5(c)]

9) The CAIR designated representative shall submit quarterly reports of the SO₂ mass emissions data and heat input data for each CAIR SO₂ unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with: [245-8.5(d)(1)]

- i) the calendar quarter covering January 1, 2009 through March 31, 2009 for a unit that commences commercial operation before July 1, 2008; or
- ii) for a unit that commences commercial operation on or after July 1, 2008, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 245-8.1(b), unless that quarter is the third or fourth quarter of 2008, in which case reporting shall commence in the quarter covering January 1, 2009 through March 31, 2009.

10) The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days



following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.64. [245-8.5(d)(2)]

11) For CAIR SO₂ units that are also subject to an Acid Rain emissions limitation or the CAIR NO_x Annual Trading Program, CAIR NO_x Ozone Season Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the SO₂ mass emission data, heat input data, and other information required by this Subpart. [245-8.5(d)(3)]

12) The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that: [245-8.5(e)]

- i) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR Part 75, including the quality assurance procedures and specifications; and
- ii) for a unit with add-on SO₂ emission controls and for all hours where SO₂ data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate SO₂ emissions.

Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL TOTAL
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2009.
Subsequent reports are due every 3 calendar month(s).

Condition 41: EPA Region 2 address.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement: 40CFR 60.4, NSPS Subpart A

Item 41.1:

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

**Condition 42: Date of construction notification - If a COM is not used.
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:40CFR 60.7(a), NSPS Subpart A

Item 42.1:

Any owner or operator subject to this part shall furnish the Administrator with the following information:

- 1) a notification of the date construction or reconstruction commenced, post marked no later than 30 days after such date;
- 3) a notification of the actual date of initial start up, post marked within 15 days after such date;
- 4) a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the change is specifically exempted under this part. The notice shall be post marked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capability of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional information regarding the change;
- 5) a notification of the date upon which the demonstration of continuous monitoring system performance commences, post marked not less than 30 days prior to such date;
- 6) a notification of the anticipated date for conducting the opacity observations, post marked not less than 30 days prior to such date.

**Condition 43: Date of Construction Notification - if a COM is used
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:40CFR 60.7(a), NSPS Subpart A

Item 43.1:

Any owner or operator subject to this part shall furnish the Administrator with the following information:

- 1) a notification of the date construction or reconstruction commenced, post marked no later than



30 days after such date;

3) a notification of the actual date of initial start up, post marked within 15 days after such date;

4) a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the change is specifically exempted under this part. The notice shall be post marked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capability of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional information regarding the change;

5) a notification of the date upon which the demonstration of continuous monitoring system performance commences, post marked not less than 30 days prior to such date;

6) a notification of the anticipated date for conducting the opacity observations, post marked not less than 30 days prior to such date, if a continuous opacity monitor is not being used at the facility; and

7) a notification that continuous opacity monitoring system data results will be used to determine compliance with the applicable opacity standard during the performance test, post marked not less than 30 days prior to the performance test.

Condition 44: Recordkeeping requirements.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.7(b), NSPS Subpart A

Item 44.1:

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

Condition 45: Excess emissions report.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.7(d), NSPS Subpart A

Item 45.1:

A summary report form, for each pollutant monitored, shall be sent to the Administrator in the form prescribed in Figure 1 of 40 CFR Part 60.7(d).

Condition 46: Facility files for subject sources.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.7(f), NSPS Subpart A

Item 46.1:

The following files shall be maintained at the facility for all affected sources: all measurements, including continuous monitoring systems, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations;all continuous

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. The file shall be maintained for at least two years following the date of such measurements, reports, and records.

Condition 47: Performance testing timeline.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.8(a), NSPS Subpart A

Item 47.1:

Within 60 days after achieving the maximum production rate, but not later than 180 days after initial startup of the facility, the owner or operator of the facility shall conduct performance testing and provide the results of such tests, in a written report, to the Administrator.

Condition 48: Performance test methods.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.8(b), NSPS Subpart A

Item 48.1:

Performance testing shall be conducted in accordance with the methods and procedures prescribed in 40 CFR 60 or by alternative methods and procedures approved by the Administrator.

Condition 49: Required performance test information.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.8(c), NSPS Subpart A

Item 49.1:

Performance tests shall be conducted under such conditions specified by the Administrator, based upon representative performance data supplied by the owner or operator of the facility.

Condition 50: Prior notice.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.8(d), NSPS Subpart A

Item 50.1:

The owner or operator shall provide the Administrator with prior notice of any performance test at least 30 days in advance of testing.

Condition 51: Performance testing facilities.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.8(e), NSPS Subpart A

Item 51.1:

The following performance testing facilities shall be provided during all tests:

- 1) sampling ports adequate for tests methods applicable to such facility;



- 2) a safe sampling platform;
- 3) a safe access to the sampling platform; and
- 4) utilities for sampling and testing equipment.

Condition 52: Number of required tests.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.8(f), NSPS Subpart A

Item 52.1:

Each performance test shall consist of three separate runs, at the specified duration required in the applicable test method. Compliance with all applicable standards shall be determined by using the arithmetic means of the results of the three runs.

Condition 53: Availability of information.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.9, NSPS Subpart A

Item 53.1:

The availability to the public of information provided to, or otherwise obtained by, the Administrator under this part shall be governed by 40 CFR Part 2.

Condition 54: Opacity standard compliance testing.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.11, NSPS Subpart A

Item 54.1:

The following conditions shall be used to determine compliance with the opacity standards:

- 1) observations shall be conducted in accordance with Reference Method 9, in Appendix A of 40 CFR Part 60(or an equivalent method approved by the Administrator including continuous opacity monitors);
- 2) the opacity standards apply at all times except during periods of start up, shutdown, and malfunction; and
- 3) all other applicable conditions cited in section 60.11 of this part.

Condition 55: Circumvention.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.12, NSPS Subpart A

Item 55.1:

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not



limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

Condition 56: Monitoring requirements.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.13, NSPS Subpart A

Item 56.1:

All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

Condition 57: Modifications.
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.14, NSPS Subpart A

Item 57.1:

Within 180 days of the completion of any physical or operational change (as defined in section 60.14), compliance with the applicable standards must be achieved.

Condition 58: Reconstruction
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.15, NSPS Subpart A

Item 58.1:

The following shall be submitted to the Administrator prior to reconstruction (as defined in section 60.15):

- 1) a notice of intent to reconstruct 60 days prior to the action;
- 2) name and address of the owner or operator;
- 3) the location of the existing facility;
- 4) a brief description of the existing facility and the components to be replaced;
- 5) a description of the existing air pollution control equipment and the proposed air pollution control equipment;
- 6) an estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility;
- 7) the estimated life of the facility after the replacements; and
- 8) a discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.

Condition 59: Facility Subject to Title IV Acid Rain Regulations and Permitting

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40 CFR Part 72

Item 59.1: This facility is subject to the Title IV Acid Rain Regulations found in 40 CFR Parts 72, 73, 75, 76, 77 and 78. The Acid Rain Permit is an attachment to this permit.

****** Emission Unit Level ******

**Condition 60: Emission Point Definition By Emission Unit
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 60.1(From Mod 0):

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00003

Emission Point: 0003A

Height (ft.): 250

Diameter (in.): 222

NYTMN (km.): 4515.2

NYTME (km.): 591.7

Building: CCNYPA1

Emission Point: 0003B

Height (ft.): 250

Diameter (in.): 222

NYTMN (km.): 4515.2

NYTME (km.): 591.7

Building: CCNYPA1

**Condition 61: Process Definition By Emission Unit
Effective between the dates of 03/17/2008 and 03/16/2013**

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 61.1(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003

Process: PC1

Source Classification Code: 2-01-002-01

Process Description:

EMISSION UNIT U00003 REPRESENTS TWO GE S207FA COMBUSTION TURBINES RATED AT 1,779 MMBTU/HR WHEN FIRING NATURAL GAS (THE PRIMARY FUEL) AT 54.6 D F AND 2,041 MMBTU/HR WHEN FIRING KEROSENE (BACK-UP FUEL) AT -5 D F OPERATING AT 50-100% LOAD. PROCESS PC1 FOR EM ISSION UNIT U00003 REPRESENTS NATURAL GAS FIRING IN THE TURBINE. FOR THIS PROCESS, DRY LOW-NOX BURNERS AND SELECTIVE CATALYTIC REDUCTION ARE USED TO CONTROL NOX EMISSIONS. EMISSIONS OF VOC AND CO ARE CONTROLLED BY AN OXIDATION CATALYST. TOTAL THROUGHPUT



VALUES LISTED BELOW REPRESENT MAXIMUM NATURAL GAS USE FOR THE SHORT-TERM (HOURLY) BASIS WHILE THE ANNUAL QUANTITY PER YEAR OF NATURAL GAS REPRESENTS TURBINE OPERATIONS AT THE AVERAGE ANNUAL TEMPERATURE (54.6 D F).

Emission Source/Control: CC03A - Combustion
Design Capacity: 1,779 million Btu per hour

Emission Source/Control: CC03B - Combustion
Design Capacity: 2,041 million Btu per hour

Emission Source/Control: CAT3A - Control
Control Type: CATALYTIC OXIDATION

Emission Source/Control: CAT3B - Control
Control Type: CATALYTIC OXIDATION

Emission Source/Control: DLN3A - Control
Control Type: DRY LOW NO_x BURNER

Emission Source/Control: DLN3B - Control
Control Type: DRY LOW NO_x BURNER

Emission Source/Control: SCR3A - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Emission Source/Control: SCR3B - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Item 61.2(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003

Process: PC2

Source Classification Code: 2-01-009-01

Process Description:

EMISSION UNIT U00003 REPRESENTS TWO GE S207FA COMBUSTION TURBINES RATED AT 1,779 MMBTU/HR WHEN FIRING NATURAL GAS (THE PRIMARY FUEL) AT 54.6 D F AND 2,041 MMBTU/HR WHEN FIRING KEROSENE (BACK-UP FUEL) AT -5 D F OPERATING AT 50-100% LOAD. PROCESS PC2 FOR EMISSION UNIT U00003 REPRESENTS KEROSENE FIRING IN THE TURBINE. FOR THIS PROCESS, DRY LOW-NO_x BURNERS AND SELECTIVE CATALYTIC REDUCTION ARE USED TO CONTROL NO_x EMISSIONS. EMISSIONS OF VOC AND CO ARE CONTROLLED BY AN OXIDATION CATALYST. KEROSENE USE WILL BE LIMITED TO 21.8 MILLION GALLONS PER YEAR, WHICH IS EQUIVALENT TO 720 HOURS PER YEAR OF

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



OPERATION. MAXIMUM TOTAL THROUGHPUT OF KEROSENE, ON AN HOURLY BASIS, REPRESENTS TURBINE OPERATIONS AT -5 D F AT FULL LOAD.

Emission Source/Control: CC03A - Combustion
Design Capacity: 1,779 million Btu per hour

Emission Source/Control: CC03B - Combustion
Design Capacity: 2,041 million Btu per hour

Emission Source/Control: CAT3A - Control
Control Type: CATALYTIC OXIDATION

Emission Source/Control: CAT3B - Control
Control Type: CATALYTIC OXIDATION

Emission Source/Control: DLN3A - Control
Control Type: DRY LOW NO_x BURNER

Emission Source/Control: DLN3B - Control
Control Type: DRY LOW NO_x BURNER

Emission Source/Control: SCR3A - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Emission Source/Control: SCR3B - Control
Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Item 61.3(From Mod 0):

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00003
Process: PC3 Source Classification Code: 2-04-004-02
Process Description:
ONE DIESEL ENGINE (MANUFACTURER: DETROIT DIESEL): OPERATION IS LIMITED TO 200 HOURS OF OPERATION PER YEAR AND ONE HOUR OF TESTING PER WEEK.

Emission Source/Control: DE001 - Combustion

Condition 62: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 227-1.3 (a)

Item 62.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):



CAS No: 0NY075-00-0 PARTICULATES

Item 62.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity (on a six minute block period) except for one six minute block period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - weather condition
 - was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then the Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY
Upper Permit Limit: 20 percent
Reference Test Method: Method 9
Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 6 calendar month(s).

Condition 63: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.6

Item 63.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 63.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Records for demonstration of compliance with the CO emission limit shall be maintained on site for five years. These records shall include i) mass emissions totaled over each 24-hour daily period (the total of hourly averages 12:00 midnight to the following midnight), and ii) the total mass emissions over a 365 day period beginning with the start-up of the facility. Any exceedance of the allowable annual CO emission limitation must be reported in writing to the DEC Regional office within 10 working days of the exceedance.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 90.0 tons per year

Reference Test Method: PT60,APP A,METH 10

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL MAXIMUM ROLLED DAILY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 64: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.6

Item 64.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 64.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Records for demonstration of compliance with the VOC emission limit shall be maintained on site for five years.
Any exceedance of the allowable annual VOC emission limitation must be reported in writing to the DEC Regional office within 10 working days of the exceedance.

Parameter Monitored: VOC
Upper Permit Limit: 31.0 tons per year
Reference Test Method: PART 60,APP A
Monitoring Frequency: DAILY
Averaging Method: ANNUAL MAXIMUM ROLLED DAILY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 65: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.6

Item 65.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 65.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Records for demonstration of compliance with the NOx emission limit shall be maintained on site for five years. These records shall include i) mass emissions totaled over each 24-hour daily period (the total of 3-hour block averages 12:00 midnight to the following midnight), and ii) the total mass emissions over a 365 day period beginning with the start-up of the facility. Any exceedance of the allowable annual NOx emission limitation must be reported in writing to the DEC Regional office within 10 working days of the exceedance.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 165.0 tons per year

Reference Test Method: 40CFR 60,APP A,M 19

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 66: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.9

Item 66.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Item 66.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Use of Emission Reduction Credit: NYPA will require offset amounts of 41 tons for VOC and 217 tons for NOx for the proposed project. NYPA has arranged to buy 41 tons of VOC offsets from "Minnesota Mining and Manufacturing Company (3M), Bristol Township, Bucks County, PA". For NOx, NYPA has arranged to buy 217 tons of offsets from "Wisvest-Connecticut, LLC, Bridgeport, CT". This would

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



satisfy the ERCs offset requirements to go ahead with the proposed project.

The information concerning ERCs (Emission Reduction Credits) were noticed in NYSDEC's ENB on November 28, 2001 for the minimum 30 day public notice. Details are provided

at:

[http://ww](http://www.w.dec.state.ny.us/website/ohms/notices/nypasupplemental.htm)

[w.dec.sta](http://www.w.dec.state.ny.us/website/ohms/notices/nypasupplemental.htm)

[te.ny.us/website/ohms/notices/nypasupplemental.htm](http://www.w.dec.state.ny.us/website/ohms/notices/nypasupplemental.htm)

The comment period was extended till January 10, 2002 based on a request from Queens/CHOKe.

In view of the above, the requirements for 6 NYCRR 231-2.10 were satisfied. The donating sources must be in compliance with the enforceable conditions effecting the emissions reductions at least 10-30 working days before NYPA project commences operation.

If the situation changes, 60 day public notice period per 231-2 is applicable prior to operations, but that has to be done 60 days in advance so that the Department can revise the permit.

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 12 calendar month(s).

Condition 67: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 67.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):

CAS No: 0NY075-00-5 PM-10

Item 67.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Records for demonstration of compliance with the PM-10 emission limit shall be maintained on site for five years.

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Any exceedance of the allowable annual PM-10 emission limitation must be reported in writing to the DEC Regional office within 10 working days of the exceedance.

Parameter Monitored: PM-10
Upper Permit Limit: 169.0 tons per year
Reference Test Method: 201A & 202
Monitoring Frequency: DAILY
Averaging Method: ANNUAL MAXIMUM ROLLED DAILY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 68: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 68.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 68.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:

Records for demonstration of compliance with the Ammonia slip limit shall be maintained on site for five years. These records shall include i) mass emissions totaled over each 24-hour daily period (the total of 3-hour block averages 12:00 midnight to the following midnight), and ii) the total mass emissions over a 365 day period beginning with the start-up of the facility. Any exceedance of the allowable annual NOx emission limitation must be reported in writing to the DEC Regional office within 10 working days of the exceedance.

Manufacturer Name/Model Number: CISCO Model # 10006040
Parameter Monitored: AMMONIA
Upper Permit Limit: 129.0 tons per year
Reference Test Method: As proposed
Monitoring Frequency: DAILY
Averaging Method: ANNUAL MAXIMUM ROLLED DAILY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.



Subsequent reports are due every 3 calendar month(s).

Condition 69: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.334(b), NSPS Subpart GG

Item 69.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Item 69.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Records of fuel supply and sample analysis for the determination of sulfur and nitrogen content in fuel pertinent to regulations under 40 CFR 60.334(b), NSPS Subpart GG and the custom fuel monitoring schedule being proposed by NYPA and approved by EPA, for the stationary gas turbines shall be kept and retained for a period of three (3) years and be available for inspection by personnel of federal, state and local air pollution control agencies.

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL CHANGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 70: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 227-2.4 (e) (2) (i)

Item 70.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 70.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Monitoring Description:

COMPLIANCE WITH THE NOX RACT AND LAER
EMISSION LIMIT WILL BE DEMONSTRATED
PURSUANT TO 40 CFR 60 APPEND A, METH 19
AND 6 NYCRR 227-2.6 (b).

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 2.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40CFR 60,APP A,M 19

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 71: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 71.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 71.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

1.3 PPM VOC EMISSION LIMIT DURING
NATURALGAS FIRING IN GAS TURBINE BASED
UPON HHV OF FUEL. THIS LIMIT APPLIES AT
ALL LOADS. NYPA WILL SHOW COMPLINACE
WITH VOC EMISSION LIMIT BY STACK TESTING,
WHICH WILL BE DONE ONCE PER PERMIT TERM.
REPORTING REQUIREMENTS WILL BE 30 DAYS
AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 1.3 parts per million (by volume)

Reference Test Method: PT60,APP A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED



Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 72: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 72.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 72.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

2.5PPM (BY VOL, DRY, CORR TO 15% O₂) CO
EMISSION LIMIT DURING NATURAL GAS FIRING
IN GAS TURBINE BASED UPON HHV OF FUEL.
EMISSION LIMIT APPLIES AT ALL LOADS.
NYSPA WILL USE CEM TO MONITOR CO EMISSION
AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 2.5 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: PT60,APP A,METH 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 73: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 73.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):



CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 73.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

2.0 PPM (BY VOL, DRY, CORR TO 15% O2) NOX
EMISSION LIMIT DURING NATURAL GAS FIRING
IN GAS TURBINE BASED UPON HHV OF FUEL.
EMISSION LIMIT APPLIES AT ALL LOADS.
NYPA WILL USE CEM TO MONITOR NOX EMISSION
AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 2.0 parts per million by volume
(dry, corrected to 15% O2)

Reference Test Method: 40CFR PT60,APP A,M19

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 74: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 74.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 74.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

0.0074 LB/MMBTU NOX EMISSION LIMIT
DURING NATURAL GAS FIRING IN GAS TURBINE
BASED UPON HHV OF FUEL. EMISSION LIMIT
APPLIES AT ALL LOADS. NYPA WILL USE CEM
TO MONITOR NOX EMISSION AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Parameter Monitored: CONCENTRATION
Upper Permit Limit: 0.0074 pounds per million Btus
Reference Test Method: 40CFR PT60,APP A,M19
Monitoring Frequency: CONTINUOUS
Averaging Method: 3-HOUR BLOCK AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 75: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 75.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC1

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 75.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

0.0056 POUNDS PER MILLION BTUs CO
EMISSION LIMIT DURING NATURAL GAS FIRING
IN GAS TURBINE BASED UPON HHV OF FUEL.
EMISSION LIMIT APPLIES AT ALL LOADS.
NYPA WILL USE CEM TO MONITOR CO EMISSION
AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION
Upper Permit Limit: 0.0056 pounds per million Btus
Reference Test Method: PT60,APP A,METHOD 10
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 76: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Item 76.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 76.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

0.0017 LB/MMBTU VOC EMISSION LIMIT
DURING NATURAL GAS FIRING IN GAS TURBINE
BASED UPON HHV OF FUEL. THIS LIMIT
APPLIES AT ALL LOADS. NYPA WILL SHOW
COMPLIANCE WITH VOC EMISSION LIMIT BY
STACK TESTING, WHICH WILL BE DONE ONCE
PER PERMIT TERM. REPORTING REQUIREMENTS
WILL BE 30 DAYS AFTER THE TEST IS
COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.0017 pounds per million Btus

Reference Test Method: PT60,APP A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 77: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 77.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 77.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

0.0150 LB/MMBTU PARTICULATE MATTER

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



EMISSION LIMIT DURING NATURAL GAS FIRING
IN GAS TURBINE BASED UPON HIGHER HTNG
VALUE (HHV) OF FUEL. EMISSION LIMIT
APPLIES AT ALL LOADS. NYPA WILL SHOW
COMPL BY STACK TEST, WHICH WILL BE DONE
ONCE PER PERMIT TERM. REPORTING
REQUIREMENTS WILL BE 30 DAYS AFTER THE
TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.0150 pounds per million Btus

Reference Test Method: 201A & 202

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 78: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement: 40CFR 52.21(j), Subpart A

Item 78.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC1

Regulated Contaminant(s):

CAS No: 007664-93-9 SULFURIC ACID

Item 78.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

0.002 LB/MMBTU SULFUR ACID MIST EMISSION
LIMIT DURING NATURAL GAS FIRING IN GAS
TURBINE BASED UPON HIGHER HTNG VALUE
(HHV) OF FUEL. EMISSION LIMIT APPLIES AT
ALL LOADS. NYPA WILL SHOW COMPL BY STACK
TEST, WHICH WILL BE DONE ONCE PER PERMIT
TERM. REPORTING REQUIREMENTS WILL BE 30
DAYS AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.002 pounds per million Btus

Reference Test Method: PT 60, APP A, M 8A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION



Condition 79: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 79.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC1

Item 79.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

NYP&A WILL BURN NATURAL GAS AS A PRIMARY
FUEL IN THE COMBUSTION TURBINE. THE
UPPER LIMIT FOR THE NATURAL GAS USAGE
GIVEN HERE IS PER TURBINE.

Work Practice Type: PROCESS MATERIAL THRUPUT

Process Material: NATURAL GAS

Upper Permit Limit: 1,868,000 cubic feet per hour

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 80: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 80.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC1

Item 80.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

NYP&A WILL BURN NATURAL GAS AS A PRIMARY
FUEL IN THE COMBUSTION TURBINE. THE

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



UPPER LIMIT FOR THE NATURAL GAS USAGE
GIVEN HERE IS PER TURBINE.

Work Practice Type: PROCESS MATERIAL THRUPUT
Process Material: NATURAL GAS
Upper Permit Limit: 16,364 million cubic feet per year
Monitoring Frequency: CONTINUOUS
Averaging Method: ANNUAL MAXIMUM ROLLED DAILY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 81: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement: 40CFR 52.21(j), Subpart A

Item 81.1:
The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC1

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 81.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:
5.0 PPM AMMONIA EMISSION LIMIT DURING
NATURAL GAS FIRING IN GAS TURBINE.
EMISSION LIMIT APPLIES AT ALL LOADS.
NYPA WILL USE CEM TO SHOW COMPLIANCE.

Manufacturer Name/Model Number: CISCO Model # 10006040
Parameter Monitored: CONCENTRATION
Upper Permit Limit: 5.0 parts per million by volume
(dry, corrected to 15% O₂)
Reference Test Method: As proposed
Monitoring Frequency: CONTINUOUS
Averaging Method: 3-HOUR BLOCK AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 82: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013



Applicable Federal Requirement:6 NYCRR 201-6.1

Item 82.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 82.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

NYPA IS PROPOSING A FUEL SULFUR LIMIT OF 0.04 PERCENT BY WEIGHT TO BE TESTED EACH TIME A TANK IS FILLED.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: OIL (NOT ELSEWHERE CLASSIFIED)
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.04 percent by weight
Reference Test Method: ASTM METH D4294
Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL CHANGE
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 83: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 227-2.4 (e) (2) (ii)

Item 83.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 83.2:

Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

COMPLIANCE WITH THE NOX RACT AND LAER
EMISSION LIMIT WILL BE DEMONSTRATED
PURSUANT TO 40 CFR 60 APPEND A, METH 19
AND 6 NYCRR 227-2-6 (b).

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 10 parts per million by volume (dry,
corrected to 15% O₂)

Reference Test Method: 40CFR 60,APP A,M 19

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 84: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 84.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC2

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 84.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

3.0 PPM VOC EMISSION LIMIT DURING
KEROSENE FIRING IN GAS TURBINE BASED UPON
HHV OF FUEL. THIS LIMIT APPLIES AT ALL
LOADS. NYPA WILL SHOW COMPLIANCE BY
STACK TESTING, WHICH WILL BE DONE ONCE
PER PERMIT TERM. REPORTING REQUIREMENTS
WILL BE 30 DAYS AFTER THE TEST IS
COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 3.0 parts per million (by volume)

Reference Test Method: PART 60,APP A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



METHOD INDICATED
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 85: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 85.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 85.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

0.0041 LB/MMBTU VOC EMISSION LIMIT
DURING KEROSENE FIRING IN GAS TURBINE
BASED UPON HHV OF FUEL. THIS LIMIT
APPLIES AT ALL LOADS. NYPA WILL SHOW
COMPLIANCE BY STACK TESTING, WHICH WILL
BE DONE ONCE PER PERMIT TERM. REPORTING
REQUIREMENTS WILL BE 30 DAYS AFTER THE
TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.0041 pounds per million Btus

Reference Test Method: PART 60,APP A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 86: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 86.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Item 86.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

COMPLIANCE WITH THE NOX RACT AND LAER
EMISSION LIMIT WILL BE DEMONSTRATED
PURSUANT TO 40 CFR 60 APPEND A, METH 19
AND 6 NYCRR 227-2.6 (b).

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.0400 pounds per million Btus

Reference Test Method: 40CFR 60,APP A,M 19

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 87: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 87.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC2

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 87.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

COMPLIANCE WITH THE NOX RACT AND LAER
EMISSION LIMIT WILL BE DEMONSTRATED
PURSUANT TO 40 CFR 60 APPEND A, METH 19
AND 6 NYCRR 227-2.6 (b).

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 10 parts per million by volume (dry,
corrected to 15% O₂)

Reference Test Method: 40CFR 60,APP A,M 19

Monitoring Frequency: CONTINUOUS

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Averaging Method: 3-HOUR BLOCK AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 88: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 88.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 88.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

5.0 PPM (BY VOL, DRY, CORR TO 15% O2) CO
EMISSION LIMIT DURING KEROSENE FIRING IN
GAS TURBINE BASED UPON HHV OF FUEL.
EMISSION LIMIT APPLIES AT ALL LOADS.
NYPA WILL USE CEM TO MONITOR CO EMISSION
AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 5.0 parts per million by volume
(dry, corrected to 15% O2)

Reference Test Method: As Proposed

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 89: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 89.1:

The Compliance Certification activity will be performed for:

New York State Department of Environmental Conservation
Permit ID: 2-6301-00084/00015 Facility DEC ID: 2630100084



Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 89.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

0.0121POUNDS PER MILLION BTU CO EMISSION
LIMIT DURING KEROSENE FIRING IN GAS
TURBINE BASED UPON HHV OF FUEL. EMISSION
LIMIT APPLIES AT ALL LOADS. NYPA WILL
USE CEM TO MONITOR CO EMISSION AT THE
STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.0121 pounds per million Btus

Reference Test Method: PT 60,APP A,M 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 90: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 90.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 90.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

NYPA WILL BURN NATURAL GAS AS THE
PRIMARY FUEL WITH UP TO 720 HOURS OF
KEROSENE FUEL OIL AS A BACK UP. THE

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



SULFUR CONTENT OF KEROSENE FUEL OIL WILL NOT EXCEED 0.04% BY WEIGHT. NYPA WILL SHOW COMPL BY TESTING THE FUEL EACH TIME IT IS TRANSFERRED TO THE STORAGE TANK.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
Process Material: OIL (NOT ELSEWHERE CLASSIFIED)
Parameter Monitored: SULFUR CONTENT
Upper Permit Limit: 0.04 percent by weight
Reference Test Method: ASTM METH D4294
Monitoring Frequency: PER DELIVERY
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 91: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 91.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 0NY075-00-5 PM-10

Item 91.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

0.0470 LB/MMBTU PARTICULATE MATTER(<10 MICRONS) EMISSION LIMIT DURING KEROSENE FIRING IN GAS TURBINE BASED UPON HHV OF FUEL. THIS LIMIT APPLIES AT ALL LOADS. NYPA WILL SHOW COMPLIANCE BY STACK TEST, WHICH WILL BE DONE ONCE PER PERMIT TERM. REPORTING REQUIREMENTS WILL BE 30 DAYS AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION
Upper Permit Limit: 0.0470 pounds per million Btus
Reference Test Method: 201A & 202
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED



Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 92: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 92.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 92.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

0.0470 LB/MMBTU PARTICULATE MATTER
EMISSION LIMIT DURING KEROSENE FIRING IN
GAS TURBINE BASED UPON HHV OF FUEL. THIS
LIMIT APPLIES AT ALL LOADS. NYPA WILL
SHOW COMPLIANCE BY STACK TESTING, WHICH
WILL BE DONE ONCE PER PERMIT TERM.
REPORTING REQUIREMENTS WILL BE 30 DAYS
AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.0470 pounds per million Btus

Reference Test Method: 201A & 202

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 93: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 93.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 007664-93-9 SULFURIC ACID

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Item 93.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

0.0120 LB/MMBTU SULFUR ACID MIST
EMISSION LIMIT DURING KEROSENE FIRING IN
GAS TURBINE BASED UPON HHV OF FUEL. THIS
LIMIT APPLIES AT ALL LOADS. NYPA WILL
SHOW COMPLIANCE BY STACK TESTING, WHICH
WILL BE DONE ONCE PER PERMIT TERM.
REPORTING REQUIREMENTS WILL BE 30 DAYS
AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 0.0120 pounds per million Btus

Reference Test Method: PT 60, APP A, M 8A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 94: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 94.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC2

Item 94.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

ALTERNATE FUEL USAGE (KEROSENE) IN THE
COMBUSTION TURBINE IS LIMITED TO 21.8
MILLION GALLONS PER YEAR.

Work Practice Type: PROCESS MATERIAL THRUPUT

Process Material: OIL (NOT ELSEWHERE CLASSIFIED)

Upper Permit Limit: 21.8 million gallons

Monitoring Frequency: DAILY

Averaging Method: ANNUAL MAXIMUM ROLLED DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).



Condition 95: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 95.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 95.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

10.0 PPM AMMONIA EMISSION LIMIT DURING
KEROSENE FIRING IN GAS TURBINE BASED UPON
HHV OF FUEL. THIS LIMIT APPLIES AT ALL
LOADS. NYPA WILL USE CEM TO SHOW
COMPLIANCE

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 10.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 206

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 96: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 60.333(b), NSPS Subpart GG

Item 96.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003
Process: PC2

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Item 96.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

NYPA WILL COMPLY WITH A FUEL SULFUR CONTENT LIMIT OF 0.04% BY WEIGHT.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: OIL (NOT ELSEWHERE CLASSIFIED)

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.04 percent by weight

Reference Test Method: ASTM METH D4294

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 97: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 227.2 (b) (1)

Item 97.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Process: PC3

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 97.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,

2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



3) all records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 98: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 98.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003A

Process: PC1

Emission Source: CC03A

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 98.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

3.2 LB/HR VOC EMISSION LIMIT DURING NATURAL GAS FIRING IN GAS TURBINE BASED UPON HHV OF FUEL. THIS LIMIT APPLIES AT ALL LOADS. NYPA WILL SHOW COMPLIANCE BY STACK TESTING, WHICH WILL BE DONE ONCE PER PERMIT TERM. REPORTING REQUIREMENTS WILL BE 30 DAYS AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 3.2 pounds per hour

Reference Test Method: PT60,APP A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 99: Compliance Certification



Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 99.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003A
Process: PC1 Emission Source: CC03A

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 99.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

14.3 LB/HR. NOX E EMISSION LIMIT DURING
NATURAL GAS FIRING IN GAS TURBINE BASED
UPON HHV OF FUEL. EMISSION LIMIT APPLIES
AT ALL LOADS. NYPA WILL USE CEM TO
MONITOR NOX EMISSION AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 14.3 pounds per hour

Reference Test Method: 40CFR PT60,APP A,M19

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 100: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 100.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003A
Process: PC1 Emission Source: CC03A

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 100.2:

Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

10.9 POUNDS PER HOUR CO EMISSION LIMIT
DURING NATURAL GAS FIRING IN GAS TURBINE
BASED UPON HHV OF FUEL. EMISSION LIMIT
APPLIES AT ALL LOADS. NYPA WILL USE CEM
TO MONITOR CO EMISSION AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 10.9 pounds per hour

Reference Test Method: PT60,APP A,METHOD 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 101: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 101.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003A

Process: PC1

Emission Source: CC03A

Regulated Contaminant(s):

CAS No: 007664-93-9

SULFURIC ACID

Item 101.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

3.0 LB/HR SULFUR ACID MIST EMISSION
LIMIT DURING NATURAL GAS FIRING IN GAS
TURBINE BASED UPON HHV OF FUEL. EMISSION
LIMIT APPLIES AT ALL LOADS. NYPA WILL
SHOW COMPL BY STACK TEST, WHICH WILL BE
DONE ONCE PER PERMIT TERM. REPORTING
REQUIREMENTS WILL BE 30 DAYS AFTER THE
TEST IS COMPLETED.

Upper Permit Limit: 3.0 pounds per hour

Reference Test Method: PT 60, App A, Meth 8A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED



Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 102: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 102.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003A
Process: PC1 Emission Source: CC03A

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 102.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

15 LB/HR PARTICULATE MATTER EMISSION
LIMIT DURING NATURAL GAS FIRING IN GAS
TURBINE BASED UPON HIGHER HTNG VALUE
(HHV) OF FUEL. EMISSION LIMIT APPLIES AT
ALL LOADS. NYPA WILL SHOW COMPL BY STACK
TEST, WHICH WILL BE DONE ONCE PER PERMIT
TERM. REPORTING REQUIREMENTS WILL BE 30
DAYS AFTER THE TEST IS COMPLETED.

Upper Permit Limit: 15 pounds per hour

Reference Test Method: 201A & 202

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 103: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 103.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003A
Process: PC1 Emission Source: CC03A

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 103.2:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

13.3 LB/HR AMMONIA EMISSION LIMIT DURING
NATURAL GAS FIRING IN GAS TURBINE.
EMISSION LIMIT APPLIES AT ALL LOADS.
NYPA WILL USE CEM TO SHOW COMPLIANCE.

Manufacturer Name/Model Number: CISCO Model # 10006040

Upper Permit Limit: 13.3 pounds per hour

Reference Test Method: As proposed

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 104: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 104.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003A

Process: PC2

Emission Source: CC03A

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 104.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

8.4 LB/HR. VOC EMISSION LIMIT DURING
KEROSENE FIRING IN GAS TURBINE BASED UPON
HHV OF FUEL. THIS LIMIT APPLIES AT ALL
LOADS. NYPA WILL SHOW COMPLIANCE BY
STACK TESTING, WHICH WILL BE DONE ONCE
PER PERMIT TERM. REPORTING REQUIREMENTS
WILL BE 30 DAYS AFTER THE TEST IS
COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 8.4 pounds per hour

Reference Test Method: PART 60,APP A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 105: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 105.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003A
Process: PC2 Emission Source: CC03A

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 105.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

COMPLIANCE WITH THE NOX RACT AND LAER
EMISSION LIMIT WILL BE DEMONSTRATED
PURSUANT TO 40 CFR 60 APPEND A, METH 19
AND 6 NYCRR 227-2.6 (b).

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 80.9 pounds per hour

Reference Test Method: 40CFR 60,APP A,M 19

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 106: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 106.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003A
Process: PC2 Emission Source: CC03A

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Item 106.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

24.6 LB/HR. CO EMISSION LIMIT DURING KEROSENE FIRING IN GAS TURBINE BASED UPON HHV OF FUEL. EMISSION LIMIT APPLIES AT ALL LOADS. NYPA WILL USE CEM TO MONITOR CO EMISSION AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 24.6 pounds per hour

Reference Test Method: PART60,APP A,M 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 107: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 107.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003A

Process: PC2

Emission Source: CC03A

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 107.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

67.0 LB/HR. PARTICULATE MATTER EMISSION LIMIT DURING KEROSENE FIRING IN GAS TURBINE BASED UPON HHV OF FUEL. THIS LIMIT APPLIES AT ALL LOADS. NYPA WILL SHOW COMPLIANCE BY STACK TESTING, WHICH WILL BE DONE ONCE PER PERMIT TERM. REPORTING REQUIREMENTS WILL BE 30 DAYS AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 67 pounds per hour

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Reference Test Method: 201A & 202

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 108: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 108.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003A

Process: PC2

Emission Source: CC03A

Regulated Contaminant(s):

CAS No: 007664-93-9 SULFURIC ACID

Item 108.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

23.2 LB/HR. SULFUR ACID MIST EMISSION
LIMIT DURING KEROSENE FIRING IN GAS
TURBINE BASED UPON HHV OF FUEL. THIS
LIMIT APPLIES AT ALL LOADS. NYPA WILL
SHOW COMPLIANCE BY STACK TESTING, WHICH
WILL BE DONE ONCE PER PERMIT TERM.
REPORTING REQUIREMENTS WILL BE 30 DAYS
AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 23.2 pounds per hour

Reference Test Method: PT 60, APP A, M 8

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 109: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 109.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003A

Process: PC2

Emission Source: CC03A

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 109.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

29.9 LB/HR. AMMONIA EMISSION LIMIT
DURING KEROSENE FIRING IN GAS TURBINE.
NYPA WILL USE CEM TO SHOW COMPLIANCE

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 29.9 pounds per hour

Reference Test Method: As proposed

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 110: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 110.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003B
Process: PC1 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 110.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

3.2 LB/HR VOC EMISSION LIMIT DURING
NATURAL GAS FIRING IN GAS TURBINE BASED
UPON HHV OF FUEL. THIS LIMIT APPLIES AT
ALL LOADS. NYPA WILL SHOW COMPLIANCE BY
STACK TESTING, WHICH WILL BE DONE ONCE
PER PERMIT TERM. REPORTING REQUIREMENTS
WILL BE 30 DAYS AFTER THE TEST IS
COMPLETED.



Parameter Monitored: CONCENTRATION
Upper Permit Limit: 3.2 pounds per hour
Reference Test Method: PT60,APP A
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 111: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 111.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003B
Process: PC1 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 111.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
Monitoring Description:

14.3 LB/HR. NOX EMISSION LIMIT DURING
NATURAL GAS FIRING IN GAS TURBINE BASED
UPON HHV OF FUEL. EMISSION LIMIT APPLIES
AT ALL LOADS. NYPA WILL USE CEM TO
MONITOR NOX EMISSION AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040
Parameter Monitored: CONCENTRATION
Upper Permit Limit: 14.3 pounds per hour
Reference Test Method: 40CFR PT60,APP A,M19
Monitoring Frequency: CONTINUOUS
Averaging Method: 3-HOUR BLOCK AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2008.
Subsequent reports are due every 3 calendar month(s).

Condition 112: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 112.1:

The Compliance Certification activity will be performed for:

New York State Department of Environmental Conservation
Permit ID: 2-6301-00084/00015 Facility DEC ID: 2630100084



Emission Unit: U-00003 Emission Point: 0003B
Process: PC1 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 112.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

10.9 POUND PER HOUR CO EMISSION LIMIT
DURING NATURAL GAS FIRING IN GAS TURBINE
BASED UPON HHV OF FUEL. EMISSION LIMIT
APPLIES AT ALL LOADS. NYPA WILL USE CEM
TO MONITOR CO EMISSION AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 10.9 pounds per hour

Reference Test Method: PT60,APP A,METHOD 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 113: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 113.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003B
Process: PC1 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 007664-93-9 SULFURIC ACID

Item 113.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

3.0 LB/HR SULFUR ACID MIST EMISSION
LIMIT DURING NATURAL GAS FIRING IN GAS
TURBINE BASED UPON HHV OF FUEL. EMISSION
LIMIT APPLIES AT ALL LOADS. NYPA WILL
SHOW COMPL BY STACK TEST, WHICH WILL BE

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



DONE ONCE PER PERMIT TERM. REPORTING
REQUIREMENTS WILL BE 30 DAYS AFTER THE
TEST IS COMPLETED.

Upper Permit Limit: 3.0 pounds per hour
Reference Test Method: PT 60, App A, Meth 8A
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 114: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 114.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003B
Process: PC1 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 114.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

15 LB/HR PARTICULATE MATTER EMISSION
LIMIT DURING NATURAL GAS FIRING IN GAS
TURBINE BASED UPON HIGHER HTNG VALUE
(HHV) OF FUEL. EMISSION LIMIT APPLIES AT
ALL LOADS. NYPA WILL SHOW COMPL BY STACK
TEST, WHICH WILL BE DONE ONCE PER PERMIT
TERM. REPORTING REQUIREMENTS WILL BE 30
DAYS AFTER THE TEST IS COMPLETED.

Upper Permit Limit: 15 pounds per hour
Reference Test Method: 201A & 202
Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT
Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED
Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 115: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 115.1:

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003B

Process: PC1

Emission Source: CC03B

Regulated Contaminant(s):

CAS No: 007664-41-7 AMMONIA

Item 115.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

13.3 LB/HR AMMONIA EMISSION LIMIT DURING
NATURAL GAS FIRING IN GAS TURBINE.
EMISSION LIMIT APPLIES AT ALL LOADS.
NYP A WILL USE CEM TO SHOW COMPLIANCE.

Manufacturer Name/Model Number: CISCO Model # 10006040

Upper Permit Limit: 13.3 pounds per hour

Reference Test Method: As proposed

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 116: Compliance Certification

Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 116.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003B

Process: PC2

Emission Source: CC03B

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 116.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

8.4 LB/HR. VOC EMISSION LIMIT DURING
KEROSENE FIRING IN GAS TURBINE BASED UPON
HHV OF FUEL. THIS LIMIT APPLIES AT ALL
LOADS. NYP A WILL SHOW COMPLIANCE BY
STACK TESTING, WHICH WILL BE DONE ONCE

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



PER PERMIT TERM. REPORTING REQUIREMENTS
WILL BE 30 DAYS AFTER THE TEST IS
COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 8.4 pounds per hour

Reference Test Method: PART 60,APP A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 117: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)

Item 117.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003B

Process: PC2

Emission Source: CC03B

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 117.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

COMPLIANCE WITH THE NOX RACT AND LAER
EMISSION LIMIT WILL BE DEMONSTRATED
PURSUANT TO 40 CFR 60 APPEND A, METH 19
AND 6 NYCRR 227-2.6 (b).

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 80.9 pounds per hour

Reference Test Method: 40CFR 60,APP A,M 19

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 118: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:6 NYCRR 231-2.5 (a)



Item 118.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003B
Process: PC2 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 118.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

24.6 LB/HR. CO EMISSION LIMIT DURING
KEROSENE FIRING IN GAS TURBINE BASED UPON
HHV OF FUEL. EMISSION LIMIT APPLIES AT
ALL LOADS. NYPA WILL USE CEM TO MONITOR
CO EMISSION AT THE STACK.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 24.6 pounds per hour

Reference Test Method: PART60,APP A,M 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).

Condition 119: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 119.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003B
Process: PC2 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 119.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

67.0 LB/HR. PARTICULATE MATTER EMISSION
LIMIT DURING KEROSENE FIRING IN GAS

New York State Department of Environmental Conservation

Permit ID: 2-6301-00084/00015

Facility DEC ID: 2630100084



TURBINE BASED UPON HHV OF FUEL. THIS
LIMIT APPLIES AT ALL LOADS. NYPA WILL
SHOW COMPLIANCE BY STACK TESTING, WHICH
WILL BE DONE ONCE PER PERMIT TERM.
REPORTING REQUIREMENTS WILL BE 30 DAYS
AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 67 pounds per hour

Reference Test Method: 201A & 202

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 120: Compliance Certification
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement:40CFR 52.21(j), Subpart A

Item 120.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003

Emission Point: 0003B

Process: PC2

Emission Source: CC03B

Regulated Contaminant(s):

CAS No: 007664-93-9 SULFURIC ACID

Item 120.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

23.2 LB/HR. SULFUR ACID MIST EMISSION
LIMIT DURING KEROSENE FIRING IN GAS
TURBINE BASED UPON HHV OF FUEL. THIS
LIMIT APPLIES AT ALL LOADS. NYPA WILL
SHOW COMPLIANCE BY STACK TESTING, WHICH
WILL BE DONE ONCE PER PERMIT TERM.
REPORTING REQUIREMENTS WILL BE 30 DAYS
AFTER THE TEST IS COMPLETED.

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 23.2 pounds per hour

Reference Test Method: PT 60, APP A, M 8

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 121: Compliance Certification



Effective between the dates of 03/17/2008 and 03/16/2013

Applicable Federal Requirement: 40CFR 52.21(j), Subpart A

Item 121.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00003 Emission Point: 0003B
Process: PC2 Emission Source: CC03B

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 121.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

29.9 LB/HR. AMMONIA EMISSION LIMIT
DURING KEROSENE FIRING IN GAS TURBINE.
NYPA WILL USE CEM TO SHOW COMPLIANCE.

Manufacturer Name/Model Number: CISCO Model # 10006040

Parameter Monitored: CONCENTRATION

Upper Permit Limit: 29.9 pounds per hour

Reference Test Method: As proposed

Monitoring Frequency: CONTINUOUS

Averaging Method: 3-HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2008.

Subsequent reports are due every 3 calendar month(s).



STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 122: Contaminant List
Effective between the dates of 03/17/2008 and 03/16/2013

Applicable State Requirement:ECL 19-0301

Item 122.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0
Name: CARBON MONOXIDE



CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 007664-93-9
Name: SULFURIC ACID

CAS No: 0NY075-00-0
Name: PARTICULATES

CAS No: 0NY075-00-5
Name: PM-10

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

CAS No: 0NY998-00-0
Name: VOC

Condition 1-18: Unavoidable noncompliance and violations
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable State Requirement:6 NYCRR 201-1.4

Item 1-18.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a



written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 1-19: Air pollution prohibited
Effective between the dates of 07/02/2009 and 03/16/2013

Applicable State Requirement:6 NYCRR 211.2

Item 1-19.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 2-6: Visible Emissions Limited
Effective between the dates of 01/19/2012 and 03/16/2013

Applicable State Requirement:6 NYCRR 211.2

Item 2-6.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

