

**New York State Department of Environmental Conservation
Facility DEC ID: 3551800474**



**PERMIT
Under the Environmental Conservation Law (ECL)**

IDENTIFICATION INFORMATION

Permit Type: Air State Facility
Permit ID: 3-5518-00474/02001
Effective Date: 02/17/2004 Expiration Date: No expiration date

Permit Issued To: ST JOSEPH MEDICAL CENTER
127 SOUTH BROADWAY
YONKERS, NY 10701-4006

Contact: ST JOSEPH MEDICAL CENTER
127 SOUTH BROADWAY
YONKERS, NY 10701-4006
(914) 378-7484

Facility: ST JOSEPH MEDICAL CENTER
127 SOUTH BROADWAY
YONKERS, NY 10701

Description:

Facility is a hospital and operates three small boilers, three emergency generators, an ethylene oxide sterilizer equipped with an abator and a few exempt sources.
Facility is applying for a State Facility permit to cap emissions of Oxides of Nitrogen to less than 25 tons per year and avoid Title V applicability. Fuel usage will be limited to 775,000 gallons #6 fuel oil per year and 2535 gallons diesel fuel per year. Records will be maintained to verify compliance with the cap.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: ROBERT J STANTON
NYS DEC DIVISION OF AIR RESOURCES
21 SOUTH PUTT CORNERS RD
NEW PALTZ, NY 12561-1696

Authorized Signature: _____ Date: ___ / ___ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Applications for Permit Renewals and Modifications

Permit Modifications, Suspensions and Revocations by the Department

Facility Level

Submission of Applications for Permit Modification or Renewal-REGION 3

HEADQUARTERS



DEC GENERAL CONDITIONS
****** General Provisions ******
GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301.2(m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for Permit Renewals and Modifications
Applicable State Requirement: 6NYCRR 621.13

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 3.3:

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual

New York State Department of Environmental Conservation
Facility DEC ID: 3551800474



transfer of ownership.

Condition 4: Permit Modifications, Suspensions and Revocations by the Department
Applicable State Requirement: 6NYCRR 621.14

Item 4.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of Applications for Permit Modification or Renewal-REGION 3 HEADQUARTERS
Applicable State Requirement: 6NYCRR 621.5(a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 3 Headquarters
Division of Environmental Permits
21 South Putt Corners Road
New Paltz, NY 12561-1696
(845) 256-3054



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: ST JOSEPH MEDICAL CENTER
127 SOUTH BROADWAY
YONKERS, NY 10701-4006

ST JOSEPH MEDICAL CENTER

127 SOUTH BROADWAY
YONKERS, NY 10701

Authorized Activity By Standard Industrial Classification Code:
8062 - GENERAL MEDICAL & SURGICAL HOSPITALS

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 5 6NYCRR 211.3: Compliance Demonstration
- 1 6NYCRR 201-6: Facility Permissible Emissions
- *2 6NYCRR 201-6: Compliance Demonstration
- 3 6NYCRR 201-7.2: Compliance Demonstration
- 4 6NYCRR 201-7.2(e): Compliance Demonstration
- 6 6NYCRR 225-1.2(a): Compliance Demonstration

Emission Unit Level

- 7 6NYCRR 201-6: Emission Unit Permissible Emissions
- 8 6NYCRR 201-6: Process Permissible Emissions

EU=U-00001,EP=00001,Proc=001,ES=S0001

- 9 6NYCRR 227-1.3: Compliance Demonstration

EU=U-00001,EP=00001,Proc=001,ES=S0003

- 10 6NYCRR 227-1.3: Compliance Demonstration

EU=U-00001,EP=00002,Proc=001,ES=S0002

- 11 6NYCRR 227-1.3: Compliance Demonstration

EU=U-00002,EP=00003

- 12 6NYCRR 212.3(a): EtO sterilization - Abator operation required during sterilization

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 13 ECL 19-0301: Contaminant List
- 14 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 15 6NYCRR 201-5: Emission Unit Definition
- 16 6NYCRR 201-5.1(a)(1): General Conditions - Synthetic Minor Facilities Obtaining State Facility Permits
- 17 6NYCRR 211.2: Air pollution prohibited

Emission Unit Level

- 18 6NYCRR 201-5: Emission Point Definition By Emission Unit
- 19 6NYCRR 201-5: Process Definition By Emission Unit

NOTE: * preceding the condition number indicates capping.

Permit Effective Date: 02/17/2004

Permit Expiration Date: No expiration date.



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Sealing - 6NYCRR Part 200.5

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

Item B: Acceptable Ambient Air Quality - 6NYCRR Part 200.6

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Item C: Maintenance of Equipment - 6NYCRR Part 200.7

Any person who owns or operates an air contamination

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Item D: Unpermitted Emission Sources - 6NYCRR Part 201-1.2

If an existing emission source was subject to the permitting requirements of 6NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

Item E: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department within two working days after the event

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item F: Recycling and Salvage - 6NYCRR Part 201-1.7

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

Item G: Prohibition of Reintroduction of Collected Contaminants to the Air - 6NYCRR Part 201-1.8

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Item H: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR Part 201-3.2(a)

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item I: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR Part 201-3.3(a)

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

Item J: Required Emission Tests - 6 NYCRR Part 202-1.1

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6NYCRR Part 202-1.

Item K: Visible Emissions Limited - 6 NYCRR Part 211.3

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Item L: Open Fires - 6 NYCRR Part 215

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, rubbish for salvage, or rubbish generated by industrial or commercial activities.

Item M: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item N: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

FEDERAL APPLICABLE REQUIREMENTS

The following conditions are federally enforceable.

Condition 5: Compliance Demonstration
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 211.3

Item 5.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 5.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Except as permitted by a specific part of Title 6 of the NYCRR, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
 - weather condition
 - was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY
Upper Permit Limit: 57 percent



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ONE CONTINUOUS 6-MINUTE PERIOD PER HOUR

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 1: Facility Permissible Emissions

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 201-6

Item 1.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 PTE: 44,000 pounds per year
Name: OXIDES OF NITROGEN

Condition 2: Compliance Demonstration

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 201-6

Item 2.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 2.2:

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Facility wide fuel usage will be limited to 775,000 gallons per year #6 fuel and 2535 gallons per year diesel.

Work Practice Type: PROCESS MATERIAL THRUPUT

Manufacturer Name/Model Number: Records

Upper Permit Limit: 775000 gallons per year

Reference Test Method: Records

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL TOTAL ROLLED MONTHLY



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2005.
Subsequent reports are due every 12 calendar month(s).

Condition 3: Compliance Demonstration
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 201-7.2

Item 3.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 3.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

Capping provisions for synthetic minor facilities firing
distillate oil.

Work Practice Type: PROCESS MATERIAL THRUPUT

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Upper Permit Limit: 999999999 gallons per year

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Compliance Demonstration

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 201-7.2(e)

Item 4.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 4.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

On an annual basis beginning one year after the granting
of an emissions cap, the responsible official shall
provide a certification to the Department that the
facility has operated within the limits imposed by the
emissions cap. This certification shall include a brief



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

summary of the emissions subject to the cap for that time period and a comparison to those threshold values that would require compliance with an applicable requirement.

Monitoring Frequency: MONTHLY
Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2005.
Subsequent reports are due every 12 calendar month(s).

Condition 6: Compliance Demonstration
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 225-1.2(a)

Item 6.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 6.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person shall sell, purchase, or use oil whose sulfur content is greater than 0.37% by weight.

Parameter Monitored: SULFUR 35

Upper Permit Limit: 0.37 percent by weight

Reference Test Method: Applicable method

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

****** Emission Unit Level ******

Condition 7: Emission Unit Permissible Emissions
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 201-6

Item 7.1:

The sum of emissions from all regulated processes specified in this permit for the emission unit cited



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: U-00001

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 29.1 pounds per hour

44,400 pounds per year

Condition 8: Process Permissible Emissions

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 201-6

Item 8.1:

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: U-00001

Process: 001

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 29.1 pounds per hour

44,400 pounds per year

Compliance Demonstration

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 227-1.3

Item 9.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001

Emission Point: 00001

Process: 001

Emission Source: S0001

Item 9.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired boilers which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



1) Observe the stack for each boiler which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- date and time of day
- observer's name
- identity of emission point
- weather condition
- was a plume observed?

Inclement weather conditions shall be recorded for those days when observations are prohibited. This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the

Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



Monitoring Frequency: DAILY

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Compliance Demonstration

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 227-1.3

Item 10.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: U-00001 Emission Point: 00001

Process: 001 Emission Source: S0003

Item 10.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired boilers which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack for each boiler which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- date and time of day
- observer's name
- identity of emission point
- weather condition
- was a plume observed?

Inclement weather conditions shall be recorded for those days when observations are prohibited. This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 11: Compliance Demonstration

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 227-1.3

Item 11.1:

The Compliance Demonstration activity will be performed for:

EmisEmission Point: 00002

Process: 001

Emission Source: S0002

Item 11.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired boilers which are not exempt from permitting and where a continuous opacity monitor is not

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack for each boiler which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- date and time of day
- observer's name
- identity of emission point
- weather condition
- was a plume observed?

Inclement weather conditions shall be recorded for those days when observations are prohibited. This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 12: EtO sterilization - Abator operation required during sterilization
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable Federal Requirement: 6NYCRR 212.3(a)

Item 12.1:

This Condition applies to Emission Unit: U-00002 Emission Point: 00003

Item 12.2:

The EtO abator must be in operation whenever EtO sterilization is conducted.



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Public Access to Recordkeeping for Facilities With State Facility Permits - 6NYCRR Part 201-1.10(a)

Where emission source owners and/or operators keep records pursuant to compliance with the operational flexibility requirements of 6 NYCRR Subpart 201-5.4(b)(1) , and/or the emission capping requirements of 6 NYCRR Subparts 201-7.2(d), 201-7.3(f), 201-7.3(g), 201-7.3(h)(5), 201-7.3(i) and 201-7.3(j), the Department will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Emission source owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department of receipt of the request.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state only enforceable.

Condition 13: Contaminant List

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable State Requirement: ECL 19-0301

Item 13.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

Condition 14: Unavoidable noncompliance and violations

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable State Requirement: 6NYCRR 201-1.4

Item 14.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 15: Emission Unit Definition
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable State Requirement: 6NYCRR 201-5

Item 15.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

THIS EMISSION UNIT CONSISTS OF THREE (3) CLEAVER-BROOKS BOILERS. TWO BOILERS OF CAPACITY 25.1 MMBTU/HR, EACH. THE THIRD BOILER OF CAPACITY 29.2 MMBTU/HR. FLUE GASES EXIT THROUGH A COMMON STACK AT THE MAIN BUILDING AND AN INDIVIDUAL STACK AT THE NURSING HOME.

Building(s): 1
2
3

Item 15.2:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00002

Emission Unit Description:



New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474

THIS UNIT CONSISTS OF ONE ETHYLENE OXIDE
STERILIZER (AMSCO-CRYOTHERM) OPERATED WITH
AN ABATOR.

Building(s): 4

**Condition 16: General Conditions - Synthetic Minor Facilities Obtaining
State Facility Permits
Effective between the dates of 02/17/2004 and Permit Expiration Date**

Applicable State Requirement: 6NYCRR 201-5.1(a)(1)

Item 16.1:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 16.2:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 16.3:

On an annual basis, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to those threshold levels that would require the submission of an application for a Title V facility permit, or compliance with an applicable requirement.

Item 16.4:

The emission of pollutants in exceedance of the applicability thresholds for obtaining a Title V facility permit or other applicable requirements constitutes a violation of Part 201 and of the Act.

Air pollution prohibited

Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable State Requirement: 6NYCRR 211.2

Item 17.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



****** Emission Unit Level ******

Condition 18: Emission Point Definition By Emission Unit
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable State Requirement: 6NYCRR 201-5

Item 18.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001
Height (ft.): 78 Diameter (in.): 36
NYTMN (km.): 4531.4 NYTME (km.): 592.8 Building: 2

Emission Point: 00002
Height (ft.): 78 Diameter (in.): 36
NYTMN (km.): 4531.4 NYTME (km.): 592.8 Building: 2

Item 18.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00002

Emission Point: 00003
Height (ft.): 31 Diameter (in.): 6
NYTMN (km.): 4531.4 NYTME (km.): 592.8 Building: 2

Condition 19: Process Definition By Emission Unit
Effective between the dates of 02/17/2004 and Permit Expiration Date

Applicable State Requirement: 6NYCRR 201-5

Item 19.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 001

Source Classification Code: 1-02-004-01

Process Description: THE THREE BOILERS OPERATE ON NO. 6 FUEL OIL.

Emission Source/Control: S0001 - Combustion
Design Capacity: 25.1 million Btu per hour

Emission Source/Control: S0002 - Combustion

New York State Department of Environmental Conservation

Permit ID: 3-5518-00474/02001

Facility DEC ID: 3551800474



Design Capacity: 25.1 million Btu per hour

Emission Source/Control: S0003 - Combustion

Design Capacity: 29.2 million Btu per hour

Item 19.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002

Process: 002

Source Classification Code: 3-99-999-94

Process Description:

THIS UNIT CONSISTS OF ONE ETHYLENE OXIDE STERILIZER (AMSCO-CRYOTHERM), UTILIZING OXYFUME GAS MIXTURE AND OPERATED WITH AN ABATOR. TYPICALLY, THE STERILIZER IS OPERATED TWO CYCLES A DAY, TEN CYCLES A WEEK.

Emission Source/Control: S0004 - Process

Design Capacity: 40 cubic feet