

**New York State Department of Environmental Conservation  
Facility DEC ID: 4192800040**



**PERMIT  
Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air State Facility  
Permit ID: 4-1928-00040/00007  
Mod 0 Effective Date: 05/04/1999 Expiration Date: No expiration date.  
Mod 1 Effective Date: 01/14/2002 Expiration Date: No expiration date.  
Mod 3 Effective Date: 03/26/2002 Expiration Date: No expiration date.  
Mod 4 Effective Date: 09/20/2004 Expiration Date: No expiration date.  
Mod 5 Effective Date: 05/11/2006 Expiration Date: No expiration date.

Permit Issued To: NYS DEPT OF CORRECTIONAL SERVICES  
BUILDING 2  
1220 WASHINGTON AVE  
ALBANY, NY 12226-2050

Facility: GREENE CORRECTIONAL FACILITY  
COUNTY RTE 9  
COXSACKIE, NY 12051

Contact: JOSEPH DAVID  
COUNTY ROUTE 9W, P.O. BOX #8  
COXSACKIE, NY 12051

Description:  
Modification is for addition of one boiler

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: NANCY M ADAMS  
1150 NORTH WESTCOTT RD  
SCHENECTADY, NY 12306-2014

Authorized Signature: \_\_\_\_\_ Date: \_\_\_ / \_\_\_ / \_\_\_\_



**Notification of Other State Permittee Obligations**

**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



**LIST OF CONDITIONS**

**DEC GENERAL CONDITIONS**

**General Provisions**

Facility Inspection by the Department

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Relationship of this Permit to Other Department Orders and Determinations

Applications for Permit Renewals and Modifications

Applications for Permit Renewals and Modifications

Applications for Permit Renewals and Modifications

Permit Modifications, Suspensions and Revocations by the Department

Permit Modifications, Suspensions, and Revocations by the Department

Permit Modifications, Suspensions, and Revocations by the Department

**Facility Level**

Submission of Applications for Permit Modification or Renewal -REGION 4  
HEADQUARTERS

Submission of Applications for Permit Modification or Renewal -REGION 4  
HEADQUARTERS



**DEC GENERAL CONDITIONS**  
**\*\*\*\* General Provisions \*\*\*\***  
**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1-1: Facility Inspection by the Department**  
**Applicable State Requirement: ECL 19-0305**

**Item 1-1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1-1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1-1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 1: Facility Inspection by the Department**  
**Applicable State Requirement: ECL 3-0301.2(g)**

**Expired by Mod No: 4**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 1-2: Relationship of this Permit to Other Department Orders and Determinations**  
**Applicable State Requirement: ECL 3-0301.2(m)**

**Item 1-2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or



**New York State Department of Environmental Conservation**  
**Facility DEC ID: 4192800040**

rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**  
**Applicable State Requirement: ECL 3-0301.2(m)**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 4-1: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 4-1.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 4-1.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 4-1.3:**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 3: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13(a)**

**Expired by Mod No: 4**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Condition 1-3: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13(a)**

**Expired by Mod No: 4**



**New York State Department of Environmental Conservation**  
**Facility DEC ID: 4192800040**

**Item 1-3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 1-3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Condition 4-2: Permit Modifications, Suspensions and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Item 4-2.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**Condition 1-4: Permit Modifications, Suspensions, and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Expired by Mod No: 4**

**Item 1-4.1:**

The Department reserves the right to modify, suspend, or revoke this permit. The grounds for modification, suspension or revocation include:

- a) the scope of the permitted activity is exceeded or a violation of any condition of the permit or provisions of the ECL and pertinent regulations is found;
- b) the permit was obtained by misrepresentation or failure to disclose relevant facts;
- c) new material information is discovered; or
- d) environmental conditions, relevant technology, or applicable law or regulation have materially changed since the permit was issued.

**Condition 4: Permit Modifications, Suspensions, and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Expired by Mod No: 4**

**Item 4.1:**

The Department reserves the right to modify, suspend, or revoke this permit. The grounds for

**New York State Department of Environmental Conservation**  
**Facility DEC ID: 4192800040**



modification, suspension or revocation include:

- a) the scope of the permitted activity is exceeded or a violation of any condition of the permit or provisions of the ECL and pertinent regulations is found;
- b) the permit was obtained by misrepresentation or failure to disclose relevant facts;
- c) new material information is discovered; or
- d) environmental conditions, relevant technology, or applicable law or regulation have materially changed since the permit was issued.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 1-5: Submission of Applications for Permit Modification or Renewal -REGION 4 HEADQUARTERS**

**Applicable State Requirement: 6NYCRR 621.5(a)**

**Expired by Mod No: 4**

**Item 1-5.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 4 Headquarters  
Division of Environmental Permits  
1150 North Westcott Rd.  
Schenectady, NY 12306-2014  
(518) 357-2069

**Condition 5: Submission of Applications for Permit Modification or Renewal -REGION 4 HEADQUARTERS**

**Applicable State Requirement: 6NYCRR 621.5(a)**

**Expired by Mod No: 4**

**Item 5.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 4 Headquarters  
Division of Environmental Permits  
1150 North Westcott Rd.  
Schenectady, NY 12306-2014  
(518) 357-2068

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: NYS DEPT OF CORRECTIONAL SERVICES  
BUILDING 2  
1220 WASHINGTON AVE  
ALBANY, NY 12226-2050

Facility: GREENE CORRECTIONAL FACILITY  
COUNTY RTE 9  
COXSACKIE, NY 12051

Authorized Activity By Standard Industrial Classification Code:  
9223 - CORRECTIONAL INSTITUTIONS

Mod 0 Permit Effective Date: 05/04/1999	Permit Expiration Date: No expiration date.
Mod 1 Permit Effective Date: 01/14/2002	Permit Expiration Date: No expiration date.
Mod 3 Permit Effective Date: 03/26/2002	Permit Expiration Date: No expiration date.
Mod 4 Permit Effective Date: 09/20/2004	Permit Expiration Date: No expiration date.
Mod 5 Permit Effective Date: 05/11/2006	Permit Expiration Date: No expiration date.



**LIST OF CONDITIONS**

**FEDERALLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 5-1 6NYCRR 201-7.2: Facility Permissible Emissions
- \*5-2 6NYCRR 201-7.2: Capping Monitoring Condition
- 5-3 6NYCRR 225-1.8: Compliance Demonstration
- 5-4 6NYCRR 227-1.3(a): Compliance Demonstration

**Emission Unit Level**

**EU=0-00005,Proc=GEN**

- 5-5 6NYCRR 227-1.3: Compliance Demonstration

**EU=0-0MAIN**

- 5-6 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
- 5-7 40CFR 60.7(a), NSPS Subpart A: Date of construction notification -  
If a COM is not used.
- 5-8 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
- 5-9 40CFR 60.9, NSPS Subpart A: Availability of information.
- 5-10 40CFR 60.12, NSPS Subpart A: Circumvention.
- 5-11 40CFR 60.48c(g), NSPS Subpart Dc: Compliance Demonstration
- 5-12 40CFR 60.48c(i), NSPS Subpart Dc: Compliance Demonstration

**EU=0-0MAIN,Proc=OIL**

- 5-13 6NYCRR 227-1.3: Compliance Demonstration
- 5-14 40CFR 60.42c(d), NSPS Subpart Dc: Compliance Demonstration
- 5-15 40CFR 60.42c(h), NSPS Subpart Dc: Exemption from the averaging period.
- 5-16 40CFR 60.42c(i), NSPS Subpart Dc: Enforceability.
- 5-17 40CFR 60.48c(d), NSPS Subpart Dc: Compliance Demonstration
- 5-18 40CFR 60.48c(e)(1), NSPS Subpart Dc: Compliance Demonstration
- 5-19 40CFR 60.48c(e)(11), NSPS Subpart Dc: Compliance Demonstration
- 5-20 40CFR 60.48c(f)(1), NSPS Subpart Dc: Compliance Demonstration

**STATE ONLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 4-24 ECL 19-0301: Contaminant List
- 4-25 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 27 6NYCRR 201-5: Emission Unit Definition
- 28 6NYCRR 211.2: Air pollution prohibited

**Emission Unit Level**

- 31 6NYCRR 201-5: Emission Point Definition By Emission Unit
- 32 6NYCRR 201-5: Process Definition By Emission Unit

NOTE: \* preceding the condition number indicates capping.



**FEDERALLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Sealing - 6NYCRR Part 200.5**

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

**Item B: Acceptable Ambient Air Quality - 6NYCRR Part 200.6**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Item C: Maintenance of Equipment - 6NYCRR Part 200.7**

Any person who owns or operates an air contamination

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Item D: Unpermitted Emission Sources - 6NYCRR Part 201-1.2**

If an existing emission source was subject to the permitting requirements of 6NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

**Item E: Emergency Defense - 6NYCRR Part 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department within two working days after the event



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item F: Recycling and Salvage - 6NYCRR Part 201-1.7**

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

**Item G: Prohibition of Reintroduction of Collected Contaminants to the Air - 6NYCRR Part 201-1.8**

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Item H: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR Part 201-3.2(a)**

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item I: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR Part 201-3.3(a)**

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item J: Required Emission Tests - 6 NYCRR Part 202-1.1**

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6NYCRR Part 202-1.

**Item K: Visible Emissions Limited - 6 NYCRR Part 211.3**

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Item L: Open Fires - 6 NYCRR Part 215**

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**Item M: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item N: Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**FEDERAL APPLICABLE REQUIREMENTS**

**The following conditions are federally enforceable.**

**Condition 5-1: Facility Permissible Emissions**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 201-7.2**

**Item 5-1.1:**

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 000630-08-0 (From Mod 5) PTE: 156,000 pounds per year  
Name: CARBON MONOXIDE

CAS No: 007446-09-5 (From Mod 5) PTE: 156,000 pounds per year  
Name: SULFUR DIOXIDE

CAS No: 0NY210-00-0 (From Mod 5) PTE: 156,000 pounds per year  
Name: OXIDES OF NITROGEN

**Condition 5-2: Capping Monitoring Condition**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



**Applicable Federal Requirement: 6NYCRR 201-7.2**

**Item 5-2.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6NYCRR 201-6

6NYCRR 227-2

**Item 5-2.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 5-2.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 5-2.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 5-2.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 5-2.6:**

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

CAS No: 007446-09-5 SULFUR DIOXIDE

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 5-2.7:**

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

**Monitoring Description:**

Emissions limited to less than 78 ton/yr (less than 80% of the major source threshold). Emissions shall be calculated using the most current AP-42 emission factors. The amount of fuel used and the sulfur content of the oil shall be included in the annual report. Records shall be maintained in accordance with Part 201-7.2(d).

The emission factors at the time of permit issuance are:

SO<sub>2</sub>: [(71 X thousands of gallons of No. 2 oil used in boilers) + (0.6 X million cubic feet of natural gas used in boilers) + (71 X thousands of gallons of No. 2 oil used in exempt combustion units) + (0.07 X gallons of diesel used in large (> 600 hp) generators) + (0.04 X gallons of diesel used in small (< 600 hp) generators)]/2000 < 95 tons.

NO<sub>x</sub>: [(20 X thousands of gallons of No. 2 oil used in boilers) + (100 X million cubic feet of natural gas used in boilers) + (18 X thousands of gallons of No. 2 oil used in exempt combustion units) + (0.44 X gallons of diesel used in large (> 600 hp) generators) + (0.60 X gallons of diesel used in small (< 600 hp) generators)]/2000 < 95 tons.

CO: [(5 X thousands of gallons of No. 6 oil used in boilers) + (84 X million cubic feet of natural gas used in boilers) + (5 X thousands of gallons of No. 2 oil used in exempt combustion units) + (0.12 X gallons of diesel used in large (> 600 hp) generators) + (0.13 X gallons of diesel used in small (< 600 hp) generators)]/2000 < 95 tons.

Parameter Monitored: FUEL

Upper Permit Limit: 78 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2007.

Subsequent reports are due every 12 calendar month(s).

**Condition 5-3: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 225-1.8**



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

**Item 5-3.1:**

The Compliance Demonstration activity will be performed for the Facility.

**Item 5-3.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

An owner or operator of a facility which purchases and fires coal and/or fuel oil shall compile and retain records of the following information:

- a. fuel analyses and data on the quantities of all residual and distillate oil and coal received, burned or sold;
- b. the names of all purchasers of all residual and distillate oil and coal sold;
- c. any results of stack sampling, stack monitoring and other procedures used to ensure compliance with the provisions of 6 NYCRR Part 225-1.

Fuel analyses must contain, as a minimum, data on the sulfur content, specific gravity and heating value of any residual oil, distillate oil or coal received, burned or sold. Ash content shall also be included in the fuel analyses for any residual oil or coal received, burned or sold.

These records shall be retained for a minimum period of three years. If the facility is subject to Title V requirements the minimum record retention period shall be five years. The records shall be made available for inspection by department staff during normal business hours. In addition, copies of such records shall be furnished to department staff upon request. All required sampling, compositing and analysis of fuel samples must be done in accordance with methods acceptable to the department.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**Condition 5-4: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.3(a)**

**Item 5-4.1:**



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

The Compliance Demonstration activity will be performed for the Facility.

**Item 5-4.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 5-5: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.3**

**Item 5-5.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-00005

Process: GEN

**Item 5-5.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired internal combustion engines which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

1) Observe the stack for each internal combustion engine which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition
- was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**\*\* NOTE \*\*** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**Condition 5-6: EPA Region 2 address.**



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.4, NSPS Subpart A**

**Item 5-6.1:**

This Condition applies to Emission Unit: 0-0MAIN

**Item 5-6.2:**

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance  
USEPA Region 2  
290 Broadway, 21st Floor  
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC  
Bureau of Quality Assurance  
625 Broadway  
Albany, NY 12233-3258

**Condition 5-7: Date of construction notification - If a COM is not used.**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.7(a), NSPS Subpart A**

**Item 5-7.1:**

This Condition applies to Emission Unit: 0-0MAIN

**Item 5-7.2:**

Any owner or operator subject to this part shall furnish the Administrator with the following information:

- 1) a notification of the date construction or reconstruction commenced, post marked no later than 30 days after such date;
- 3) a notification of the actual date of initial start up, post marked within 15 days after such date;
- 4) a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the change is specifically exempted under this part. The notice shall be post marked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

proposed emission control systems, productive capability of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional information regarding the change;

5) a notification of the date upon which the demonstration of continuous monitoring system performance commences, post marked not less than 30 days prior to such date;

6) a notification of the anticipated date for conducting the opacity observations, post marked not less than 30 days prior to such date.

**Condition 5-8: Recordkeeping requirements.**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.7(b), NSPS Subpart A**

**Item 5-8.1:**

This Condition applies to Emission Unit: 0-0MAIN

**Item 5-8.2:**

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

**Condition 5-9: Availability of information.**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.9, NSPS Subpart A**

**Item 5-9.1:**

This Condition applies to Emission Unit: 0-0MAIN

**Item 5-9.2:**

The availability to the public of information provided to, or otherwise obtained by, the Administrator under this part shall be governed by part 2 of this chapter.

**Condition 5-10: Circumvention.**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.12, NSPS Subpart A**

**Item 5-10.1:**

This Condition applies to Emission Unit: 0-0MAIN

**Item 5-10.2:**

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

**Condition 5-11: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.48c(g), NSPS Subpart Dc**

**Item 5-11.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

**Item 5-11.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of an affected facility shall record and maintain records of the amounts of each fuel combusted during each day.

Monitoring Frequency: DAILY

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**Condition 5-12: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.48c(i), NSPS Subpart Dc**

**Item 5-12.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

**Item 5-12.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



**Condition 5-13: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.3**

**Item 5-13.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

Process: OIL

**Item 5-13.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired boilers which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack for each boiler which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
  - date and time of day
  - observer's name
  - identity of emission point
  - weather condition
  - was a plume observed?

Inclement weather conditions shall be recorded for those days when observations are prohibited. This logbook must be retained at the facility for five (5) years after the date of the last entry.

- 3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**\*\* NOTE \*\*** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

**Condition 5-14: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.42c(d), NSPS Subpart Dc**

**Item 5-14.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

Process: OIL

**Item 5-14.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

On or after the date on which the initial performance test is completed or required to be completed under section 60.8 of this part, no owner or operator of an affected facility that combusts oil shall combust oil with

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



a sulfur content in excess of 0.5 percent by weight.

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL  
Parameter Monitored: SULFUR CONTENT  
Upper Permit Limit: 0.50 percent by weight  
Monitoring Frequency: PER DELIVERY  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 5-15: Exemption from the averaging period.**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.42c(h), NSPS Subpart Dc**

**Item 5-15.1:**

This Condition applies to Emission Unit: 0-0MAIN  
Process: OIL

**Item 5-15.2:**

Compliance with emission limits and/or fuel oil sulfur limitations shall be based on a certification from the fuel supplier as stated in paragraph 40 CFR 60-Dc.48c(f)(1), (2), or (3) as applicable.

**Condition 5-16: Enforceability.**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.42c(i), NSPS Subpart Dc**

**Item 5-16.1:**

This Condition applies to Emission Unit: 0-0MAIN  
Process: OIL

**Item 5-16.2:**

The sulfur dioxide emission limits, percentage reductions, and fuel oil sulfur limitations shall apply at all times, including periods of startup, shutdown, and malfunction.

**Condition 5-17: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.48c(d), NSPS Subpart Dc**

**Item 5-17.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

Process: OIL

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 5-17.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c shall submit semi-annual reports to the Administrator.

Monitoring Frequency: SEMI-ANNUALLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).

**Condition 5-18: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.48c(e)(1), NSPS Subpart Dc**

**Item 5-18.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

Process: OIL

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 5-18.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c shall keep records as required under §60.48c(d) including the following information.

Calendar dates covered in the reporting period.

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).

**Condition 5-19: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.48c(e)(11), NSPS Subpart Dc**

**Item 5-19.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

Process: OIL

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 5-19.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of each affected facility subject to the SO<sub>2</sub> emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c shall keep records as required under §60.48c(d) including the following information.

If fuel supplier certification is used to demonstrate compliance, records of fuel supplier certification as described under paragraph §60.48c(f)(1)(2) or (3). In addition to records of fuel supplier certification, the semi-annual report shall include a certified statement signed by the owner or operator of the affected facility that the records of fuel supplier certifications submitted represent all of the fuel combusted during the period.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



Subsequent reports are due every 6 calendar month(s).

**Condition 5-20: Compliance Demonstration**

**Effective between the dates of 05/11/2006 and Permit Expiration Date**

**Applicable Federal Requirement: 40CFR 60.48c(f)(1), NSPS Subpart Dc**

**Item 5-20.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

Process: OIL

Regulated Contaminant(s):

CAS No: 007446-09-5      SULFUR DIOXIDE

**Item 5-20.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Fuel supplier certification shall include the following information for distillate oil:

- i) The name of the oil supplier, and
- ii) A statement from the oil supplier that the oil complies with the specifications under the definition of distillate oil in §60.41c. 60-Dc 41c defines distillate oil as fuel that complies with the specifications for fuel oil numbers 1 or 2, as defined by the American Society for Testing and Materials in ASTM D396-78, A standard Specification for Fuel Oils.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).



**STATE ONLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Public Access to Recordkeeping for Facilities With State Facility Permits - 6NYCRR Part 201-1.10(a)**

Where emission source owners and/or operators keep records pursuant to compliance with the operational flexibility requirements of 6 NYCRR Subpart 201-5.4(b)(1) , and/or the emission capping requirements of 6 NYCRR Subparts 201-7.2(d), 201-7.3(f), 201-7.3(g), 201-7.3(h)(5), 201-7.3(i) and 201-7.3(j), the Department will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Emission source owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department of receipt of the request.

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or

**New York State Department of Environmental Conservation**

Permit ID: 4-1928-00040/00007

Facility DEC ID: 4192800040



law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state only enforceable.**

**Condition 4-24: Contaminant List**

**Effective between the dates of 09/20/2004 and Permit Expiration Date**

**Applicable State Requirement: ECL 19-0301**

**Item 4-24.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0

Name: CARBON MONOXIDE

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

CAS No: 007446-09-5

Name: SULFUR DIOXIDE

**Condition 4-25: Unavoidable noncompliance and violations**

**Effective between the dates of 09/20/2004 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-1.4**

**Item 4-25.1:**

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

- (a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superseded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

**Condition 27: Emission Unit Definition**  
**Effective between the dates of 05/04/1999 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-5**

**Item 27.1(From Mod 5):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 0-00005

Emission Unit Description:

Two diesel fired generators.

Building(s): 18

43

**Item 27.2(From Mod 5):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 0-0MAIN

Emission Unit Description:

(2) 16.74 MM BTU/HR BOILERS AND (2) 10.46  
MM BTU/HR BOILERS. EACH BOILER VENTS TO AN

**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**



**INDIVIDUAL STACK.**

Building(s): 42

**Condition 28: Air pollution prohibited**  
**Effective between the dates of 05/04/1999 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 211.2**

**Item 28.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 31: Emission Point Definition By Emission Unit**  
**Effective between the dates of 05/04/1999 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-5**

**Item 31.1(From Mod 5):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 0-00005

Emission Point: 00004

Height (ft.): 13

Diameter (in.): 15

Building: 43

Emission Point: 00005

Height (ft.): 11

Diameter (in.): 11

Building: 18

**Item 31.2(From Mod 5):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 0-0MAIN

Emission Point: 00001

Height (ft.): 35

Diameter (in.): 36

NYTMN (km.): 4687.824 NYTME (km.): 596.733 Building: 42



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

Emission Point: 00002  
Height (ft.): 35                      Diameter (in.): 36  
NYTMN (km.): 4687.824    NYTME (km.): 596.733    Building: 42

Emission Point: 00003  
Height (ft.): 35                      Diameter (in.): 36  
NYTMN (km.): 4687.824    NYTME (km.): 596.733    Building: 42

Emission Point: 00006  
Height (ft.): 35                      Diameter (in.): 20  
NYTMN (km.): 4687.824    NYTME (km.): 596.733    Building: 42

**Condition 32:    Process Definition By Emission Unit**  
**Effective between the dates of 05/04/1999 and Permit Expiration Date**

**Applicable State Requirement:    6NYCRR 201-5**

**Item 32.1(From Mod 5):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-00005  
Process: GEN    Source Classification Code: 2-01-001-02  
Process Description: Diesel firing generator

Emission Source/Control: 0GEN1 - Combustion  
Design Capacity: 1,500 kilowatts

Emission Source/Control: 0GEN2 - Combustion  
Design Capacity: 750 kilowatts

**Item 32.2(From Mod 5):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-0MAIN  
Process: GAS    Source Classification Code: 1-02-006-02  
Process Description:

(2) 16.74 MM BTU/HR BOILERS AND (2) 10.46  
MM BTU/HR BOILERS BURNING NATURAL GAS

Emission Source/Control: 00B01 - Combustion  
Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B02 - Combustion  
Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B03 - Combustion



**New York State Department of Environmental Conservation**

**Permit ID: 4-1928-00040/00007**

**Facility DEC ID: 4192800040**

Design Capacity: 10.46 million Btu per hour

Emission Source/Control: 00B04 - Combustion

Design Capacity: 10.46 million Btu per hour

**Item 32.3(From Mod 5):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-0MAIN

Process: OIL

Source Classification Code: 1-02-005-01

Process Description:

(2) 16.74 MM BTU/HR AND (2) 10.46 MM  
BTU/HR BOILERS BURNING 0.5% SULFUR (BY  
WEIGHT) #2 FUEL OIL

Emission Source/Control: 00B01 - Combustion

Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B02 - Combustion

Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B03 - Combustion

Design Capacity: 10.46 million Btu per hour

Emission Source/Control: 00B04 - Combustion

Design Capacity: 10.46 million Btu per hour