



**PERMIT**  
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air Title V Facility  
Permit ID: 5-5205-00013/00058  
Mod 0 Effective Date: 11/20/2006 Expiration Date: 11/19/2011  
Mod 1 Effective Date: Expiration Date:

Permit Issued To: LEHIGH NORTHEAST CEMENT COMPANY  
313 WARREN ST  
GLENS FALLS, NY 12801

Contact: STUART GUNTHER  
LEHIGH NORTHEAST CEMENT COMPANY  
PO BOX 440 - 313 WARREN ST  
GLENS FALLS, NY 12801-0440  
(518) 792-1137

Facility: LEHIGH NORTHEAST CEMENT COMPANY  
313 WARREN ST  
GLENS FALLS, NY 12801

Contact: STUART GUNTHER  
LEHIGH NORTHEAST CEMENT COMPANY  
PO BOX 440 - 313 WARREN ST  
GLENS FALLS, NY 12801-0440  
(518) 792-1137

**Description:**

The Glens Falls Cement Company facility, located in Glens Falls, NY, consists of a Portland cement manufacturing operation and an associated quarry. Various types of Portland cements are produced using a combination of limestone, sand gypsum, and other materials of similar chemical composition. These materials are heated in the facility's rotary kiln to form cement clinker, which is cooled and ground to form cement.

Operations at the facility have been broken down into nine (9) emission units, each having related functions and processes, as follows:

Stone quarrying and preliminary crushing (Emission Unit U-QUARY);  
Raw material storage and handling (Emission Unit U-RMHND);  
Raw material grinding (Emission Unit (U-RAWGR);  
Kiln or pyroprocessing system (Emission Unit U-KILN);  
Solid fuel (coal) system (Emission Unit U-FUEL);  
Cement clinker transport and storage (Emission Unit U-CLTRN);  
Precrusher (Polycom) system (Emission Unit U-PLYCM);  
Finish mill/Product storage (Emission Unit U-FINML); and  
Product packing and loading (Emission Unit U-SHPNG).

Applicable Requirements at the facility-wide level include:



6 NYCRR 200	
6 NYCRR 215.2	
6 NYCRR 202-2	
6 NYCRR 220.4(c)	
6 NYCRR 211.2	
6 NYCRR 243	
6 NYCRR 211.3	40 CFR
82.106 (SubPart E)	

Quarry Operations (Emission Unit U-QUARY) - Glens Falls owns and operates a quarry on property adjacent to the manufacturing facility. Limestone is mined from the quarry walls primarily by drilling and blasting into the stone. The fragmented stone loosened from the walls is loaded into large dump trucks using wheel loaders. The rock is transported to a crusher where the size of the mined stone is reduced. The crushed material is transported by conveyor to the stone storage building or storage piles to await further processing or direct sale. Applicable Requirements Include: 6NYCRR 212.3(a).

Raw Material Handling (Emission Unit U-RMHND) - Raw materials (other than limestone) are delivered to the facility via trucks.. These materials are off-loaded for storage using a series of conveyors and wheel loaders and placed in piles. As previously mentioned, limestone and related raw material stone is stored in the stone storage building. A reclaiming is used to recover the piles within the storage building. A series of conveyors are used to transport the raw materials from storage to the raw grinding operation. Applicable Requirements Include: 6 NYCRR 212.3(a).

Raw Mererial Grinding (Emission Unit U-RAWGR) - After transport from storage, the various raw materials are blended and pulverized in the raw (roller) mill for preparation as a feed mixture for the kilns. When the feed mixture has reached a desired consistency or blend, it is transported to a series of storage silos until it is fed into the kiln for further processing. Applicable Requirements Include: 6 NYCRR 212.3(a).

Kiln (Pyroprocessing) System (Emission Unit U-KILN) - The rotary kiln (and its associated clinker cooler) are the primary tools used in the manufacture of Portland cement. Two primary operations occur in this equipment: (1) creation of cement "clinker" in the kilns and (2) cooling of the newly-manufactured clinker for further processing or storage. Raw feed is transported to the kiln from the storage silow. Within the interior of the kiln, temperatures in excess of 2700 deg F create the clinker, consisting of balls of hard, rock-like material, from the raw feed. Coal is the primary fuel used to fire the kiln, with natural gas used as a startup or backup fuel. When the clinker has been fully formed, it is conveyed to the clinker cooler, which consists of a series of grates over which the clinker travels and is exposed to forced ambient air for cooling. The Applicable Requirements Include:

6 NYCRR 212.3(a)	40 CFR
60.7 (SubPart A)	
6 NYCRR 220.3(a)	40
CFR60.8 (SubPart A)	
6 NYCRR 220.6(b)(1)	40 CFR
60.11 (SubPart A)	
6 NYCRR 220.8(a & b)	40 CFR
60.13 (SubPart A)	
6 NYCRR 225-1.2(a)(2)	40 CFR 60
(SubPart F)	



6 NYCRR 204  
(SubPart LLL) for area source  
6 NYCRR 243

40 CFR 63

Note: Not all equipment and/or processes within this emission unit are subject to the requirements of 40 CFR 60 (New Source Performance Standards).

Solid Fuel System (Emission Unit U-FUEL) - Coal is delivered to the facility via trucks or railcars. The material is unloaded to an outdoor storage pile directly from the truck (through dumping) or using wheel loaders or similar equipment. Coal from the pile is fed into a coal bin to a ball mill (coal mill), which reduces the size of the coal for optimum combustion within the kiln.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: WALTER L HAYNES  
DIVISION OF ENVIRONMENTAL PERMITS  
232 GOLF COURSE RD PO BOX 220  
WARRENSBURG, NY 12885-0220

Authorized Signature: \_\_\_\_\_ Date: \_\_\_ / \_\_\_ / \_\_\_\_\_



### Notification of Other State Permittee Obligations

**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



## LIST OF CONDITIONS

### DEC GENERAL CONDITIONS

#### General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
  - Applications for permit renewals, modifications and transfers
  - Applications for Permit Renewals and Modifications
  - Permit modifications, suspensions or revocations by the Department
  - Permit Modifications, Suspensions and Revocations by the Department

#### Facility Level

- Submission of Applications for Permit Modification or Renewal -REGION 5 SUBOFFICE
- Submission of application for permit modification or renewal-REGION 5 SUBOFFICE - WARRENSBURG



**DEC GENERAL CONDITIONS**

**\*\*\*\* General Provisions \*\*\*\***

**For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.**

**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**  
**Applicable State Requirement:**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**  
**Applicable State Requirement:**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 3: Applications for permit renewals, modifications and transfers**  
**Applicable State Requirement: 6NYCRR 621.11**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 3.3:**



Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 4: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 4.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 4.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 4.3:**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 5: Permit modifications, suspensions or revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 5.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**Condition 6: Permit Modifications, Suspensions and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Item 6.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;



- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 7: Submission of Applications for Permit Modification or Renewal -REGION 5  
SUBOFFICE**

**Applicable State Requirement: 6NYCRR 621.5(a)**

**Item 7.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 5 Sub-office  
Division of Environmental Permits  
232 Hudson St, PO Box 220  
Warrensburg, NY 12885-0220  
(518) 623-1281

**Condition 8: Submission of application for permit modification or renewal-REGION 5  
SUBOFFICE - WARRENSBURG**

**Applicable State Requirement: 6NYCRR 621.6(a)**

**Item 8.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 5 Sub-office  
Division of Environmental Permits  
232 Golf Course Road, PO Box 220  
Warrensburg, NY 12885-0220  
(518) 623-1281



**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: LEHIGH NORTHEAST CEMENT COMPANY  
313 WARREN ST  
GLENS FALLS, NY 12801

Facility: LEHIGH NORTHEAST CEMENT COMPANY  
313 WARREN ST  
GLENS FALLS, NY 12801

Authorized Activity By Standard Industrial Classification Code:  
3241 - CEMENT, HYDRAULIC

Permit Effective Date:

Permit Expiration Date:



## LIST OF CONDITIONS

### DEC GENERAL CONDITIONS

#### General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
  - Applications for permit renewals, modifications and transfers
  - Applications for Permit Renewals and Modifications
  - Permit modifications, suspensions or revocations by the Department
  - Permit Modifications, Suspensions and Revocations by the Department

#### Facility Level

- Submission of Applications for Permit Modification or Renewal -REGION 5 SUBOFFICE
- Submission of application for permit modification or renewal-REGION 5 SUBOFFICE - WARRENSBURG

### FEDERALLY ENFORCEABLE CONDITIONS

#### Facility Level

- 1-1 6NYCRR 243-1.6(c): NOx Ozone Season Emission Requirements
- 1-2 6NYCRR 243-1.6(d): Excess emission requirements
- 1-3 6NYCRR 243-1.6(e): Recordkeeping and reporting requirements
- 1-4 6NYCRR 243-8.1: General requirements
- 1-5 6NYCRR 243-8.1: Prohibitions
- 1-6 6NYCRR 243-8.3: Out of control periods
- 1-7 6NYCRR 243-8.5(d): Quarterly reports
- 1-8 6NYCRR 243-8.5(e): Compliance certification
- 1-9 40CFR 63.1342, Subpart LLL: Part 63 General Provisions requirements

### STATE ONLY ENFORCEABLE CONDITIONS

#### Facility Level

- 77 : Contaminant List



**FEDERALLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.**

**Item A: Emergency Defense - 6NYCRR Part 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or

operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department

within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



- Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)**  
Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.
- Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)**  
Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**  
The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**  
This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
- Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)**  
It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.
- Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)**  
This permit does not convey any property rights of any sort or any exclusive privilege.
- Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)**



If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the



effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item L: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.



**Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**The following conditions are subject to annual compliance certification requirements for Title V permits only.**

**Condition 1-1: NOx Ozone Season Emission Requirements  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 243-1.6(c)**

**Item 1-1.1:**

As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NOx Ozone Season source and each CAIR NOx Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NOx Ozone Season allowances available for compliance deductions for the control period under section 243-6.5(a) in an amount not less than the tons of total nitrogen oxides emissions for the control period from all CAIR NOx Ozone Season units at the source, as determined in accordance with Subpart 243-8. The CAIR NOx ozone season is the period beginning May 1 of a calendar year, except as provided in section 243-1.6(c)(2), and ending on September 30 of the same year, inclusive.

A CAIR NOx Ozone Season unit shall be subject to the requirements under paragraph (c)(1) of this section for the control period starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under sections 243-8.1(b)(1), (2), (3), or (7) and for each control period thereafter.

A CAIR NOx Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (c)(1) of this section, for a control period in a calendar year before the year for which the CAIR NOx Ozone Season allowance was allocated.

CAIR NOx Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NOx Ozone Season Allowance Tracking System accounts in accordance with Subparts 243-6, 243-7, and 243-9.

A CAIR NOx Ozone Season allowance is a limited authorization to emit one ton of nitrogen oxides in accordance with the CAIR NOx Ozone Season Trading Program. No provision of the CAIR NOx Ozone Season Trading Program, the CAIR permit application, the CAIR permit, or an exemption under section 243-1.5 and no provision of law shall be



construed to limit the authority of the State or the United States to terminate or limit such authorization.

A CAIR NOx Ozone Season allowance does not constitute a property right.

Upon recordation by the Administrator under Subpart 243-6, 243-7, or 243-9, every allocation, transfer, or deduction of a CAIR NOx Ozone Season allowance to or from a CAIR NOx Ozone Season source's compliance account is incorporated automatically in any CAIR permit of the source.

**Condition 1-2: Excess emission requirements**  
**Effective for entire length of Permit**

**Applicable Federal Requirement:6NYCRR 243-1.6(d)**

**Item 1-2.1:**

If a CAIR NOx Ozone Season source emits nitrogen oxides during any control period in excess of the CAIR NOx Ozone Season emissions limitation, then:

(1) the owners and operators of the source and each CAIR NOx Ozone Season unit at the source shall surrender the CAIR NOx Ozone Season allowances required for deduction under section 243-6.5(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Act or applicable State law; and

(2) each ton of such excess emissions and each day of such control period shall constitute a separate violation of this Subpart, the Act, and applicable State law.

**Condition 1-3: Recordkeeping and reporting requirements**  
**Effective for entire length of Permit**

**Applicable Federal Requirement:6NYCRR 243-1.6(e)**

**Item 1-3.1:**

Unless otherwise provided, the owners and operators of the CAIR NOx Ozone Season source and each CAIR NOx Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time before the end of five years, in writing by the department or the Administrator.

(i) The certificate of representation under section 243-2.4 for the CAIR designated representative for the source and each CAIR NOx Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation under section 243-2.4 changing the CAIR designated representative.

(ii) All emissions monitoring information, in accordance with Subpart 243-8, provided that to the extent that Subpart 243-8 provides for a three-year period for recordkeeping, the three-year period shall apply.



(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Ozone Season Trading Program.

(iv) Copies of all documents used to complete a CAIR permit application and any other submission under the CAIR NO<sub>x</sub> Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.

**Condition 1-4: General requirements  
Effective for entire length of Permit**

**Applicable Federal Requirement:6NYCRR 243-8.1**

**Item 1-4.1:**

The owners and operators, and to the extent applicable, the CAIR designated representative, of a CAIR NO<sub>x</sub> Ozone Season unit, shall comply with the monitoring, recordkeeping, and reporting requirements as provided in this Subpart and in Subpart H of 40 CFR Part 75. For purposes of complying with such requirements, the definitions in section 243-1.2 and in 40 CFR 72.2 shall apply, and the terms "affected unit," "designated representative," and "continuous emission monitoring system" (or "CEMS") in 40 CFR Part 75 shall be deemed to refer to the terms "CAIR NO<sub>x</sub> Ozone Season unit," "CAIR designated representative," and "continuous emission monitoring system" (or "CEMS") respectively, as defined in section 243-1.2. The owner or operator of a unit that is not a CAIR NO<sub>x</sub> Ozone Season unit but that is monitored under 40 CFR 75.72(b)(2)(ii) shall comply with the same monitoring, recordkeeping, and reporting requirements as a CAIR NO<sub>x</sub> Ozone Season unit.

'Requirements for installation, certification, and data accounting.' The owner or operator of each CAIR NO<sub>x</sub> Ozone Season unit shall:

(1) install all monitoring systems required under this Subpart for monitoring NO<sub>x</sub> mass emissions and individual unit heat input (including all systems required to monitor NO<sub>x</sub> emission rate, NO<sub>x</sub> concentration, stack gas moisture content, stack gas flow rate, CO<sub>2</sub> or O<sub>2</sub> concentration, and fuel flow rate, as applicable, in accordance with 40 CFR 75.71 and 40 CFR 75.72);

(2) successfully complete all certification tests required under section 243-8.2 and meet all other requirements of this Subpart and 40 CFR Part 75 applicable to the monitoring systems under paragraph (a)(1) of this section; and

(3) record, report, and quality-assure the data from the monitoring systems under paragraph (a)(1) of this section.

**Condition 1-5: Prohibitions  
Effective for entire length of Permit**

**Applicable Federal Requirement:6NYCRR 243-8.1**

**Item 1-5.1:**

No owner or operator of a CAIR NO<sub>x</sub> Ozone Season unit shall use any alternative



monitoring system, alternative reference method, or any other alternative to any requirement of this Subpart without having obtained prior written approval in accordance with section 243-8.6.

No owner or operator of a CAIR NO<sub>x</sub> Ozone Season unit shall operate the unit so as to discharge, or allow to be discharged, NO<sub>x</sub> emissions to the atmosphere without accounting for all such emissions in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NO<sub>x</sub> Ozone Season unit shall disrupt the continuous emission monitoring system, any portion thereof, or any other approved emission monitoring method, and thereby avoid monitoring and recording NO<sub>x</sub> mass emissions discharged into the atmosphere or heat input, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed in accordance with the applicable provisions of this Subpart and 40 CFR Part 75.

No owner or operator of a CAIR NO<sub>x</sub> Ozone Season unit shall retire or permanently discontinue use of the continuous emission monitoring system, any component thereof, or any other approved monitoring system under this Subpart, except under any one of the following circumstances:

- (i) during the period that the unit is covered by an exemption under section 243-1.5 that is in effect;
- (ii) the owner or operator is monitoring emissions from the unit with another certified monitoring system approved, in accordance with the applicable provisions of this Subpart and 40 CFR Part 75, by the department for use at that unit that provides emission data for the same pollutant or parameter as the retired or discontinued monitoring system; or
- (iii) the CAIR designated representative submits notification of the date of certification testing of a replacement monitoring system for the retired or discontinued monitoring system in accordance with section 243-8.2(d)(3)(i).

**Condition 1-6: Out of control periods**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 243-8.3**

**Item 1-6.1:**

Whenever any monitoring system fails to meet the quality-assurance and quality-control requirements or data validation requirements of 40 CFR Part 75, data shall be substituted using the applicable missing data procedures in Subpart D or Subpart H of, or appendix D or appendix E to, 40 CFR Part 75.

**Condition 1-7: Quarterly reports**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 243-8.5(d)**

**Item 1-7.1:**

The CAIR designated representative shall submit quarterly reports, as follows:

If the CAIR NO<sub>x</sub> Ozone Season unit is subject to an Acid Rain emissions limitation or a



CAIR NO<sub>x</sub> emissions limitation or if the owner or operator of such unit chooses to report on an annual basis under this Subpart, the CAIR designated representative shall meet the requirements of Subpart H of 40 CFR Part 75 (concerning monitoring of NO<sub>x</sub> mass emissions) for such unit for the entire year and shall report the NO<sub>x</sub> mass emissions data and heat input data for such unit, in an electronic quarterly report in a format prescribed by the Administrator, for each calendar quarter beginning with:

(i) for a unit that commences commercial operation before July 1, 2007, the calendar quarter covering May 1, 2008 through June 30, 2008;

(ii) for a unit that commences commercial operation on or after July 1, 2007, the calendar quarter corresponding to the earlier of the date of provisional certification or the applicable deadline for initial certification under section 243-8.1(b), unless that quarter is the third or fourth quarter of 2007 or the first quarter of 2008, in which case reporting shall commence in the quarter covering May 1, 2008 through June 30, 2008.

The CAIR designated representative shall submit each quarterly report to the Administrator within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in 40 CFR 75.73(f).

For CAIR NO<sub>x</sub> Ozone Season units that are also subject to an Acid Rain emissions limitation or the CAIR NO<sub>x</sub> Annual Trading Program, CAIR SO<sub>2</sub> Trading Program, or the Mercury Reduction Program for Coal-Fired Electric Utility Steam Generating Units (6 NYCRR Part 246), quarterly reports shall include the applicable data and information required by Subparts F through I of 40 CFR Part 75 as applicable, in addition to the NO<sub>x</sub> mass emission data, heat input data, and other information required by this Subpart.

**Condition 1-8: Compliance certification  
Effective for entire length of Permit**

**Applicable Federal Requirement: 6NYCRR 243-8.5(e)**

**Item 1-8.1:**

The CAIR designated representative shall submit to the Administrator a compliance certification (in a format prescribed by the Administrator) in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(1) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR Part 75, including the quality assurance procedures and specifications;

(2) for a unit with add-on NO<sub>x</sub> emission controls and for all hours where NO<sub>x</sub> data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emission controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B to 40 CFR Part 75 and the substitute data values do not systematically underestimate NO<sub>x</sub> emissions; and

(3) for a unit that is reporting on a control period basis under subparagraph (d)(2)(ii) of this section, the NO<sub>x</sub> emission rate and NO<sub>x</sub> concentration values substituted for missing data under



Subpart D of 40 CFR Part 75 are calculated using only values from a control period and do not systematically underestimate NOx emissions.

**Condition 1-9: Part 63 General Provisions requirements  
Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 63.1342, Subpart LLL**

**Item 1-9.1:**

Owners or operators of affected sources subject to 40CFR63 Subpart LLL must also comply with the requirements of Subpart A of Part 63, according to the applicability of Subpart A to such sources, as identified in Table 1 of Subpart LLL. Subpart A is the General Provisions for the NESHAP for Source Categories regulations. The General Provisions contain requirements for performance testing, monitoring, notification, recordkeeping, reporting, and control devices that may apply to the source.



**STATE ONLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.**

**Condition 77: Contaminant List  
Effective between the dates of 11/20/2006 and Permit Expiration Date**

**Applicable State Requirement:**

**Item 77.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this permit (emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY100-00-0

Name: HAP

CAS No: 0NY210-00-0



Name: OXIDES OF NITROGEN

CAS No: 0NY075-00-0  
Name: PARTICULATES

CAS No: 0NY075-00-5  
Name: PM-10

