



**PERMIT**  
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air Title V Facility  
Permit ID: 6-2338-00012/00004  
Mod 0 Effective Date: 02/13/2006 Expiration Date: 02/12/2011  
Mod 1 Effective Date: 03/02/2009 Expiration Date: 02/12/2011

Permit Issued To: LYONSDALE BIOMASS LLC  
3823 MARMON RD  
LYONS FALLS, NY 13368

Contact: DAVID BONDURANT  
LYONSDALE BIOMASS LLC  
3823 MARMON RD  
LYONS FALLS, NY 13368  
(315) 348-4208

Facility: LYONSDALE BIOMASS LLC  
MARMON LOWDALE & LYONSDALE RDS  
LYONSDALE, NY 13433

Description:

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: LAWRENCE R AMBEAU  
NYSDEC - STATE OFFICE BLDG  
317 WASHINGTON ST  
WATERTOWN, NY 13601

Authorized Signature: \_\_\_\_\_ Date: \_\_\_ / \_\_\_ / \_\_\_\_



### Notification of Other State Permittee Obligations

**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



## LIST OF CONDITIONS

### DEC GENERAL CONDITIONS

#### General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
  - Applications for permit renewals, modifications and transfers
  - Applications for Permit Renewals and Modifications
  - Permit modifications, suspensions or revocations by the Department
  - Permit Modifications, Suspensions and Revocations by the Department

#### Facility Level

- Submission of Applications for Permit Modification or Renewal -REGION 6 HEADQUARTERS
- Submission of application for permit modification or renewal-REGION 6 HEADQUARTERS



**DEC GENERAL CONDITIONS**

\*\*\*\* General Provisions \*\*\*\*

**For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.**

**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**

**Applicable State Requirement: ECL 19-0305**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**

**Applicable State Requirement: ECL 3-0301.2(m)**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 1-1: Applications for permit renewals, modifications and transfers**

**Applicable State Requirement: 6NYCRR 621.11**

**Item 1-1.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 1-1.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 1-1.3:**



Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 3: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 3.3:**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

**Condition 1-2: Permit modifications, suspensions or revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 1-2.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**Condition 4: Permit Modifications, Suspensions and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Item 4.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting



papers;

- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 5: Submission of Applications for Permit Modification or Renewal -REGION 6 HEADQUARTERS**

**Applicable State Requirement: 6NYCRR 621.5(a)**

**Item 5.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 6 Headquarters  
Division of Environmental Permits  
State Office Building, 317 Washington Street  
Watertown, NY 13601-3787  
(315) 785-2245

**Condition 1-3: Submission of application for permit modification or renewal-REGION 6**

**HEADQUARTERS**  
**Applicable State Requirement: 6NYCRR 621.6(a)**

**Item 1-3.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 6 Headquarters  
Division of Environmental Permits  
State Office Building, 317 Washington Street  
Watertown, NY 13601-3787  
(315) 785-2245



**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: LYONSDALE BIOMASS LLC  
3823 MARMON RD  
LYONS FALLS, NY 13368

Facility: LYONSDALE BIOMASS LLC  
MARMON LOWDALE & LYONSDALE RDS  
LYONSDALE, NY 13433

Authorized Activity By Standard Industrial Classification Code:  
4911 - ELECTRIC SERVICES  
4931 - ELEC & OTHER SERVICES COMBINED

Mod 0 Permit Effective Date: 02/13/2006

Permit Expiration Date: 02/12/2011

Mod 1 Permit Effective Date: 03/02/2009

Permit Expiration Date: 02/12/2011



## LIST OF CONDITIONS

### DEC GENERAL CONDITIONS

#### General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
  - Applications for permit renewals, modifications and transfers
  - Applications for Permit Renewals and Modifications
  - Permit modifications, suspensions or revocations by the Department
  - Permit Modifications, Suspensions and Revocations by the Department

#### Facility Level

- Submission of Applications for Permit Modification or Renewal -REGION 6 HEADQUARTERS
- Submission of application for permit modification or renewal-REGION 6 HEADQUARTERS

### FEDERALLY ENFORCEABLE CONDITIONS

#### Facility Level

- 1 6NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6NYCRR 201-6.5(a)(7): Fees
- 3 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 4 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 6 6NYCRR 201-6.5(e): Compliance Certification
- 7 6NYCRR 202-2.1: Compliance Certification
- 8 6NYCRR 202-2.5: Recordkeeping requirements
- 9 6NYCRR 215: Open Fires Prohibited at Industrial and Commercial Sites
- 10 6NYCRR 200.7: Maintenance of Equipment
- 11 6NYCRR 201-1.7: Recycling and Salvage
- 1-1 6NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 12 6NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6NYCRR 201-3.2(a): Exempt Sources - Proof of Eligibility
- 14 6NYCRR 201-3.3(a): Trivial Sources - Proof of Eligibility
- 15 6NYCRR 201-6.5(a)(4): Standard Requirement - Provide Information
- 16 6NYCRR 201-6.5(a)(8): General Condition - Right to Inspect
- 17 6NYCRR 201-6.5(d)(5): Standard Requirements - Progress Reports
- 18 6NYCRR 201-6.5(f)(6): Off Permit Changes
- 19 6NYCRR 202-1.1: Required Emissions Tests
- 20 6NYCRR 211.3: Visible Emissions Limited
- 21 40CFR 68: Accidental release provisions.
- 22 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 23 6NYCRR 201-6: Emission Unit Definition
- 1-2 6NYCRR 201-7.1: Facility Permissible Emissions
- 24 6NYCRR 202-1.2: Notification
- 25 6NYCRR 202-1.3: Acceptable procedures
- 26 6NYCRR 202-1.3: Acceptable procedures - Stack test report submittal
- 27 6NYCRR 202-1.3: Alternate test methods



- 28 6NYCRR 225-1.4: Temporary variances.
- 29 6NYCRR 225-1.6(b): Compliance.
- 30 6NYCRR 225-1.7: Emission and fuel monitoring methods.
- 31 6NYCRR 227-2.1: This condition states the facility is applicable to  
NO<sub>x</sub> RACT.
- 32 40CFR 52.21, Subpart A: Compliance Certification
- 33 40CFR 52.21, Subpart A: Compliance Certification
- 34 40CFR 52.21, Subpart A: Compliance Certification
- 35 40CFR 52.21, Subpart A: Compliance Certification
- 36 40CFR 52.21(j)(1), Subpart A: Minimum requirements.
- 37 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
- 38 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
- 39 40CFR 60.7(c), NSPS Subpart A: Excess emissions report.
- 40 40CFR 60.7(d), NSPS Subpart A: Excess emissions report.
- 41 40CFR 60.7(f), NSPS Subpart A: Facility files for subject sources.
- 42 40CFR 60.9, NSPS Subpart A: Availability of information.
- 43 40CFR 60.11, NSPS Subpart A: Opacity standard compliance testing.
- 44 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
- 45 40CFR 60.49b(d), NSPS Subpart Db: Compliance Certification
- 46 40CFR 82: Recycling and emissions reduction.

**Emission Unit Level**

- 47 6NYCRR 201-6: Emission Point Definition By Emission Unit
- 48 6NYCRR 201-6: Process Definition By Emission Unit

**EU=U-00001**

- \*1-3 6NYCRR 201-7.1: Capping Monitoring Condition
- \*1-4 6NYCRR 201-7.1: Capping Monitoring Condition
- \*1-5 6NYCRR 201-7.1: Capping Monitoring Condition
- \*1-6 6NYCRR 201-7.1: Capping Monitoring Condition
- 49 40CFR 52.21, Subpart A: Compliance Certification
- 50 40CFR 52.21, Subpart A: Compliance Certification
- 53 40CFR 52.21, Subpart A: Compliance Certification
- 54 40CFR 52.21, Subpart A: Compliance Certification
- 1-7 40CFR 60.43b(c)(1), NSPS Subpart Db: Compliance Certification
- 56 40CFR 60.43b(g), NSPS Subpart Db: Particulate matter and opacity  
exemption.
- 57 40CFR 60.48b(a), NSPS Subpart Db: Compliance Certification
- 58 40CFR 60.48b(f), NSPS Subpart Db: Use of alternative methods for  
measuring NO<sub>x</sub> during CEMS downtime
- 59 40CFR 60.49b, NSPS Subpart Db: Recordkeeping and reporting requirements.
- 60 40CFR 60.49b(f), NSPS Subpart Db: Compliance Certification
- 61 40CFR 60.49b(h), NSPS Subpart Db: Compliance Certification
- 62 40CFR 64: Compliance Certification
- 63 40CFR 64: Compliance Certification

**EU=U-00001,Proc=100**

- 64 6NYCRR 227.2(b)(1): Compliance Certification
- 65 40CFR 60.42b(j), NSPS Subpart Db: Demonstration criteria for low  
sulfur oil.
- 66 40CFR 60.43b(c)(1), NSPS Subpart Db: Particulate matter standard.
- 67 40CFR 60.43b(e), NSPS Subpart Db: Annual capacity factor.
- 68 40CFR 60.43b(f), NSPS Subpart Db: Compliance Certification
- 69 40CFR 60.45b(d), NSPS Subpart Db: Compliance Certification



- 70 40CFR 60.45b(j), NSPS Subpart Db: Compliance Certification
- 71 40CFR 60.46b, NSPS Subpart Db: Compliance methods for particulate matter.
- 72 40CFR 60.47b(f), NSPS Subpart Db: Alternative sulfur dioxide monitoring method.
- 73 40CFR 60.49b(r), NSPS Subpart Db: Compliance Certification

**EU=U-00001,EP=00001**

- 74 6NYCRR 227-1.3(a): Compliance Certification

**EU=U-00002**

- 75 6NYCRR 227-1.3: Compliance Certification
- 76 6NYCRR 227-1.3(a): Compliance Certification
- 77 6NYCRR 227.2(b)(1): Compliance Certification
- 78 40CFR 52.21, Subpart A: Compliance Certification

**STATE ONLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 79 ECL 19-0301: Contaminant List
- 80 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 81 6NYCRR 211.2: Air pollution prohibited

NOTE: \* preceding the condition number indicates capping.



**FEDERALLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.**

**Item A: Emergency Defense - 6NYCRR Part 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or

operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department

within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



- Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)**  
Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.
- Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)**  
Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**  
The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**  
This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
- Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)**  
It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.
- Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)**  
This permit does not convey any property rights of any sort or any exclusive privilege.
- Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)**



If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the



effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item L: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.



**Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS  
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

**The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.**

**Condition 1: Acceptable Ambient Air Quality**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 200.6**

**Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Condition 2: Fees**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6.5(a)(7)**

**Item 2.1:**

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

**Condition 3: Recordkeeping and reporting of compliance monitoring**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6.5(c)**

**Item 3.1:**

The following information must be included in any required compliance monitoring records and reports:



- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

**Condition 4: Monitoring, Related Recordkeeping, and Reporting Requirements.**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)**

**Item 4.1:**

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

**Condition 5: Compliance Certification**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)**

**Item 5.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 5.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to



the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for



deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).

**Condition 6: Compliance Certification**

**Effective between the dates of 02/13/2006 and 02/12/2011**



**Applicable Federal Requirement:6NYCRR 201-6.5(e)**

**Item 6.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 6.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
  - the identification of each term or condition of the permit that is the basis of the certification;
  - the compliance status;
  - whether compliance was continuous or intermittent;
  - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
  - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions; and
  - such additional requirements as may be specified elsewhere in this permit related to compliance certification.
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.
- iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.
- iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional



office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2  
Air Compliance Branch  
290 Broadway  
New York, NY 10007-1866

The address for the RAPCE is as follows:

State Office Building  
317 Washington Street  
Watertown, NY 13601-3787

The address for the BQA is as follows:

NYSDEC  
Bureau of Quality Assurance  
625 Broadway  
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 1/30/2007.  
Subsequent reports are due on the same day each year

**Condition 7: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 202-2.1**

**Item 7.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 7.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

Monitoring Frequency: ANNUALLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due by April 15th for previous calendar year

**Condition 8: Recordkeeping requirements**  
**Effective between the dates of 02/13/2006 and 02/12/2011**



**Applicable Federal Requirement:6NYCRR 202-2.5**

**Item 8.1:**

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

**Condition 9: Open Fires Prohibited at Industrial and Commercial Sites  
Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 215**

**Item 9.1:**

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, refuse, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS  
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period. [NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 10: Maintenance of Equipment  
Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 200.7**

**Item 10.1:**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Condition 11: Recycling and Salvage  
Effective between the dates of 02/13/2006 and 02/12/2011**



**Applicable Federal Requirement:6NYCRR 201-1.7**

**Item 11.1:**

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

**Condition 1-1: Prohibition of Reintroduction of Collected Contaminants to the air**  
**Effective between the dates of 03/02/2009 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-1.8**

**Item 1-1.1:**

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-1.8**

**Item 12.1:**

No person shall remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 13: Exempt Sources - Proof of Eligibility**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-3.2(a)**

**Item 13.1:**

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

**Condition 14: Trivial Sources - Proof of Eligibility**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-3.3(a)**

**Item 14.1:**

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part



may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

**Condition 15: Standard Requirement - Provide Information**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6.5(a)(4)**

**Item 15.1:**

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

**Condition 16: General Condition - Right to Inspect**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6.5(a)(8)**

**Item 16.1:**

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

**Condition 17: Standard Requirements - Progress Reports**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6.5(d)(5)**

**Item 17.1:**



Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

**Condition 18: Off Permit Changes**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6.5(f)(6)**

**Item 18.1:**

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

- (i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.
- (ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

**Condition 19: Required Emissions Tests**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 202-1.1**

**Item 19.1:**

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time. Such person shall bear the cost of measurement and preparing the report of measured emissions. Failure of such person to submit a report acceptable to the commissioner within the time stated shall be sufficient reason for the commissioner to suspend or deny a certificate to operate.

**Condition 20: Visible Emissions Limited**  
**Effective between the dates of 02/13/2006 and 02/12/2011**



**Applicable Federal Requirement:6NYCRR 211.3**

**Item 20.1:**

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Condition 21: Accidental release provisions.  
Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 68**

**Item 21.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
  - b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
    - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
    - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan.
- Information should be submitted to:

Risk Management Plan Reporting Center  
C/O CSC  
8400 Corporate Dr  
Carrollton, Md. 20785

**Condition 22: Recycling and Emissions Reduction  
Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 82, Subpart F**

**Item 22.1:**

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**The following conditions are subject to annual compliance certification requirements for Title V permits only.**

**Condition 23: Emission Unit Definition**



Effective between the dates of 02/13/2006 and 02/12/2011

Applicable Federal Requirement:6NYCRR 201-6

**Item 23.1(From Mod 1):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

U00001 is the Zurn main wood boiler rated at 290 mmbtu/hr.

Building(s): PH

**Item 23.2(From Mod 1):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00002

Emission Unit Description:

This is the Cleaver Brooks backup boiler rated at 50.9 mmbtu/hr. This boiler fires No. 2 distillate oil.

Building(s): PH

**Condition 1-2: Facility Permissible Emissions**

Effective between the dates of 03/02/2009 and 02/12/2011

Applicable Federal Requirement:6NYCRR 201-7.1

**Item 1-2.1:**

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 000630-08-0 (From Mod 1) PTE: 498,000 pounds  
per year

Name: CARBON MONOXIDE

CAS No: 0NY210-00-0 (From Mod 1) PTE: 498,000 pounds  
per year

Name: OXIDES OF NITROGEN

**Condition 24: Notification**

Effective between the dates of 02/13/2006 and 02/12/2011

Applicable Federal Requirement:6NYCRR 202-1.2

**Item 24.1:**

A person who is required by the commissioner to submit a stack test report shall notify the commissioner, in writing, not less than 30 days prior to the test, of the time and date of the test. Such notification shall also include the acceptable procedures to be used to stack test including sampling and analytical procedures. Such person shall allow the commissioner, or his representative, free access to observe stack testing being conducted by such person.



**Condition 25: Acceptable procedures**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 202-1.3**

**Item 25.1:**

Emission testing, sampling, and analytical determinations to ascertain compliance with this Subpart shall be conducted in accordance with test methods acceptable to the commissioner.

**Condition 26: Acceptable procedures - Stack test report submittal**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 202-1.3**

**Item 26.1:**

Emission test reports must be submitted in triplicate to the commissioner within 60 days after the completion of the tests, unless additional time is requested in writing.

**Condition 27: Alternate test methods**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 202-1.3**

**Item 27.1:**

Alternate emission test methods or deviations from acceptable test methods may be utilized if it is impractical to utilize the acceptable test methods or where no applicable test method is available, if prior acceptance of the proposed alternate method is granted by the commissioner.

**Condition 28: Temporary variances.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 225-1.4**

**Item 28.1:**

Upon application by an air contamination source owner or a fuel supplier the commissioner may issue an order granting a temporary variance from the provisions of 6 NYCRR Part 225-1 where it can be shown, to the commissioner's satisfaction, that there is an insufficient supply of conforming fuel, either:

- (1) of the proper type required for use in a particular air contamination source; or
- (2) generally throughout an area of the State.

**Condition 29: Compliance.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 225-1.6(b)**

**Item 29.1:**



As of January 1, 1988 any person who buys, sells, offer for sale, or uses fuel must comply with the percent sulfur requirements specified in section 6 NYCRR 225-1.2 of this regulation.

**Condition 30: Emission and fuel monitoring methods.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 225-1.7**

**Item 30.1:**

Facilities subject to Part 225-1 shall comply with the emission and fuel monitoring methods and requirements of this section 6 NYCRR 225-1.7.

**Condition 31: This condition states the facility is applicable to NOx RACT.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 227-2.1**

**Item 31.1:**

This facility is subject to NOx RACT.

**Condition 32: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 32.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 32.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:  
FUEL OIL NITROGEN LIMITS FOR PSD  
AVOIDANCE OF NO<sub>x</sub>

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL  
Parameter Monitored: NITROGEN  
Upper Permit Limit: 0.30 percent by weight  
Monitoring Frequency: PER DELIVERY  
Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.



The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 33: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 33.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
CAS No: 000630-08-0 CARBON MONOXIDE

**Item 33.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC  
OPERATIONS

Monitoring Description:

Total yearly CO emissions will be verified utilizing CEM Data for the main boiler, test data and fuel use for the auxiliary boiler and AP-42 methods and fuel use for the emergency diesel generator. The sum of emissions from the emission units specified in this permit shall not exceed the following Potential To Emit (PTE) rate for each regulated contaminant:

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: WOOD

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 498000 pounds per year

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 34: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 34.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 34.2:**

Compliance Certification shall include the following monitoring:



Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Total yearly NOx emissions will be verified utilizing CEM Data for the main boiler, test data and fuel use for the auxiliary boiler and AP-42 methods and fuel use for the emergency diesel generator. The sum of emissions from the emission units specified in this permit shall not exceed the following Potential To Emit (PTE) rate for each regulated contaminant:

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: WOOD

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 498000 pounds per year

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 35: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 35.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 35.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

TOTAL YEARLY NOX & CO EMISSIONS WILL BE VERIFIED UTILIZING CEM DATA FOR THE MAIN BOILER, TEST DATA AND FUEL USE FOR THE AUXILIARY BOILER AND AP-42 METHODS FOR THE EMERGENCY DIESEL GENERATOR.

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 36: Minimum requirements.**



**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 52.21(j)(1), Subpart A**

**Item 36.1:**

The affected facility shall, at a minimum, meet each applicable emission limitation under the State Implementation Plan and each applicable emissions standard and standard of performance under Parts 40 CFR 60 and 61.

**Condition 37: EPA Region 2 address.**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A**

**Item 37.1:**

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance  
USEPA Region 2  
290 Broadway, 21st Floor  
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC  
Bureau of Quality Assurance  
625 Broadway  
Albany, NY 12233-3258

**Condition 38: Recordkeeping requirements.**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.7(b), NSPS Subpart A**

**Item 38.1:**

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

**Condition 39: Excess emissions report.**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.7(c), NSPS Subpart A**



**Item 39.1:**

Affected owners or operators shall submit an excess emissions report and/or a summary report form (as defined in 40 CFR 60.7(d)) semi-annually (or more frequently as required by the applicable Subpart or the Administrator), to the Administrator. These reports shall be post marked no later than 30 days after each calendar quarter (or as appropriate), and shall contain the following information:

- 1) the magnitude of excess emissions computed, any conversion factors used, the date and time of each occurrence, and the process operating time during the reporting period;
- 2) specific identification of each period of excess emissions that occur during startup, shutdown, or malfunction, where the nature, cause, and corrective action are provided for a malfunction;
- 3) the date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments; and
- 4) when no excess emissions have occurred or when the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be provided in the report.

**Condition 40: Excess emissions report.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.7(d), NSPS Subpart A**

**Item 40.1:**

A summary report form, for each pollutant monitored, shall be sent to the Administrator in the form prescribed in Figure 1 of 40 CFR Part 60.7(d).

**Condition 41: Facility files for subject sources.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.7(f), NSPS Subpart A**

**Item 41.1:**

The following files shall be maintained at the facility for all affected sources: all measurements, including continuous monitoring systems, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations;all continuous monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. The file shall be maintained for at least two years following the date of such measurements, reports, and records.

**Condition 42: Availability of information.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.9, NSPS Subpart A**



**Item 42.1:**

The availability to the public of information provided to, or otherwise obtained by, the Administrator under this part shall be governed by 40 CFR Part 2.

**Condition 43: Opacity standard compliance testing.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.11, NSPS Subpart A**

**Item 43.1:**

The following conditions shall be used to determine compliance with the opacity standards:

1) observations shall be conducted in accordance with Reference Method 9, in Appendix A of 40 CFR Part 60(or an equivalent method approved by the Administrator including continuous opacity monitors);

2) the opacity standards apply at all times except during periods of start up, shutdown, and malfunction; and

3) all other applicable conditions cited in section 60.11 of this part.

**Condition 44: Monitoring requirements.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.13, NSPS Subpart A**

**Item 44.1:**

All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

**Condition 45: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.49b(d), NSPS Subpart Db**

**Item 45.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 45.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES  
Monitoring Description:

The owner or operator shall record and maintain records of the amounts of each fuel combusted during each day and calculate the annual capacity factor individually for coal, distillate oil, residual oil, natural gas, wood, and municipal-type solid waste for each calendar quarter. The annual capacity factor is determined on a 12-month rolling



average basis with a new annual capacity factor calculated at the end of each calendar month.

Monitoring Frequency: DAILY  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 46: Recycling and emissions reduction.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 82**

**Item 46.1:** The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 47: Emission Point Definition By Emission Unit**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6**

**Item 47.1(From Mod 1):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001

Height (ft.): 185

Diameter (in.): 75

NYTMN (km.): 4829.45

NYTME (km.): 475.341

Building: PH

**Item 47.2(From Mod 1):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00002

Emission Point: 00002

Height (ft.): 147

Diameter (in.): 28

NYTMN (km.): 4829.45

NYTME (km.): 475.341

Building: PH

**Condition 48: Process Definition By Emission Unit**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-6**

**Item 48.1(From Mod 1):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 100

Source Classification Code: 1-02-009-03

Process Description:



PROCESS 100 IS THE ZURN BOILER. THIS BOILER FIRES FUEL OIL IN AN AUXILIARY BURNER FOR STARTUP. THE MAIN FUEL IS WOOD (UNADULTERATED WOOD), AS DEFINED IN NYCRR PART 200.1(CG). THE OIL-FIRED BURNER CANNOT OPERATE CONCURRENTLY WITH THE WOOD EXCEPT DURING STARTUP, SHUTDOWN, AND MALFUNCTION.

Emission Source/Control: 00001 - Combustion  
Design Capacity: 290 million Btu per hour

Emission Source/Control: 00002 - Control  
Control Type: MULTIPLE CYCLONE W/ FLY ASH INJECTION

Emission Source/Control: 00003 - Control  
Control Type: ELECTROSTATIC PRECIPITATOR

**Item 48.2(From Mod 1):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002  
Process: 201 Source Classification Code: 1-02-005-01  
Process Description:  
EMISSION UNIT U-00002 IS THE CLEAVER BROOKS AUXILIARY BOILER WHICH FIRES DISTILLATE NO. 2 FUEL OIL.

Emission Source/Control: 00007 - Combustion  
Design Capacity: 50.9 million Btu per hour

**Item 48.3(From Mod 0):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001  
Process: 10A Source Classification Code: 1-01-009-02  
Process Description:  
PROCESS 10A INVOLVES THE COMBUSTION OF UNADULTERATED WOOD AND PALLET DERIVED WOOD. THE PALLET DERIVED WOOD SHALL MAKE UP EQUAL TO OR LESS THAN 30% BY WEIGHT OF THE TOTAL FUEL FED TO THE BOILER. PALLET DERIVED WOOD IS MATERIAL OBTAINED FROM CHIPPED WOODEN SHIPPING PALLETS, CRATES, AND SKIDS. THIS TYPE OF FUEL IS SUBJECT TO THE INSPECTION CRITERIA CONTAINED IN APPENDIX A.

Emission Source/Control: 00001 - Combustion  
Design Capacity: 290 million Btu per hour

**Item 48.4(From Mod 0):**

This permit authorizes the following regulated processes for the cited Emission Unit:



Emission Unit: U-00001

Process: 10B

Source Classification Code: 1-02-012-02

Process Description:

This process is for the co-firing of an alternative fuel, non-recyclable fibrous material such as wax cardboard in combination with other fuels in quantities up to and equal to 30% by weight of the boiler's fuel feed. Non-recyclable fibrous material may be in the form of pellets, extrusions, chips, shreds, or other shapes that provide suitable fuel management capability.

Emission Source/Control: 00001 - Combustion

Design Capacity: 290 million Btu per hour

Emission Source/Control: 00002 - Control

Control Type: MULTIPLE CYCLONE W/ FLY ASH INJECTION

Emission Source/Control: 00003 - Control

Control Type: ELECTROSTATIC PRECIPITATOR

**Condition 1-3: Capping Monitoring Condition**  
**Effective between the dates of 03/02/2009 and 02/12/2011**

**Applicable Federal Requirement: 6NYCRR 201-7.1**

**Item 1-3.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40CFR 52-A.21

**Item 1-3.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 1-3.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 1-3.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.



**Item 1-3.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 1-3.6:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

**Item 1-3.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

PSD AVOIDANCE LIMIT FOR CO EMISSIONS FROM THE ZURN WOOD BOILER. CO EMISSIONS FROM THIS EMISSION UNIT ARE LIMITED TO 0.25 LB/MMBTU (DRY, CORRECTED TO 7% O<sub>2</sub>) OR 58.05 LB/HR.

Manufacturer Name/Model Number: ThermoElectron, Model 48C

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 58.05 pounds per hour

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2009.

Subsequent reports are due every 3 calendar month(s).

**Condition 1-4: Capping Monitoring Condition**

**Effective between the dates of 03/02/2009 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 201-7.1**

**Item 1-4.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40CFR 52-A.21

**Item 1-4.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.



**Item 1-4.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 1-4.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 1-4.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 1-4.6:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 1-4.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

PSD AVOIDANCE LIMIT FOR NO<sub>x</sub> EMISSIONS FROM THE ZURN WOOD BOILER. NO<sub>x</sub> EMISSIONS FROM THIS EMISSION UNIT ARE LIMITED TO 0.20 LB/MMBTU (DRY, CORRECTED TO 7% O<sub>2</sub>) OR 58.05 LB/HR.

Manufacturer Name/Model Number: ThermoElectron, Model 42C

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 58.05 pounds per hour

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 24 HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2009.

Subsequent reports are due every 3 calendar month(s).

**Condition 1-5: Capping Monitoring Condition**  
**Effective between the dates of 03/02/2009 and 02/12/2011**



**Applicable Federal Requirement: 6NYCRR 201-7.1**

**Item 1-5.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40CFR 52-A.21

**Item 1-5.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 1-5.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 1-5.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 1-5.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 1-5.6:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 1-5.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

PSD AVOIDANCE LIMIT FOR NO<sub>x</sub> EMISSIONS FROM THE ZURN WOOD BOILER. NO<sub>x</sub> EMISSIONS FROM THIS EMISSION UNIT ARE LIMITED TO 0.20 LB/MMBTU (DRY, CORRECTED TO 7% O<sub>2</sub>)



OR 58.05 LB/HR.

Manufacturer Name/Model Number: ThermoElectron, Model 42C  
Parameter Monitored: OXIDES OF NITROGEN  
Upper Permit Limit: 0.20 pounds per million Btus  
Reference Test Method: 40 CFR 60 APP B&F  
Monitoring Frequency: CONTINUOUS  
Averaging Method: 24 HOUR BLOCK AVERAGE  
Reporting Requirements: QUARTERLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 4/30/2009.  
Subsequent reports are due every 3 calendar month(s).

**Condition 1-6: Capping Monitoring Condition**  
**Effective between the dates of 03/02/2009 and 02/12/2011**

**Applicable Federal Requirement: 6NYCRR 201-7.1**

**Item 1-6.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40CFR 52-A.21

**Item 1-6.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 1-6.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 1-6.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 1-6.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 1-6.6:**

The Compliance Certification activity will be performed for:



Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

**Item 1-6.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

PSD AVOIDANCE LIMIT FOR CO EMISSIONS FROM THE ZURN WOOD BOILER. CO EMISSIONS FROM THIS EMISSION UNIT ARE LIMITED TO 0.25 LB/MMBTU (DRY, CORRECTED TO 7% O<sub>2</sub>) OR 58.05 LB/HR.

Manufacturer Name/Model Number: ThermoElectron, Model 48C

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 0.25 pounds per million Btus

Reference Test Method: 40 CFR 60 APP B&F

Monitoring Frequency: CONTINUOUS

Averaging Method: 24 HOUR BLOCK AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2009.

Subsequent reports are due every 3 calendar month(s).

**Condition 49: Compliance Certification**

Effective between the dates of 02/13/2006 and 02/12/2011

Applicable Federal Requirement: 40CFR 52.21, Subpart A

**Item 49.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

**Item 49.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

THE OIL FIRED STARTUP BURNER FOR THE MAIN BOILER CANNOT OPERATE SIMULTANEOUSLY WITH WOOD FIRING OF THE MAIN BOILER EXCEPT FOR STARTUP, SHUTDOWN, AND MALFUNCTION.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.



The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 50: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 50.1:**  
The Compliance Certification activity will be performed for:

Emission Unit: U-00001

**Item 50.2:**  
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES  
Monitoring Description:

SIMULTANEOUS OPERATION OF THE WOOD BOILER WITH THE AUXILIARY BOILER IS PROHIBITED EXCEPT FOR TRANSITIONS AND TESTING. TRANSITION AND TESTING IS LIMITED TO SIX HOURS PER OCCURRENCE. RECORDS OF SIMULTANEOUS OPERATION, INCLUDING THE DURATION AND REASON FOR OPERATION ARE REQUIRED.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).

**Condition 53: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 53.1:**  
The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):  
CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 53.2:**  
Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:



The sulfur in fuel oil to be used in the wood boiler and the auxiliary boiler shall not exceed 0.10 percent by weight. Records of fuel sulfur content (fuel supplier's specifications for the delivered fuel certified receipts) shall be kept for 2 years to verify compliance. Since this fuel sulfur limit is more stringent than Part 225-1 and 40 CFR 60.42c limit, and to aid in permit streamlining, this condition also covers the limits in Part 225-1 and 40 CFR 60.42c.

Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 0.10 percent by weight

Reference Test Method: EPA METHOD APPENDIX A

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 54: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement: 40CFR 52.21, Subpart A**

**Item 54.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

**Item 54.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

THE PALLET DERIVED WOOD SHALL MAKE UP EQUAL TO OR LESS THAN 30% BY WEIGHT OF THE TOTAL FUEL FED TO THE MAIN BOILER. PALLET DERIVED WOOD IS MATERIAL OBTAINED FROM CHIPPED WOODEN SHIPPING PALLETS, CRATES, AND SKIDS. THIS TYPE OF FUEL IS SUBJECT TO THE INSPECTION CRITERIA CONTAINED IN APPENDIX A. TO ENSURE THAT THE 30% BY WEIGHT LIMIT IS MAINTAINED, LYONSDALE BIOMASS MUST HAVE 3 TRUCKLOADS OF WHOLE TREE CHIPS EMPTIED ONTO THE WOOD PILE FOR EVERY TRUCKLOAD OF PALLET DERIVED WOOD. RECORDS MUST BE MAINTAINED TO CONFIRM COMPLIANCE.



Work Practice Type: PROCESS MATERIAL THRUPUT  
Process Material: WOODWASTE  
Upper Permit Limit: 30 percent  
Monitoring Frequency: DAILY  
Averaging Method: AVERAGING METHOD - SEE MONITORING DESCRIPTION  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 1-7: Compliance Certification**  
**Effective between the dates of 03/02/2009 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.43b(c)(1), NSPS Subpart Db**

**Item 1-7.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 1-7.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

NSPS LIMIT FOR PM/PM-10 EMISSIONS FROM THE MAIN WOOD BOILER. STACK TESTING IS REQUIRED ONCE PER PERMIT TERM. PM/PM-10 EMISSIONS FROM THIS EMISSION UNIT ARE LIMITED TO 0.10 LB/MMBTU (DRY, CORRECTED TO 7% O<sub>2</sub>) AND 29.03 LB/HR.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: 40 CFR 60 APP. A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

**Condition 56: Particulate matter and opacity exemption.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.43b(g), NSPS Subpart Db**

**Item 56.1:**

This Condition applies to Emission Unit: U-00001

**Item 56.2:**

The particulate matter and opacity standards



shall apply at all times, except during periods of startup, shutdown, or malfunction.

**Condition 57: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.48b(a), NSPS Subpart Db**

**Item 57.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 57.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The owner or operator shall install, calibrate, maintain, and operate a continuous monitoring system for measuring the opacity of emissions discharged to the atmosphere and record the output of the system.

Manufacturer Name/Model Number: Zurn wood boiler

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: 40CFR 60, Appendix B

Monitoring Frequency: CONTINUOUS

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 58: Use of alternative methods for measuring NOx during CEMS downtime**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.48b(f), NSPS Subpart Db**

**Item 58.1:**

This Condition applies to Emission Unit: U-00001

**Item 58.2:**

When nitrogen oxides emission data are not obtained because of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments, emission data will be obtained by using standby monitoring systems, Method 7, Method 7A, or other approved reference methods to provide emission data for a minimum of 75 percent of the operating hours



in each steam generating unit operating day, in at least 22 out of 30 successive steam generating unit operating days.

**Condition 59: Recordkeeping and reporting requirements.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.49b, NSPS Subpart Db**

**Item 59.1:**  
This Condition applies to Emission Unit: U-00001

**Item 59.2:**  
This facility is subject to the provisions of Subpart Db. Therefore, the facility must meet the record keeping and reporting requirements of section 40 CFR 60.49b.

**Condition 60: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.49b(f), NSPS Subpart Db**

**Item 60.1:**  
The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):  
CAS No: 0NY075-00-0 PARTICULATES

**Item 60.2:**  
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES  
Monitoring Description:

The owner or operator shall maintain records of opacity measurements made by the monitoring system required under 40CFR60.48b(a).

Monitoring Frequency: CONTINUOUS  
Reporting Requirements: QUARTERLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 4/30/2006.  
Subsequent reports are due every 3 calendar month(s).

**Condition 61: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.49b(h), NSPS Subpart Db**

**Item 61.1:**  
The Compliance Certification activity will be performed for:

Emission Unit: U-00001



**Item 61.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator shall submit semiannual excess emission reports for opacity and/or, oxides of nitrogen, and/or sulfur dioxide any reporting period during which there are excess emissions from the affected facility. If there are no excess emissions during the reporting period, the owner or operator shall submit a report semiannually stating that no excess emissions occurred during that semiannual reporting period.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).

**Condition 62: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 64**

**Item 62.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

**Item 62.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

This emission unit is subject to the Compliance Assurance Monitoring Rule (CAM Rule). The owner or operator of this emission unit must submit a plan to the Department for its review and approval showing how they will comply with this rule. The plan must include the following:

- An indicator to be monitored to show compliance with the applicable emission limit or standard.
- The ranges or designated conditions for such indicators, or the process by which such indicators ranges or designated conditions will be established.
- the performance criteria for the monitoring stated above
- if applicable, the indicator ranges and performance criteria for a CEMS, COMS or PEMS (if used).

The owner or operator of this emission unit shall submit an annual report of the monitoring required above. The



report shall include the following:

- summary of information on the number, duration and cause (including unknown cause) of excursions or exceedances, as applicable, and the corrective actions taken;
- summary information on the number, duration and cause (including unknown cause) for monitor downtime incidents (other than downtime associated with zero and span or other daily calibration checks if applicable); and
- a description of the actions taken to implement a Quality Improvement Plan (QIP) during the reporting period. Upon completion of a QIP, the owner or operator shall include in the next summary report documentation that the implementation of the plan has been completed and reduced the likelihood of similar levels of excursions or exceedances occurring.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2007.

Subsequent reports are due every 12 calendar month(s).

**Condition 63: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 64**

**Item 63.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 63.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Lyonsdale must monitor and record the sum of the the power to each of the three electrostatic precipitator(ESP) fields. The power levels must be monitored and recorded at least 4 times per hour. The total power to the three ESP fields shall not fall below 6.0 KW.

Parameter Monitored: CORONA POWER

Lower Permit Limit: 6.0 kilowatts

Monitoring Frequency: FOUR TIMES PER HOUR



Averaging Method: 1-HOUR AVERAGE  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 64: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement: 6NYCRR 227.2(b)(1)**

**Item 64.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001  
Process: 100

Regulated Contaminant(s):  
CAS No: 0NY075-00-0 PARTICULATES

**Item 64.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,
- 2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and
- 3) all records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: Zurn main boiler

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).

**Condition 65: Demonstration criteria for low sulfur oil.**



Effective between the dates of 02/13/2006 and 02/12/2011

Applicable Federal Requirement:40CFR 60.42b(j), NSPS Subpart Db

**Item 65.1:**

This Condition applies to Emission Unit: U-00001  
Process: 100

**Item 65.2:**

Affected facilities which fire very low sulfur oil shall demonstrate that the oil meets the definition of very low sulfur oil by:

1) Following the performance testing procedures in subdivision 60.45b(c) or subdivision 60.45b(d) and following monitoring procedures in subdivision 60.47b(a) or in subdivision 60.47b(b) to determine SO<sub>2</sub> emission rate or fuel oil sulfur content; or

2) Maintaining fuel receipts as described in subdivision 60.49b(r).

**Condition 66: Particulate matter standard.**  
Effective between the dates of 02/13/2006 and 02/12/2011

Applicable Federal Requirement:40CFR 60.43b(c)(1), NSPS Subpart Db

**Item 66.1:**

This Condition applies to Emission Unit: U-00001  
Process: 100

**Item 66.2:**

Particulate matter emissions while firing a minimum of 30 percent wood (or greater) with other fuels (except coal) shall not exceed 0.10 lb/mmBtu.

**Condition 67: Annual capacity factor.**  
Effective between the dates of 02/13/2006 and 02/12/2011

Applicable Federal Requirement:40CFR 60.43b(e), NSPS Subpart Db

**Item 67.1:**

This Condition applies to Emission Unit: U-00001  
Process: 100

**Item 67.2:**

The annual capacity factor = the actual unit heat input of the fuel (coal, wood, or other) /



potential heat input of the fuel, operating at 8760 hours per year and at the maximum unit design heat input.

**Condition 68: Compliance Certification**  
Effective between the dates of 02/13/2006 and 02/12/2011

**Applicable Federal Requirement: 40CFR 60.43b(f), NSPS Subpart Db**

**Item 68.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001  
Process: 100

Regulated Contaminant(s):  
CAS No: 0NY075-00-0 PARTICULATES

**Item 68.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The owner or operator shall not cause to be discharged into the atmosphere any gases that exhibit greater than 20 percent opacity (6 minute average), except for one 6-minute period per hour of not more than 27 percent opacity.

Parameter Monitored: OPACITY  
Upper Permit Limit: 20 percent  
Monitoring Frequency: CONTINUOUS  
Averaging Method: 6 MINUTE AVERAGE  
Reporting Requirements: QUARTERLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 4/30/2006.  
Subsequent reports are due every 3 calendar month(s).

**Condition 69: Compliance Certification**  
Effective between the dates of 02/13/2006 and 02/12/2011

**Applicable Federal Requirement: 40CFR 60.45b(d), NSPS Subpart Db**

**Item 69.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001  
Process: 100

**Item 69.2:**

Compliance Certification shall include the following monitoring:



Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The oil fired auxiliary burner cannot contribute more than 10 % of the combined annual capacity factor of the Zurn boiler and will be shown by the calculation btu/yr of oil divided by the btu/yr (wood & oil). Records must be maintained for at least 3 years.

annual cap. factor (aux. burner oil)= btu/yr (aux. burner oil)/ btu/yr(wood and oil for the aux. burner).

Monitoring Frequency: DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 70: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.45b(j), NSPS Subpart Db**

**Item 70.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Process: 100

**Item 70.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of an affected facility that combusts very low sulfur oil is not subject to the compliance and performance testing requirements of this section if the owner or operator obtains fuel receipts as described in §60.49b(r).

Reference Test Method: EPA Method 6

Monitoring Frequency: PER DELIVERY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 71: Compliance methods for particulate matter.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.46b, NSPS Subpart Db**

**Item 71.1:**



This Condition applies to Emission Unit: U-00001  
Process: 100

**Item 71.2:**

The particulate matter standards in section 40 CFR 60-Db.43b shall apply at all times except during periods of startup, shutdown and malfunction.

**Condition 72: Alternative sulfur dioxide monitoring method.**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.47b(f), NSPS Subpart Db**

**Item 72.1:**

This Condition applies to Emission Unit: U-00001  
Process: 100

**Item 72.2:**

Facilities which combust very low sulfur oil are not subject to the requirements of section 40 CFR 60-Db.47b if fuel receipts are obtained in accordance with subdivision 40 CFR 60-Db.49b(r).

**Condition 73: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:40CFR 60.49b(r), NSPS Subpart Db**

**Item 73.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001  
Process: 100

Regulated Contaminant(s):  
CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 73.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator who elects to demonstrate that the affected facility combusts only very low sulfur oil shall obtain and maintain at the facility fuel receipts from the fuel supplier which certify that the the oil meets the definition of distillate oil as defined 40CFR60.41b. For the purposes of this requirement, the oil need not meet the fuel nitrogen content specification in the definition of distillate oil. Semiannual reports shall be submitted



to the Administrator certifying that only very low sulfur oil was combusted in the affected facility during the preceding semiannual period.

Monitoring Frequency: PER DELIVERY  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 74: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 227-1.3(a)**

**Item 74.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00001                      Emission Point: 00001

**Item 74.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average utilizing a continuous opacity monitor (COM).

Manufacturer Name/Model Number: ZURN WOOD BOILER, 290 MMBTU/HR

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Monitoring Frequency: CONTINUOUS

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 75: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 227-1.3**

**Item 75.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):



CAS No: 0NY075-00-0 PARTICULATES

**Item 75.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

When the auxiliary boiler is operating, the facility must have 2 people certified in EPA Method 9 (opacity reading) on staff at all times. One of these certified people must be at the facility during daylight hours when the boiler is operating.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: EPA Method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2006.

Subsequent reports are due every 3 calendar month(s).

**Condition 76: Compliance Certification**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 227-1.3(a)**

**Item 76.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

**Item 76.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING  
DESCRIPTION



Averaging Method: 6-MINUTE AVERAGE (METHOD 9)  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2006.  
Subsequent reports are due every 6 calendar month(s).

**Condition 77: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable Federal Requirement:6NYCRR 227.2(b)(1)**

**Item 77.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 77.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,
- 2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and
- 3) all records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: Auxiliary Boiler

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST  
METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2006.

Subsequent reports are due every 6 calendar month(s).

**Condition 78: Compliance Certification**  
**Effective between the dates of 02/13/2006 and 02/12/2011**



**Applicable Federal Requirement:40CFR 52.21, Subpart A**

**Item 78.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

|                     |                    |
|---------------------|--------------------|
| CAS No: 000630-08-0 | CARBON MONOXIDE    |
| CAS No: 0NY210-00-0 | OXIDES OF NITROGEN |

**Item 78.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

PSD AVOIDANCE LIMIT FOR NO<sub>x</sub> AND CO EMISSIONS FROM THE AUXILIARY BOILER. THE AUXILIARY BOILER TESTING IS REQUIRED ONCE PER PERMIT TERM TO SHOW COMPLIANCE WITH THE NO<sub>x</sub> EMISSION PERMIT LIMITS OF 0.30 LB/MMBTU AND 15.27 LB/HR.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: .30 pounds per million Btus

Reference Test Method: 40 CFR 60 APP. A

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE



**STATE ONLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.**

**Condition 79: Contaminant List**

**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable State Requirement:ECL 19-0301**

**Item 79.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0

Name: CARBON MONOXIDE

CAS No: 007446-09-5



Name: SULFUR DIOXIDE

CAS No: 0NY075-00-0

Name: PARTICULATES

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

**Condition 80: Unavoidable noncompliance and violations  
Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable State Requirement: 6NYCRR 201-1.4**

Item 80.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which



result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

**Condition 81: Air pollution prohibited**  
**Effective between the dates of 02/13/2006 and 02/12/2011**

**Applicable State Requirement:6NYCRR 211.2**

**Item 81.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

