

**New York State Department of Environmental Conservation  
Facility DEC ID: 6401200111**



**PERMIT  
Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air State Facility  
Permit ID: 6-4012-00111/00001  
Mod 0 Effective Date: 03/07/2001 Expiration Date: No expiration date.  
Mod 1 Effective Date: 06/08/2004 Expiration Date: No expiration date.

Permit Issued To: NYS DEPT OF CORRECTIONAL SERVICES  
BUILDING 2 - STATE OFFICE BUILDING CAMPUS  
ALBANY, NY 12226

Contact: KEITH D RUPERT  
NYS DEPARTMENT OF CORRECTIONAL SERVICES  
1220 WASHINGTON AVENUE  
ALBANY, NY 12226  
(518) 435-9477

Facility: RIVERVIEW CORRECTIONAL FACILITY  
ROUTE 37 NEAR 37A  
OGDENSBURG, NY 13669

Contact: MICHAEL J BINTZ  
PO BOX 158  
ROUTE 37  
OGDENSBURG, NY 13669  
(315) 393-8400

Description:

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: BRIAN D FENLON  
DIVISION OF ENVIRONMENTAL PERMITS  
STATE OFFICE BLDG, 317 WASHINGTON ST  
WATERTOWN, NY 13601-3787

Authorized Signature: \_\_\_\_\_ Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_



**Notification of Other State Permittee Obligations**

**Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



**LIST OF CONDITIONS**

**DEC GENERAL CONDITIONS**

**General Provisions**

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Applications for Permit Renewals and Modifications

Applications for Permit Renewals and Modifications

Permit Modifications, Suspensions and Revocations by the Department

Permit Modifications, Suspensions, and Revocations by the Department

Permit Modifications, Suspensions, and Revocations by the Department

**Facility Level**

Submission of Applications for Permit Modification or Renewal -REGION 6  
HEADQUARTERS



**DEC GENERAL CONDITIONS**  
**\*\*\*\* General Provisions \*\*\*\***  
**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**  
**Applicable State Requirement: ECL 19-0305**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**  
**Applicable State Requirement: ECL 3-0301.2(m)**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 1-1: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13**

**Item 1-1.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 1-1.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Item 1-1.3:**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual

**New York State Department of Environmental Conservation**  
**Facility DEC ID: 6401200111**



transfer of ownership.

**Condition 3: Applications for Permit Renewals and Modifications**  
**Applicable State Requirement: 6NYCRR 621.13(a)**

**Expired by Mod No: 1**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

**Condition 1-2: Permit Modifications, Suspensions and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Item 1-2.1:**

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**Condition 5: Permit Modifications, Suspensions, and Revocations by the Department**  
**Applicable State Requirement: 6NYCRR 621.14**

**Item 5.1:**

The Department reserves the right to modify, suspend, or revoke this permit. The grounds for modification, suspension or revocation include:

- a) the scope of the permitted activity described in the application is exceeded or a violation of any condition of the permit or provisions of the ECL and pertinent regulations is found;
- b) the permit was obtained by misrepresentation or failure to disclose relevant facts;
- c) new material information is discovered; or
- d) environmental conditions, relevant technology, or applicable law or regulation have materially changed since the permit was issued.

**Condition 4: Permit Modifications, Suspensions, and Revocations by the Department**

**New York State Department of Environmental Conservation**  
**Facility DEC ID: 6401200111**



**Applicable State Requirement: 6NYCRR 621.14**

**Item 4.1:**

The Department reserves the right to modify, suspend, or revoke this permit. The grounds for modification, suspension or revocation include:

- a) the scope of the permitted activity is exceeded or a violation of any condition of the permit or provisions of the ECL and pertinent regulations is found;
- b) the permit was obtained by misrepresentation or failure to disclose relevant facts;
- c) new material information is discovered; or
- d) environmental conditions, relevant technology, or applicable law or regulation have materially changed since the permit was issued.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 6: Submission of Applications for Permit Modification or Renewal -REGION 6 HEADQUARTERS**

**Applicable State Requirement: 6NYCRR 621.5(a)**

**Item 6.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 6 Headquarters  
Division of Environmental Permits  
State Office Building, 317 Washington Street  
Watertown, NY 13601-3787  
(315) 785-2245



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: NYS DEPT OF CORRECTIONAL SERVICES  
BUILDING 2 - STATE OFFICE BUILDING CAMPUS  
ALBANY, NY 12226

Facility: RIVERVIEW CORRECTIONAL FACILITY  
ROUTE 37 NEAR 37A  
OGDENSBURG, NY 13669

Authorized Activity By Standard Industrial Classification Code:  
9223 - CORRECTIONAL INSTITUTIONS

**New York State Department of Environmental Conservation**

Permit ID: 6-4012-00111/00001

Facility DEC ID: 6401200111



**LIST OF CONDITIONS**

**FEDERALLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 1-1 6NYCRR 201-3.1(a): Exempt and Trivial Activities Applicability
- 1-2 6NYCRR 202-1.1: Required Emissions Tests - Facility Level
- 1-3 6NYCRR 202-1.2: Notification
- 1-4 6NYCRR 202-1.3: Acceptable procedures
- 1-5 6NYCRR 202-1.3: Acceptable procedures - Stack test report submittal
- 1-6 6NYCRR 202-1.5: Prohibitions
- 1-7 6NYCRR 226: Compliance Demonstration
- 1-8 6NYCRR 227-1.3(a): Compliance Demonstration
- 1-9 6NYCRR 227-1.6(a): Corrective action.
- 1-10 6NYCRR 227-1.6(b): Corrective action.
- 1-11 6NYCRR 227-1.6(c): Corrective action.
- 1-12 6NYCRR 227-1.6(d): Corrective action.

**Emission Unit Level**

**EU=0-0MAIN**

- 22 6NYCRR 225: Compliance Demonstration
- 1-13 6NYCRR 227-1.7: General Provisions

**STATE ONLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 1-14 ECL 19-0301: Contaminant List
- 1-15 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 27 6NYCRR 201-5: Emission Unit Definition
- 1-16 6NYCRR 201-7.2: Facility Permissible Emissions
- \*1-17 6NYCRR 201-7.2: Capping Monitoring Condition
- \*1-18 6NYCRR 201-7.2: Capping Monitoring Condition
- 29 6NYCRR 211.2: Air pollution prohibited

**Emission Unit Level**

- 30 6NYCRR 201-5: Emission Point Definition By Emission Unit
- 31 6NYCRR 201-5: Process Definition By Emission Unit
- 1-19 6NYCRR 201-7.2: Process Permissible Emissions

**NOTE: \* preceding the condition number indicates capping.**

Mod 0 Permit Effective Date: 03/07/2001                      Permit Expiration Date: No expiration date.

Mod 1 Permit Effective Date: 06/08/2004                      Permit Expiration Date: No expiration date.



**FEDERALLY ENFORCEABLE CONDITIONS**

\*\*\*\* Facility Level \*\*\*\*

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Sealing - 6NYCRR Part 200.5**

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation.

Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

**Item B: Acceptable Ambient Air Quality - 6NYCRR Part 200.6**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Item C: Maintenance of Equipment - 6NYCRR Part 200.7**

Any person who owns or operates an air contamination

**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**



source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Item D: Unpermitted Emission Sources - 6NYCRR Part 201-1.2**

If an existing emission source was subject to the permitting requirements of 6NYCRR Part 201 at the time of construction or modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

**Item E: Emergency Defense - 6NYCRR Part 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department within two working days after the event

**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**



occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item F: Recycling and Salvage - 6NYCRR Part 201-1.7**

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

**Item G: Prohibition of Reintroduction of Collected Contaminants to the Air - 6NYCRR Part 201-1.8**

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Item H: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR Part 201-3.2(a)**

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item I: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR Part 201-3.3(a)**

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item J: Required Emission Tests - 6 NYCRR Part 202-1.1**

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6NYCRR Part 202-1.

**Item K: Visible Emissions Limited - 6 NYCRR Part 211.3**

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Item L: Open Fires - 6 NYCRR Part 215**

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**Item M: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item N: Federally Enforceable Requirements - 40 CFR 70.6(b)**  
All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**FEDERAL APPLICABLE REQUIREMENTS**  
**The following conditions are federally enforceable.**

**Condition 1-1: Exempt and Trivial Activities Applicability**  
**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 201-3.1(a)**

**Item 1-1.1:**

If the facility owner and/or operator performs any of the exempt and trivial activities listed in 6 NYCRR Part 201-3.2(c) or 201-3.3(c), such activities are exempt from the permitting provisions of 6 NYCRR Part 201-5, but not from other Parts of 6 NYCRR Chapter III, or from applicable permitting requirements of local air pollution control agencies.

**Condition 1-2: Required Emissions Tests - Facility Level**  
**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 202-1.1**

**Item 1-2.1:**

An acceptable report of measured emissions shall be submitted, as required by the commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation.

**Condition 1-3: Notification**



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 202-1.2**

**Item 1-3.1:**

A person who is required by the commissioner to submit a stack test report shall notify the commissioner, in writing, not less than 30 days prior to the test, of the time and date of the test. Such notification shall also include the acceptable procedures to be used to stack test including sampling and analytical procedures. Such person shall allow the commissioner, or his representative, free access to observe stack testing being conducted by such person.

**Acceptable procedures**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 202-1.3**

**Item 1-4.1:**

Emission testing, sampling, and analytical determinations to ascertain compliance with this Subpart shall be conducted in accordance with test methods acceptable to the commissioner.

**Condition 1-5: Acceptable procedures - Stack test report submittal**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 202-1.3**

**Item 1-5.1:**

Emission test reports must be submitted in triplicate to the commissioner within 60 days after the completion of the tests, unless additional time is requested in writing.

**Condition 1-6: Prohibitions**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 202-1.5**

**Item 1-6.1:**

No person shall conceal an emission by the use of air or other gaseous diluents to achieve compliance with an emission standard which is based on the concentration of a contaminant in the gases emitted through a stack.

**Compliance Demonstration**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 226**

**Item 1-7.1:**

The Compliance Demonstration activity will be performed for the Facility.

**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**



Regulated Contaminant(s):

CAS No: 0NY998-00-0

VOC

**Item 1-7.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

6NYCRR 226. Requirements for Cold Cleaning Degreasers  
(Non Title V after 12/31/2003)

A. Equipment Specifications

The following types of control equipment must be used when conducting cold cleaning degreasing, solvent metal cleaning:

- (1) A cover which can be operated easily.
- (2) An internal drainage facility (under cover), if practical.
- (3) A control system that limits VOC emissions to those achievable with equipment having a freeboard ratio greater than or equal to 0.5, or a water cover when the solvent is insoluble in and heavier than water. This does not apply to remote reservoir degreasers.
- (4) Solvent with a vapor pressure of 1.0 mm Hg, or less, at 20 C.

B. Operating Requirements:

When cold cleaning, the clean parts must be drained at least 15 seconds or until dripping ceases.

C. General Requirements:

A Person conducting solvent metal cleaning must:

- (1) Store solvent in covered containers and transfer or dispose of waste solvent in such a manner that less than 20 percent of the waste solvent (by weight) can evaporate into the atmosphere.
- (2) Maintain equipment to minimize leaks and fugitive emissions.
- (3) Display at the equipment location a conspicuous summary of proper operating procedures consistent with minimizing emissions of VOCs.
- (4) Keep the degreaser cover closed except when:
  - (a) parts are being placed into or being removed



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

from the degreaser;

- (b) adding or removing solvent from the degreaser;
- (c) no solvent is in the degreaser; or
- (d) when manually cleaning metal parts in the cold

cleaning degreaser.

(5) Create and retain a record of solvent consumption for five years. This record must be made available to the

Department upon request.

(6) Not clean sponges, fabric, wood, leather, paper products and other absorbent materials in a degreaser.

(7) If using a cold cleaning degreaser that is subject to paragraph 226.3(a)(4), retain a record of the following three items for five years and provide these records to the Department upon request. An invoice, a bill of sale, a certificate covering multiple sales, a Material Safety Data Sheet (MSDS), or other appropriate documentation acceptable to the Department may be used to comply with this requirement.

- (a) the name and address of the solvent supplier;
- (b) the type of solvent including the product or vendor

identification number; and

(c) the vapor pressure of the solvent measured in mm Hg at 20 °C (68 °F).

Monitoring Frequency: MONTHLY  
 Reporting Requirements: ANNUALLY (CALENDAR)  
 Reports due 30 days after the reporting period.  
 The initial report is due 1/30/2005.  
 Subsequent reports are due every 12 calendar month(s).

**Compliance Demonstration**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.3(a)**

**Item 1-8.1:**

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):  
CAS No: 0NY075-00-0

PARTICULATES

**Item 1-8.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE



Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity (on a six minute block period) except for one six minute block period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition

- was a plume observed?

This logbook must be retained at the facility for five (5) years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then the Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

\*\* NOTE \*\* Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: EPA Method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

**DESCRIPTION**

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2005.

Subsequent reports are due every 12 calendar month(s).

**Condition 1-9: Corrective action.**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.6(a)**

**Item 1-9.1:**

Any facility found in violation of the provisions of this Part shall not cause, permit, or allow the operation of the affected stationary combustion installation unless:

- (1) it is equipped with approved emission control equipment;
- (2) it is rehabilitated or upgraded in an approved manner; or
- (3) the fuel is changed to an acceptable type.

**Condition 1-10: Corrective action.**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.6(b)**

**Item 1-10.1:**

The commissioner may seal the affected stationary combustion installation that does not comply with the provisions in subdivision 6 NYCRR 227-1.6(a) within the time provided.

**Condition 1-11: Corrective action.**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.6(c)**

**Item 1-11.1:**



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

No person shall cause, permit, or allow the operation of any affected stationary combustion installation sealed by the commissioner in accordance with this section.

**Condition 1-12: Corrective action.**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.6(d)**

**Item 1-12.1:**

No person except the commissioner or his representative shall remove, tamper with, or destroy any seal affixed to any affected stationary combustion installation.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Compliance Demonstration**

**Effective between the dates of 03/07/2001 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 225**

**Item 22.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: 0-0MAIN

Regulated Contaminant(s):

CAS No: 007446-09-5

SULFUR DIOXIDE

**Item 22.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

THE FACILITY WILL ESTABLISH & MAINTAIN A FUEL CONTRACT SPECIFYING A MAXIMUM SULFUR CONTENT BY WEIGHT OF 0.5% FOR NO.2 FUEL OIL. THIS IS BELOW THE 1.5% LIMIT OF PART 225. A COPY OF THE ANNUAL FUEL CONTRACT WILL BE SUBMITTED EACH YEAR AND MADE

AVAILABLE UPON REQUEST.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: NUMBER 2 OIL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 1.5 percent by weight



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

Monitoring Frequency: ANNUALLY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 1-13: General Provisions**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable Federal Requirement: 6NYCRR 227-1.7**

**Item 1-13.1:**

Condition applies to Emission Unit: 0-0MAIN

**Item 1-13.2:**

(a) Emission data. Any person who owns or operates a stationary combustion installation described in 6 NYCRR Part 227-1 shall provide pertinent data concerning emissions when so requested by the commissioner.

(b) Test methods. Sampling, compositing and analysis of fuel samples shall be carried out in accordance with the most recent ASTM standard methods or equivalent methods acceptable to the commissioner.



**STATE ONLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Public Access to Recordkeeping for Facilities With State Facility Permits - 6NYCRR Part 201-1.10(a)**

Where emission source owners and/or operators keep records pursuant to compliance with the operational flexibility requirements of 6 NYCRR Subpart 201-5.4(b)(1) , and/or the emission capping requirements of 6 NYCRR Subparts 201-7.2(d), 201-7.3(f), 201-7.3(g), 201-7.3(h)(5), 201-7.3(i) and 201-7.3(j), the Department will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Emission source owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department of receipt of the request.

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or

**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**



law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state only enforceable.**

**Condition 1-14: Contaminant List**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable State Requirement: ECL 19-0301**

**Item 1-14.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0  
: OXIDES OF NITROGEN

CAS No: 0NY075-00-0  
Name: PARTICULATES

CAS No: 007446-09-5  
Name: SULFUR DIOXIDE

CAS No: 0NY998-00-0  
Name: VOC

**Condition 1-15: Unavoidable noncompliance and violations**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-1.4**

**Item 1-15.1:**

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

- (a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions depending on the deviation of the malfunction and the air taminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

**Emission Unit Definition**

**Effective between the dates of 03/07/2001 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-5**

**Mod 1(From Mod 1):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 0-0MAIN

Emission Unit Description:

TWO 16.74 MILLION BTU/HR BOILERS AND ONE 10.46 MILLION BTU/HR BOILER ARE LOCATED IN THE POWERHOUSE. ALL OF THE BOILERS ARE DUAL FUEL FIRED. NATURAL GAS IS THE PRIMARY FUEL AND NO.2 FUEL OIL IS USED AS A BACKUP. THE BOILERS HAVE INDIVIDUAL STACKS. THE BOILERS WERE INSTALLED IN DECEMBER 1987



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

AND ARE NOT SUBJECT TO NSPS. THE BOILERS WERE SUBJECT TO PSD AT THE TIME OF INSTALLATION AND ARE CAPPING OUT OF PSD WITH A NO. 2 FUEL OIL CAP. THIS EMISSION UNIT ALSO INCLUDES THE OPERATION OF 2 DIESEL POWERED GENERATORS AS PART OF THE COORDINATED DEMAND REDUCTION PLAN.

Building(s): 21

**Condition 1-16: Facility Permissible Emissions**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-7.2**

**Item 1-16.1:**

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 007446-09-5 (From Mod 1) PTE: 190,000 pounds per year  
Name: SULFUR DIOXIDE

CAS No: 0NY210-00-0 (From Mod 1) PTE: 190,000 pounds per year  
: OXIDES OF NITROGEN

**Condition 1-17: Capping Monitoring Condition**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-7.2**

**Item 1-17.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6NYCRR 201-6.1(a)

**Item 1-17.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 1-17.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 1-17.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 1-17.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 1-17.6:**

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5

SULFUR DIOXIDE

**Item 1-17.7:**

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Facility owner shall ensure that emissions Sulfur Dioxide ( SO<sub>2</sub> ), including those from permitted, exempt, and trivial sources, remain less than 190,000 pounds during any consecutive 12 month period.

Facility owner must maintain records that verify the facility's monthly NO<sub>x</sub> emissions. These records must be maintained at the facility for a period of five years.

Reports will be submitted annually, in a format acceptable to the commissioner's representative, which document that the facility's SO<sub>2</sub> emissions over any consecutive 12 month period were below 190,000 pounds. The annual reports must include information that documents the SO<sub>2</sub> emissions from each emission source at the facility, including exempt and trivial activities. The report must also include all emission factors and other data used in calculating the

monthly NO<sub>x</sub> emissions.

Any noncompliance with the SO<sub>2</sub> emission limit in this



**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**

condition must be reported by sending a copy of such record to the NYSDEC, Region 6, within 30 days of the occurrence.

This Facility is also capped out of 40 CFR 52.21 as a result of the above limitation.

Monitoring Frequency: MONTHLY  
Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY  
Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 1/30/2005.  
Subsequent reports are due every 12 calendar month(s).

**Condition 1-18: Capping Monitoring Condition**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-7.2**

**Item 1-18.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6NYCRR 201-6.1(a)

**Item 1-18.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 1-18.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 1-18.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 1-18.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**



**Item 1-18.6:**

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0

OXIDES OF NITROGEN

**Item 1-18.7:**

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Facility owner shall ensure that emissions Oxides of Nitrogen ( NOx ), including those from permitted, exempt, and trivial sources, remain less than 190,000 pounds during any consecutive 12 month period.

Facility owner must maintain records that verify the facility's monthly NOx emissions. These records must be maintained at the facility for a period of five years.

Reports will be submitted annually, in a format acceptable to the commissioner's representative, which document that the facility's NOx emissions over any consecutive 12 month period were below 190,000 pounds. The annual reports must include information that documents the NOX emissions from each emission source at the facility, including exempt and trivial activities. The report must also include all emission factors and other data used in calculating the monthly NOx emissions.

Any noncompliance with the NOx emission limit in this condition must be reported by sending a copy of such record to the NYSDEC, Region 6, within 30 days of the occurrence.

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2005.

Subsequent reports are due every 12 calendar month(s).

**Air pollution prohibited**

**Effective between the dates of 03/07/2001 and Permit Expiration Date**

**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**



**Applicable State Requirement: 6NYCRR 211.2**

**Item 29.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 30: Emission Point Definition By Emission Unit  
Effective between the dates of 03/07/2001 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-5**

**.1(From Mod 0):**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 0-0MAIN

Emission Point: 00001

Height (ft.): 38

Diameter (in.): 24

Building: 21

Emission Point: 00002

Height (ft.): 38

Diameter (in.): 24

Building: 21

Emission Point: 00003

Height (ft.): 38

Diameter (in.): 24

Building: 21

**Condition 31: Process Definition By Emission Unit  
Effective between the dates of 03/07/2001 and Permit Expiration Date**

**Applicable State Requirement: 6NYCRR 201-5**

**.1(From Mod 1):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-0MAIN

Process: GAS

Source Classification Code: 1-02-006-02

**New York State Department of Environmental Conservation**

**Permit ID: 6-4012-00111/00001**

**Facility DEC ID: 6401200111**



Process Description: THE THREE POWERHOUSE BOILERS BURN NATURAL GAS.

Emission Source/Control: 00B01 - Combustion  
Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B02 - Combustion  
Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B03 - Combustion  
Design Capacity: 10.46 million Btu per hour

**.2(From Mod 1):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-0MAIN

Process: GEN

Process Description:

The Facility operates a 1000 kilowatt Caterpillar Diesel powered generator and a 300 kilowatt Cummins Diesel powered generator as part of the Coordinated Demand Reduction Program.

Emission Source/Control: OGEN1 - Combustion  
Design Capacity: 1,000 kilowatts

Emission Source/Control: OGEN2 - Combustion  
Design Capacity: 300 kilowatts

**.3(From Mod 1):**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 0-0MAIN

Process: OIL

Source Classification Code: 1-02-005-01

Process Description: THE THREE POWERHOUSE BOILERS BURN NO.2 FUEL OIL.

Emission Source/Control: 00B01 - Combustion  
Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B02 - Combustion  
Design Capacity: 16.74 million Btu per hour

Emission Source/Control: 00B03 - Combustion  
Design Capacity: 10.46 million Btu per hour

**Condition 1-19: Process Permissible Emissions**

**Effective between the dates of 06/08/2004 and Permit Expiration Date**

**New York State Department of Environmental Conservation**  
**Permit ID: 6-4012-00111/00001      Facility DEC ID: 6401200111**



**Applicable State Requirement: 6NYCRR 201-7.2**

**Item 1-19.1:**

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: 0-0MAIN

Process: OIL

CAS No: 007446-09-5

(From Mod 1)

Name: SULFUR DIOXIDE

66.77 pounds per hour

190,000 pounds per year