

**New York State Department of Environmental Conservation
Facility DEC ID: 8180200045**



**PERMIT
Under the Environmental Conservation Law (ECL)**

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 8-1802-00045/00022
Effective Date: 08/13/2007 Expiration Date: 08/12/2012

Permit Type: Title IV (Phase II Acid Rain)
Permit ID: 8-1802-00045/00025
Effective Date: 08/13/2007 Expiration Date: 08/12/2012

Permit Issued To: SENECA POWER PARTNERS LP
163 CEDAR ST
BATAVIA, NY 14020

Contact: MARK A SCHMIDT
BATAVIA POWER PLANT
163 CEDAR ST
BATAVIA, NY 14020
(585) 343-9200

Facility: BATAVIA POWER PLANT
163 CEDAR ST
BATAVIA, NY 14020

Contact: MARK A SCHMIDT
BATAVIA POWER PLANT
163 CEDAR ST
BATAVIA, NY 14020
(585) 343-9200

Description:

Initial Title IV (Acid Rain) permit and renewal of the Title V Facility Permit originally issued January 18, 2000 for a 57 megawatt steam and electrical power cogeneration facility. The single Facility Emission Unit includes a 551.3 MMBTU/hr natural gas fired turbine generator, two 16 MMBTU/hr natural gas fired steam backup boilers, a 10.9 MMBTU/hr diesel powered backup plant electrical supply generator, and a diesel powered starting engine for the gas turbine. The facility remains subject to the requirements of 6NYCRR Part 201-6 (Title V) for Major Stationary Sources due to potential emissions of oxides of nitrogen (NOx) and carbon monoxide (CO) in excess of 100 tons per year each.

No change in operations is authorized in this Title V Permit renewal. The renewed Permit retains the NOx cap in the initial Title V Permit, restricting NOx emissions to 499,800 pounds per year calculated on a rolling 12 month basis. This caps the facility's NOx emissions below the 250 tons per year applicability threshold for federal 40 CFR 52.21 Prevention of Significant Deterioration (PSD) regulations. Since facility construction in 1990, the facility has operated with NOx emissions restricted to below 250 tons per year.

New York State Department of Environmental Conservation
Facility DEC ID: 8180200045



By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: DAVID L BIMBER
 DIVISION OF ENVIRONMENTAL PERMITS
 6274 EAST AVON LIMA RD
 AVON, NY 14414-9519

Authorized Signature: _____ Date: ____ / ____ / ____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees, and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

Facility Inspection by the Department

Relationship of this Permit to Other Department Orders and Determinations

Applications for permit renewals, modifications and transfers

Permit modifications, suspensions or revocations by the Department

Facility Level

Submission of application for permit modification or renewal-REGION 8
HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department
Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 4: Relationship of this Permit to Other Department Orders and Determinations
Applicable State Requirement: ECL 3-0301.2(m)

Item 4.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 6: Applications for permit renewals, modifications and transfers
Applicable State Requirement: 6NYCRR 621.11

Item 6.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 6.2:

The permittee must submit a renewal application at least 180 days before expiration of permits for Title V Facility Permits, or at least 30 days before expiration of permits for State Facility Permits.

Item 6.3:



New York State Department of Environmental Conservation
Facility DEC ID: 8180200045

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 8: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6NYCRR 621.13

Item 8.1:

The Department reserves the right to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 11: Submission of application for permit modification or renewal-REGION 8 HEADQUARTERS
Applicable State Requirement: 6NYCRR 621.6(a)

Item 11.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 8 Headquarters
Division of Environmental Permits
6274 Avon-Lima Road
Avon, NY 14414-9519
(716) 226-2466



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: SENECA POWER PARTNERS LP
163 CEDAR ST
BATAVIA, NY 14020

Facility: BATAVIA POWER PLANT
163 CEDAR ST
BATAVIA, NY 14020

Authorized Activity By Standard Industrial Classification Code:
4931 - ELEC & OTHER SERVICES COMBINED
4961 - STEAM SUPPLY

Permit Effective Date: 08/13/2007

Permit Expiration Date: 08/12/2012



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6NYCRR 201-6.5(a)(7): Fees
- 3 6NYCRR 201-6.5(c): Recordkeeping and reporting of compliance monitoring
- 4 6NYCRR 201-6.5(c)(2): Monitoring, Related Recordkeeping, and Reporting Requirements.
- 5 6NYCRR 201-6.5(c)(3)(ii): Compliance Certification
- 6 6NYCRR 201-6.5(e): Compliance Certification
- 7 6NYCRR 202-2.1: Compliance Certification
- 8 6NYCRR 202-2.5: Recordkeeping requirements
- 9 6NYCRR 215: Open Fires Prohibited at Industrial and Commercial Sites
- 10 6NYCRR 200.7: Maintenance of Equipment
- 11 6NYCRR 201-1.7: Recycling and Salvage
- 22 6NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 12 6NYCRR 201-3.2(a): Exempt Sources - Proof of Eligibility
- 13 6NYCRR 201-3.3(a): Trivial Sources - Proof of Eligibility
- 14 6NYCRR 201-6.5(a)(4): Standard Requirement - Provide Information
- 15 6NYCRR 201-6.5(a)(8): General Condition - Right to Inspect
- 16 6NYCRR 201-6.5(d)(5): Standard Requirements - Progress Reports
- 17 6NYCRR 201-6.5(f)(6): Off Permit Changes
- 18 6NYCRR 202-1.1: Required Emissions Tests
- 19 6NYCRR 211.3: Visible Emissions Limited
- 20 40CFR 68: Accidental release provisions.
- 21 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 23 6NYCRR 201-6: Emission Unit Definition
- 24 6NYCRR 201-7.1: Facility Permissible Emissions
- *25 6NYCRR 201-7.1: Capping Monitoring Condition
- 26 6NYCRR 202-1: Emission Testing, Sampling and Analytical Determinations
- 27 6NYCRR 202-1.2: Notification
- 28 40CFR 52.21, Subpart A: Compliance Certification
- 29 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
- 30 40CFR 60.7(c), NSPS Subpart A: Excess emissions report.
- 31 40CFR 60.11, NSPS Subpart A: Opacity standard compliance testing.
- 32 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
- 33 40CFR 60.335(b), NSPS Subpart GG: Test methods and procedures for NOx emission testing

Emission Unit Level

- 34 6NYCRR 201-6: Emission Point Definition By Emission Unit
- 35 6NYCRR 201-6: Process Definition By Emission Unit
- 36 6NYCRR 201-7.1: Emission Unit Permissible Emissions

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



EU=1-CMBTN

- 37 6NYCRR 201-6.5(a)(1): Compliance Certification
- 38 6NYCRR 201-6.5(a)(1): Compliance Certification
- 39 6NYCRR 207.3(d): Episode action plans.
- 40 6NYCRR 225-1.2(a)(2): Compliance Certification
- 41 6NYCRR 227-1.3(a): Compliance Certification
- 42 40CFR 60.333(b), NSPS Subpart GG: Compliance Certification
- 43 40CFR 60.334(b)(2), NSPS Subpart GG: Compliance Certification

EU=1-CMBTN,Proc=ALL,ES=000GT

- 44 40CFR 60.332(a)(1), NSPS Subpart GG: Compliance Certification

EU=1-CMBTN,EP=00001

- 45 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
- 46 40CFR 60.333, NSPS Subpart GG: Sulfur in fuel standard.

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 47 ECL 19-0301: Contaminant List
- 48 6NYCRR 201-1.4: Unavoidable noncompliance and violations
- 49 6NYCRR 211.2: Air pollution prohibited

Emission Unit Level

EU=1-CMBTN

- 50 6NYCRR 201-1.4: Compliance Demonstration

NOTE: * preceding the condition number indicates capping.



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated;

(3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

Condition 1: Acceptable Ambient Air Quality
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0302.

Condition 3: Recordkeeping and reporting of compliance monitoring

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii) The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.3 of this Part 201.

Condition 4: Monitoring, Related Recordkeeping, and Reporting Requirements.

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 5: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(c)(3)(ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

(1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



(2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.

(3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.3(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.5(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2008.
Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;and
 - such additional requirements as may be specified elsewhere in this permit related to compliance certification.
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.
- iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.
- iv. All compliance certifications shall be submitted to the Administrator (or his or her representative) as well as two copies to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office). Please send annual compliance certifications to Chief of the Stationary Source Compliance Section, the Region 2 EPA representative for the Administrator, at the following address:

USEPA Region 2

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Air Compliance Branch
290 Broadway
New York, NY 10007-1866

The address for the RAPCE is as follows:

6274 East Avon-Lima Road
Avon, NY 14414-9519

The address for the BQA is as follows:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2008.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 202-2.1

Item 7.1:
The Compliance Certification activity will be performed for the Facility.

Item 7.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:
Emission statements shall be submitted on or before April
15th each year for emissions of the previous calendar
year.

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 202-2.5



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

Item 8.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires Prohibited at Industrial and Commercial Sites
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 215

Item 9.1:

No person shall burn, cause, suffer, allow or permit the burning in an open fire of garbage, refuse, rubbish for salvage, or rubbish generated by industrial or commercial activities.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS SUBJECT
TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period. [NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

Condition 10: Maintenance of Equipment
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-1.7



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

Item 11.1:

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 22: Prohibition of Reintroduction of Collected Contaminants to the air

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-1.8

Item 22.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 12: Exempt Sources - Proof of Eligibility

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-3.2(a)

Item 12.1:

The owner and/or operator of an emission source or unit that is eligible to be exempt may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 13: Trivial Sources - Proof of Eligibility

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-3.3(a)

Item 13.1:

The owner and/or operator of an emission source or unit that is listed as being trivial in this Part may be required to certify that it operates within the specific criteria described in this Subpart. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other State and Federal air pollution control requirements, regulations, or law.

Condition 14: Standard Requirement - Provide Information

Effective between the dates of 08/13/2007 and 08/12/2012



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(4)

Item 14.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 15: General Condition - Right to Inspect
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(8)

Item 15.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 16: Standard Requirements - Progress Reports
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(d)(5)

Item 16.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

preventive or corrective measures adopted.

Condition 17: Off Permit Changes
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(f)(6)

Item 17.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.6 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 202-1.1

Item 18.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time. Such person shall bear the cost of measurement and preparing the report of measured emissions. Failure of such person to submit a report acceptable to the commissioner within the time stated shall be sufficient reason for the commissioner to suspend or deny a certificate to operate.

Condition 19: Visible Emissions Limited
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 211.3

Item 19.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 20: Accidental release provisions.
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 68

Item 20.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
C/O CSC
8400 Corporate Dr
Carrollton, Md. 20785

Condition 21: Recycling and Emissions Reduction
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 82, Subpart F

Item 21.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 23: Emission Unit Definition
Effective between the dates of 08/13/2007 and 08/12/2012

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Applicable Federal Requirement: 6NYCRR 201-6

Item 23.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: 1-CMBTN

Emission Unit Description:

SINGLE GENERAL ELECTRIC FRAME 6 GAS TURBINE UNIT AND HRSG WITH STEAM INJECTION (PT1); TWO IDENTICAL NATURAL GAS FIRED AUXILIARY BOILERS WITH A COMBINED STACK (PT2); AN AUXILIARY GENERATOR FIRING DISTILLATE FUEL OIL (PT3); AND A DISTILLATE OIL FIRED STARTING ENGINE FOR THE GAS TURBINE (PT6).

Building(s): 1

Condition 24: Facility Permissible Emissions

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-7.1

Item 24.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 PTE: 499,800 pounds per year
Name: OXIDES OF NITROGEN

Condition 25: Capping Monitoring Condition

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-7.1

Item 25.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40CFR 52-A.21

Item 25.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Item 25.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 25.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 25.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 25.6:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 25.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

As part of the facility-wide PSD cap, NO_x emissions are limited to 499,800 pounds per year on a rolling twelve month basis.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

**Condition 26: Emission Testing, Sampling and Analytical Determinations
Effective between the dates of 08/13/2007 and 08/12/2012**

Applicable Federal Requirement: 6NYCRR 202-1

Item 26.1:



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

The provisions of 6NYCRR Subpart 202-1 apply to this facility.

Condition 27: Notification

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 202-1.2

Item 27.1:

A person who is required by the commissioner to submit a stack test report shall notify the commissioner, in writing, not less than 30 days prior to the test, of the time and date of the test. Such notification shall also include the acceptable procedures to be used to stack test including sampling and analytical procedures. Such person shall allow the commissioner, or his representative, free access to observe stack testing being conducted by such person.

Condition 28: Compliance Certification

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 28.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 28.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

AS PART OF THE PSD NON-APPLICABILITY
CAPPING, FACILITY WIDE NO_x EMISSIONS
SHALL NOT EXCEED A MAXIMUM OF 499,800
POUNDS PER YEAR ROLLED MONTHLY.

Reference Test Method: EPA METHOD 20

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 29: EPA Region 2 address.

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.4, NSPS Subpart A

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Item 29.1:

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2
290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

**Condition 30: Excess emissions report.
Effective between the dates of 08/13/2007 and 08/12/2012**

Applicable Federal Requirement: 40CFR 60.7(c), NSPS Subpart A

Item 30.1:

Affected owners or operators shall submit an excess emissions report and/or a summary report form (as defined in 40 CFR 60.7(d)) semi-annually (or more frequently as required by the applicable Subpart or the Administrator), to the Administrator. These reports shall be post marked no later than 30 days after each calendar quarter (or as appropriate), and shall contain the following information:

- 1) the magnitude of excess emissions computed, any conversion factors used, the date and time of each occurrence, and the process operating time during the reporting period;
- 2) specific identification of each period of excess emissions that occur during startup, shutdown, or malfunction, where the nature, cause, and corrective action are provided for a malfunction;
- 3) the date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments; and
- 4) when no excess emissions have occurred or when the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be provided in the report.

**Condition 31: Opacity standard compliance testing.
Effective between the dates of 08/13/2007 and 08/12/2012**

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Applicable Federal Requirement: 40CFR 60.11, NSPS Subpart A

Item 31.1:

The following conditions shall be used to determine compliance with the opacity standards:

1) observations shall be conducted in accordance with Reference Method 9, in Appendix A of 40 CFR Part 60 (or an equivalent method approved by the Administrator including continuous opacity monitors);

2) the opacity standards apply at all times except during periods of start up, shutdown, and malfunction; and

3) all other applicable conditions cited in section 60.11 of this part.

Condition 32: Monitoring requirements.

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.13, NSPS Subpart A

Item 32.1:

All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

Condition 33: Test methods and procedures for NO_x emission testing

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.335(b), NSPS Subpart GG

Item 33.1:

The owner or operator shall determine compliance with the applicable nitrogen oxides emission limitation in §60.332 and shall meet the performance test requirements of §60.8 as follows:

(1) For each run of the performance test, the mean nitrogen oxides emission concentration (NO_{xo}) corrected to 15 percent O₂ shall be corrected to ISO standard conditions using the following equation. Notwithstanding this requirement, use of the ISO correction equation is optional for: Lean premix stationary combustion turbines; units used in association with heat recovery steam generators (HRSG) equipped with duct burners; and units equipped with add-on emission control devices:

$$NO_x = (NO_{xo}) (Pr/Po)^{0.5} e^{19 (Ho - 0.00633) (288^\circ K / Ta)^{1.53}}$$

Where:

NO_x = emission concentration of NO_x at 15 percent O₂ and ISO standard ambient conditions, ppm by volume, dry basis, NO_{xo} = mean observed NO_x concentration, ppm by volume, dry basis, at 15 percent O₂, Pr = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg, Po = observed combustor inlet absolute pressure at test, mm Hg, Ho = observed humidity of ambient air, g H₂O/g air, e = transcendental constant, 2.718, and Ta = ambient temperature, °K.



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

(2) The 3-run performance test required by §60.8 must be performed within ± 5 percent at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice. If the turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel. Notwithstanding these requirements, performance testing is not required for any emergency fuel (as defined in §60.331).

(3) For a combined cycle turbine system with supplemental heat (duct burner), the owner or operator may elect to measure the turbine NO_x emissions after the duct burner rather than directly after the turbine. If the owner or operator elects to use this alternative sampling location, the applicable NO_x emission limit in §60.332 for the combustion turbine must still be met.

(4) If water or steam injection is used to control NO_x with no additional post-combustion NO_x control and the owner or operator chooses to monitor the steam or water to fuel ratio in accordance with §60.334(a), then that monitoring system must be operated concurrently with each EPA Method 20, ASTM D6522-00 (incorporated by reference, see §60.17), or EPA Method 7E run and shall be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.332 NO_x emission limit.

(5) If the owner operator elects to claim an emission allowance for fuel bound nitrogen as described in §60.332, then concurrently with each reference method run, a representative sample of the fuel used shall be collected and analyzed, following the applicable procedures described in §60.335(b)(9). These data shall be used to determine the maximum fuel nitrogen content for which the established water (or steam) to fuel ratio will be valid.

(6) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately (as described in paragraph (b)(7) of this section) or as part of the initial performance test of the affected unit.

(7) If the owner or operator elects to install and certify a NO_x CEMS under §60.334(e), then the initial performance test required under §60.8 may be done in the following alternative manner:

(i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.

(ii) Use the test data both to demonstrate compliance with the applicable NO_x emission limit under §60.332 and to provide the required reference method data for the RATA of the CEMS described under §60.334(b).

(iii) The requirement to test at three additional load levels is waived.

(8) If the owner or operator is required under §60.334(f) to monitor combustion parameters or parameters indicative of proper operation of NO_x emission controls, the appropriate parameters shall be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.334(g).



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

(9) To determine the fuel bound nitrogen content of fuel being fired (if an emission allowance is claimed for fuel bound nitrogen), the owner or operator may use equipment and procedures meeting the requirements of:

(i) For liquid fuels, ASTM D2597-94 (Reapproved 1999), D6366-99, D4629-02, D5762-02 (all of which are incorporated by reference, see §60.17); or

(ii) For gaseous fuels, shall use analytical methods and procedures that are accurate to within 5 percent of the instrument range and are approved by the Administrator.

(10) If the owner or operator is required under §60.334(i)(1) or (3) to periodically determine the sulfur content of the fuel combusted in the turbine, a minimum of three fuel samples shall be collected during the performance test. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129-00, D2622-98, D4294-02, D1266-98, D5453-00 or D1552-01 (all of which are incorporated by reference, see §60.17); or

(ii) For gaseous fuels, ASTM D1072-80, 90 (Reapproved 1994); D3246-81, 92, 96; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see §60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the Administrator.

(11) The fuel analyses required under paragraphs (b)(9) and (b)(10) of this section may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

****** Emission Unit Level ******

**Condition 34: Emission Point Definition By Emission Unit
Effective between the dates of 08/13/2007 and 08/12/2012**

Applicable Federal Requirement: 6NYCRR 201-6

Item 34.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: 1-CMBTN

Emission Point: 00001

Height (ft.): 150

Diameter (in.): 132

NYTMN (km.): 4763.921 NYTME (km.): 242.429 Building: 1

Emission Point: 00002

Height (ft.): 76

Diameter (in.): 36



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

NYTMN (km.): 4763.921 NYTME (km.): 242.429 Building: 1

Emission Point: 00003

Height (ft.): 18

Diameter (in.): 12

NYTMN (km.): 4763.921 NYTME (km.): 242.429 Building: 1

Emission Point: 00006

Height (ft.): 20

Diameter (in.): 12

NYTMN (km.): 4763.921 NYTME (km.): 242.429 Building: 1

**Condition 35: Process Definition By Emission Unit
Effective between the dates of 08/13/2007 and 08/12/2012**

Applicable Federal Requirement: 6NYCRR 201-6

Item 35.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-CMBTN

Process: ALL

Source Classification Code: 2-03-002-03

Process Description:

GAS TURBINE/HRSG, FIRING NATURAL GAS (PT1); AUXILIARY BOILERS (1 OR BOTH) FIRING NATURAL GAS (PT2); AUXILIARY GENERATOR, FIRING DISTILLATE OIL (PT3); AND THE STARTING ENGINE FIRING DISTILLATE OIL (PT6); ALL OPERATING SIMULTANEOUSLY, OR IN ANY COMBINATION.

Emission Source/Control: 000GT - Combustion

Design Capacity: 551.3 million Btu per hour

Emission Source/Control: AUXBS - Combustion

Design Capacity: 16 million Btu per hour

Emission Source/Control: AXGEN - Combustion

Design Capacity: 10.9 million Btu per hour

Emission Source/Control: DETEN - Combustion

Design Capacity: 4.61 million Btu per hour

Emission Source/Control: 0SINJ - Control

Control Type: STEAM OR WATER INJECTION

**Condition 36: Emission Unit Permissible Emissions
Effective between the dates of 08/13/2007 and 08/12/2012**

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Applicable Federal Requirement: 6NYCRR 201-7.1

Item 36.1:

The sum of emissions from all regulated processes specified in this permit for the emission unit cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: 1-CMBTN

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 122.3 pounds per hour

499,800 pounds per year

Condition 37: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(1)

Item 37.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-CMBTN

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 37.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Carbon monoxide emissions are limited to 41 lbs/hr, at 48 degrees F, as determined during the initial stack test.

CO mass emission rates across the temperature spectrum are limited to those represented by figure 2, submitted as part of the application for this permit. CO emissions are to be monitored via the CEM (continuous emission monitoring) system.

Manufacturer Name/Model Number: CEM

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 41 pounds per hour

Reference Test Method: EPA method 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 38: Compliance Certification

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 201-6.5(a)(1)

Item 38.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-CMBTN

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Carbon monoxide emissions are limited to 40 ppmv (dry, corrected to 15% oxygen.) as determined during the initial stack test. CO emissions are to be monitored via the CEM (continuous emission monitoring) system.

Manufacturer Name/Model Number: CEM

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 40 parts per million by volume (dry, corrected to 15% O₂)

Reference Test Method: EPA method 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 39: Episode action plans.

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 207.3(d)

Item 39.1:

This Condition applies to Emission Unit: 1-CMBTN

Item 39.2:



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

Any person who owns an air contamination source for which an episode action plan has been issued or approved shall take whatever actions are prescribed by this episode action plan when an air pollution episode is in effect.

Condition 40: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 225-1.2(a)(2)

Item 40.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-CMBTN

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The auxiliary generator and the diesel turbine starting engine shall be limited to a sulfur in (distillate) fuel oil content of 0.2% by weight. Monitoring of this limit shall be accomplished through specifications provided to, and confirmed by, the fuel supplier. An analysis may be requested by the Department at its discretion.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 41: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 6NYCRR 227-1.3(a)

Item 41.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-CMBTN

Item 41.2:

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall operate the installation in such a way to emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test Method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 42: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.333(b), NSPS Subpart GG

Item 42.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-CMBTN

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Sulfur in fuel shall be limited to 0.8% by weight, and monitored annually, per the requirements of 40CFR60.333(b) and 40CFR60.334(b)(2).

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

The initial report is due 1/30/2008.
Subsequent reports are due every 6 calendar month(s).

Condition 43: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.334(b)(2), NSPS Subpart GG

Item 43.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-CMBTN

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 43.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Nitrogen in fuel shall be monitored semiannually, on a
calendar year basis, per the requirements of
40CFR60.334(b)(2).

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 44: Compliance Certification
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.332(a)(1), NSPS Subpart GG

Item 44.1:

The Compliance Certification activity will be performed for:

Emission Unit: 1-CMBTN
Process: ALL Emission Source: 000GT

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 44.2:



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$\text{STD} = 0.0075 (14.4/Y) + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NOX emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NOX emission allowance for fuel-bound nitrogen as defined in paragraph 40 CFR 60.332(a)(4).

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 139 parts per million by volume
(dry, corrected to 15% O₂)

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).

Condition 45: Recordkeeping requirements.

Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.7(b), NSPS Subpart A

Item 45.1:

This Condition applies to Emission Unit: 1-CMBTN Emission Point: 00001

Item 45.2:

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is



New York State Department of Environmental Conservation
Permit ID: 8-1802-00045/00022 Facility DEC ID: 8180200045

inoperative.

Condition 46: Sulfur in fuel standard.
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable Federal Requirement: 40CFR 60.333, NSPS Subpart GG

Item 46.1:

This Condition applies to Emission Unit: 1-CMBTN Emission Point: 00001

Item 46.2:

No gas turbine shall fire a fuel with more than 0.80% sulfur content.



STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 47: Contaminant List
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable State Requirement: ECL 19-0301

Item 47.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0

Name: CARBON MONOXIDE

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

CAS No: 007446-09-5

Name: SULFUR DIOXIDE

Condition 48: Unavoidable noncompliance and violations
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable State Requirement: 6NYCRR 201-1.4

Item 48.1:

At the discretion of the commissioner a violation of any applicable emission standard for necessary scheduled equipment maintenance, start-up/shutdown conditions and malfunctions or upsets may be excused if such violations are unavoidable. The following actions and recordkeeping and reporting requirements must be adhered to in such circumstances.

(a) The facility owner and/or operator shall compile and maintain records of all equipment maintenance or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the commissioner's representative when requested to do so in writing or when so required by a condition of a permit issued for the corresponding air contamination source except where conditions elsewhere in this permit which contain more stringent reporting and notification provisions for an applicable requirement, in which case they supercede those stated here. Such reports shall describe why the violation was unavoidable and shall include the time, frequency and duration of the maintenance and/or start-up/shutdown activities and the identification of air contaminants, and the estimated emission rates. If a facility owner and/or operator is subject to continuous stack monitoring and quarterly reporting requirements, he need not submit reports for equipment maintenance or start-up/shutdown for the facility to the commissioner's representative.

(b) In the event that emissions of air contaminants in excess of any emission standard in 6 NYCRR Chapter III Subchapter A occur due to a malfunction, the facility owner and/or operator shall report such malfunction by telephone to the commissioner's representative as soon as possible during normal working hours, but in any event not later than two working days after becoming aware that the malfunction occurred. Within 30 days thereafter, when requested in writing by the commissioner's representative, the facility owner and/or operator shall submit a written report to the commissioner's representative describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates. These reporting requirements are superceded by conditions elsewhere in this permit which contain reporting and notification provisions for applicable requirements more stringent than those above.

(c) The Department may also require the owner and/or operator to include in reports described under (a) and (b) above an estimate of the maximum ground level concentration of each air contaminant



New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045

emitted and the effect of such emissions depending on the deviation of the malfunction and the air contaminants emitted.

(d) In the event of maintenance, start-up/shutdown or malfunction conditions which result in emissions exceeding any applicable emission standard, the facility owner and/or operator shall take appropriate action to prevent emissions which will result in contravention of any applicable ambient air quality standard. Reasonably available control technology, as determined by the commissioner, shall be applied during any maintenance, start-up/shutdown or malfunction condition subject to this paragraph.

(e) In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets.

Condition 49: Air pollution prohibited
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable State Requirement: 6NYCRR 211.2

Item 49.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

****** Emission Unit Level ******

Condition 50: Compliance Demonstration
Effective between the dates of 08/13/2007 and 08/12/2012

Applicable State Requirement: 6NYCRR 201-1.4

Item 50.1:

The Compliance Demonstration activity will be performed for:

Emission Unit: 1-CMBTN

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 50.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

New York State Department of Environmental Conservation

Permit ID: 8-1802-00045/00022

Facility DEC ID: 8180200045



Monitoring Description:

Startups and shutdowns shall be limited to the following:

Cold Start: 2.5 hours maximum duration, 305.75 pounds of NOx emissions, 102.5 pounds of CO emissions.

Warm start: 1.5 hours maximum duration, 183.45 pounds of NOx emissions, 61.5 pounds of CO emissions.

Shutdown: 1 hour maximum duration, 122.3 pounds of NOx emissions, 41 pounds of CO emissions.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2008.

Subsequent reports are due every 6 calendar month(s).