



**Facility Identification Data**

Name: TBG COGEN FACILITY  
Address: 939 S BROADWAY  
HICKSVILLE, NY 11801-5032

**Owner/Firm**

Name: TBG COGEN PARTNERS  
Address: 717 TEXAS AVE STE 1000  
HOUSTON, TX 77002, USA  
Owner Classification: Corporation/Partnership

**Permit Contacts**

Division of Environmental Permits:  
Name: KEVIN A KISPERT  
Address: SUNY @ STONY BROOK  
50 CIRCLE RD  
STONY BROOK, NY 11790  
Phone:6314440302

Division of Air Resources:  
Name: HUMBERTO ROMAN  
Address: NYSDEC - SUNY @ STONY BROOK  
50 CIRCLE RD  
STONY BROOK, NY 11790-3409  
Phone:6314440211

Air Permitting Facility Owner Contact:  
Name: JULIE A STINEDURF  
Address: CALPINE CORPORATION  
717 TEXAS AVE STE 1000  
HOUSTON, TX 77002  
Phone:7138308618

**Permit Description**

**Introduction**

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

**Summary Description of Proposed Project**

Application is to amend the TV Permit for the TBG Cogen Partners facility by adding the new GE LM6000 SPRINT gas turbine for which its preconstruction permit was previously issued to CPN 3rd Turbine, Inc. The application also adds to the TV permit an auxiliary boiler and space heaters for the turbine building ( attached as exempt activities) .

The existing TBG Cogen Partners facility includes a cogeneration plant, peaking power plant and a combined cycle power plant. The cogeneration plant consists of two identical GE LM2500 combustion turbines, two heat recovery



boilers with duct burners and steam turbine generator. The LM2500 units are permitted to fire natural gas and distillate oil, while the duct burners are limited to natural gas. The peaking power plant consists of one GELM6000 combustion turbine permitted to fire only natural gas. The combined cycle power plant consists of one LM6000 combustion turbine and once-through boiler with duct burner permitted to fire natural gas exclusively. The auxiliary boiler and furnaces will provide space heating for the turbine building when the cogeneration plant is out of service.

**Attainment Status**

TBG COGEN FACILITY is located in the town of OYSTER BAY in the county of NASSAU. The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

| Criteria Pollutant                          | Attainment Status     |
|---|-----------------------|
| Particulate Matter (PM)                     | ATTAINMENT            |
| Particulate Matter < 10µ in diameter (PM10) | ATTAINMENT            |
| Sulfur Dioxide (SO2)                        | ATTAINMENT            |
| Ozone*                                      | SEVERE NON-ATTAINMENT |
| Oxides of Nitrogen (NOx)**                  | ATTAINMENT            |
| Carbon Monoxide (CO)                        | ATTAINMENT            |

\* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

\*\* NOx has a separate ambient air quality standard in addition to being an ozone precursor

**Facility Description**

Application is to amend the TV Permit for the TBG Cogen Partners facility by adding the new GE LM6000 SPRINT gas turbine for which its preconstruction permit was previously issued to CPN 3rd Turbine, Inc. The application also adds to the TV permit an auxiliary boiler and space heaters for the turbine building ( attached as exempt activities) .

The existing TBG Cogen Partners facility includes a cogeneration plant, peaking power plant and a combined cycle power plant. The cogeneration plant consists of two identical GE LM2500 combustion turbines, two heat recovery boilers with duct burners and steam turbine generator. The LM2500 units are permitted to fire natural gas and distillate oil, while the duct burners are limited to natural gas. The peaking power plant consists of one GELM6000 combustion turbine permitted to fire only natural gas. The combined cycle power plant consists of one LM6000 combustion turbine and once-through boiler with duct burner permitted to fire natural gas exclusively. The auxiliary boiler and furnaces will provide space heating for the turbine building when the cogeneration plant is out of service.

**Permit Structure and Description of Operations**

The Title V permit for TBG COGEN FACILITY is structured in terms of the following hierarchy: facility, emission unit,



emission point, emission source and process.

A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
  - incinerator - devices which burn waste material for disposal
  - control - emission control devices
  - process - any device or contrivance which may emit air contaminants
- that is not included in the above categories.

TBG COGEN FACILITY is defined by the following emission unit(s):

Emission unit U00003 - This emission unit will consist of a GE LM6000 SPRINT combustion turbine, a once through steam generator equipped with duct burners, and a 2 cell cooling tower. The combustion turbine and the duct burners will operate exclusively on natural gas.

Emission unit U00003 is associated with the following emission points (EP):  
0000B, 00SH1, 00SH2, 00SH3, 00SH4, U0003

It is further defined by the following process(es):

Process: GSH This process consists of 8 350,000 Btu/hr heat input gas fired only space heaters.

Process: OFB This process consists of the operation of one 9.5 mmBtu/hr heat input distillate oil fired boiler.

Emission unit U00002 - Calpine Bethpage Inc. installed a GE LM6000 sprint combustion turbine, 3rd Turbine, at the existing cogeneration facility owned by TBG Cogen Partners. The GE LM6000 combustion turbine is fired exclusively with natural gas and has a nominal net electrical power output of less than 50 mw. The combustion turbine employs selective catalytic reduction for NOx control and an oxidation catalyst system for CO control.

Emission unit U00002 is associated with the following emission points (EP):  
00002

It is further defined by the following process(es):

Process: 003 is located at Building CT - GE LM6000 COMBUSTION TURBINE FIRING EXCLUSIVELY NATURAL GAS.

Emission unit U00001 - Two identical GE Model LM2500 gas turbines and associated Heat Recovery Steam Generator ( HRSG ) with duct burners. The gas turbines may fire natural gas, distillate oil, or mixed fuel (gas/oil). Each HRSG on each gas turbine includes a duct burner for supplemental firing on natural gas only. The turbines may operate with or without the duct burners. Each turbine/hrsg combustion unit has a maximum heat input of 416 mmbtu/hr. The total heat input for the emission unit is 832 mmbtu/hr. There are two emission points for this emission unit consisting of one stack for each combustion turbine/hrsg combustion unit.

Emission unit U00001 is associated with the following emission points (EP):  
00001, 00003

It is further defined by the following process(es):

Process: DBG is located at Building 1 - TWO DUCT BURNERS, ONE ON EACH HRSG, FIRING NATURAL



GAS WITHOUT OPERATION OF THE TURBINES. THIS PROCESS IS PROVIDED TO IDENTIFY THE EMISSION LIMIT FOR THE DUCT BURNERS. THE DUCT BURNERS CANNOT OPERATE WITHOUT THE TURBINES.

Process: GTG is located at Building 1 - TWO IDENTICAL GE COMBUSTION TURBINES FIRING NATURAL GAS WITHOUT SUPPLEMENTAL FIRING OF THE DUCT BURNER. NOX EMISSIONS ARE CONTROLLED WITH STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Process: GTM is located at Building 1 - TWO IDENTICAL GE COMBUSTION TURBINES FIRING MIXED FUEL (NATURAL GAS AND DISTILLATE OIL) WITH OR WITHOUT SUPPLEMENTAL FIRING OF THE DUCT BURNER ON GAS. NOX IS CONTROLLED BY STEAM INJECTION AND CO IS CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Process: GTO is located at Building 1 - TWO IDENTICAL GE COMBUSTION TURBINES FIRING OIL WITHOUT SUPPLEMENTAL FIRING OF THE DUCT BURNER. NOX EMISSIONS ARE CONTROLLED WITH STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Process: TGB is located at Building 1 - TWO IDENTICAL GE COMBUSTION TURBINES FIRING NATURAL GAS WITH SUPPLEMENTAL FIRING OF THE DUCT BURNER ON GAS. NOX EMISSIONS ARE CONTROLLED BY STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

Process: TOB is located at Building 1 - TWO IDENTICAL GE COMBUSTION TURBINES FIRING OIL WITH SUPPLEMENTAL FIRING OF THE DUCT BURNER ON GAS. NOX EMISSIONS ARE CONTROLLED BY STEAM INJECTION AND CO EMISSIONS ARE CONTROLLED WITH A CATALYTIC OXIDATION UNIT.

**Title V/Major Source Status**

TBG COGEN FACILITY is subject to Title V requirements. This determination is based on the following information:

Facility is major for NOx, therefore, subject to Title V requirements.

**Program Applicability**

The following chart summarizes the applicability of TBG COGEN FACILITY with regards to the principal air pollution regulatory programs:

| Regulatory Program             | Applicability |
|--------------------------------|---------------|
| PSD                            | YES           |
| NSR (non-attainment)           | YES           |
| NESHAP (40 CFR Part 61)        | NO            |
| NESHAP (MACT - 40 CFR Part 63) | NO            |
| NSPS                           | YES           |
| TITLE IV                       | YES           |
| TITLE V                        | YES           |



|          |     |
|----------|-----|
| TITLE VI | NO  |
| RACT     | YES |
| SIP      | YES |

**NOTES:**

**PSD**                                      Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**NSR**                                      New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**NESHAP**      National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's)

**MACT**                                      Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

**NSPS**                                      New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

**Title IV**                                      Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

**Title VI**                                      Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

**RACT**                                      Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.



## Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

### Compliance Status

Facility is in compliance with all requirements

### SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

#### SIC Code

4911

#### Description

ELECTRIC SERVICES

### SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

#### SCC Code

1-03-006-01

#### Description

EXTERNAL COMBUSTION BOILERS -  
COMMERCIAL/INDUSTRIAL  
COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS  
Over 100 MMBtu/Hr

1-02-005-03

EXTERNAL COMBUSTION BOILERS - INDUSTRIAL  
INDUSTRIAL BOILER - DISTILLATE OIL  
<10MMBTU/HR \*\*

1-05-001-06

EXTERNAL COMBUSTION BOILERS - SPACE HEATERS  
INDUSTRIAL SPACE HEATER

2-03-001-02

Natural Gas  
INTERNAL COMBUSTION ENGINES -  
COMMERCIAL/INSTITUTIONAL  
COMMERCIAL/INSTITUTIONAL IC ENGINE - DISTILLATE OIL  
(DIESEL)

2-03-002-03

Turbine  
INTERNAL COMBUSTION ENGINES -  
COMMERCIAL/INSTITUTIONAL  
COMMERCIAL/INSTITUTIONAL IC ENGINE - NATURAL  
GAS  
TURBINE: COGENERATION

### Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Series code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air



Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

contaminant , including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount of material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

| Cas No.     | Contaminant Name                     | PTE     |       |
|-------------|--------------------------------------|---------|-------|
|             |                                      | lbs/yr  | Range |
| 000106-99-0 | 1,3-BUTADIENE                        | pteyear | Y     |
| 000075-07-0 | ACETALDEHYDE                         | pteyear | Y     |
| 000107-02-8 | ACROLEIN                             | pteyear | Y     |
| 007664-41-7 | AMMONIA                              | pteyear | D     |
| 000071-43-2 | BENZENE                              | pteyear | Y     |
| 000630-08-0 | CARBON MONOXIDE                      | pteyear | F     |
| 007440-47-3 | CHROMIUM                             | pteyear | Y     |
| 000100-41-4 | ETHYLBENZENE                         | pteyear | Y     |
| 000050-00-0 | FORMALDEHYDE                         | pteyear | Y     |
| 0NY100-00-0 | HAP                                  | pteyear | B     |
| 007439-92-1 | LEAD                                 | pteyear | Y     |
| 007439-96-5 | MANGANESE                            | pteyear | Y     |
| 000091-20-3 | NAPHTHALENE                          | pteyear | Y     |
| 007440-02-0 | NICKEL METAL AND INSOLUBLE COMPOUNDS | pteyear | Y     |
| 0NY210-00-0 | OXIDES OF NITROGEN                   | pteyear | H     |
| 0NY075-00-0 | PARTICULATES                         | pteyear | E     |
| 007723-14-0 | PHOSPHORUS (YELLOW)                  | pteyear | Y     |
| 0NY075-00-5 | PM-10                                | pteyear | E     |
| 130498-29-2 | POLYCYCLIC AROMATIC HYDROCARBONS     | pteyear | Y     |
| 000075-56-9 | PROPANE, 1,2-EPOXY-                  | pteyear | Y     |
| 007446-09-5 | SULFUR DIOXIDE                       | pteyear | H     |
| 007664-93-9 | SULFURIC ACID                        | pteyear | A     |
| 000108-88-3 | TOLUENE                              | pteyear | Y     |
| 0NY998-00-0 | VOC                                  | pteyear | C     |
| 001330-20-7 | XYLENE, M, O & P MIXT.               | pteyear | Y     |



## NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

### Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

### Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

### Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

### Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this



permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

**Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

**Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

**Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing



herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow



the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item L: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility



## Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

## Regulatory Analysis

| Location<br>Facility/EU/EP/Process/ES | Regulation                                 | Condition                                   | Short Description   |
|---------------------------------------|--|---|---|
| FACILITY                              |  | 80  | Powers and Duties of the Department with respect to air pollution control   |
| FACILITY                              | 40CFR 52-A.21                              | 24, 2-51                                    | Prevention of Significant Deterioration                                     |
| U-00001<br>2-56, 2-57                 | 40CFR 52-A.21<br>Prevention of Significant | 48, 49, 50, 51, 52, 2-52, 2-53, 2-54, 2-55, | Deterioration   |
| U-00001/-/DBG/000DB                   | 40CFR 52-A.21                              | 55  | Prevention of Significant Deterioration                                     |
| U-00001/-/GTG/000GT                   | 40CFR 52-A.21                              | 56, 57, 58                                  | Prevention of Significant Deterioration                                     |
| U-00001/-/GTM                         | 40CFR 52-A.21                              | 59, 60                                      | Prevention of Significant Deterioration                                     |
| U-00001/-/GTO/000GT                   | 40CFR 52-A.21                              | 61, 62, 63                                  | Prevention of Significant Deterioration                                     |
| U-00001/-/TGB                         | 40CFR 52-A.21                              | 64, 65, 66                                  | Prevention of Significant Deterioration                                     |
| U-00001/-/TOB                         | 40CFR 52-A.21                              | 67, 68                                      | Prevention of Significant Deterioration                                     |
| U-00001/-/TOB/000GT                   | 40CFR 52-A.21                              | 69  | Prevention of Significant Deterioration                                     |
| U-00002                               | 40CFR 52-A.21                              | 2-69, 79                                    | Prevention of Significant Deterioration                                     |
| FACILITY                              | 40CFR 60-A.11                              | 37  | General provisions - compliance with standards and maintenance requirements |
| FACILITY                              | 40CFR 60-A.12                              | 38  | General provisions - Circumvention  |
| FACILITY                              | 40CFR 60-A.13                              | 39  | General provisions - Monitoring requirements                                |
| FACILITY                              | 40CFR 60-A.14                              | 40  | General provisions - Modification   |
| FACILITY                              | 40CFR 60-A.15                              | 41  | General provisions - Reconstruction   |
| FACILITY                              | 40CFR 60-A.4                               | 25  | General provisions - Address  |
| FACILITY                              | 40CFR 60-A.7(a)                            | 26  | Notification and Recordkeeping  |
| FACILITY                              | 40CFR 60-A.7(b)                            | 27  | Notification and Recordkeeping  |
| FACILITY                              | 40CFR 60-A.7(c)                            | 28  | Notification and Recordkeeping  |
| FACILITY                              | 40CFR 60-A.7(d)                            | 29  | Notification and Recordkeeping  |
| FACILITY                              | 40CFR 60-A.7(e)                            | 30  | Notification and Recordkeeping  |
| FACILITY                              | 40CFR 60-A.8(a)                            | 31  |   |
| FACILITY                              | 40CFR 60-A.8(b)                            | 32  |   |
| FACILITY                              | 40CFR 60-A.8(c)                            | 33  |   |
| FACILITY                              | 40CFR 60-A.8(d)                            | 34  |   |
| FACILITY                              | 40CFR 60-A.8(e)                            | 35  |   |
| FACILITY                              | 40CFR 60-A.9                               | 36  | General provisions - Availability of information                            |
| U-00001                               | 40CFR 60-Db                                | 2-58  | Steam generators over 100 million Btu per hour                              |
| U-00001                               | 40CFR 60-GG.332                            | 2-59  | Standard for Nitrogen   |



Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

|          |                             |   |   |
|----------|-----------------------------|---|---|
| FACILITY | 40CFR 68                    | 42  | Oxides for Gas Turbines > 100 mmBtu/hr  |
| FACILITY | 40CFR 72                    | 43  | Chemical accident prevention provisions   |
| FACILITY | 40CFR 82-F                  | 44  | Protection of Stratospheric Ozone - recycling and emissions reduction           |
| FACILITY | 6NYCRR 200.6                | 2-1   | Acceptable ambient air quality.   |
| FACILITY | 6NYCRR 200.7                | 2-4   |   |
| FACILITY | 6NYCRR 201-1.4              | 81  | Unavoidable noncompliance and violations  |
| FACILITY | 6NYCRR 201-1.7              | 2-5   |   |
| FACILITY | 6NYCRR 201-1.8              | 2-6   | Prohibition of reintroduction of collected contaminants to the air              |
| FACILITY | 6NYCRR 201-3.2 (a)          | 2-7   | Exempt Activities - Proof of eligibility  |
| FACILITY | 6NYCRR 201-3.3 (a)          | 2-8   | Trivial Activities - proof of eligibility                                       |
| FACILITY | 6NYCRR 201-5                | 2-79  | State Facility Permit General Provisions  |
| FACILITY | 6NYCRR 201-6                | 1, 45   | Title V Permits and the Associated Permit Conditions                            |
| U-00002  | 6NYCRR 201-6                | 1-2, 2-60, 2-61, 2-62, 2-63, 2-64, 2-65, 2-66, 2-67, 70, 71, 73, 74, 76, 77 | Title V Permits and the Associated Permit Conditions                            |
| U-00003  | 6NYCRR 201-6                | 2-70, 2-71, 2-72, 2-73, 2-74, 2-75, 2-76, 2-77, 2-78                        | Title V Permits and the Associated Permit Conditions                            |
| FACILITY | 6NYCRR 201-6.5 (a) (4)      | 2-9   |   |
| FACILITY | 6NYCRR 201-6.5 (a) (7)      | 2-2   |   |
| FACILITY | 6NYCRR 201-6.5 (a) (8)      | 2-10  |   |
| FACILITY | 6NYCRR 201-6.5 (c)          | 2   | Permit conditions for Recordkeeping and Reporting of Compliance Monitoring      |
| FACILITY | 6NYCRR 201-6.5 (c) (2)      | 3   | Permit conditions for Recordkeeping and Reporting of Compliance Monitoring      |
| FACILITY | 6NYCRR 201-6.5 (c) (3) (ii) | 4   | Permit conditions for Recordkeeping and Reporting of Compliance Monitoring      |
| FACILITY | 6NYCRR 201-6.5 (d) (5)      | 2-11  |   |
| FACILITY | 6NYCRR 201-6.5 (e)          | 5   |   |
| FACILITY | 6NYCRR 201-6.5 (f) (6)      | 2-12  |   |
| FACILITY | 6NYCRR 202-1.1              | 2-13  |   |
| FACILITY | 6NYCRR 202-2.1              | 6   | Emission Statements - Applicability   |
| FACILITY | 6NYCRR 202-2.5              | 7   | Emission Statements - record keeping requirements.                              |
| FACILITY | 6NYCRR 204-1.6              | 2-15  |   |
| FACILITY | 6NYCRR 204-2                | 2-16  | Authorized Account Representative for NOx Budget Sources                        |
| FACILITY | 6NYCRR 204-2.1              | 9   | Authorization and Responsibilities of the NOx Authorized Account Representative |
| FACILITY | 6NYCRR 204-2.1 (e)          | 2-17  | Authorization and Responsibilities of the NOx Authorized Account Representative |
| FACILITY | 6NYCRR 204-4.1              | 10, 11, 12, 2-18, 2-19  | Compliance  |



## Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

## Certification

|          |                        |                  |  |
|----------|------------------------|------------------|--|
| FACILITY | 6NYCRR 204-7.1         | 13               | Report<br>Submission of NOx<br>Allowance Transfers                                   |
| FACILITY | 6NYCRR 204-8.1         | 14, 15, 16, 2-20 |  |
| FACILITY | 6NYCRR 204-8.2         | 17, 18, 2-21     | Initial Certification and<br>Recertification<br>Procedures                           |
| FACILITY | 6NYCRR 204-8.2 (b) (2) | 2-22             | Initial Certification and<br>Recertification<br>Procedures                           |
| FACILITY | 6NYCRR 204-8.3         | 19               |  |
| FACILITY | 6NYCRR 204-8.4         | 20, 2-23         |  |
| FACILITY | 6NYCRR 204-8.5         | 2-24             | Recordkeeping and<br>Reporting   |
| FACILITY | 6NYCRR 204-8.7         | 21, 2-25         | Additional Requirements<br>to Provide Heat Input<br>Data for Allocations<br>Purposes |
| FACILITY | 6NYCRR 211.2           | 82               | General Prohibitions -<br>air pollution<br>prohibited.                               |
| FACILITY | 6NYCRR 211.3           | 2-14             | General Prohibitions -<br>visible emissions<br>limited                               |
| FACILITY | 6NYCRR 215             | 2-3              |  |
| FACILITY | 6NYCRR 225-1.2         | 22, 2-26         | Sulfur in Fuel<br>Limitations.   |
| FACILITY | 6NYCRR 225-1.2 (c)     | 23               | Sulfur-in-fuel<br>limitations - Table 1  |
| FACILITY | 6NYCRR 227-1.3 (a)     | 2-27             | Smoke Emission<br>Limitations.   |
| U-00001  | 6NYCRR 227-2.6 (a) (1) | 47               | Testing, monitoring, and<br>reporting requirements<br>for very large boilers.        |
| U-00002  | 6NYCRR 231-2           | 2-68             | New Source Review in<br>Nonattainment Areas and<br>Ozone Transport Region            |
| FACILITY | 6NYCRR 231-2.4         | 2-28             |  |
| FACILITY | 6NYCRR 237-1.4 (a)     | 2-80, 83         | Generators equal to or<br>greater than 25 MWe  |
| FACILITY | 6NYCRR 237-1.6 (a)     | 2-81, 2-82, 84   | Standard permit<br>requirements  |
| FACILITY | 6NYCRR 237-1.6 (c)     | 2-83, 85         | Nitrogen oxides<br>requirements  |
| FACILITY | 6NYCRR 237-1.6 (e)     | 86               | Recordkeeping and<br>reporting requirements  |
| FACILITY | 6NYCRR 237-1.6 (f)     | 2-84, 87         |  |
| FACILITY | 6NYCRR 237-1.6 (g)     | 88               | Effect on other<br>authorities   |
| FACILITY | 6NYCRR 237-2           | 2-85, 89         | NOx Athorized account<br>representative for NOx<br>budget sources                    |
| FACILITY | 6NYCRR 237-3.2         | 2-86             | Submission of NOx budget<br>permit applications.                                     |
| FACILITY | 6NYCRR 237-4.1         | 2-87, 90         | Compliance certification<br>report.  |
| FACILITY | 6NYCRR 237-7.1         | 91               | Submission of NOx<br>allowance transfers   |
| FACILITY | 6NYCRR 237-8           | 2-88, 92         | MONITORING AND<br>REPORTING  |
| U-00002  | 6NYCRR 238-1.4         | 97               |  |
| FACILITY | 6NYCRR 238-1.6 (a)     | 2-89             |  |
| U-00002  | 6NYCRR 238-1.6 (a)     | 98               |  |
| FACILITY | 6NYCRR 238-1.6 (c)     | 2-90             | Sulfur Dioxide<br>requirements   |
| U-00002  | 6NYCRR 238-1.6 (c)     | 99               | Sulfur Dioxide<br>requirements   |
| FACILITY | 6NYCRR 238-1.6 (e)     | 2-91             | Recordkeeping and<br>Reporting Requirements  |
| U-00002  | 6NYCRR 238-1.6 (e)     | 100              | Recordkeeping and<br>Reporting Requirements  |
| FACILITY | 6NYCRR 238-1.6 (f)     | 93               |  |



Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

|          |                    |            |  |
|----------|--------------------|------------|--|
| FACILITY | 6NYCRR 238-1.6 (g) | 2-92       | Effect on Other Authorities  |
| FACILITY | 6NYCRR 238-2.1     | 95         | Authorization/responsibilities of the authorized account representative  |
| FACILITY | 6NYCRR 238-3.2     | 2-93       | Submission of SO2 Budget permit applications   |
| FACILITY | 6NYCRR 238-4.1     | 2-94       | Compliance certification report  |
| U-00002  | 6NYCRR 238-4.1     | 101        | Compliance certification report  |
| FACILITY | 6NYCRR 238-7.1     | 96         | Submission of SO2 allowance transfers  |
| FACILITY | 6NYCRR 238-8       | 2-95       |  |
| U-00002  | 6NYCRR 238-8       | 102        |  |
| FACILITY | 6NYCRR 243-1.6 (a) | 2-29       | Permit Requirements - CAIR NOx Ozone Season Trading Program  |
| FACILITY | 6NYCRR 243-1.6 (b) | 2-30       | Monitoring Requirements - CAIR NOx Ozone Season Trading Program  |
| FACILITY | 6NYCRR 243-1.6 (c) | 2-31       | NOx Ozone Season Emission Requirements - CAIR NOx Ozone Season Trading Program   |
| FACILITY | 6NYCRR 243-1.6 (d) | 2-32       | Excess Emission Requirements - CAIR NOx Ozone Season Trading Program   |
| FACILITY | 6NYCRR 243-1.6 (e) | 2-33       | Recordkeeping and reporting requirements - CAIR NOx Ozone Season Trading Program   |
| FACILITY | 6NYCRR 243-2.1     | 2-34       | Authorization and responsibilities - CAIR Designated Representative Certificate of representation - CAIR Designated Representative |
| FACILITY | 6NYCRR 243-2.4     | 2-35       | General Requirements - Monitoring and Reporting  |
| FACILITY | 6NYCRR 243-8.1     | 2-36, 2-37 | Quarterly reports re: recordkeeping and reporting - Monitoring and Reporting   |
| FACILITY | 6NYCRR 243-8.5 (d) | 2-38       | Compliance certification re: recordkeeping and reporting - Monitoring and Reporting  |
| FACILITY | 6NYCRR 243-8.5 (e) | 2-39       | CAIR NOx Ozone Annual Trading Program General Provisions   |
| FACILITY | 6NYCRR 244-1       | 2-40, 2-41 | CAIR Designated Representative for CAIR NOx Sources  |
| FACILITY | 6NYCRR 244-2       | 2-42, 2-43 | Monitoring and Reporting CAIR NOx Allowances   |
| FACILITY | 6NYCRR 244-8       | 2-44, 2-45 | CAIR SO2 Trading Program General Provisions  |
| FACILITY | 6NYCRR 245-1       | 2-46, 2-47 | CAIR Designated Representative for CAIR SO2 Sources  |
| FACILITY | 6NYCRR 245-2       | 2-48       | Monitoring and Reporting for CAIR SO2 Trading Program  |
| FACILITY | 6NYCRR 245-8       | 2-49, 2-50 |  |

Applicability Discussion:



Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-301.

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6NYCRR Part 200-6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6NYCRR Part 200-7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6NYCRR Part 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6NYCRR Part 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6NYCRR Part 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6NYCRR Part 201-3.2(a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-3.3(a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-5



This regulation applies to those permit terms and conditions which are not federally enforceable. It specifies the applicability criteria for state facility permits, the information to be included in all state facility permit applications as well as the permit content, terms of permit issuance, and sets guidelines for modifying state facility permits and allowing for operational flexibility. For permitting purposes, this rule specifies the need to list all emission units except those that are exempt or trivial pursuant to Subpart 201-3 in the permit application and provide a description of the emission unit's processes and products. Finally, this rule also provides the Department the authority to include this and any other information that it deems necessary to identify applicable Federal standards, recordkeeping and reporting requirements, and establish terms and conditions that will ensure compliance with the national ambient air quality standards.

6NYCRR Part 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6NYCRR 201-6.5(a)(4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6NYCRR 201-6.5(a)(7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6NYCRR 201-6.5(a)(8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6NYCRR Part 201-6.5(c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.



6NYCRR Part 201-6.5(c)(2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6NYCRR Part 201-6.5(c)(3)(ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6NYCRR 201-6.5(d)(5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6NYCRR Part 201-6.5(e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6NYCRR 201-6.5(f)(6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6NYCRR Part 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6NYCRR Part 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

6NYCRR Part 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6NYCRR Part 211-.2

This regulation prohibits any emissions of air contaminants to the outdoor atmosphere which may be detrimental to human, plant or animal life or to property, or which unreasonably interferes with the comfortable enjoyment of life or property regardless of the existence of any specific air quality standard or emission limit.



6 NYCRR Part 211.3

This condition requires that the opacity (i.e., the degree to which emissions other than water reduce the transmission of light) of the emissions from any air contamination source be less than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent.

6 NYCRR Part 215

Prohibits open fires at industrial and commercial sites.

40 CFR Part 68.

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

**Facility Specific Requirements**

In addition to Title V, TBG COGEN FACILITY has been determined to be subject to the following regulations:

40CFR 52-A.21

This citation applies to facilities that are subject to Prevention of Significant Deterioration provisions; ie: facilities that are located in an attainment area and that emit pollutants which are listed in 40 CFR 52.21(b)(23)(i) .

40CFR 60-A.11

This regulation specifies the type of opacity monitoring requirements in relation to compliance with the standards and maintenance requirements.

40CFR 60-A.12

This regulation prohibits an owner or operator from concealing emissions in violation of applicable standards by any means.

40CFR 60-A.13

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

40CFR 60-A.14

This regulation defines the term modification and what is and is not considered to be a modification, for the purpose of rule applicability.



40CFR 60-A.15

This regulation defines the term reconstruction and what is and is not considered to be a reconstruction project, for the purpose of rule applicability.

40CFR 60-A.4

This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Enforcement and Compliance Assurance.

40CFR 60-A.7 (a)

This regulation requires any owner or operator subject to a New Source Performance Standard (NSPS) to furnish the Administrator with notification of the dates of: construction or reconstruction, initial startup, any physical or operational changes, commencement of performance testing for continuous monitors and anticipated date for opacity observations as required.

40CFR 60-A.7 (b)

This regulation requires the owner or operator to maintain records of the occurrence and duration of any startup, shutdown, or malfunction of the source or control equipment or continuous monitoring system.

40CFR 60-A.7 (c)

This requirement details the information to be submitted in excess emissions and monitoring systems performance reports which must be submitted at least semi-annually for sources with compliance monitoring systems.

40CFR 60-A.7 (d)

This condition specifies the required information and format for a summary report form and details when either a summary form and/or excess emissions reports are required.

40CFR 60-A.7 (f)

This condition specifies requirements for maintenance of files of all measurements, including continuous monitoring system (CMS), monitoring device, and performance testing measurements; all CMS performance evaluations; all CMS or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices for at least two years.

40CFR 60-A.8 (a)

This regulation contains the requirements for the completion date and reporting of Performance Testing (stack testing), at the facility. Within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup, the owner or operator of the facility must conduct performance test(s) and furnish a written report of the test results.

40CFR 60-A.8 (b)

This regulation contains the requirements for Performance test methods and procedures, to be used by the owner or operator, of the affected facility.

40CFR 60-A.8 (c)

This condition contains the requirements for operating conditions, of the emission source, during performance testing.



40CFR 60-A.8 (d)

This regulation contains the requirements for advance notification of Performance (stack) testing.

40CFR 60-A.8 (e)

This regulation requires the facility to provide appropriate sampling ports, safe platforms and utilities as necessary for Performance (stack) testing.

40CFR 60-A.9

This rule citation allows the public access to any information submitted to the EPA Administrator (or state contact), in conjunction with a project subject to this section of the regulation.

40CFR 60-Db

The affected facility to which this subpart applies is each steam generating unit that commences construction, modification, or reconstruction after June 19, 1984, and that has a heat input capacity from fuels combusted in the steam generating unit of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr)).

40CFR 60-GG.332

Standard for Oxides of Nitrogen, NO<sub>x</sub>.

40CFR 72

In order to reduce acid rain the the U.S. and Canada, Title IV of the Clean Air Act Amendments of 1990 requires the establishment of a program to reduce emissions of SO<sub>2</sub> and NO<sub>x</sub> (sulfur dioxide and oxides of nitrogen). Fossil fuel burning electric utility companies are a major source of these contaminants in the US. These sources where regulated in a phased approach. Phase I, which began in 1995, requires 110 of the higher-emitting utility plants in the eastern and Midwest states to meet intermediate SO<sub>2</sub> emission limitations. Phase II, which began in 2000, tightens the emission limitations and expands the coverage to most fossil fuel burning utilities. The utilities are given "allowances" which is a limited authorization to emit one ton of SO<sub>2</sub>. The utilities are required to limit SO<sub>2</sub> emissions to the number of allowances they hold. Some can benefit however by reducing their emissions and selling their excess allowances. Part 72 contains the means of implementing this portion of Title IV of the Clean Air Act.

6NYCRR 201-6.5 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6NYCRR 204-1.6

This condition requires the designated representative of the permittee to make submissions for the NO<sub>x</sub> Budget Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.



## 6NYCRR 204-2

Except as provided under section 204-2.2 of this Subpart, each NO<sub>x</sub> budget source, including all NO<sub>x</sub> budget units at the source, shall have one and only one NO<sub>x</sub> authorized account representative, with regard to all matters under the NO<sub>x</sub> Budget Trading Program concerning the source or any NO<sub>x</sub> budget unit at the source.

### 6NYCRR 204-2.1

This condition states the submission requirements for the NO<sub>x</sub> Budget Trading Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.

#### 6NYCRR 204-2.1 (e)

This condition states the submission requirements for the NO<sub>x</sub> Budget Trading Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.

#### 6NYCRR 204-4.1

This condition covers the compliance certification report requirements for the NO<sub>x</sub> Budget Program.

#### 6NYCRR 204-7.1

This condition lists the requirements for transfer of allowances in the NO<sub>x</sub> Budget Program.

#### 6NYCRR 204-8.1

This condition lists the general requirements for the NO<sub>x</sub> Budget trading program. They include, but are not limited to monitoring requirements, certification, record keeping and reporting.

#### 6NYCRR 204-8.2

This condition covers the procedures for initially certifying and recertifying the monitoring systems of the unit meet the requirements of the NO<sub>x</sub> Budget Program

#### 6NYCRR 204-8.2 (b) (2)

This condition covers the procedures for initially certifying and recertifying the monitoring systems of the unit meet the requirements of the NO<sub>x</sub> Budget Program

#### 6NYCRR 204-8.3

This condition states the requirements for data substitution during times when the monitoring systems to not meet applicable quality assurance requirements.

#### 6NYCRR 204-8.4

This condition lists the addresses where monitoring plans and their modifications, compliance certifications, recertifications, quarterly QA/QC reports and petitions for alternative monitoring shall be sent.

#### 6NYCRR 204-8.5

The NO<sub>x</sub> authorized account representative shall comply with all recordkeeping and reporting requirements in this section and with the requirements of section 204-2.1(e) of this Part.

#### 6NYCRR 204-8.7

This condition is a requirement for monitoring and reporting if a particular monitoring scenario is utilized.



6NYCRR 225-1.2

This regulation limits the amount of sulfur present in the fuel burned at the facility.

6NYCRR 225-1.2 (c)

The sulfur-in-fuel limitations for residual and distillate oil and for solid fuel are listed in Tables 1,2 and 3 or 6 NYCRR Part 225-1.2(c), (d) and (e).

6NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6NYCRR 227-2.6 (a) (1)

This regulation establishes the monitoring requirements for NO<sub>x</sub> RACT affected very large boilers (boilers with a heat input of greater than 250 mmBtu/hr).

6NYCRR 231-2

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

6NYCRR 231-2.4

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In the New York City metropolitan area, carbon monoxide is also a non-attainment contaminant. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

The permitting requirements for proposed source projects and new major facilities are set forth in section 231-2.4.

6NYCRR 237-1.4 (a)

This condition specifies that any emission unit or facility with a unit; that at any time on or after January 1, 1999, serves a generator with a nameplate capacity equal to or greater than 25 MWe, and sells any amount of electricity, is a NO<sub>x</sub> budget unit and subject to the requirements of NYCRR 237

6NYCRR 237-1.6 (a)

This condition requires the applicant to submit a NO<sub>x</sub> budget application for a permit and to operate in compliance with that permit.

6NYCRR 237-1.6 (c)

This subdivision outlines the standard requirements of the Acid Deposition Reduction NO<sub>x</sub> Budget Trading Program for oxides of nitrogen.

6NYCRR 237-1.6 (e)

This requires the owners and operators of the NO<sub>x</sub> budget source and each NO<sub>x</sub> budget unit at the source to keep pertinent documents at the site for a period of 5 years; and lists which documents are pertinent.

6NYCRR 237-1.6 (f)

This describes the liability issues regarding the requirements of the ADR NO<sub>x</sub> Budget Trading Program .

6NYCRR 237-1.6 (g)



This item states that no provision of the ADR NO<sub>x</sub> Budget Trading Program, a NO<sub>x</sub> budget permit application, or a NO<sub>x</sub> budget permit, will exempt or exclude the owners and operators from compliance with any other provisions of applicable State and federal law and regulations.

6NYCRR 237-2

This condition requires the permittee to select and authorize one person to manage, and represent the owners of any NO<sub>x</sub> budget unit; and specifies the responsibilities of this NO<sub>x</sub> authorized account representative

6NYCRR 237-3.2

For any source, with any NO<sub>x</sub> budget unit under section 237-1.4 of this Subpart the NO<sub>x</sub> authorized account representative shall submit a complete NO<sub>x</sub> budget permit application under section 237-3.3 of this Subpart covering such NO<sub>x</sub> budget unit to the department by the later of October 1, 2004 or 12 months before the date on which the NO<sub>x</sub> budget unit commences operation.

6NYCRR 237-4.1

This item specifies the requirements of the compliance certification report.

6NYCRR 237-7.1

This item specifies what information and actions are necessary in order to record the transfer of NO<sub>x</sub> allowances. t

6NYCRR 237-8

This item requires the owners and operators of a NO<sub>x</sub> budget unit to comply with the monitoring and reporting requirements of 6 NYCRR 237-8 and Subpart H of 40 CFR part 75; and allows NO<sub>x</sub> budget units which are also NO<sub>x</sub> budget units under 6 NYCRR Part 204 to be summarily referenced in order to demonstrate compliance with the requirements of this item.

6NYCRR 238-1.4

This citation identifies the facility as having one or more SO<sub>2</sub> budget units as defined by Federal Law, and as such is subject to the requirements of 6 NYCRR 238

6NYCRR 238-1.6 (a)

This condition requires the applicant to submit a SO<sub>2</sub> budget application for a permit and to operate in compliance with that permit.

6NYCRR 238-1.6 (c)

This Item requires the owners and operators of each SO<sub>2</sub> budget source and each SO<sub>2</sub> budget unit to hold SO<sub>2</sub> allowances available for compliance deductions under 6 NYCRR 238-6.5; and how such allowances will be managed.

6NYCRR 238-1.6 (e)

This item requires the owners and operators of the SO<sub>2</sub> budget source to keep on site at the source pertinent documents for a period of 5 years from the date the document is created.



6NYCRR 238-1.6 (f)

This item describes the liability issues regarding the requirements of the ADR SO<sub>2</sub> Budget Trading Program.

6NYCRR 238-1.6 (g)

This subdivision outlines the liability of an affected source as subject to other requirements.

6NYCRR 238-2.1

This condition requires the permittee to select and authorize one person to manage, and represent the owners of any SO<sub>2</sub> budget unit; and specifies the responsibilities of this SO<sub>2</sub> authorized account representative.

6NYCRR 238-3.2

For any source, with any SO<sub>2</sub> budget unit, the SO<sub>2</sub> authorized account representative shall submit a complete SO<sub>2</sub> budget permit application under section 238-3.3 of this Subpart covering such SO<sub>2</sub> budget unit to the department by the later of October 1, 2004 or 12 months before the date on which the SO<sub>2</sub> budget unit commences operation.

6NYCRR 238-4.1

This section lists all of the requirements for the submission of the compliance certification report.

6NYCRR 238-7.1

This item specifies what information and actions are necessary in order to record the transfer of SO<sub>2</sub> allowances.

6NYCRR 238-8

This condition requires the owner or operator of the facility to comply with the reporting and record keeping requirements of 40 CFR Part 75.

6NYCRR 243-1.6 (a)

This condition requires the facility to acknowledge that they are subject to this CAIR regulation and provide owner and contact information. It also requires them to update this information as it changes or provide supplemental information at the Departments request.

6NYCRR 243-1.6 (b)

This condition obligates the owners and operators of the facility to comply with the monitoring and reporting requirements of the CAIR regulations.

6NYCRR 243-1.6 (c)

This citation explains the general provisions of the Clean Air Interstate Rule (CAIR) NO<sub>x</sub> Ozone Season Trading Program. This ozone season NO<sub>x</sub> cap and trade program runs from May 1 through September 30 each year, starting in 2009. Each source shall hold a tonnage equivalent in CAIR NO<sub>x</sub> Ozone Season allowances that is not less than the total tons of NO<sub>x</sub> emissions for the ozone season.

6NYCRR 243-1.6 (d)

This citation for the Clean Air Interstate Rule (CAIR) NO<sub>x</sub> Ozone Season Trading Program explains some of the penalties that can be imposed on a CAIR NO<sub>x</sub> Ozone Season source that does not surrender enough CAIR NO<sub>x</sub> Ozone Season allowances to cover their NO<sub>x</sub> Ozone Season emissions.

6NYCRR 243-1.6 (e)

This citation for the Clean Air Interstate Rule (CAIR) NO<sub>x</sub> Ozone Season Trading Program requires that all reports



be submitted as required by this program, and that copies of all records and submissions made for this program be kept on site for at least five years.

6NYCRR 243-2.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that an CAIR NOx Ozone Season designated representative must be selected to submit, sign and certify each submission on behalf of the source for the this program.

6NYCRR 243-2.4

This condition describes the required elements of the "Certificate of Representation" for the CAIR program and the certifying language required with submissions to the Department.

6NYCRR 243-8.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that CAIR NOx Ozone Season Trading Program sources must install, certify and operate monitoring systems the meet the monitoring, recordkeeping, and reporting requirements in Subpart 6 NYCRR 243-8 and in Subpart H of 40 CFR Part 75.

6NYCRR 243-8.5 (d)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains the what requirements the quarterly reports must meet.

6NYCRR 243-8.5 (e)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains the compliance certification requirements the source must follow for each quarterly report.

6NYCRR 244-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) Nitrogen Oxide (NOx) Annual Trading Program. The control period for this annual NOx cap and trade program runs from January 1 to December 31 each year, starting in 2009. Each source shall hold a tonnage equivalent in CAIR NOx allowances that is not less than the total tons of NOx emissions for the control period.

6NYCRR 244-2

Each Clean Air Interstate Rule (CAIR) NOx source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR NOx Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate representative.

6NYCRR 244-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR NOx unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 244-8 and in 40 CFR Part 75, Subparts F and G. A certified NOx emission monitoring system must be used to measure NOx emissions. NOx emission reports must be certified and submitted quarterly.

6NYCRR 245-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) sulfur dioxide (SO2) Trading Program. The control period for this annual SO2 cap and trade program runs from January 1 to December 31, starting in the year 2010. Each source shall hold a tonnage equivalent in CAIR SO2 allowances that is not less than the total tons of SO2 emissions for the control period.

6NYCRR 245-2

Each Clean Air Interstate Rule (CAIR) SO2 source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR SO2 Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate representative.



## Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

6NYCRR 245-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR SO2 unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. A certified SO2 emission monitoring system must be used to measure SO2 emissions. SO2 emission reports must be certified and submitted quarterly..

**Compliance Certification**

Summary of monitoring activities at TBG COGEN FACILITY:

| Location<br>Facility/EU/EP/Process/ES | Cond No. | Type of Monitoring                                       |
|---------------------------------------|----------|--|
| FACILITY                              | 24       | work practice involving<br>specific operations           |
| FACILITY                              | 2-51     | work practice involving<br>specific operations           |
| U-00001                               | 48       | continuous emission monitoring<br>(cem)                  |
| U-00001                               | 49       | record keeping/maintenance<br>procedures                 |
| U-00001                               | 50       | intermittent emission testing                            |
| U-00001                               | 51       | intermittent emission testing                            |
| U-00001                               | 52       | intermittent emission testing                            |
| U-00001                               | 2-52     | continuous emission monitoring<br>(cem)                  |
| U-00001                               | 2-53     | intermittent emission testing                            |
| U-00001                               | 2-54     | continuous emission monitoring<br>(cem)                  |
| U-00001                               | 2-55     | intermittent emission testing                            |
| U-00001                               | 2-56     | intermittent emission testing                            |
| U-00001                               | 2-57     | record keeping/maintenance<br>procedures                 |
| U-00001/-/DBG/000DB                   | 55       | intermittent emission testing                            |
| U-00001/-/GTG/000GT                   | 56       | intermittent emission testing                            |
| U-00001/-/GTG/000GT                   | 57       | intermittent emission testing                            |
| U-00001/-/GTG/000GT                   | 58       | continuous emission monitoring<br>(cem)                  |
| U-00001/-/GTM                         | 59       | continuous emission monitoring<br>(cem)                  |
| U-00001/-/GTM                         | 60       | intermittent emission testing                            |
| U-00001/-/GTO/000GT                   | 61       | intermittent emission testing                            |
| U-00001/-/GTO/000GT                   | 62       | continuous emission monitoring<br>(cem)                  |
| U-00001/-/GTO/000GT                   | 63       | intermittent emission testing                            |
| U-00001/-/TGB                         | 64       | intermittent emission testing                            |
| U-00001/-/TGB                         | 65       | continuous emission monitoring<br>(cem)                  |
| U-00001/-/TGB                         | 66       | intermittent emission testing                            |
| U-00001/-/TOB                         | 67       | intermittent emission testing                            |
| U-00001/-/TOB                         | 68       | intermittent emission testing                            |
| U-00001/-/TOB/000GT                   | 69       | continuous emission monitoring<br>(cem)                  |
| U-00002                               | 2-69     | intermittent emission testing                            |
| U-00002                               | 79       | intermittent emission testing                            |
| U-00001                               | 2-58     | record keeping/maintenance<br>procedures                 |
| U-00001                               | 2-59     | continuous emission monitoring<br>(cem)                  |
| FACILITY                              | 2-79     | record keeping/maintenance<br>procedures                 |
| U-00002                               | 1-2      | continuous emission monitoring<br>(cem)                  |
| U-00002                               | 2-60     | continuous emission monitoring<br>(cem)                  |
| U-00002                               | 2-61     | monitoring of process or<br>control device parameters as |



## Permit Review Report

Permit ID: 1-2824-00947/00004

Renewal Number: 1

Modification Number: 2 05/20/2008

|          |      |   |
|----------|------|---|
| U-00002  | 2-62 | surrogate<br>continuous emission monitoring<br>(cem)                  |
| U-00002  | 2-63 | monitoring of process or<br>control device parameters as<br>surrogate |
| U-00002  | 2-64 | continuous emission monitoring<br>(cem)                               |
| U-00002  | 2-65 | continuous emission monitoring<br>(cem)                               |
| U-00002  | 2-66 | continuous emission monitoring<br>(cem)                               |
| U-00002  | 2-67 | continuous emission monitoring<br>(cem)                               |
| U-00002  | 70   | continuous emission monitoring<br>(cem)                               |
| U-00002  | 71   | continuous emission monitoring<br>(cem)                               |
| U-00002  | 73   | monitoring of process or<br>control device parameters as<br>surrogate |
| U-00002  | 74   | continuous emission monitoring<br>(cem)                               |
| U-00002  | 76   | continuous emission monitoring<br>(cem)                               |
| U-00002  | 77   | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-70 | monitoring of process or<br>control device parameters as<br>surrogate |
| U-00003  | 2-71 | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-72 | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-73 | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-74 | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-75 | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-76 | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-77 | continuous emission monitoring<br>(cem)                               |
| U-00003  | 2-78 | monitoring of process or<br>control device parameters as<br>surrogate |
| FACILITY | 4    | record keeping/maintenance<br>procedures                              |
| FACILITY | 5    | record keeping/maintenance<br>procedures                              |
| FACILITY | 6    | record keeping/maintenance<br>procedures                              |
| FACILITY | 12   | record keeping/maintenance<br>procedures                              |
| FACILITY | 2-19 | record keeping/maintenance<br>procedures                              |
| FACILITY | 18   | record keeping/maintenance<br>procedures                              |
| FACILITY | 2-21 | record keeping/maintenance<br>procedures                              |
| FACILITY | 20   | record keeping/maintenance<br>procedures                              |
| FACILITY | 2-23 | record keeping/maintenance<br>procedures                              |
| FACILITY | 2-24 | record keeping/maintenance<br>procedures                              |
| FACILITY | 21   | record keeping/maintenance<br>procedures                              |
| FACILITY | 2-25 | record keeping/maintenance<br>procedures                              |
| FACILITY | 22   | work practice involving<br>specific operations                        |



**Permit Review Report**

**Permit ID: 1-2824-00947/00004**

**Renewal Number: 1**

**Modification Number: 2 05/20/2008**

|          |      |   |
|----------|------|---|
| FACILITY | 2-26 | work practice involving specific operations                     |
| FACILITY | 23   | work practice involving specific operations                     |
| FACILITY | 2-27 | monitoring of process or control device parameters as surrogate |
| U-00002  | 2-68 | continuous emission monitoring (cem)                            |
| FACILITY | 2-83 | record keeping/maintenance procedures                           |
| FACILITY | 85   | record keeping/maintenance procedures                           |
| FACILITY | 2-87 | record keeping/maintenance procedures                           |
| FACILITY | 90   | record keeping/maintenance procedures                           |
| FACILITY | 2-88 | record keeping/maintenance procedures                           |
| FACILITY | 92   | record keeping/maintenance procedures                           |
| FACILITY | 2-90 | record keeping/maintenance procedures                           |
| U-00002  | 99   | record keeping/maintenance procedures                           |
| FACILITY | 2-91 | record keeping/maintenance procedures                           |
| U-00002  | 100  | record keeping/maintenance procedures                           |
| FACILITY | 2-94 | record keeping/maintenance procedures                           |
| U-00002  | 101  | record keeping/maintenance procedures                           |
| U-00002  | 102  | record keeping/maintenance procedures                           |
| FACILITY | 2-44 | record keeping/maintenance procedures                           |
| FACILITY | 2-45 | record keeping/maintenance procedures                           |
| FACILITY | 2-50 | record keeping/maintenance procedures                           |

**Basis for Monitoring**

Continuous emission monitors are required to ascertain compliance with limits for regulated contaminants in current Title Five, TV, Permit.

New York State Department of Environmental Conservation



Permit ID: 1-2824-00947/00004

Permit Review Report  
Renewal Number: 1

Modification Number: 2 05/20/2008