

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

**Facility Identification Data**

Name: PORT JEFFERSON POWER STATION  
Address: BEACH ST  
PORT JEFFERSON, NY 11777

**Owner/Firm**

Name: KEYSpan ENERGY CORP  
Address: 175 EAST OLD COUNTRY RD  
HICKSVILLE, NY 11801, USA  
Owner Classification: Corporation/Partnership

**Permit Contacts**

Division of Environmental Permits:  
Name: SUSAN ACKERMAN  
Address: NYSDEC - SUNY @ STONY BROOK  
50 CIRCLE RD  
STONY BROOK, NY 11790-3409

Division of Air Resources:  
Name: HUMBERTO ROMAN  
Address: NYSDEC  
BUILDING 40 SUNY  
STONY BROOK, NY 11790  
Phone:6314440211

Air Permitting Contact:  
Name: ROBERT D TEETZ  
Address: KEYSpan  
175 EAST OLD COUNTRY RD  
HICKSVILLE, NY 11801-4280  
Phone:5165452577

**Permit Description**

**Introduction**

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

**Summary Description of Proposed Project**

**New York State Department of Environmental Conservation**



**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1    11/17/2006**

This is a minor Title V modification. The applicant has requested a reduction of the current NOx cap from 2199 tons per year to 2178.7 tons per year. In addition, a small boiler ( nominal 800 HP) will be installed on either a permanent or temporary basis to supply heat to the facility when the main boilers are out-of-service. Emissions from this source are capped at 2.5 tons per year. This facility consists of two (2) 45 MWe (nominal) turbine/generator boiler sets operating on #1, #2, or #6 residual oil, two (2) 185 MWe (nominal) turbine/generator boiler sets operating on #1, #2 or #6 fuel oils and/or natural gas. In addition to #1, #2, and #6 fuel oil and natural gas, these boilers burn waste oil generated on site for energy recovery, and incinerate citrosolv, a boiler cleaning solution, following boiler chemical cleaning. There are four main tanks used for storing #6 fuel oil, ranging from 336,000 to 13,000,000 gallons. There are numerous smaller tanks used for storing distillate, lubrication and/or di-electrical oils. A complete list of tanks is included in the documentation section of this application. In addition, a 15 MWe black start combustion turbine is maintained on site to meet load demand and emergency power requirements.

**Attainment Status**

PORT JEFFERSON POWER STATION is located in the town of BROOKHAVEN in the county of SUFFOLK.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

<b>Criteria Pollutant</b>	<b>Attainment Status</b>
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

\* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

\*\* NOx has a separate ambient air quality standard in addition to being an ozone precursor

**Facility Description**

This is a minor Title V modification. The applicant has requested a reduction of the current NOx cap from 2199 tons per year to 2178.7 tons per year. This facility consists of two (2) 45 MWe (nominal) turbine/generator boiler sets operating on #1, #2, or #6 residual oil, two (2) 185 MWe (nominal)



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1    11/17/2006**

turbine/generator boiler sets operating on #1, #2 or #6 fuel oils and/or natural gas. In addition to #1, #2, and #6 fuel oil and natural gas, these boilers burn waste oil generated on site for energy recovery, and incinerate citrosolv, a boiler cleaning solution, following boiler chemical cleaning. There are four main tanks used for storing #6 fuel oil, ranging from 336,000 to 13,000,000 gallons. There are numerous smaller tanks used for storing distillate, lubrication and/or di-electrical oils. A complete list of tanks is included in the documentation section of this application. In addition, a 15 MWe black start combustion turbine is maintained on site to meet load demand and emergency power requirements.

**Permit Structure and Description of Operations**

The Title V permit for PORT JEFFERSON POWER STATION is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process.

A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device.

[NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion        -        devices which burn fuel to generate heat, steam or power
- incinerator       -        devices which burn waste material for disposal
- control           -        emission control devices
- process           -        any device or contrivance which may emit air contaminants that is not included in the above categories.

PORT JEFFERSON POWER STATION is defined by the following emission unit(s):

Emission unit UHBOO1 - This emission unit is a small boiler( nominal 800 hp ) installed on either a permanent or temporary basis to supply heat to the facility when the main boilers are out of service. Specifics of the boiler design have not been finalized. Consequently, emission point and emission source details are not yet available.

It is further defined by the following process(es):

Process: HB1 is located at Building BLR BLD1/2 - This process involves the operation of an 800 hp steam boiler firing natural gas. Hours per day, days per year, quantity per hour and quantity per year values will be monitored to insure NOx emissions do not exceed 2.5 ton per year.

Emission unit U00002 - This unit is a 185 MWe turbine/generator boiler set firing #1, #2 or #6 fuel oil and/or natural gas. Exhaust is through emission point 00002.



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1    11/17/2006**

Emission unit U00002 is associated with the following emission points (EP):  
00002

It is further defined by the following process(es):

Process: P13 is located at GROUND FLOOR, Building BLR BLD #3 - This process is the combustion of #6 residual oil in a tangentially fired steam electric boiler. In order to improve boiler operation, a fuel additive is mixed into the residual oil prior to combustion.

Process: P14 is located at GROUND FLOOR, Building BLR BLD #3 - This process is the combustion of #1 distillate oil in a tangentially fired steam electric boiler. When natural gas is unavailable, this fuel is used during the initial start up of the boiler

Process: P15 is located at GROUND FLOOR, Building BLR BLD #3 - This process is the combustion of #2 distillate oil in a tangentially fired steam electric boiler. When natural gas is unavailable, this fuel is used during the initial start up of the boiler

Process: P16 is located at GROUND FLOOR, Building BLR BLD #3 - This process is the combustion of pipeline natural gas in a tangentially fired steam electric boiler. Electrostatic precipitator not used when firing natural gas.

Process: P17 is located at GROUND FLOOR, Building BLR BLD #3 - This process is the co firing of waste oil in a tangentially fired steam electric boiler. This fuel is only used in combination with pipeline natural gas or #6 residual oil.

Process: P18 is located at GROUND FLOOR, Building BLR BLD #3 - This process is the incineration, by co firing with a primary fuel, of boiler chemical cleaning solutions. Following a chemical cleaning of the water side of the boilers tubes with an acidic solution, the spent material is evaporated in an adjacent boiler operating at nominal full load.

Process: PS2 is located at GROUND FLOOR, Building BLR BLD #3 - THIS PROCESS INVOLVES THE CO FIRING OF NATURAL GAS AND HI SULFUR #6 FUEL OIL IN A RATIO NOT TO EXCEED THE HEAT INPUT EQUIVALENT PERMISSIBLE SO2 EMISSION RATE.

Emission unit U00001 - This unit consists of two 45 MWe turbine/generator boiler sets firing #6 residual fuel oil. Exhaust is through a stack common to both boiler 1 ES001 & boiler 2 ES002 (emission point 00001). The stack has been removed because of safety concerns. A replacement stack has not yet been built. The Commissioner will be notified prior to construction of a new stack.

Emission unit U00001 is associated with the following emission points (EP):  
00001

It is further defined by the following process(es):

Process: P01 is located at GROUND FLOOR, Building BLR BLD1/2 - This process is the combustion of #6 residual oil in a tangentially fired steam electric boiler. In order to improve boiler operation, a fuel additive is mixed into the residual oil prior to combustion.

Process: P02 is located at GROUND FLOOR, Building BLR BLD1/2 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A TANGENTIALLY FIRED STEAM ELECTRIC BOILER. THIS FUEL IS USED PRIMARILY DURING THE INITIAL START UP OF THE BOILER.

Process: P03 is located at GROUND FLOOR, Building BLR BLD1/2 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A TANGENTIALLY FIRED STEAM ELECTRIC BOILER. THIS FUEL IS USED PRIMARILY DURING THE INITIAL START UP OF THE BOILER.

Emission unit U00003 - This unit is a 185 MWe turbine/generator boiler set firing #1, #2 and #6 fuel oil and/or natural gas. Exhaust is through emission point 00003.

Emission unit U00003 is associated with the following emission points (EP):

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

00003

It is further defined by the following process(es):

Process: P19 is located at GROUND FLOOR, Building BLR BLD #4 - This process is the combustion of #6 residual oil in a tangentially fired steam electric boiler. In order to improve boiler operation, a fuel additive is mixed into the residual oil prior to combustion.

Process: P20 is located at GROUND FLOOR, Building BLR BLD #4 - This process is the combustion of #1 distillate oil in a tangentially fired steam electric boiler. When natural gas is unavailable, this fuel is used during the initial start up of the boiler.

Process: P21 is located at GROUND FLOOR, Building BLR BLD #4 - This process is the combustion of #2 distillate oil in a tangentially fired steam electric boiler. When natural gas is unavailable, this fuel is used during the initial start up of the boiler.

Process: P22 is located at GROUND FLOOR, Building BLR BLD #4 - This process is the combustion of pipeline natural gas in a tangentially fired steam electric boiler. Electrostatic precipitator not used when firing natural gas.

Process: P23 is located at GROUND FLOOR, Building BLR BLD #4 - This process is the cofiring of waste oil in a tangentially fired steam electric boiler. This fuel is only used in combination with pipeline natural gas or #6 residual oil.

Process: P24 is located at GROUND FLOOR, Building BLR BLD #4 - This process is the incineration, by cofiring with a primary fuel, of boiler chemical cleaning solutions. Following a chemical cleaning of the water side of the boilers tubes with an acidic solution, the spent material is evaporated in an adjacent boiler operating at nominal full load

Process: PS3 is located at GROUND FLOOR, Building BLR BLD #4 - THIS PROCESS INVOLVES THE CO FIRING OF NATURAL GAS AND HI SULFUR #6 FUEL OIL IN A RATIO NOT TO EXCEED THE HEAT INPUT EQUIVALENT PERMISSIBLE SO2 EMISSION RATE.

Emission unit UGT001 - This unit is a "black start" combustion turbine designed to provide sufficient power to bring the entire power station back on line following a catastrophic system collapse. In addition the unit is used to supply peak generation capacity, as required to support the Long Island electric distribution system.

Emission unit UGT001 is associated with the following emission points (EP):

GT001

It is further defined by the following process(es):

Process: P28 is located at GROUND FLOOR, Building CT1 - This process is the combustion of #1 distillate oil in a combustion turbine. In order to improve combustion a fuel additive may be mixed with the distillate oil prior to combustion. In addition, when fuel oil is stored for extended periods a biocide may be added to prevent fouling.

Process: P29 is located at GROUND FLOOR, Building CT1 - This process is the combustion of #2 distillate oil in a combustion turbine. In order to improve combustion a fuel additive may be mixed with the distillate oil prior to combustion. In addition, when fuel oil is stored for extended periods a biocide may be added to prevent fouling.

Emission unit UGT0S1 - This unit is a 430 hp diesel engine used to start the "black start" combustion turbine, designated emission unit UGT001. This unit only operates during start up of the combustion turbine, generally less than 15 minutes per event.

Emission unit UGT0S1 is associated with the following emission points (EP):

GT0S1



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1    11/17/2006**

It is further defined by the following process(es):

Process: P91 is located at GROUND FLOOR, Building CT1 - This process is the combustion of #1 distillate oil in a diesel engine. This engine is used to start the associated combustion turbine. During each start up the engine operates for less than 15 minutes.

Process: P92 is located at GROUND FLOOR, Building CT1 - This process is the combustion of #2 distillate oil in a diesel engine. This engine is used to start the associated combustion turbine. During each start up the engine operates for less than 15 minutes.

**Title V/Major Source Status**

PORT JEFFERSON POWER STATION is subject to Title V requirements. This determination is based on the following information:

Facility is in compliance with TV Permit conditions. Facility is a major for different contaminants. Continuous Monitors are installed to demonstrate compliance with Oxides of Nitrogen emissions and Opacity .

**Program Applicability**

The following chart summarizes the applicability of PORT JEFFERSON POWER STATION with regards to the principal air pollution regulatory programs:

<b>Regulatory Program</b>	<b>Applicability</b>
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	NO
TITLE IV	YES
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

NOTES:

## New York State Department of Environmental Conservation

### Permit Review Report

Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1



11/17/2006

**PSD**                    Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**NSR**                    New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**NESHAP**            National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's)

**MACT**                Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

**NSPS**                New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

**Title IV**              Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

**Title VI**              Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

**RACT**                Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

**SIP**                    State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1    11/17/2006**

individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

**Compliance Status**

Facility is out of compliance with specific requirements (see attached compliance schedule)  
Compliance Schedule:

<b>Location</b>	<b>Short Description</b>	<b>Regulation</b>
<b>Facility/EU/EP/Process/ES</b>		
FACILITY	Smoke Emission Limitations.	6NYCRR 227-1.3
U-00001	Smoke Emission Limitations.	6NYCRR 227-1.3 (a)
U-00002	Smoke Emission Limitations.	6NYCRR 227-1.3 (a)
U-00003	Smoke Emission Limitations.	6NYCRR 227-1.3 (a)

**Compliance Discussion:**

PORT JEFFERSON POWER STATION is in violations of the following requirement(s): KeySpan signed a Consent Order with the NYSDEC for opacity violations. Facility is in compliance with the terms of Consent Order D1-9000-97-08.

**SIC Codes**

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

<b>SIC Code</b>	<b>Description</b>
4911	ELECTRIC SERVICES

**SCC Codes**

SCC or Source Classification Code is a code developed and used by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

<b>SCC Code</b>	<b>Description</b>
1-01-005-01	EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION ELECTRIC UTILITY BOILER - DISTILLATE OIL Grades 1 and 2 Oil
1-01-013-01	EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION ELECTRIC UTILITY BOILER - LIQUID WASTE Specify Waste Material in Comments



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 1-4722-00107/00025 Renewal Number: 1 Modification Number: 1 11/17/2006

- 1-01-013-02 EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION
ELECTRIC UTILITY BOILER - LIQUID WASTE
Waste Oil
1-01-006-04 EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION
ELECTRIC UTILITY BOILER - NATURAL GAS
Tangentially Fired Units
1-01-004-04 EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION
ELECTRIC UTILITY BOILER - RESIDUAL OIL
Grade 6 Oil: Tangential Firing
1-02-006-03 EXTERNAL COMBUSTION BOILERS - INDUSTRIAL
INDUSTRIAL BOILER - NATURAL GAS
Less Than 10 MMBtu/Hr
2-01-009-01 INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION
ELECTRIC UTILITY IC ENGINE - KEROSENE/NAPHTHA (JET
FUEL)
Turbine
2-01-001-02 INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION
ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - DISTILLATE OIL
(DIESEL)
Reciprocating
2-01-001-01 INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION
ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - DISTILLATE OIL
(DIESEL)
Turbine
2-02-009-02 INTERNAL COMBUSTION ENGINES - INDUSTRIAL
INDUSTRIAL INTERNAL COMBUSTION ENGINE - KEROSENE/NAPHTHA
(JET FUEL)
Reciprocating

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Series code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Table with 3 columns: Cas No., Contaminant Name, PTE. Sub-headers: lbs/yr, Range.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 1-4722-00107/00025 Renewal Number: 1

Modification Number: 1



11/17/2006

000123-91-1	1,4-DIETHYLENE DIOXIDE (HAP)	> 0 but < 10 tpy
007440-38-2	ARSENIC (HAP)	> 0 but < 10 tpy
007440-43-9	CADMIUM (HAP)	> 0 but < 10 tpy
000630-08-0	CARBON MONOXIDE	>= 250 tpy
007440-47-3	CHROMIUM (HAP)	> 0 but < 10 tpy
007440-50-8	COPPER	> 0 but < 2.5 tpy
0NY100-00-0	HAP	>= 10 tpy but < 25 tpy
007439-89-6	IRON	>= 10 tpy but < 25 tpy
007439-92-1	LEAD (HAP)	> 0 but < 10 tpy
007439-97-6	MERCURY (HAP)	> 0 but < 10 tpy
007440-02-0	NICKEL METAL AND INSOLUBLE COMPOUNDS (HAP)	> 0 but < 10 tpy
0NY210-00-0	OXIDES OF NITROGEN	>= 250 tpy
0NY075-00-0	PARTICULATES	>= 250 tpy
0NY075-00-5	PM-10	>= 250 tpy
007446-09-5	SULFUR DIOXIDE	>= 250 tpy
0NY998-00-0	VOC	>= 250 tpy
007440-66-6	ZINC	> 0 but < 2.5 tpy

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

**Item B:            Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

**Item C:            Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)**

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Item D:            Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)**

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

**Item E:            Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**Item F:            Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**Item G:            Cessation or Reduction of Permitted Activity Not a Defense - 6NYCRR Part 201-6.5(a)(5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

have been necessary in order to maintain compliance with the conditions of this permit.

**Item H:            Property Rights - 6 NYCRR Part 201-6.5(a)(6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

**Item I:            Severability - 6 NYCRR Part 201-6.5(a)(9)**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item J:            Permit Shield - 6 NYCRR Part 201-6.5(g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i.            The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii.          The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii.        The applicable requirements of Title IV of the Act;
- iv.         The ability of the Department or the Administrator to obtain

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item K:            Reopening for Cause - 6 NYCRR Part 201-6.5(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i.            If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii.           The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii.           The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv.           If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item L:            Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring,

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item M:                    Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A:                    General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 1-4722-00107/00025 Renewal Number: 1

Modification Number: 1



11/17/2006

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Short Description	Condition
FACILITY	ECL 19-0301	Powers and Duties of the Department with respect to air pollution control	55
FACILITY	40CFR 68	Chemical accident prevention provisions	21
FACILITY	40CFR 72	Permits regulation	41
FACILITY	40CFR 82	Protection of Stratospheric Ozone	42
FACILITY	40CFR 82-F	Protection of Stratospheric Ozone - recycling and emissions reduction	22
FACILITY	6NYCRR 200.6	Acceptable ambient air quality.	1
FACILITY	6NYCRR 200.7	Maintenance of equipment.	10
FACILITY	6NYCRR 201-1.4	Unavoidable noncompliance and violations	56
FACILITY	6NYCRR 201-1.7	Recycling and Salvage	11
FACILITY	6NYCRR 201-1.8	Prohibition of reintroduction of collected contaminants to the air	12
FACILITY	6NYCRR 201-3.2(a)	Exempt Activities - Proof of eligibility	13
FACILITY	6NYCRR 201-3.3(a)	Trivial Activities - proof of eligibility	14
FACILITY	6NYCRR 201-6	Title V Permits and the Associated Permit Conditions	23, 43, 44
FACILITY	6NYCRR 201-6.5(a) (4)	General conditions	15
FACILITY	6NYCRR 201-6.5(a) (7)	General conditions	
Fees 2			
FACILITY	6NYCRR 201-6.5(a) (8)	General conditions	16
FACILITY	6NYCRR 201-6.5(c)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	3
FACILITY	6NYCRR 201-6.5(c) (2)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	4
FACILITY	6NYCRR 201-6.5(c) (3) (ii)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	5
FACILITY	6NYCRR 201-6.5(d) (5)	Compliance schedules	17
FACILITY	6NYCRR 201-6.5(e)	Compliance Certification	6
FACILITY	6NYCRR 201-6.5(f) (6)	Off Permit Changes	18
FACILITY	6NYCRR 201-7	Federally Enforceable Emissions Caps	1-1, 1-3, 1-4
U-HBO01	6NYCRR 201-7	Federally Enforceable Emissions Caps	1-20
FACILITY	6NYCRR 202-1.1	Required emissions tests.	19
FACILITY	6NYCRR 202-2.1	Emission Statements - Applicability	7
FACILITY	6NYCRR 202-2.5	Emission Statements -	8

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1**

**Modification Number: 1**

**11/17/2006**



		record keeping requirements.	
FACILITY	6NYCRR 204-1.6	Standard Requirements	24, 25
FACILITY	6NYCRR 204-2.1	Authorization and Responsibilities of the NOx Authorized Account Representative	26
FACILITY	6NYCRR 204-4.1	Compliance Certification Report	27, 28, 29
FACILITY	6NYCRR 204-7.1	Submission of NOx Allowance Transfers	30
FACILITY	6NYCRR 204-8.1	General Requirements	31, 32
FACILITY	6NYCRR 204-8.2	Initial Certification and Recertification Procedures	33, 34
FACILITY	6NYCRR 204-8.3	Out of Control Periods	35
FACILITY	6NYCRR 204-8.4	Notifications	36
FACILITY	6NYCRR 204-8.7	Additional Requirements to Provide Heat Input Data for Allocations Purposes	37
FACILITY	6NYCRR 211.2	General Prohibitions - air pollution prohibited.	58
FACILITY	6NYCRR 211.3	General Prohibitions - visible emissions limited	20
FACILITY	6NYCRR 215	Open Fires	9
U-00001/00001	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-5, 82
U-00002/00002/P13	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-8, 83
U-00002/00002/P14	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-9, 84
U-00002/00002/P15	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	85
U-00003/00003/P19	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-12, 86
U-00003/00003/P20	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-13, 87
U-00003/00003/P21	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-14, 88
U-GT001/GT001/P28	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-16, 89
U-GT001/GT001/P29	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-17, 90
U-GT0S1/GT0S1/P91	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-18, 91
U-GT0S1/GT0S1/P92	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	1-19, 92
U-00002/00002/P17	6NYCRR 225-2.3	Eligibility to burn waste fuel A.	1-10, 50



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 1-4722-00107/00025 Renewal Number: 1 Modification Number: 1 11/17/2006

U-00003/00003/P23	6NYCRR 225-2.3	Eligibility to burn waste fuel A.	1-15, 54
U-00002	6NYCRR 227.2 (b) (1)	Particulate emissions.	48
U-00003	6NYCRR 227.2 (b) (1)	Particulate emissions.	52
FACILITY	6NYCRR 227-1.3	Smoke Emission Limitations.	38
FACILITY	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	39
U-00001	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	45
U-00001/00001	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	1-6, 46
U-00002	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	47
U-00002/00002	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	1-7, 49
U-00003	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	51
U-00003/00003	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	1-11, 53
FACILITY	6NYCRR 227-2	Reasonably available control technology for NOx	1-2, 40
FACILITY	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	1-1
U-HBO01	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	1-20
FACILITY	6NYCRR 237-1.4 (a)	Generators equal to or greater than 25 MWe	59
FACILITY	6NYCRR 237-1.6 (a)	Standard permit requirements	60, 61
FACILITY	6NYCRR 237-1.6 (c)	Nitrogen oxides requirements	62
FACILITY	6NYCRR 237-1.6 (e)	Recordkeeping and reporting requirements	63
FACILITY	6NYCRR 237-1.6 (f)	Liability	64
FACILITY	6NYCRR 237-1.6 (g)	Effect on other authorities	65
FACILITY	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	66
FACILITY	6NYCRR 237-4.1	Compliance certification report.	67
FACILITY	6NYCRR 237-7.1	Submission of NOx allowance transfers	68
FACILITY	6NYCRR 237-8	MONITORING AND REPORTING	69
FACILITY	6NYCRR 238-1.4	Applicability	70
FACILITY	6NYCRR 238-1.6 (a)	Permit Requirements	71
FACILITY	6NYCRR 238-1.6 (c)	Sulfur Dioxide requirements	72
FACILITY	6NYCRR 238-1.6 (e)	Recordkeeping and Reporting Requirements	73
FACILITY	6NYCRR 238-1.6 (f)	Liability	
FACILITY	6NYCRR 238-1.6 (g)	Effect on Other Authorities	75
FACILITY	6NYCRR 238-2.1	Authorization/responsibilities of the authorized account representative	76
FACILITY	6NYCRR 238-4.1	Compliance certification	77

74



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1    11/17/2006**

FACILITY	6NYCRR 238-7.1	report Submission of SO2 allowance transfers	78
FACILITY	6NYCRR 238-8	Monitoring and Reporting	79

**Applicability Discussion:**

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-301.

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6NYCRR Part 200-.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6NYCRR Part 200-.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6NYCRR Part 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6NYCRR Part 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6NYCRR Part 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6NYCRR Part 201-3.2(a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

requirements, regulations, or law.

6NYCRR Part 201-3.3(a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6NYCRR 201-6.5(a)(4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6NYCRR 201-6.5(a)(7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6NYCRR 201-6.5(a)(8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6NYCRR Part 201-6.5(c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses;

## New York State Department of Environmental Conservation

### Permit Review Report

Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1



11/17/2006

analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

#### 6NYCRR Part 201-6.5(c)(2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

#### 6NYCRR Part 201-6.5(c)(3)(ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

#### 6NYCRR 201-6.5(d)(5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

#### 6NYCRR Part 201-6.5(e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

#### 6NYCRR 201-6.5(f)(6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

#### 6NYCRR Part 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

#### 6NYCRR Part 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

6NYCRR Part 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6NYCRR Part 211-.2

This regulation prohibits any emissions of air contaminants to the outdoor atmosphere which may be detrimental to human, plant or animal life or to property, or which unreasonably interferes with the comfortable enjoyment of life or property regardless of the existence of any specific air quality standard or emission limit.

6 NYCRR Part 211.3

This condition requires that the opacity (i.e., the degree to which emissions other than water reduce the transmission of light) of the emissions from any air contamination source be less than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent.

6 NYCRR Part 215

Prohibits open fires at industrial and commercial sites.

40 CFR Part 68.

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

**Facility Specific Requirements**

In addition to Title V, PORT JEFFERSON POWER STATION has been determined to be subject to the following regulations:

40CFR 72

## New York State Department of Environmental Conservation

### Permit Review Report

Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1



11/17/2006

In order to reduce acid rain the the U.S. and Canada, Title IV of the Clean Air Act Amendments of 1990 requires the establishment of a program to reduce emissions of SO<sub>2</sub> and NO<sub>x</sub> (sulfur dioxide and oxides of nitrogen). Fossil fuel burning electric utility companies are a major source of these contaminants in the US. These sources were regulated in a phased approach. Phase I, which began in 1995, requires 110 of the higher-emitting utility plants in the eastern and Midwest states to meet intermediate SO<sub>2</sub> emission limitations. Phase II, which began in 2000, tightens the emission limitations and expands the coverage to most fossil fuel burning utilities. The utilities are given "allowances" which is a limited authorization to emit one ton of SO<sub>2</sub>. The utilities are required to limit SO<sub>2</sub> emissions to the number of allowances they hold. Some can benefit however by reducing their emissions and selling their excess allowances. Part 72 contains the means of implementing this portion of Title IV of the Clean Air Act.

#### 40CFR 82

The purpose of this regulation is to implement standards on the protection of stratospheric ozone through the control of chloroflourocarbons (CFCs).

#### 6NYCRR 201-6.5 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide any information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

#### 6NYCRR 201-6.5 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

#### 6NYCRR 201-6.5 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

#### 6NYCRR 201-6.5 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

#### 6NYCRR 201-6.5 (d) (5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

#### 6NYCRR 201-6.5 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

6NYCRR 201-7

This facility is limiting the emissions of oxides of nitrogen to 2,178.7 tons per year, in order to cap out of the requirements of 6 NYCRR Part 231.

6NYCRR 204-1.6

This condition requires the designated representative of the permittee to make submissions for the NOx Budget Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.

6NYCRR 204-2.1

This condition states the submission requirements for the NOx Budget Trading Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.

6NYCRR 204-4.1

This condition covers the compliance certification report requirements for the NOx Budget Program.

6NYCRR 204-7.1

This condition lists the requirements for transfer of allowances in the NOx Budget Program.

6NYCRR 204-8.1

This condition lists the general requirements for the NOx Budget trading program. They include, but are not limited to monitoring requirements, certification, record keeping and reporting.

6NYCRR 204-8.2

This condition covers the procedures for initially certifying and recertifying the monitoring systems of the unit meet the requirements of the NOx Budget Program

6NYCRR 204-8.3

This condition states the requirements for data substitution during times when the monitoring systems do not meet applicable quality assurance requirements.

6NYCRR 204-8.4

This condition lists the addresses where monitoring plans and their modifications, compliance certifications, recertifications, quarterly QA/QC reports and petitions for alternative monitoring shall be sent.

6NYCRR 204-8.7

This condition is a requirement for monitoring and reporting if a particular monitoring scenario is utilized.

6NYCRR 225-1.2 (a) (2)

This regulation prohibits any person from selling, offering for sale, purchasing or using any fuel which contains sulfur in a quantity exceeding the limitations set forth in Table 1, Table 2, or Table 3 of this section.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

6NYCRR 225-2.3

This regulation prohibits the burning of Waste Fuel A in stationary combustion units. Waste fuel A is a waste oil that contains between 25 and 250 parts per million of lead and/or more than 50 parts per million of PCB or 1,000 parts per million of halogens.

6NYCRR 227 .2 (b) (1)

This regulation is from the 1972 version of Part 227 and still remains as part of New York's SIP. The rule establishes a particulate limit of 0.10 lbs/mmBtu based on a 2 hour average emission for any oil fired stationary combustion installation.

6NYCRR 227-1.3

This regulation requires a limitation and compliance monitoring for opacity from a stationary combustion installation.

6NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6NYCRR 227-2

This regulation limits the emission of oxides of nitrogen (NOx) from stationary combustion installations (boilers, combustion turbines and internal combustion engines).

6NYCRR 231-2

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

6NYCRR 237-1.4 (a)

This condition specifies that any emission unit or facility with a unit; that at any time on or after January 1, 1999, serves a generator with a nameplate capacity equal to or greater than 25 MWe, and sells any amount of electricity, is a NOx budget unit and subject to the requirements of NYCRR 237

6NYCRR 237-1.6 (a)

This condition requires the applicant to submit a NOx budget application for a permit and to operate in compliance with that permit.

6NYCRR 237-1.6 (c)

This subdivision outlines the standard requirements of the Acid Deposition Reduction NOx Budget Trading Program for oxides of nitrogen.

6NYCRR 237-1.6 (e)

This requires the owners and operators of the NOx budget source and each NOx budget unit at the source

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

to keep pertinent documents at the site for a period of 5 years; and lists which documents are pertinent.

6NYCRR 237-1.6 (f)

This describes the liability issues regarding the requirements of the ADR NOx Budget Trading Program .

6NYCRR 237-1.6 (g)

This item states that no provision of the ADR NOx Budget Trading Program, a NOx budget permit application, or a NOx budget permit, will exempt or exclude the owners and operators from compliance with any other provisions of applicable State and federal law and regulations.

6NYCRR 237-2

This condition requires the permittee to select and authorize one person to manage, and represent the owners of any NOx budget unit; and specifies the responsibilities of this NOx authorized account representative

6NYCRR 237-4.1

This item specifies the requirements of the compliance certification report.

6NYCRR 237-7.1

This item specifies what information and actions are necessary in order to record the transfer of NOx allowances. t

6NYCRR 237-8

This item requires the owners and operators of a NOx budget unit to comply with the monitoring and reporting requirements of NYCRR 237-8 and Subpart H of 40 CFR part 75; and allows NOx budget units which are also NOx budget units under NYCRR Part 204 to be summarily referenced in order to demonstrate compliance with the requirements of this item.

6NYCRR 238-1.4

This citation identifies the facility as having one or more SO2 budget units as defined by Federal Law, and as such is subject to the requirements of 6 NYCRR 238

6NYCRR 238-1.6 (a)

This condition requires the applicant to submit a SO2 budget application for a permit and to operate in compliance with that permit.

6NYCRR 238-1.6 (c)

This Item requires the owners and operators of each SO2 budget source and each SO2 budget unit to hold SO2 allowances available for compliance deductions under NYCRR 238-6.5; and how such allowances will be managed.

6NYCRR 238-1.6 (e)

This item requires the owners and operators of the SO2 budget source to keep on site at the source pertinent documents for a period of 5 years from the date the document is created.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 1-4722-00107/00025    Renewal Number: 1    Modification Number: 1**



**11/17/2006**

6NYCRR 238-1.6 (f)

This subdivision outlines the liability of an affected source.

6NYCRR 238-1.6 (g)

This subdivision outlines the liability of an affected source as subject to other requirements.

6NYCRR 238-2.1

This section outlines the authorization and responsibilities of the SO2 authorized account representative.

6NYCRR 238-4.1

This section lists all of the requirements for the submission of the compliance certification report.

6NYCRR 238-7.1

This section outlines the requirements for the submission of SO2 allowance transfers.

6NYCRR 238-8

This condition requires the owner or operator of the facility to comply with the reporting and record keeping requirements of 40 CFR Part 75.

**Compliance Certification**

Summary of monitoring activities at PORT JEFFERSON POWER STATION:

<b>Location Facility/EU/EP/Process/ES</b>	<b>Type of Monitoring</b>	<b>Cond No.</b>
FACILITY	record keeping/maintenance procedures	5
FACILITY	record keeping/maintenance procedures	6
FACILITY	continuous emission monitoring (cem)	1-1
U-HBO01	record keeping/maintenance procedures	1-20
FACILITY	record keeping/maintenance procedures	7
FACILITY	record keeping/maintenance procedures	29
FACILITY	record keeping/maintenance procedures	34
FACILITY	record keeping/maintenance procedures	36
FACILITY	record keeping/maintenance procedures	37
U-00001/00001	work practice involving specific operations	1-5
U-00001/00001	work practice involving specific operations	82
U-00002/00002/P13	work practice involving specific operations	1-8
U-00002/00002/P13	work practice involving specific operations	83
U-00002/00002/P14	work practice involving specific operations	1-9
U-00002/00002/P14	work practice involving specific operations	84
U-00002/00002/P15	work practice involving specific operations	85
U-00003/00003/P19	work practice involving specific operations	1-12
U-00003/00003/P19	work practice involving specific operations	86



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 1-4722-00107/00025

Renewal Number: 1

Modification Number: 1

11/17/2006

U-00003/00003/P20	work practice involving specific operations	1-13
U-00003/00003/P20	work practice involving specific operations	87
U-00003/00003/P21	work practice involving specific operations	1-14
U-00003/00003/P21	work practice involving specific operations	88
U-GT001/GT001/P28	work practice involving specific operations	1-16
U-GT001/GT001/P28	work practice involving specific operations	89
U-GT001/GT001/P29	work practice involving specific operations	1-17
U-GT001/GT001/P29	work practice involving specific operations	90
U-GT0S1/GT0S1/P91	work practice involving specific operations	1-18
U-GT0S1/GT0S1/P91	work practice involving specific operations	91
U-GT0S1/GT0S1/P92	work practice involving specific operations	1-19
U-GT0S1/GT0S1/P92	work practice involving specific operations	92
U-00002/00002/P17	record keeping/maintenance procedures	1-10
U-00002/00002/P17	record keeping/maintenance procedures	50
U-00003/00003/P23	record keeping/maintenance procedures	1-15
U-00003/00003/P23	record keeping/maintenance procedures	54
U-00002	intermittent emission testing	48
U-00003	intermittent emission testing	52
FACILITY	monitoring of process or control device parameters as surrogate	39
U-00001/00001	monitoring of process or control device parameters as surrogate	1-6
U-00001/00001	monitoring of process or control device parameters as surrogate	46
U-00002/00002	monitoring of process or control device parameters as surrogate	1-7
U-00002/00002	monitoring of process or control device parameters as surrogate	49
U-00003/00003	monitoring of process or control device parameters as surrogate	1-11
U-00003/00003	monitoring of process or control device parameters as surrogate	53
FACILITY	record keeping/maintenance procedures	1-2
FACILITY	record keeping/maintenance procedures	40
FACILITY	record keeping/maintenance procedures	62
FACILITY	record keeping/maintenance procedures	67
FACILITY	record keeping/maintenance procedures	69
FACILITY	record keeping/maintenance procedures	72
FACILITY	record keeping/maintenance procedures	73
FACILITY	record keeping/maintenance procedures	77
FACILITY	record keeping/maintenance procedures	79

**Basis for Monitoring**

Opacity , Oxides of Nitrogen, NOx,are continuously monitored. Continuous Monitors are required to demonstrate compliance with opacity and NOx emission limits.