



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Facility Identification Data

Name: DOWNSTATE MEDICAL CENTER

Address: 450 CLARKSON AVE

BROOKLYN, NY 11203-2098

Owner/Firm

Name: STATE UNIVERSITY OF NEW YORK

Address: STATE UNIVERSITY PLAZA

381 BROADWAY

ALBANY, NY 12246, USA

Owner Classification: State

Permit Contacts

Division of Environmental Permits:

Name: ELIZABETH A CLARKE

Address: NYSDEC

47-40 21ST ST

LONG ISLAND CITY, NY 11101-5407

Phone:7184824997

Division of Air Resources:

Name: DIANA MENASHA

Address: NYSDEC REGION 2 OFFICE

HUNTERS POINT PLAZA

LONG ISLAND CITY, NY 11101

Phone:7184827263

Air Permitting Contact:

Name: BRIAN PITT

Address: DOWNSTATE MEDICAL CENTER

450 CLARKSON AVE

BROOKLYN, NY 11203

Phone:7182702345

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

This is a major Title V permit modification for the installation of three (3) new 3.0 MM Btu/hr each dual fuel boilers (Emission Sources S0008, S0009 & S0010) and a 1,500 kilowatt exempt emergency generator



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

(Emission Source GEN01) in Emission Unit 0-U0004 - the New Academic Building (NAB). The three new boilers are to burn #2 fuel oil (Process FO2) and natural gas (Process NG1), while the emergency generator is to burn diesel fuel oil (Process GEN). In addition, in Emission Unit 0-U0005, the four (4) emergency generators will be replaced with four (4) new emergency generators (Emission Sources GEN02, GEN03, GEN04 & GEN05), and a 2000 KW temporary emergency generator (Emission Source TEMPG) will be added, burning diesel fuel oil (Process GN1). All emissions from the new sources are to be included under the existing 225 tons per year cap of NOx and the existing 225 tons per year cap of SO2.

The emissions from the new sources, three 3 MM Btu/hr each dual fuel boilers and the 1500 KW exempt emergency generator in the New Academic Building (Emission Source GEN01), meet the current NOx emission limit of 225 tons/yr, and the current SOx emission limit of 225 tons/yr. Even though there are no new limits being implemented and the old limits remain the same, this modification is considered a major modification due to the addition of several new sources as defined in 6 NYCRR 201-6.6 (c).

Downstate Medical Center (SUNY) is located at 450 Clarkson Avenue, in Brooklyn, New York. SUNY maintains a 225 tons/year limit on both NOx and SOx emissions as stated in their current Title V permit. Based on their current natural gas and #2 fuel oil usage, SUNY emits approximately 25 tons/yr of NOx on average, well below their current limit.

The 1,500 kilowatt exempt emergency generator (Emission Source GEN01) in the new Academic Building was purchase on 6/8/2010, is turbocharged and low temperature aftercooled, and hence 40 CFR 89.112, Supart B and 40 CFR 89.113, Supart B are not applicable.

The facility has submitted the EPA Tier 2 Exhaust Emission Certification for the 1,500 kilowatt emergency generator with the permit modification application. Using emission factors from AP-42 as well as Tier 2 emission certificated provided by the manufacturer for the 1,500 kilowatt emergency generator, the potential emissions are as follows:

Total Potential Emissions:

Pollutant	Generator (tpy)	Boiler (tpy)	Total (tpy)
PM	0.17	0.19	0.36
SOx	2.03	2.70	4.74
NOx	5.29	1.90	7.19
VOC	0.35	0.07	0.42
CO	2.89	1.07	3.96
Lead	----	1.44 E-04	1.44E-04
HAP	0.01	0.02	0.03
CO2e	5,526	2,131	7,657

The Total Potential Emissions above are based on maximum runtime (500 hrs/yr for the generator and 8,760 hrs/yr for the boiler). However; the emissions from the two new sources are to be included under



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

the facility's current existing permit limit and will not cause modifying the permit limits. But, this modification is considered a major modification due to the addition of several new sources as defined in 6 NYCRR 201-6.6 (c).

Also, SUNY will be replacing four emergency generators and removing a fifth. The four (4) generators that are to be replaced are Generators 2-5 (Emission Sources GEN02, GEN03, GEN04 & GEN05), which are all Caterpillar D348 Model SR4 (620 kW each).

The replacement emergency generators are to be 2013 Caterpillar C27 each rated at 750kW, EPA Tier II emission level certified, and each is a four-cycle diesel engines. The fifth generator that is to be removed (and not replaced) is the Onan natural gas generator (115 kW). Each of the replacement standby stationary generator is a diesel 2013 Caterpillar Model C27, compression ignition, each is rated at 750 KW (1,141 bHP), EPA Tier II emission level certified. All replacement generators meet the emission limitations found in 40 CFR 60 Subpart IIII. Each emergency generator will be operated a maximum of 500 hours/yr.

There will also be four (4) identical 275 gallon Day tanks located in the generator room and will gbe used for the four replacement generators. Each generator is a 4-stroke water-cooled diesel, each with a displacement of 27.03 liter, and with a compression ration of 16.5: 1.0.

The facility has submitted data for the four (4) identical replacement emergency generators. The gaseous emissions data measurements are consistent with those described in EPA 40 CFR Part 89 Subpart D, 40 CFR Part 60 Subpart IIII, and ISO 8178 for measuring HC, CO, PM, and NOx. Gaseous emissions values are weighted cycle averages and are in compliance with the non-road regulations. The maximum limits are as follows:

CO: 3.5 g/bKW-hr

NOx + HC: 6.4 g/bKW-hr

PM: 0.20 g/bKW-hr

Total Potential Emissions for the four (4) 750 KW (1,141 bHP) each generator (GEN02, GEN03, GEN04, and GEN05):

Pollutant	Emissions	Fuel Consumption @ 100% Load
-----------	-----------	------------------------------

NOx	5.25 g/HP-hr	202.9 L/hr or 53.6 gal/hr
-----	--------------	---------------------------

CO	0.25 g/HP-hr	
----	--------------	--

HC	0.03 g/HP-hr	
----	--------------	--

PM	0.21 g/HP-hr	
----	--------------	--

Pollutant	Emissions	Emissions (lb/hr)
-----------	-----------	-------------------

NOx	5.25 g/HP-hr	15.83
-----	--------------	-------

CO	0.25 g/HP-hr	
----	--------------	--



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

HC 0.03 g/HP-hr 0.12

PM 0.21 g/HP-hr 0.10

Emissions Power Category: 560 < KW < or = 2237

Attainment Status

DOWNSTATE MEDICAL CENTER is located in the town of BROOKLYN in the county of KINGS. The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.
** NOx has a separate ambient air quality standard in addition to being an ozone precursor.

Facility Description:

The facility currently has a Title V permit for the operation of six (6) industrial boilers (five at 42 MM Btu/hr each and one boiler at 10.461 MM Btu/hr), six (6) generators and a 200 lbs/hr crematorium on site. The facility is constructing a new building (New Academic Building) which will require the addition of three (3) 3.0 MM Btu/hr each boiler and a 1,500 kilowatt emergency generator as well as replacing four (4) existing emergency generators with four (4) new 750 KW emergency generators and a 2000 KW emergency generator.

The facility operates other sources which are considered exempt from permitting in accordance with 6 NYCRR 201-3.2(c), including one small boiler in the HSEB Nurse's Residence (<10 MM Btu/hr), two (2) internal combustion engines in the Garage University Hospital (<225 bhp), five (5) emergency power generators in the Power Plant University Hospital HSEB (<500 hours/yr), four (4) non-contact water cooling towers and water treatment systems in the University Hospital Basic Science Study Center HSEB, twenty (20) fuel oil storage tanks in the HSEB University Hospital Basic Science Nurse's Residence (<300,000 bbls), and one hundred and twenty (120) ventilating and exhaust systems for laboratory operations campus-wide. These exempt units remain unchanged.

Permit Structure and Description of Operations

The Title V permit for DOWNSTATE MEDICAL CENTER is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
- incinerator - devices which burn waste material for disposal
- control - emission control devices
- process - any device or contrivance which may emit air contaminants that is not included in the above categories.

DOWNSTATE MEDICAL CENTER is defined by the following emission unit(s):

Emission unit 0U0001 - Emission Unit 0-U0001 consists of five (5) Combustion Engineering boilers, each with a maximum heat input of 42 MM Btu/hr, identified as Emission Sources S0001, S0002, S0003, S0004 & S0005. These five external combustion boilers operate on dual-fuel, natural gas (Process GAS) and #6 fuel oil (Process OIL). The flue gases from these boilers exit through a common stack, identified as Emission Point E0001.

Emission unit 0U0001 is associated with the following emission points (EP):
E0001

Process: GAS is located at BOILER ROOM/SUBBASEM, Building 1 - Process GAS consists of the operation of the burning natural gas in the five (5) dual-fuel external combustion boilers, Emission Sources S0001, S0002, S0003, S0004 & S0005, burning natural gas, in Emission Unit 0-U0001. The flue gases from these boilers exit through a common stack, identified as Emission Point E0001.

Process: OIL is located at BOILER ROOM/SUBBASEM, Building 1 - Process OIL consists of the operation of the burning of # 2 fuel oil in the five (5) dual-fuel external combustion boilers, Emission Sources S0001, S0002, S0003, S0004 & S0005, burning #6 fuel oil, in Emission Unit 0-U0001. The flue gases from these boilers exit through a common stack, identified as Emission Point E0001.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Emission unit 0U0004 - Emission Unit 0-U0004 consists of three 3.0 MM Btu/hr each dual fuel boilers (Emission Sources S0008, S0009 & S0010) burning #2 fuel oil (Process FO2) and natural gas (Process NG1), and one new 1500 KW emergency generator (Emission Source GEN01) burning #2 fuel oil (Process GEN) at the New Academic Building (NAB).

The flue gases from the three boilers (Emission Sources S0008, S0009 & S0010) exit through their individual stack, identified as Emission Points 0NAB1, 0NAB2 & 0NAB3; respectively.

The flue gases from the new 1500 KW emergency generator (Emission Source GEN01) exit through its individual stack, identified as Emission Point 0NAB4.

Emission unit 0U0004 is associated with the following emission points (EP):
0NAB1, 0NAB2, 0NAB3, 0NAB4

Process: FO2 is located at Building NAB - Process FO2 consists of the operation of the burning of #2 fuel oil in the three (30 dual-fuel 3.0 MM Btu/hr each boilers (Emission Sources S0008, S0009 & S0010) in Emission Unit 0-U0004 in the New Academic Building (NAB). The flue gases from each of the three boilers exit through their individual stack, identified as Emission points 0NAB1, 0NAB2 & 0NAB3; respectively.

In addition to the boiler burning #2 fuel oil (Process FO2), the three boilers also burn natural gas (Process NG1).

Process: GEN is located at Building NAB - Process GEN consists of the operation of the burning of



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

diesel fuel in the new 1500 KW emergency generator (Emission Source GEN01) in Emission Unit 0-U0004 in the New Academic Building (NAB). The flue gases from this new 1500 KW new emergency generator exit through its individual stack, identified as Emission Point Point 0NAB4. This new 1500 KW emergency generator (Emission Source GEN01) is allowed to operate up to 500 hours annually.

Process: NG1 is located at Building NAB - Process NG1 consists of the operation of the burning natural gas in the three (3) dual-fuel 3.0 MM Btu/hr each boilers (Emission Sources S0008, S0009 & S0010) in Emission Unit 0-U0004 in the New Academic Building. The flue gases from each of the three boilers exit through their individual stack, identified as Emission Points 0NAB1, 0NAB2 & 0NAB3; respectively.

In addition to the boilers burning natural gas (Process NG1), the three boilers also burn #2 fuel oil (Process FO2).

Emission unit 0U0005 - Emission Unit 0-U0005 consists of four 750 KW each replacement emergency generators (Emission Sources GEN02, GEN03, GEN04 & GEN05) and a 2000 KW temporary generator (Emission Source TEMPG). Each of the replacement standby stationary generator is a diesel 2013 Caterpillar Model C27, compression ignition rated at 750 KW (1,141 bHP), EPA Tier II emission level certified, and each is a four-cycle diesel engine. Process GN1 is the combustion of diesel fuel in these 4 replacement emergency engines (Emission Sources GEN02, GEN03, GEN04 & GEN05) and the 2000 KW temporary generator (Emission Source TEMPG).

The flue gases from the four 750 KW each replacement generators (Emission Sources GEN02, GEN03, GEN04 & GEN05) exit through their individual stacks, identified as Emission Points 0GEN2, 0GEN3, 0GEN4 & 0GEN5; respectively. And the flue gases from the 2000 KW temporary generator (Emission Source TEMPG) exit through its own stack identified as Emission Point 0TEMP.

There will also be four (4) identical 275 gallon Day tanks located in the generator room and will be used



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

for the four replacement generators. Each generator is a 4-stroke water-cooled diesel, each with a displacement of 27.03 liter, and with a compression ration of 16.5: 1.0.

All replacement generators meet the emission limitations found in 40 CFR 60 Subpart IIII. Each generator will be operated a maximum of 500 hours/yr.

The facility has submitted data for the four (4) identical replacement emergency generators. The gaseous emissions data measurements are consistent with those described in EPA 40 CFR Part 89 Subpart D, 40 CFR Part 60 Subpart IIII, and ISO 8178 for measuring HC, CO, PM, and NOx. Gaseous emissions values are weighted cycle averages and are in compliance with the non-road regulations. The maximum limits are as follows:

CO: 3.5 g/bKW-hr

NOx + HC: 6.4 g/bKW-hr

PM: 0.20 g/bKW-hr

Total Potential Emissions for the four (4) 750 KW (1,141 bHP) each generator (GEN02, GEN03, GEN04, and GEN05):

Pollutant	Emissions	Fuel Consumption @ 100% Load
NOx	5.25 g/HP-hr	202.9 L/hr or 53.6 gal/hr
CO	0.25 g/HP-hr	
HC	0.03 g/HP-hr	
PM	0.21 g/HP-hr	

Pollutant	Emissions	Emissions (lb/hr)
NOx	5.25 g/HP-hr	15.83
CO	0.25 g/HP-hr	
HC	0.03 g/HP-hr	0.12
PM	0.21 g/HP-hr	0.10

Emissions Power Category: 560 < KW < or = 2237

Emission unit 0U0005 is associated with the following emission points (EP):
0GEN2, 0GEN3, 0GEN4, 0GEN5, 0TEMP

Process: GN1 is located at Building PPUH - Process GN1 consists of the burning of diesel fuel in the four 750 KW each replacement generators (Emission Sources GEN02, GEN03, GEN04 & GEN05) and the 2000 KW temporary emergency generator (Emission Source TEMPG) in Emission Unit 0-U0005 in the Power Plant University Hospital (PPUH). The



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

flue gases from this 2000 KW temporary emergency generator exit through its individual stack, identified as Emission Point 0TEMP.

The flue gases from the four 750 KW each replacement generators (Emission Sources GEN02, GEN03, GEN04 & GEN05) exit through their individual stacks, identified as Emission Points 0GEN2, 0GEN3, 0GEN4 & 0GEN5; respectively. And the flue gases from the 2000 KW temporary emergency generator (Emission Source TEMPG) exit through its own stack identified as Emission Point 0TEMP.

Each of the four (4) emergency generators combustes 53.6 gal/hr of diesel fuel @ 100% load. Each of the four (4) emergency generators operates a maximum of 500 hours per year.

The emergency generators are allowed to operate up to 500 hours annually.

Emission unit 0U0003 - Emission Unit 0-U0003 consists of a 10.46 MM Btu/hr dual fuel fired boiler (Emission Source S0007) to replace the existing exempt low pressure steam boiler and an existing exempt domestic hot water boiler. This new boiler will burn natural gas (Process NAT) as the primary fuel and #2 fuel oil (Process 2FO) as a secondary fuel. The flue gases from this new boiler exit through a stack, identified as Emission Point E0003.

Emission unit 0U0003 is associated with the following emission points (EP):
E0003

Process: 2FO is located at Building 1 - Process 2FO consists of the burning of #2 fuel oil (as the secondary fuel) in the new dual fuel external combustion boiler (Emission Source S0007) in Emission Unit 0-U0003. The flue gases from this boiler exit through a stack, identified as Emission Point E0003.

Process: NAT is located at Building 1 - Process NAT consists of the burning of natural gas (as the primary fuel) in the new dual fuel external combustion boiler (Emission Source S0007) in Emission Unit 0-U0003. The flue gases from this boiler exit through a stack, identified as Emission Point E0003.

Emission unit 0U0002 - Emission Unit 0-U0002 consists of a 200 lb/hr JK Environmental SP-300 crematorium (Emission Source S0006), which processes cadavers (Process 002). The flue gas from the crematorium exits through a dedicated stack, identified as Emission Point E0002.

Emission unit 0U0002 is associated with the following emission points (EP):
E0002

Process: 002 is located at 8TH FLOOR, Building 1 - Process 002 consists of the operation of a 200 lb/hr



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

crematorium (Emission Source S0006) in Emission Unit 0-U0002, processing cadavers generated on-site.

Title V/Major Source Status

DOWNSTATE MEDICAL CENTER is subject to Title V requirements. This determination is based on the following information:

Downstate Medical Center is a major facility because the potential emissions of nitrogen oxides is greater than the major source thresholds, which is 25 tons per year for nitrogen oxides. All facilities utilizing Title V Permits shall be considered major sources.

Program Applicability

The following chart summarizes the applicability of DOWNSTATE MEDICAL CENTER with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	YES
NSPS	YES
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

MACT Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements.

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis

of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code

Description

8062

GENERAL MEDICAL & SURGICAL HOSPITALS

SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code	Description
1-03-004-01	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - RESIDUAL OIL Grade 6 Oil
1-03-005-02	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - DISTILLATE OIL 10-100MMBTU/HR **
1-03-006-02	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS 10-100 MMBtu/Hr
2-03-001-01	INTERNAL COMBUSTION ENGINES - COMMERCIAL/INSTITUTIONAL COMMERCIAL/INSTITUTIONAL IC ENGINE - DISTILLATE OIL (DIESEL) Reciprocating
5-01-005-05	SOLID WASTE DISPOSAL - GOVERNMENT SOLID WASTE DISPOSAL: GOVERNMENT - OTHER INCINERATION Pathological

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE	
		lbs/yr	Range
0NY508-00-0	40 CFR 60 SUBPART	79660	



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

0NY750-00-0	IIII - NMHC + NOX CARBON DIOXIDE EQUIVALENTS	309575443
000630-08-0	CARBON MONOXIDE	197485
007439-92-1	LEAD	12
0NY210-00-0	OXIDES OF NITROGEN	450000
0NY075-00-0	PARTICULATES	46948
0NY075-00-5	PM-10	46948
007446-09-5	SULFUR DIOXIDE	450000
0NY100-00-0	TOTAL HAP	3779
0NY998-00-0	VOC	14918

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;
- (3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 26 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Item C: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.2(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.2(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.4(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.4(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR 201-6.4(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.4(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.4(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.4(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

**Item A: General Provisions for State Enforceable Permit Terms and Condition - 6
NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Condition	Short Description

FACILITY	ECL 19-0301	56	Powers and Duties of the Department with respect to air pollution control
FACILITY	40CFR 52-A.21(j)	1 -18	Best Available Control Technology
0-	40CFR 60-A	41	General provisions



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

U0003/E0003/2FO/S0007				
0-U0003	40CFR 60-A.4	37		General provisions - Address
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.40c	42		Steam generators 10-100 million Btu per hour
0-U0003/-/2FO/S0007	40CFR 60-Dc.42c (d)	38		Standard for Sulfur Dioxide Firing Oil. (see narrative)
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.42c (h)	43		Exemption from Averaging Requirements
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.42c (i)	44		Standard for Sulfur Dioxide Period of Requirements.
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.44c (g)	45		Alternative Compliance and Performance Test Methods and Procedures for Sulfur Dioxide.
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.44c (h)	46, 47		Alternative Compliance and Performance Test Methods and Procedures for Sulfur Dioxide.
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.46c (e)	48		Exemption from Emission Monitoring for Sulfur Dioxide.
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.48c (d)	49		Reporting and Recordkeeping Requirements.
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.48c (e) (1)	50		
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.48c (e) (11)	53		Reporting and Recordkeeping requirements - fuel supplier certifications
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.48c (e) (2)	51		
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.48c (e) (3)	52		
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.48c (g)	54		Reporting and Recordkeeping Requirements.
0-U0003/E0003/2FO/S0007	40CFR 60-Dc.48c (i)	55		Reporting and Recordkeeping Requirements.
FACILITY	40CFR 60-IIII	1 -27		Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
FACILITY	40CFR 60-IIII.4202 (a) (2)	1 -28		Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
FACILITY	40CFR 60-IIII.4205 (b)	1 -29		Emission Standards - 2007 or later



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

FACILITY	40CFR 60-IIII.4206	1	-30	Emergency Non Fire Pump Stationary CI-IC Engines Displacing < 30 liters/cylinder Stationary Compression Ignition IC Engines - Duration of Emission Standards
0- U0004/0NAB4/GEN/GEN01	40CFR 60-IIII.4207(b)	1	-56, 1 -57, 1 -58	Stationary Compression Ignition IC Engines - Fuel Requirements beginning October 1, 2010
FACILITY	40CFR 60-IIII.4208	1	-31	Stationary Compression Ignition IC Engines - Deadlines for installing or importing engines produced in previous model year
0- U0004/0NAB4/GEN/GEN01	40CFR 60-IIII.4209(a)	1	-59	Monitoring requirement - Emergency stationary CI-IC engine
0- U0004/0NAB4/GEN/GEN01	40CFR 60-IIII.4211(a)	1	-60	Stationary Compression Ignition Engines - Compliance Requirements
FACILITY	40CFR 60-IIII.4211(c)	1	-32	Stationary Compression Ignition Engines - Compliance Demonstration
FACILITY	40CFR 60-IIII.4211(e)	1	-33	Stationary Compression Ignition IC Engines - compliance demonstration
FACILITY	40CFR 60-IIII.4214	1	-34	Notification, Reporting and Recordkeeping Requirements - Stationary CI-IC engines
FACILITY	40CFR 60-IIII.4218	1	-35	Stationary Compression Ignition IC Engines - applicability of NSPS general provisions
FACILITY	40CFR 63-ZZZZ	1	-36	Reciprocating Internal Combustion Engine (RICE) NESHAP
FACILITY	40CFR 63-ZZZZ.6585	1	-37	Reciprocating Internal Combustion Engine (RICE) NESHAP - Applicability
FACILITY	40CFR 63-ZZZZ.6603(a)	1	-38, 1 -39	Reciprocating Internal Combustion Engine (RICE) NESHAP - requirements for existing engines at area sources of HAP emissions



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

FACILITY	40CFR 63-ZZZZ.6625 (e)	1	-40	Reciprocating Internal Combustion Engine (RICE) NESHAP - maintenance of engine and control device
FACILITY	40CFR 63-ZZZZ.6640 (f)	1	-41, 1 -42	Reciprocating Internal Combustion Engine (RICE) NESHAP - emergency engines
FACILITY	40CFR 63-ZZZZ.6665	1	-43, 1 -44	Reciprocating Internal Combustion Engine (RICE) NESHAP - General provisions
FACILITY	40CFR 68	22		Chemical accident prevention provisions
FACILITY	40CFR 80-I.510 (b)	1	-45	Motor vehicle diesel fuel: non road, locomotive and marine diesel fuel
FACILITY	40CFR 82-F	23		Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	40CFR 89-B.112	1	-46, 1 -47, 1 - 48, 1 -49, 1 -50	Oxides of nitrogen, carbon monoxide, hydrocarbon, and particulate matter exhaust emission standards
FACILITY	40CFR 89-B.113	1	-51	Smoke emission standard
FACILITY	6NYCRR 200.6	1		Acceptable ambient air quality.
FACILITY	6NYCRR 200.7	11		Maintenance of equipment.
FACILITY	6NYCRR 201-1.4	57, 1	-61	Unavoidable noncompliance and violations
FACILITY	6NYCRR 201-1.7	12, 1	-6	Recycling and Salvage
FACILITY	6NYCRR 201-1.8	13		Prohibition of reintroduction of collected contaminants to the air
FACILITY	6NYCRR 201-3.2 (a)	14, 1	-7	Exempt Activities - Proof of eligibility
FACILITY	6NYCRR 201-3.2 (c)	1	-12	Exempt Activities - exempt activity list
FACILITY	6NYCRR 201-3.3 (a)	15, 1	-8	Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6	24, 33, 34		Title V Permits and the Associated Permit Conditions
FACILITY	6NYCRR 201-6.4 (a) (4)	1	-9	General Conditions - Requirement to Provide Information
FACILITY	6NYCRR 201-6.4 (a) (7)	1	-1	General Conditions - Fees
FACILITY	6NYCRR 201-6.4 (a) (8)	1	-10	General Conditions - Right to Inspect
FACILITY	6NYCRR 201-6.4 (c)	1	-2	Recordkeeping and Reporting of Compliance Monitoring



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

FACILITY	6NYCRR 201-6.4 (c) (2)	1	-3	Records of Monitoring, Sampling and Measurement
FACILITY	6NYCRR 201-6.4 (c) (3) (ii)	1	-4	Reporting Requirements - Deviations and Noncompliance
FACILITY	6NYCRR 201-6.4 (d) (4)	1	-13	Compliance Schedules - Progress Reports
FACILITY	6NYCRR 201-6.4 (e)	1	-5	Compliance Certification
FACILITY	6NYCRR 201-6.4 (f) (6)	1	-11	Off Permit Changes
FACILITY	6NYCRR 201-6.4 (g)	1	-14	Permit Shield
FACILITY	6NYCRR 201-7.1	1	-15, 1 -16, 1 -17, 1 -18, 1 -52, 1 -53	Emission Capping in Facility Permits
FACILITY	6NYCRR 202-1.1	20		Required emissions tests.
FACILITY	6NYCRR 202-2.1	7		Emission Statements - Applicability
FACILITY	6NYCRR 202-2.5	8		Emission Statements - record keeping requirements.
FACILITY	6NYCRR 211.1	1	-19	General Prohibitions - air pollution prohibited
FACILITY	6NYCRR 211.2	58, 1	-62	General Prohibitions - visible emissions limited.
FACILITY	6NYCRR 215	9		Open Fires
FACILITY	6NYCRR 215.2	10		Open Fires - Prohibitions
0-U0002/E0002/002/S0006	6NYCRR 219-4	60		ALL NEW AND MODIFIED INCINERATORS, CREMATOR IES
0-U0002/E0002/002/S0006	6NYCRR 219-4.11	66		Inspection and reporting.
0-U0002/E0002/002/S0006	6NYCRR 219-4.5 (a)	61		Operating requirements.
0-U0002/E0002/002/S0006	6NYCRR 219-4.5 (b)	62, 63		Operating requirements.
0-U0002/E0002/002/S0006	6NYCRR 219-4.7	64, 65		Continuous emission monitoring.
FACILITY	6NYCRR 225.1 (a) (3)	30, 31		Sulfur in Fuel Limitations (SIP)
FACILITY	6NYCRR 225-1.2 (b)	1	-20	Sulfur-in-Fuel Limitations
FACILITY	6NYCRR 225-1.2 (f)	1	-21	Sulfur-in-Fuel Limitations
FACILITY	6NYCRR 225-1.2 (g)	1	-22	Sulfur-in-Fuel Limitations
FACILITY	6NYCRR 225-1.2 (h)	1	-23	Sulfur-in-Fuel Limitations
FACILITY	6NYCRR 225-1.6	1	-24	Reports, Sampling, and Analysis
0-U0001/E0001/OIL	6NYCRR 227.2 (b) (1)	36		Particulate emissions.
FACILITY	6NYCRR 227-1.3 (a)	32		Smoke Emission Limitations.
0-U0001/E0001/OIL	6NYCRR 227-1.3 (a)	35		Smoke Emission Limitations.
0-U0003/E0003/2FO/S0007	6NYCRR 227-1.3 (a)	40		Smoke Emission Limitations.
0-	6NYCRR 227-	1	-54	1994 Nox RACT



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

U0001/E0001/GAS/S0001 FACILITY	2.4 (c) (1) (i) 6NYCRR 227-	1	-16	presumptive limit. 2010 NOx RACT
0- U0001/E0001/GAS/S0001 FACILITY	2.4 (c) (1) (ii) 6NYCRR 227-	1	-55	presumptive limit. 2010 NOx RACT
FACILITY	2.4 (c) (1) (ii) 6NYCRR 227-2.4 (d)	59, 1	-25	presumptive limit. Small boilers, small combustion turbines, and small stationary internal combustion engines.
FACILITY	6NYCRR 227-2.5 (a)	1	-16, 1	-26 Fuel switching option.
FACILITY	6NYCRR 231-2	1	-17	New Source Review in Nonattainment Areas and Ozone Transport Region

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6 NYCRR 201-3.2 (a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR 201-3.3 (a)



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.4 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6 NYCRR 201-6.4 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6 NYCRR 201-6.4 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.4 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.4 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.4 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6 NYCRR 201-6.4 (d) (5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6 NYCRR 201-6.4 (e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6 NYCRR 201-6.4 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6 NYCRR 201-6.4 (g)

Permit Exclusion Provisions - specifies those actions, such as administrative orders, suits, claims for natural resource damages, etc that are not affected by the federally enforceable portion of the permit, unless they are specifically addressed by it.

6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6 NYCRR 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calENDar year.

6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

6 NYCRR Part 215

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

40 CFR Part 68

This Part lists the regulated substances and there applicability thresholds and sets the requirements for



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, DOWNSTATE MEDICAL CENTER has been determined to be subject to the following regulations:

40 CFR 52.21 (j)

BACT determinations are made on a case-by-case basis and can be no less stringent than any requirement that exists in the current State Implementation Plan (SIP) or 40 CFR 60 and 61. Emission and operational limitations required from a BACT determination will have to be entered into the special permit conditions, separately by the permit reviewer.

40 CFR 60.4

This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Quality Assurance (BQA).

40 CFR 60.40c

This regulation requires the source owner or operator to comply with the applicable General Provisions of 40 CFR 60 Subpart Dc. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements.

40 CFR 60.4202 (a) (2)

This regulation states that for engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants beginning in model year 2007.

40 CFR 60.4205 (b)

This requirement applies to owners and operators of 2007 model year and later emergency stationary CI IC engines with a displacement less than 30 liters/cylinder that are not fire pump engines. An



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

applicable source must comply with the emission standards for new nonroad CI engines for all pollutants (HC, PM, NO_x, NMHC + NO_x and CO) for the same model year and maximum engine power as per 40 CFR 60.4202.

40 CFR 60.4206

This requirement mandates that owners or operators of stationary compression ignition IC engines that achieve the emission standards as required in 40 CFR 60.4204 and 4205 maintain the engines according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine.

40 CFR 60.4207 (b)

These conditions states the fuel requirements for compression ignition stationary engines with a displacement of less than 30 liters per cylinder

40 CFR 60.4208

This requirement establishes deadlines dates beyond which owners and/or operators of affected stationary compression ignition IC engines are prohibited from importing or installing engines manufactured in a previous model year.

40 CFR 60.4209 (a)

The owner and/or operator of an emergency stationary compression ignition internal combustion engine subject to this subpart is required to install a non-resettable hour meter.

40 CFR 60.4211 (a)

This regulation states that the owner or operator and must comply with the emission standards specified in 40 CFR 60 Subpart IIII and must operate and maintain the stationary compression ignition internal combustion engine and control device according to the manufacturer's written instructions.

40 CFR 60.4211 (c)

This regulation is a NSPS general provision and states that the owners or operators of a 2007 model year and later stationary Compression Ignition internal combustion engine and must comply with the emission standards specified in 40 CFR 60.4204 (b) or 40 CFR 60.4205 (b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in 40 CFR 60.4205 (c), must comply by purchasing an engine certified to the emission standards in 40 CFR 60.4204 (b), or 40 CFR 60.4205 (b), or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power.

The engine must be installed and configured according to the manufacturer's specifications.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

The manufacturer's certification of compliance with the emission standards in 40 CFR 60 Subpart IIII for major pollutants will be sent to the Department prior to commencement of operation of the engines.

40 CFR 60.4211 (e)

This citation lists the compliance options for modified and reconstructed compression ignition engines that must comply with emission standards.

40 CFR 60.4214

This notification, reporting and recordkeeping requirement applies to non-emergency stationary compression ignition internal combustion engines greater than 2237 kW, or those having a displacement greater than or equal to 10 liters per cylinder or are pre-2007 model year engines exceeding 130 kW and not certified or are emergency stationary CI-IC engines listed in Table 5 of Subpart IIII of Part 60.

40 CFR 60.4218

This requirement is for Stationary Compression Ignition IC Engines - applicability of NSPS general provisions.

Table 8 of Subpart IIII shows which parts of the general provisions in 40 CFR 60.1 - 60.19 (Subpart A) apply to any facility that is subject to 40 CFR 60, Subpart IIII.

40 CFR 60.42c (d)

This regulation requires that on or after the date on which the initial performance test is completed or required to be completed under section 60.8 of 40 CFR 60 Subpart A, no owner or operator of an affected facility that combusts oil, shall combust oil with a sulfur content in excess of 0.5 percent by weight.

40 CFR 60.42c (h)

This regulation requires that compliance with emission limits and/or fuel oil sulfur limitations be based on a certification from the fuel supplier as stated in paragraph 40 CFR 60-Dc.48c(f)(1), (2), or (3) as applicable

40 CFR 60.42c (i)

This regulation requires that the sulfur dioxide emission limits, percentage reductions, and fuel oil sulfur limitations apply at all times, including periods of startup, shutdown, and malfunction.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

40 CFR 60.44c (g)

This regulation requires that oil fired facilities, demonstrating compliance with the sulfur dioxide standard through sampling and analysis, must test every shipment of oil after the initial approval of the sampling plan.

40 CFR 60.44c (h)

This regulation requires facilities demonstrating compliance through vendor certification to follow the compliance procedures listed in the appropriate paragraphs of 40 CFR 60-Dc.48c.

40 CFR 60.46c (e)

This regulation allows facilities subject to paragraphs 40 CFR 60-Dc.42c(h)(1), (2), or (3) who show compliance through vendor certification, to be exempt from the monitoring requirements of section 40 CFR 60-Dc.46c

40 CFR 60.48c (d)

This regulation requires the owner or operator of the facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c, to submit semi-annual reports to the EPA

40 CFR 60.48c (e) (1)

Reporting and recordkeeping provisions for facilities subject to a sulfur-in-fuel standard, sulfur dioxide emission limit, or percent reduction of sulfur dioxide emissions.

40 CFR 60.48c (e) (11)

If fuel supplier certifications are used to demonstrate compliance with the distillate oil specifications under 40 CFR 60-Dc.41c, then reports shall include a certified statement signed by the owner or operator that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.

40 CFR 60.48c (e) (2)

Reporting and recordkeeping provisions for facilities subject to a sulfur-in-fuel standard, sulfur dioxide emission limit, or percent reduction of sulfur dioxide emissions.

40 CFR 60.48c (e) (3)

Reporting and recordkeeping provisions for facilities subject to a sulfur-in-fuel standard, sulfur dioxide emission limit, or percent reduction of sulfur dioxide emissions.

40 CFR 60.48c (g)

The owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each day.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

40 CFR 60.48c (i)

This regulation requires the source owner or operator to retain all records for a minimum of two years for compliance with the NSPS. This does not supercede any requirement that is more stringent, including the Title V requirement to maintain records for for a minimum of 5 years.

40 CFR 63.6585

This condition details what criteria are used to determine if a reciprocating internal combustion engine is subject to the provisions of this NESHAP rule. If the engine is meets the rule's definition of reciprocating internal combustion engine, and is located at a facility that emits at least 10 tons of a single hazardous air pollutant or 25 tons of all hazardous air pollutants, then the engine will need to meet the provisions in this rule.

40 CFR 63.6603 (a)

These conditions list the emission limits, operating limits, and work practices that existing engines located at an area source of HAP emissions must meet.

The engines must meet work practices, emission limits, and operating limits on carbon monoxide or formaldehyde for the specific type of engine listed in table 2d of subpart ~~ZZZZ~~.

40 CFR 63.6625 (e)

This regulation requires the owners or operator of an existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions, an existing stationary emergency RICE, or an existing stationary RICE located at an area source of HAP emissions must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop their own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

40 CFR 63.6640 (f)

This condition states the operation requirements for emergency engines.

40 CFR 63.6665

This regulation specifies which provisions of the General provisions (Subpart A of 40 CFR 63) apply to the owner or operators of stationary internal combustion engines at facilities with emissions of hazardous air pollutants.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

40 CFR 80.510 (b)

This regulation is for motor vehicle diesel fuel: non-road, locomotive and marine diesel fuel.

This regulation requires that beginning June 1, 2010: Except as otherwise specifically provided in 40 CFR 80 Subpart I, all nonroad and locomotive marine diesel fuel is subject to the following per-gallon standards for sulfur content:

15 ppm maximum for NR diesel fuel.

40 CFR 89.112

This regulation sets forth the limits for oxides of nitrogen, carbon monoxide, hydrocarbon, and particulate matter from the exhaust of compression-ignition nonroad engines.

40 CFR 89.113

This regulation sets the opacity standard for non road compression ignition engines. The opacity standard is 20% when the engine is accelerating, 15% when the engine is in lugging mode and 50% during the peaks of either acceleration or lugging.

40 CFR Part 60, Subpart A

This regulation contains the General Provisions of 40 CFR 60. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements

40 CFR Part 60, Subpart IIII

This regulation is for the Applicability of Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.

Facilities that have stationary compression ignition internal combustion engines must comply with applicable portions of 40 CFR 60 Subpart IIII.

40 CFR Part 63, Subpart ZZZZ

This regulation is for the Applicability of Reciprocating Internal Combustion Engine (RICE) NESHAP.

Facilities that have reciprocating internal combustion engines must comply with applicable portions of 40 CFR 63 subpart ZZZZ.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

6 NYCRR 201-3.2 (c)

This section lists the specific activities which may be exempt from the permitting provisions of this Part.

6 NYCRR 201-7.1

This section of Part 201-7 specifies the criteria that need to be met in order to restrict emissions to avoid Title V or other applicable requirements using federally enforceable permit conditions permit.

6 NYCRR 211.1

This regulation requires that no person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

6 NYCRR 219-4.11

This section sets forth the Inspection and Reporting requirements for the crematories. Each owner or operator must inspect the facility annually and submit a report to the commissioner, certifying that the condition and operation of that facility, including the calibration of all instrumentation, meet manufacturer's specifications.

6 NYCRR 219-4.5 (a)

This section sets forth the emission standards of six-minute average opacity for the crematories, which is less than 10 percent.

6 NYCRR 219-4.5 (b)

This section sets forth the primary combustion chamber temperature of the crematories and pathological incinerator(s), which is described in section 219-4.4 of this subpart.

6 NYCRR 219-4.7

This section sets forth the continuous emission monitoring (CEMs) requirements for the crematories, which are primary and secondary (or last) combustion chamber exit temperatures.

6 NYCRR 225.1 (a) (3)

This regulation limits the amount of sulfur that can be in fuel burned at a stationary source. It references Table 1 of the 1979 version of the sulfur in fuel limitations expressed in terms of percent by weight for fuel oil and pounds per million Btu gross heat content for solid fuel. **NOTE: This citation has been replaced by requirements cited under 225-1.2(a)(2) and is no longer part of current State regulations, however, it remains part of New York State's approved State Implementation Plan (SIP).**



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

6 NYCRR 225-1.2 (b)

Sulfur-in-fuel limitations for oil or solid fuel fired facilities effective through June 30, 2014.

6 NYCRR 225-1.2 (f)

Sulfur-in-fuel limitations for the purchase of #2 heating oil on or after July 1, 2012.

6 NYCRR 225-1.2 (g)

Sulfur-in-fuel limitations for the purchase of distillate oil on or after July 1, 2014.

6 NYCRR 225-1.2 (h)

Sulfur-in-fuel limitation for the firing of distillate oil on or after July 1, 2016.

6 NYCRR 225-1.6

This section establishes the requirements for reporting, sampling, and analyzing fuel by subject facilities.

6 NYCRR 227.2 (b) (1)

This regulation is from the 1972 version of Part 227 and still remains as part of New York's SIP. The rule establishes a particulate limit of 0.10 lbs/mmBtu based on a 2 hour average emission for any oil fired stationary combustion installation.

6 NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6 NYCRR 227-2.4 (c) (1) (i)

Existing NOx RACT presumptive limit that expires on 6/30/14.

6 NYCRR 227-2.4 (c) (1) (ii)



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Future NOx RACT presumptive limit effective 7/1/14.

6 NYCRR 227-2.4 (d)

This section includes NOx RACT requirements for small boilers, small combustion turbines, and small stationary internal combustion engines.

6 NYCRR 227-2.5 (a)

Fuel switching NOx RACT compliance option.

6 NYCRR Subpart 219-4

This subpart sets forth the emission standards and requirements for all new and modified (after January 1, 1989) crematories and pathological waste incinerators.

6 NYCRR Subpart 231-2

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

Compliance Certification

Summary of monitoring activities at DOWNSTATE MEDICAL CENTER:

Location Facility/EU/EP/Process/ES	Cond No.	Type of Monitoring

0-U0003/-/2FO/S0007	38	work practice involving specific operations
0-U0003/E0003/2FO/S0007	47	monitoring of process or control device parameters as surrogate
0-U0003/E0003/2FO/S0007	49	record keeping/maintenance procedures
0-U0003/E0003/2FO/S0007	50	record keeping/maintenance procedures
0-U0003/E0003/2FO/S0007	53	record keeping/maintenance procedures
0-U0003/E0003/2FO/S0007	51	record keeping/maintenance procedures
0-U0003/E0003/2FO/S0007	52	record keeping/maintenance procedures
0-U0003/E0003/2FO/S0007	54	record keeping/maintenance procedures
0-U0003/E0003/2FO/S0007	55	record keeping/maintenance procedures
FACILITY	1-28	record keeping/maintenance procedures
FACILITY	1-29	record keeping/maintenance procedures
0-U0004/0NAB4/GEN/GEN01	1-56	work practice involving specific operations

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

0-U0004/ONAB4/GEN/GEN01	1-57	work practice involving specific operations
0-U0004/ONAB4/GEN/GEN01	1-58	work practice involving specific operations
0-U0004/ONAB4/GEN/GEN01	1-59	record keeping/maintenance procedures
0-U0004/ONAB4/GEN/GEN01	1-60	record keeping/maintenance procedures
FACILITY	1-32	record keeping/maintenance procedures
FACILITY	1-33	monitoring of process or control device parameters as surrogate
FACILITY	1-34	record keeping/maintenance procedures
FACILITY	1-37	record keeping/maintenance procedures
FACILITY	1-38	record keeping/maintenance procedures
FACILITY	1-39	record keeping/maintenance procedures
FACILITY	1-40	record keeping/maintenance procedures
FACILITY	1-41	record keeping/maintenance procedures
FACILITY	1-42	record keeping/maintenance procedures
FACILITY	1-44	record keeping/maintenance procedures
FACILITY	1-45	monitoring of process or control device parameters as surrogate
FACILITY	1-46	work practice involving specific operations
FACILITY	1-47	work practice involving specific operations
FACILITY	1-48	work practice involving specific operations
FACILITY	1-49	record keeping/maintenance procedures
FACILITY	1-50	work practice involving specific operations
FACILITY	1-51	work practice involving specific operations
FACILITY	1-12	work practice involving specific operations
FACILITY	1-4	record keeping/maintenance procedures
FACILITY	1-5	record keeping/maintenance procedures
FACILITY	1-16	work practice involving specific operations
FACILITY	1-17	monitoring of process or control device parameters as surrogate
FACILITY	1-18	monitoring of process or control device parameters as surrogate
FACILITY	7	record keeping/maintenance procedures
0-U0002/E0002/002/S0006	60	record keeping/maintenance procedures
0-U0002/E0002/002/S0006	66	record keeping/maintenance procedures
0-U0002/E0002/002/S0006	61	monitoring of process or control device parameters as surrogate
0-U0002/E0002/002/S0006	62	monitoring of process or control device parameters as surrogate
0-U0002/E0002/002/S0006	63	monitoring of process or control device parameters as surrogate
0-U0002/E0002/002/S0006	64	monitoring of process or control device parameters as surrogate
0-U0002/E0002/002/S0006	65	monitoring of process or control device parameters as surrogate
FACILITY	30	work practice involving specific operations
FACILITY	31	work practice involving specific operations
FACILITY	1-20	work practice involving specific operations
FACILITY	1-21	work practice involving specific operations
FACILITY	1-22	work practice involving specific operations
FACILITY	1-23	work practice involving specific operations
FACILITY	1-24	record keeping/maintenance procedures
0-U0001/E0001/OIL	36	intermittent emission testing
FACILITY	32	monitoring of process or control device parameters as surrogate
0-U0001/E0001/OIL	35	monitoring of process or control device parameters as surrogate
0-U0003/E0003/2FO/S0007	40	monitoring of process or control device parameters as surrogate
0-U0001/E0001/GAS/S0001	1-54	intermittent emission testing
0-U0001/E0001/GAS/S0001	1-55	intermittent emission testing
FACILITY	1-25	record keeping/maintenance procedures
FACILITY	59	record keeping/maintenance procedures
FACILITY	1-26	monitoring of process or control device parameters as surrogate

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Basis for Monitoring

This facility is subject to the requirements of Title V. The facility is required, under the provisions of 6 NYCRR Subpart 201-6, to submit semiannual compliance reports and an annual Compliance Certification. This facility is required to comply with the following monitoring conditions:

Condition # 7 for 6NYCRR Part 202-2.1: This is a facility-wide condition. This condition is for Record Keeping/Maintenance Procedures. This condition sets forth the applicability criteria for submitting an annual statement of emissions. The criteria is based on annual emission threshold quantities and ozone attainment designation. This condition is a requirement for all Title V facilities. These facilities must submit an annual emission statement by April 15th of each year for emissions of the previous calendar year.

Condition # 1-12 for 6 NYCRR 201-3.2 (c): This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Operating Hours of 500 Hours per year limit.

This condition lists the specific activities which may be exempt from the permitting provisions of this Part.

The four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators are exempt from NYSDEC permitting in accordance with 6 NYCRR 201-3.1(b) and 3.2(c)(6) and each one is limited to operating 500 hours per year in order to be considered exempt.

A stationary internal combustion engine that operates as a mechanical or electrical power source only when the usual supply of power is unavailable, and operates for no more than 500 hours per year. The 500 hours of annual operation for the engine include operation during emergency situations, routine maintenance, and routine exercising (for example, test firing the engine for one hour a week to ensure reliability). A stationary internal combustion engine used for peak shaving generation is not an emergency power generating stationary internal combustion engine.

Condition # 1-16 for 6 NYCRR 201-7.1, Capping out of 6 NYCRR 227-2.4 (c) (1) (ii) and 6 NYCRR 227-2.5 (a): This condition is an emission unit level, emission point



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

level, process level and emission source/control level condition that applies to Emission Unit: 0-U0001, Emission Point: E0001, Process: OIL, and Emission Sources/Controls: S0001, S0002, S0003, S0004 & S0005 for Oxides of Nitrogen for Work Practice Involving Specific Operations for a limit of 4900 hours between May 1 and September 30.

This condition is for the five 42 MM Btu/hr each Combustion Engineering boilers (Emission Sources S0001, S0002, S0003, S0004 & S0005) operating on natural gas (Process NG1) and on #2 fuel oil (Process FO2), and the three 3.0 MM Btu/hr each Fulton boilers (Emission Sources S0008, S0009 & S0010) operating on natural gas (Process GAS) and on #2 fuel oil (Process OIL).

Condition # 1-17 for 6 NYCRR 201-7.1, Capping out of 6 NYCRR 231-2: This is a facility-wide condition. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Oxides of Nitrogen. This section of Part 201-7 specifies the criteria that need to be met in order to restrict emissions to avoid Title V or other applicable requirements using federally enforceable permit conditions in a state facility permit.

This facility is capping out of NSR (6 NYCRR 231-2) to limit the NO_x emissions to 225 tons per year (tpy) for Oxides of Nitrogen. This cap will also effectively limit the emissions of all other regulated pollutants to less than 225 tpy.

Condition # 1-18 for 6 NYCRR 201-7.1, Capping out of 40 CFR 52.21 (j): This is a facility-wide condition. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Sulfur Dioxide.

This condition for section of Part 201-7 specifies the criteria that need to be met in order to restrict emissions to avoid Title V or other applicable requirements using federally enforceable permit conditions in a state facility permit.

This facility is capping out of PSD (40 CFR 52-A.21) to limit the SO₂ emissions to 225 tons per year (tpy) for Sulfur Dioxide. This cap will also effectively limit the emissions of all other regulated pollutants to less than 225 tpy.

Condition # 1-20 for 6 NYCRR 225-1.2 (b): This is a facility-wide condition. This condition is for Work Practice Involving Specific Operations for sulfur content limit of 0.0015 percent by weight. The distillate fuel oil (#2 heating oil) purchase is limited to 0.30 percent sulfur by weight effective through June 30, 2014. Compliance with this limit will be based on vendor certifications.

Condition # 1-21 for 6 NYCRR 225-1.2 (f): This is a facility-wide condition. This condition is for Work Practice Involving Specific Operations for sulfur content limit



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

of 0.0015 percent by weight. The distillate fuel oil (#2 heating oil) purchase is limited to 0.0015 percent sulfur by weight on or after July 1, 2012. Compliance with this limit will be based on vendor certifications.

Condition # 1-22 for 6 NYCRR 225-1.2 (g): This is a facility-wide condition. This condition is for Work Practice Involving Specific Operations for sulfur content limit of 0.0015 percent by weight. The distillate fuel oil (#2 heating oil) purchase is limited to 0.0015 percent sulfur by weight on or after July 1, 2014. Compliance with this limit will be based on vendor certifications.

Condition # 1-23 for 6 NYCRR 225-1.2 (h): This is a facility-wide condition. This condition is for Work Practice Involving Specific Operations for sulfur content limit of 0.0015 percent by weight. The distillate fuel oil (#2 heating oil) firing is limited to 0.0015 percent sulfur by weight on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Condition # 1-24 for 6 NYCRR 225-1.6: This is a facility-wide condition. This condition is for Record Keeping/Maintenance Procedures. The owner or operator of a facility which purchases and fires coal or oil shall submit reports to the commissioner containing a fuel analysis, information on the quantity of the fuel received, burned, and results of any stack sampling, stack monitoring and any other procedures to ensure compliance with the provisions of 6 NYCRR Part 225-1. All records shall be available for a minimum of three years.

Condition # 30 for 6 NYCRR 225.1(a)(3): This is a facility-wide condition. This condition is for Work Practice Involving Specific Operations for sulfur content. This condition limits the amount of sulfur that can be in fuel burned at a stationary source. It references Table 1 of the 1979 version of the sulfur in fuel limitations expressed in terms of percent by weight for fuel oil and pounds per million Btu gross heat content for solid fuel. The sulfur limit is 0.20 percent by weight for distillates - number 1, number 2 oil for the New York City area. NOTE: This citation has been replaced by requirements cited under 225-1.2(a)(2) and is no longer part of current State regulations, however, it remains part of New York State's approved State Implementation Plan (SIP).

The intent of 6 NYCRR 225.1(a)(3) is to prohibit within a certain region the combustion of fuels with sulfur contents exceeding certain levels. The Downstate Medical Center is located within the New York City area which has sulfur content limit of 0.30 percent by weight for residual fuel and 0.20 percent by weight for distillates.

Condition # 31 for 6 NYCRR 225.1(a)(3): This is a facility-wide condition. This condition is for Work Practice Involving Specific Operations for sulfur content. This condition limits the amount of sulfur that can be in fuel burned at a stationary source. It



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

references Table 1 of the 1979 version of the sulfur in fuel limitations expressed in terms of percent by weight for fuel oil and pounds per million Btu gross heat content for solid fuel. The sulfur limit is 0.30 percent by weight for residual fuel oil - number 4, number 5 and/or number 6 oil for the New York City area. NOTE: This citation has been replaced by requirements cited under 225-1.2(a)(2) and is no longer part of current State regulations, however, it remains part of New York State's approved State Implementation Plan (SIP).

The intent of 6 NYCRR 225.1(a)(3) is to prohibit within a certain region the combustion of fuels with sulfur contents exceeding certain levels. The Downstate Medical Center is located within the New York City area which has sulfur content limit of 0.30 percent by weight for residual fuel and 0.20 percent by weight for distillates.

Condition # 32 for 6 NYCRR 227-1.3(a): This is a facility-wide condition. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Opacity. This condition prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20 % opacity except for one six-minute period per hour of not more than 27 % opacity. These conditions require a daily inspection for visible emissions. If visible emissions are noted for two consecutive days, a Method 9 test must be performed.

Condition # 1-25 for 6 NYCRR 227-2.4(d): This condition is an emission unit level, emission point level, process level and emission source level condition for Record Keeping/Maintenance Procedures for Oxides of Nitrogen that applies to EU:0-U0004, Emission Points: 0NAB1, 0NAB2 & 0NAB3E0003, Processes:FO2 & NG1, and Emission Sources: S0008, S0009 & S0010.

This condition is for the NOx RACT condition for small boilers (those with a heat input more than 1 and less than or equal to 25 MM Btu/hr) and applies to the three 3.0 MM Btu/hr Fulton boilers. A boiler tune-up shall be performed annually to the these three boilers. The facility is required to tune-up each boiler at least once a year in order to ensure that the boiler is operating properly, thus minimizing the emissions to the atmosphere. The owner or operator of a small boiler (between 1 and 25 MM Btu/hr) shall maintain a log (in the format acceptable to the Department as in Air Guide 5 - DAR-5) containing the following information:

- (1) The date which the equipment was adjusted; and
- (2) The name, title, and affiliation of the person who adjusted the equipment.

Annual tune-up maintenance usually includes not only some aspects of daily, weekly, and monthly scheduled maintenance, but also focuses on tests, evaluations and adjustments



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

necessary for efficient combustion. Annual tune-up maintenance requirements must include a tune-up checklist (see Appendix A of Air Guide 5) and written procedures.

Condition # 59 for 6 NYCRR 227-2.4(d): This condition is an emission unit level, emission point level, process level and emission source level condition for Record Keeping/Maintenance Procedures for Oxides of Nitrogen that applies to EU:0-U0004, Emission Points: 0NAB1, 0NAB2 & 0NAB3E0003, Processes:FO2 & NG1, and Emission Sources: S0008, S0009 & S0010.

This condition is for the NO_x RACT condition for small boilers (those with a heat input more than 1 and less than or equal to 25 MM Btu/hr) and applies to the three 3.0 MM Btu/hr Fulton boilers. A boiler tune-up shall be performed annually to the these three boilers. The facility is required to tune-up each boiler at least once a year in order to ensure that the boiler is operating properly, thus minimizing the emissions to the atmosphere. The owner or operator of a small boiler (between 1 and 25 MM Btu/hr) shall maintain a log (in the format acceptable to the Department as in Air Guide 5 - DAR-5) containing the following information:

- (1) The date which the equipment was adjusted; and
- (2) The name, title, and affiliation of the person who adjusted the equipment.

Annual tune-up maintenance usually includes not only some aspects of daily, weekly, and monthly scheduled maintenance, but also focuses on tests, evaluations and adjustments necessary for efficient combustion. Annual tune-up maintenance requirements must include a tune-up checklist (see Appendix A of Air Guide 5) and written procedures.

Condition #1-26 for 6 NYCRR 227-2.5 (a): This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: 0-U0001 & 0-U0004, Emission Points: E0001, 0NAB1, 0NAB2 & 0NAB3, Processes: GAS, OIL, FO2 & NG1, and Emission Sources/Controls: S0001, S0002, S0003, S0004, S0005, S0008, S0009 & S0010 for Monitoring of Process or Control Device Parameters as Surrogate for Oxides of Nitrogen.

This condition is for the five 42 MM Btu/hr each Combustion Engineering boilers (Emission Sources S0001, S0002, S0003, S0004 & S0005) operating on natural gas (Process NG1) and on #2 fuel oil (Process FO2), and the three 3.0 MM Btu/hr each Fulton boilers (Emission Sources S0008, S0009 & S0010) operating on natural gas (Process GAS) and on #2 fuel oil (Process OIL).

This condition is for Oxides of Nitrogen and a NO_x RACT emission limit of 0.20 pounds per million Btus on or after July 1, 2014. Due to the Fuel switching NO_x RACT



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

compliance option, the NO_x RACT emission limit is 0.20 pounds per million Btus on or after July 1, 2014.

Condition # 1-28 for 40 CFR 60.4202 (a)(2), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Unit: 0-U0005, Emission Points: 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Process: GN1, and Emission Sources/Controls: GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition states that for engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants beginning in model year 2007.

Condition # 1-29 for 40 CFR 60.4205 (b), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition applies to owners and operators of 2007 model year and later emergency stationary CI IC engines with a displacement less than 30 liters/cylinder that are not fire pump engines. An applicable source must comply with the emission standards for new nonroad CI engines for all pollutants (HC, PM, NO_x, NMHC + NO_x and CO) for the same model year and maximum engine power as per 40 CFR 60.4202.

Condition # 1-32 for 40 CFR 60.4211 (c), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition is a NSPS general provision and states that the owners or operators of a 2007 model year and later stationary Compression Ignition internal combustion engine and must comply with the emission standards specified in 40 CFR 60.4204 (b) or 40 CFR 60.4205 (b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in 40 CFR 60.4205 (c), must comply by purchasing an engine certified to the emission standards in 40 CFR 60.4204 (b), or 40 CFR 60.4205 (b), or (c), as applicable, for the



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power.

The engine must be installed and configured according to the manufacturer's specifications.

The manufacturer's certification of compliance with the emission standards in 40 CFR 60 Subpart IIII for major pollutants will be sent to the Department prior to commencement of operation of the engines.

Condition #1-33 for 40 CFR 60.4211 (e), NSPS Subpart IIII: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: 0-U0004 & 0-U0005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Monitoring of Process or Control Device Parameters as Surrogate for Hours of Operation.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators and each one is limited to operating 500 hours per year. This condition lists the compliance options for modified and reconstructed compression ignition engines that must comply with emission standards. Maintenance checks, readiness and readiness testing of the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generator are exempt from NYSDEC permitting in accordance with 6 NYCRR 201-3.1(b) and 3.2(c)(6) and each ICE generator is limited to 100 hours per year for maintenance checks, readiness and readiness testing.

Condition # 1-34 for 40 CFR 60.4214, NSPS Subpart IIII: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This notification, reporting and recordkeeping requirement applies to non-emergency stationary compression ignition internal combustion engines greater than 2237 kW, or those having a displacement greater than or equal to 10 liters per cylinder or are pre-2007 model year engines exceeding 130 kW and not certified or are emergency stationary CI-IC engines listed in Table 5 of Subpart IIII of Part 60.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Condition # 1-37 for 40 CFR 63.6585, NSPS Subpart ZZZZ: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition details what criteria are used to determine if a reciprocating internal combustion engine is subject to the provisions of this NESHAP rule. If the engine is meets the rule's definition of reciprocating internal combustion engine, and is located at a facility that emits at least 10 tons of a single hazardous air pollutant or 25 tons of all hazardous air pollutants, then the engine will need to meet the provisions in this rule.

Condition # 1-38 for 40 CFR 63.6603 (a), NSPS Subpart ZZZZ: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

These conditions list the emission limits, operating limits, and work practices that existing engines located at an area source of HAP emissions must meet.

The engines must meet work practices, emission limits, and operating limits on carbon monoxide or formaldehyde for the specific type of engine listed in table 2d of subpart ZZZZ.

Condition # 1-39 for 40 CFR 63.6603 (a), NSPS Subpart ZZZZ: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

These conditions list the emission limits, operating limits, and work practices that existing engines located at an area source of HAP emissions must meet.

The engines must meet work practices, emission limits, and operating limits on carbon monoxide or formaldehyde for the specific type of engine listed in table 2d of subpart ZZZZ.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Condition # 1-40 for 40 CFR 63.6625 (e), NSPS Subpart ZZZZ: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition requires the owners or operator of an existing stationary RICE with a site rating of less than 100 brake HP located at a major source of HAP emissions, an existing stationary emergency RICE, or an existing stationary RICE located at an area source of HAP emissions must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop their own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

Condition # 1-41 for 40 CFR 63.6640 (f), NSPS Subpart ZZZZ: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition states the operation requirements for emergency engines.

Condition # 1-42 for 40 CFR 63.6640 (f), NSPS Subpart ZZZZ: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition states the operation requirements for emergency engines.

Condition # 1-44 for 40 CFR 63.6665, NSPS Subpart ZZZZ: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

This condition specifies which provisions of the General provisions (Subpart A of 40 CFR 63) apply to the owner or operators of stationary internal combustion engines at facilities with emissions of hazardous air pollutants.

Condition # 1-45 for 40 CFR 80.510 (b), Subpart I: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: 0-U0004 & 0-U0005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Monitoring of Process or Control Device Parameters as Surrogate for Sulfur Dioxide.

This condition is for motor vehicle diesel fuel: non-road, locomotive and marine diesel fuel for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators.

This condition requires that beginning June 1, 2010: Except as otherwise specifically provided in 40 CFR 80 Subpart I, all nonroad and locomotive marine diesel fuel is subject to the following per-gallon standards for sulfur content:

15 ppm maximum for NR diesel fuel.

Condition # 1-46 for 40 CFR 89.112, Subpart B: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: 0-U0004 & 0-U0005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for 40 CFR 60 Subpart III – NMHC + NO_x for a limit of 6.4 grams per kilowatt hour.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators for 40 CFR 60 Subpart III – NMHC + NO_x.

This condition lists the compliance options for modified and reconstructed compression ignition engines that must comply with emission standards.

This condition sets forth the limits for 40 CFR 60 Subpart III – NMHC + NO_x as 6.4 grams per kilowatt hour maximum in diesel oil from the exhaust of compression-ignition nonroad engines.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Condition # 1-47 for 40 CFR 89.112, Subpart B: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Carbon Monoxide.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators for Carbon Monoxide.

This condition lists the compliance options for modified and reconstructed compression ignition engines that must comply with emission standards.

This condition sets forth the limits for Carbon Monoxide as 3.5 grams per kilowatt hour maximum in diesel oil from the exhaust of compression-ignition nonroad engines.

Condition # 1-48 for 40 CFR 89.112, Subpart B: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Particulates.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators for Particulates.

This condition lists the compliance options for modified and reconstructed compression ignition engines that must comply with emission standards.

This condition sets forth the limits for Particulates as 0.2 grams per kilowatt hour maximum in diesel oil from the exhaust of compression-ignition nonroad engines.

Condition # 1-49 for 40 CFR 89.112, Subpart B: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Particulates.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

This condition sets forth the limits for oxides of nitrogen, carbon monoxide, hydrocarbon, and particulate matter from the exhaust of compression-ignition nonroad engines.

Condition # 1-50 for 40 CFR 89.112, Subpart B: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Hours of Operation.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators.

This condition lists the compliance options for modified and reconstructed compression ignition engines that must comply with emission standards.

This condition sets forth the limits for hours of operation as 100 hours maximum in diesel oil from the exhaust of compression-ignition nonroad engines.

Condition # 1-51 for 40 CFR 89.112, Subpart B: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Particulates for Opacity.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators.

This condition lists the compliance options for modified and reconstructed compression ignition engines that must comply with emission standards.

This condition sets forth the limits for opacity as percent maximum in diesel oil from the exhaust of compression-ignition nonroad engines.

Condition # 1-54 for 6 NYCRR 227-2.4 (c) (1) (i): This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Unit: 0-U0001, Emission Point: E0001, Processes: GAS & OIL, and



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Emission Sources/Controls: S0001, S0002, S0003, S0004 & S0005 for Oxides of Nitrogen for Intermittent Emission Testing for Oxides of Nitrogen.

This condition is for the five 42 MM Btu/hr each Combustion Engineering boilers (Emission Sources S0001, S0002, S0003, S0004 & S0005) operating on natural gas (Process GAS) and on #2 fuel oil (Process OIL) to verify the NOx emission limit compliance. A mid-size boiler is a boiler with a maximum heat input capacity greater than 25 million Btu per hour and equal to or less than 100 million Btu per hour.

Prior to July 1, 2014, the owner/operator of mid-size boilers (> 25 and equal to or <100 MM Btu/hr) boilers operating on residual oil/natural gas have a limit of 0.30 pounds of NOx per million Btus under the NOx RACT plan for mid-size boilers.

Condition # 1-55 for 6 NYCRR 227-2.4 (c) (1) (ii): This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Unit: 0-U0001, Emission Point: E0001, Processes: GAS & OIL, and Emission Sources/Controls: S0001, S0002, S0003, S0004 & S0005 for Oxides of Nitrogen for Intermittent Emission Testing for Oxides of Nitrogen.

This condition is for the five 42 MM Btu/hr each Combustion Engineering boilers (Emission Sources S0001, S0002, S0003, S0004 & S0005) operating on natural gas (Process GAS) and on #2 fuel oil (Process OIL) to verify the NOx emission limit compliance. A mid-size boiler is a boiler with a maximum heat input capacity greater than 25 million Btu per hour and equal to or less than 100 million Btu per hour.

On or after July 1, 2014, the owner/operator of mid-size boilers (> 25 and equal to or <100 MM Btu/hr) boilers operating on residual oil/natural gas have a limit of 0.20 pounds of NOx per million Btus under the NOx RACT plan for mid-size boilers.

Condition # 35 for 6 NYCRR 227-1.3(a): This condition is an emission unit level, emission point level and process level monitoring condition for Particulates and opacity that applies to EU: 0-U0001, EP: E0001 and Process OIL. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Opacity. This condition prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20 % opacity except for one six-minute period per hour of not more than 27 % opacity. These conditions require a daily inspection for visible emissions. If visible emissions are noted for two consecutive days, a Method 9 test must be performed.

Condition # 36 for 6 NYCRR 227.2(b)(1): This condition is an emission unit level, emission point level and process level condition for Intermittent Emission Testing for Particulates that applies to EU: 0-U0001, EP: E0001 and Process: OIL. This condition is



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

from the 1972 version of Part 227 and still remains as part of New York's SIP. This condition establishes a particulate limit of 0.10 lbs/MM Btu based on a 2 hour average emission for any oil fired stationary combustion installation.

Condition # 38 for 40 CFR 60.42c(d), NSPS Subpart Dc: This condition is an emission unit level, process level and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, Proc: 2FO, and ES: S0007.

This condition requires that on or after the date on which the initial performance test is completed or required to be completed under section 60.8 of 40 CFR 60 Subpart A, no owner or operator of an affected facility that combusts oil, shall combust oil with a sulfur content in excess of 0.5 percent by weight.

Condition # 40 for 6 NYCRR 227-1.3(a): This condition is an emission unit level, emission point level process level and emission source level monitoring condition for Particulates and opacity that applies to EU: 0-U0003, EP: E0003, Process 2FO and ES: S0007. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Opacity. This condition prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20 % opacity except for one six-minute period per hour of not more than 27 % opacity. These conditions require a daily inspection for visible emissions. If visible emissions are noted for two consecutive days, a Method 9 test must be performed.

Condition # 47 for 40 CFR 60.44c(h), NSPS Subpart Dc: This condition is an emission unit level, emission point level process level and emission source level monitoring condition Monitoring of Process or Control Device Parameters as Surrogate that applies to EU: 0-U0003, EP: E0003, Process 2FO and ES: S0007.

This condition requires facilities demonstrating compliance through vendor certification to follow the compliance procedures listed in the appropriate paragraphs of 40 CFR 60-Dc.48c.

Condition # 49 for 40 CFR 60.48c(d), NSPS Subpart Dc: This condition is an emission unit level, emission point level, process level and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, EP: E0003, Proc: 2FO, and ES: S0007.

This condition requires the owner or operator of the facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c, to submit semi-annual reports to the EPA



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Condition # 50 for 40 CFR 60.48c(e)(1), NSPS Subpart Dc: This condition is an emission unit level, emission point level, process level and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, EP: E0003, Proc: 2FO, and ES: S0007.

This condition sets forth the reporting and recordkeeping provisions for facilities subject to a sulfur-in-fuel standard, sulfur dioxide emission limit, or percent reduction of sulfur dioxide emissions.

Condition # 51 for 40 CFR 60.48c(e)(2), NSPS Subpart Dc: This condition is an emission unit level, emission point level, process level, and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, EP: E0003, Proc: 2FO, and ES: S0007.

This condition sets forth the reporting and recordkeeping provisions for facilities subject to a sulfur-in-fuel standard, sulfur dioxide emission limit, or percent reduction of sulfur dioxide emissions.

Condition # 52 for 40 CFR 60.48c(e)(3), NSPS Subpart Dc: This condition is an emission unit level, emission point level, process level, and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, EP: E0003, Proc: 2FO, and ES: S0007.

This condition sets forth the reporting and the recordkeeping provisions for facilities subject to a sulfur-in-fuel standard, sulfur dioxide emission limit, or percent reduction of sulfur dioxide emissions.

Condition # 53 for 40 CFR 60.48c(e)(11), NSPS Subpart Dc: This condition is an emission unit level, emission point level, process level, and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, EP: E0003, Proc: 2FO, and ES: S0007.

This condition specifies that if fuel supplier certifications are used to demonstrate compliance with the distillate oil specifications under 40 CFR 60-Dc.41c, then reports shall include a certified statement signed by the owner or operator that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.

Condition # 54 for 40 CFR 60.48c(g), NSPS Subpart Dc: This condition is an emission unit level, emission point level, process level and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, EP: E0003, Proc: 2FO, and ES: S0007.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

This condition requires the owner or operator of each affected facility to record and maintain records of the amount of each fuel combusted during each day.

Condition # 55 for 40 CFR 60.48c(i), NSPS Subpart Dc: This condition is an emission unit level, emission point level, process level and emission source level Record Keeping/Maintenance Procedures condition for Sulfur Dioxide that applies to EU: 0-U0003, EP: E0003, Proc: 2FO, and ES: S0007.

This condition requires the source owner or operator to retain all records for a minimum of two years for compliance with the NSPS. This does not supersede any requirement that is more stringent, including the Title V requirement to maintain records for a minimum of 5 years.

Condition # 1-56 for 40 CFR 60.4207(b), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Aromatic Content with a limit of 35 percent in the diesel fuel.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators.

Condition # 1-57 for 40 CFR 60.4207(b), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Cetane Index of a minimum of 40 ratio in the diesel fuel oil.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators.

This condition states the fuel requirements for compression ignition stationary engines with a displacement of less than 30 liters per cylinder. The diesel fuel oil shall have a minimum Cetane Index of 40 ratio in the diesel fuel oil.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Condition # 1-58 for 40 CFR 60.4207(b), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Work Practice Involving Specific Operations for Sulfur Content of a maximum of 15 parts per million by weight.

This condition is for the four 750 KW each Cummins (Emission Sources GEN02, GEN03, GEN04 & GEN05), the 1500 KW Cummins (emission Source GEN01), and the 2000 KW Balder (Emission Source TEMPG) diesel fuel emergency generators.

This condition states the fuel requirements for compression ignition stationary engines with a displacement of less than 30 liters per cylinder. The diesel fuel oil shall have a maximum sulfur content of 15 parts per million by weight.

Condition # 1-59 for 40 CFR 60.4209(a), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition requires the owner and/or operator of an emergency stationary compression ignition internal combustion engine subject to this subpart is required to install a non-resettable hour meter.

Condition # 1-60 for 40 CFR 60.4211(a), NSPS Subpart III: This condition is an emission unit level, emission point level, process level and emission source/control level condition that applies to Emission Units: U-00004 & U-00005, Emission Points: 0NAB4, 0GEN2, 0GEN3, 0GEN4, 0GEN5 & 0TEMP, Processes GEN & GN1, and Emission Sources/Controls: GEN01, GEN02, GEN03, GEN04, GEN05 & TEMPG for Record Keeping/Maintenance Procedures.

This condition states that the owner or operator and must comply with the emission standards specified in 40 CFR 60 Subpart III and must operate and maintain the stationary compression ignition internal combustion engine and control device according to the manufacturer's written instructions.

Condition # 60 for 6 NYCRR 219-4: This condition is an emission unit level, emission point level, process level and emission source level Record Keeping/Maintenance



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Procedures condition for Particulates that applies to EU: 0-U0002, EP: E0002, Proc: 002, and ES: S0006.

This condition sets forth the emission standards and requirements for all new and modified (after January 1, 1989) crematories and pathological waste incinerators.

Condition # 61 for 6 NYCRR 219-4.5(a): This condition is an emission unit level, emission point level, process level and emission source level monitoring condition for Particulates that applies to EU: 0-U0002, EP: E0002, Proc: 002, and ES: S0006. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Opacity.

This condition sets forth the emission standards of six-minute average opacity for the crematories, which is less than 10 percent.

Condition # 62 for 6 NYCRR 219-4.5(b): This condition is an emission unit level, emission point level, process level and emission source level monitoring condition for Particulates that applies to EU: 0-U0002, EP: E0002, Proc: 002, and ES: S0006. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Temperature.

This condition sets forth the secondary combustion chamber temperature of the crematories and pathological incinerator(s), which is described in section 219-4.4 of this subpart. The secondary combustion chamber temperature of the crematory cannot fall below 1800 degrees Fahrenheit at any time.

The secondary combustion chamber temperature of the crematory must be maintained at all times at 1800 degrees Fahrenheit that waste is being burned.

Condition # 63 for 6 NYCRR 219-4.5(b): This condition is an emission unit level, emission point level, process level and emission source level monitoring condition for Particulates that applies to EU: 0-U0002, EP: E0002, Proc: 002, and ES: S0006. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Temperature.

This condition sets forth the primary combustion chamber temperature of the crematories and pathological incinerator(s), which is described in section 219-4.4 of this subpart. The primary combustion chamber temperature of the crematory cannot fall below 1400 degrees Fahrenheit at any time.

Condition # 64 for 6 NYCRR 219-4.7: This condition is an emission unit level, emission point level, process level and emission source level monitoring condition for Particulates



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

that applies to EU: 0-U0002, EP: E0002, Proc: 002, and ES: S0006. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Temperature.

This condition sets forth the continuous emission monitoring (CEMs) requirements for the crematories, which are primary combustion chamber exit temperatures.

The continuous emission monitoring (CEMs) requirements for the crematories, which are primary combustion chamber exit temperature cannot fall below 1400 degrees Fahrenheit at any time using CEMs.

Any person who owns or operates a crematory facility must install, operate and maintain in accordance with manufacturer's instructions, instruments meeting specifications acceptable to the commissioner for continuously monitoring and recording the primary combustion chamber exit temperature. Temperature charts produced by the continuous monitor/recorder shall demonstrate compliance with the combustion operating temperature requirements. Any malfunction of the monitor or recorder shall be reported to the NYSDEC within 24 hours of occurrence and corrective action shall be implemented immediately. Records of operation, monitoring, maintenance and repair shall be kept onsite for five years and shall be readily available for NYSDEC review upon request.

Condition # 65 for 6 NYCRR 219-4.7: This condition is an emission unit level, emission point level, process level and emission source level monitoring condition for Particulates that applies to EU: 0-U0002, EP: E0002, Proc: 002, and ES: S0006. This condition is for Monitoring of Process or Control Device Parameters as Surrogate for Temperature.

This condition sets forth the continuous emission monitoring (CEMs) requirements for the crematories, which are secondary (or last) combustion chamber exit temperatures.

The continuous exit temperature of the secondary (or last) combustion chamber temperature of the crematory cannot fall below 1800 degrees Fahrenheit at any time using CEMs.

Any person who owns or operates a crematory facility must install, operate and maintain in accordance with manufacturer's instructions, instruments meeting specifications acceptable to the commissioner for continuously monitoring and recording the secondary (or last) combustion chamber exit temperature. Temperature charts produced by the continuous monitor/recorder shall demonstrate compliance with the combustion operating temperature requirements. Any malfunction of the monitor or recorder shall be reported to the NYSDEC within 24 hours of occurrence and corrective action shall be implemented immediately. Records of operation, monitoring, maintenance and repair shall be kept onsite for five years and shall be readily available for NYSDEC review upon request.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 2-6104-00132/00009

Renewal Number: 2

Modification Number: 1 03/07/2014

Condition # 66 for 6 NYCRR 219-4.11: This condition is an emission unit level, emission point level, process level and emission source level monitoring condition for Particulates that applies to EU: 0-U0002, EP: E0002, Proc: 002, and ES: S0006. This condition is for Record Keeping/Maintenance Procedures.

This condition sets forth the Inspection and Reporting requirements for the crematories. Each owner or operator of a permitted crematory facility must inspect the facility annually and submit a report to the commissioner, certifying that the condition and operation of that facility, including the calibration of all instrumentation, meet manufacturer's specifications. Annual inspections shall be conducted by a qualified incinerator service technician. The Operation and Maintenance Manual for the JK Environmental SP-300 incinerator shall be utilized at all times and maintenance and calibration procedures performed shall be recorded. Records shall be kept on site for five years and shall be available for NYSDEC review upon request.