

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

**Facility Identification Data**

Name: NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST  
Address: 525 EAST 68TH ST  
NEW YORK, NY 10021

**Owner/Firm**

Name: SOCIETY OF NEW YORK HOSPITAL  
Address: 525 EAST 68TH ST  
NEW YORK, NY 10021-4873, USA  
Owner Classification: Corporation/Partnership

**Permit Contacts**

Division of Environmental Permits:  
Name: ELIZABETH A CLARKE  
Address: ONE HUNTERS POINT PLAZA  
47-40 21ST ST  
LONG ISLAND CITY, NY 11101-5407  
Phone:7184824997

Division of Air Resources:  
Name: SAJI SAMUEL  
Address: NYSDEC REGION 2 OFFICE  
HUNTERS POINT PLAZA  
LONG ISLAND CITY, NY 11101

Air Permitting Contact:  
Name: JENNIFER KEARNEY  
Address: NEW YORK PRESBYTERIAN HOSPITAL  
525 EAST 68TH ST  
NEW YORK, NY 10032  
Phone:2127461741

**Permit Description**

**Introduction**

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

**Summary Description of Proposed Project**

# New York State Department of Environmental Conservation

## Permit Review Report

Permit ID: 2-6204-00064/00005    Renewal Number: 1

08/21/2007



New York Presbyterian hospital (NYPH) down town campus operates a few emission sources that include four boilers, eight emergency generators, nine fuel oil storage tanks and fume hoods. The hospital is planning to install a new turbine and duct burner, both capable of firing natural gas. This application is being submitted to obtain a permit to construct the new Cogen plant and renew the current Title V permit.

### Attainment Status

NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST is located in the town of MANHATTAN in the county of NEW YORK.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	MODERATE NON-ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

\* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

\*\* NOx has a separate ambient air quality standard in addition to being an ozone precursor

### Facility Description

New York Presbyterian hospital (NYPH) down town campus operates a few emission sources that include four (4)boilers, eight (8)emergency generators, nine(9) fuel oil storage tanks and fume hoods.The facility also has two (2) Ethylene oxide sterilizers and one abator unit. The hospital is planning to install a new turbine and duct burner, both capable of firing natural gas.

This application is being submitted to obtain a permit to construct the new Cogen plant and renew the current Title V permit.

### Permit Structure and Description of Operations

The Title V permit for NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process.

A facility is defined as all emission sources located at one or more adjacent or

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device.

[NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion        -        devices which burn fuel to generate heat, steam or power
- incinerator       -        devices which burn waste material for disposal
- control            -        emission control devices
- process            -        any device or contrivance which may emit air contaminants that is not included in the above categories.

NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST is defined by the following emission unit(s):

Emission unit U00001 - This emission unit consists of three (3) 145 mmbtu/hr boilers , one (1) 137.8mmbtu/hr boiler , one (1) 85.7 mmbtu/hr solar turbine and one (1) 37.9 mmbtu/hr Eclipse duct burner. The flue gases will be discharged through a common stack. All the boilers are dual fuel fired (natural gas and no. 2 fuel oil) and the flue gases exit through a common stack.

Emission unit U00001 is associated with the following emission points (EP):  
E0001

It is further defined by the following process(es):

Process: 001 is located at FIRST FLOOR, Building ANNEX - The process 001 is when the four boilers fires natural gas and flue gases will exhaust via a common stack.

Process: 002 is located at FIRST FLOOR, Building ANNEX - The process 002 is when the four boilers fires no.2 oil and flue gases will exhaust via a common stack.

Process: CNG is located at Building ANNEX - The process CNG is when the turbine and the burner fire natural gas and flue gases will exhaust via a common stack.

Emission unit U00002 - Two Amsco ethylene oxide sterilizers equipped with an aerator were shutdown. The facility replaced these units with two- (2) Amsco Eagle 3017 or equivalent sterilizers equipped with an Amsco abator or equal. The vent is connected to the existing emission point E0002. 100% ETO cartridge will be used.

Emission unit U00002 is associated with the following emission points (EP):  
E0002

It is further defined by the following process(es):

Process: 003 is located at Building N - The process 003 is when the Emission unit -0002 (consists of two (2) Ethylene oxide sterilizers and an abator) use 100% ETO 100 grams or 170 grams cartridges.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

**Title V/Major Source Status**

NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST is subject to Title V requirements. This determination is based on the following information:

The New York Presbyterian Hospital is a major facility because the potential emissions of nitrogen oxides and sulfur dioxide are greater than the major source thresholds (25 tons/year for nitrogen oxides, and 100 tons/year for sulfur dioxide). The facility-wide annual actual emissions for nitrogen oxides exceed 25 tons/year.

**Program Applicability**

The following chart summarizes the applicability of NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST with regards to the principal air pollution regulatory programs:

<b>Regulatory Program</b>	<b>Applicability</b>
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	YES
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

**NOTES:**

**PSD**            Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**NSR**            New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**



**NESHAP**        National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's)

**MACT**        Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

**NSPS**        New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

**Title IV**        Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

**Title VI**        Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

**RACT**        Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

**SIP**        State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

**Compliance Status**

Facility is out of compliance with specific requirements (see attached compliance schedule)  
Compliance Schedule:

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

<b>Location Facility/EU/EP/Process/ES</b>	<b>Short Description</b>	<b>Regulation</b>
U-00002/-/003/S0006	General Process Emission Sources - emissions from existing emission sources	6NYCRR 212.3 (a)
U-00002/-/003/S0007	General Process Emission Sources - emissions from existing emission sources	6NYCRR 212.3 (a)
U-00002/-/003/S0008	General Process Emission Sources - emissions from existing emission sources	6NYCRR 212.3 (a)

**Compliance Discussion:**

NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST is in violations of the following requirement(s):  
The facility signed the following Consent Orders:

Order on Consent # R2-0293-93-12, dated May 9, 1994;  
Consent Agreement and Consent Order, CAA Docket # II-98-0110, dated Feb. 23, 1999 and  
Consent Order # R2-20020628-199 dated April 2, 2003.

The facility must comply with all the requirements of these orders on consent.

**SIC Codes**

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

<b>SIC Code</b>	<b>Description</b>
8062	GENERAL MEDICAL & SURGICAL HOSPITALS

**SCC Codes**

SCC or Source Classification Code is a code developed and used by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

<b>SCC Code</b>	<b>Description</b>
1-03-005-02	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - DISTILLATE OIL 10-100MMBTU/HR **

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6204-00064/00005 Renewal Number: 1



08/21/2007

1-03-006-02 EXTERNAL COMBUSTION BOILERS -  
 COMMERCIAL/INDUSTRIAL  
 COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS  
 10-100 MMBtu/Hr  
 3-15-020-01 PHOTOGRAPHIC EQUIPMENT  
 HEALTH CARE - HOSPITALS  
 Sterilization w/ Ethylene Oxide

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Series code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE	
		lbs/yr	Range
000075-07-0	ACETALDEHYDE (HAP)	> 0	but < 10 tpy
000107-02-8	ACROLEIN (HAP)	> 0	but < 10 tpy
007440-38-2	ARSENIC (HAP)	> 0	but < 10 tpy
000071-43-2	BENZENE (HAP)	> 0	but < 10 tpy
007440-41-7	BERYLLIUM (HAP)	> 0	but < 10 tpy
007440-43-9	CADMIUM (HAP)	> 0	but < 10 tpy
000630-08-0	CARBON MONOXIDE	>= 50	tpy but < 100 tpy
007440-47-3	CHROMIUM (HAP)	> 0	but < 10 tpy
000075-21-8	ETHYLENE OXIDE (HAP)	> 0	but < 10 tpy
000050-00-0	FORMALDEHYDE (HAP)	> 0	but < 10 tpy
007439-92-1	LEAD (HAP)	> 0	but < 10 tpy
007439-96-5	MANGANESE (HAP)	> 0	but < 10 tpy
007439-97-6	MERCURY (HAP)	> 0	but < 10 tpy
007440-02-0	NICKEL METAL AND INSOLUBLE COMPOUNDS (HAP)	> 0	but < 10 tpy
0NY210-00-0	OXIDES OF NITROGEN	>= 100	tpy but < 250 tpy
0NY075-00-0	PARTICULATES	>= 2.5	tpy but < 10 tpy
0NY075-00-5	PM-10	>= 2.5	tpy but < 10 tpy
130498-29-2	POLYCYCLIC AROMATIC HYDROCARBONS (HAP)	> 0	but < 10 tpy



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**

000115-07-1	PROPYLENE	>= 2.5 tpy but < 10 tpy
007446-09-5	SULFUR DIOXIDE	>= 50 tpy but < 100 tpy
000108-88-3	TOLUENE (HAP)	> 0 but < 10 tpy
0NY998-00-0	VOC	>= 2.5 tpy but < 10 tpy
001330-20-7	XYLENE, M, O & P MIXT. (HAP)	> 0 but < 10 tpy

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A:            Emergency Defense - 6NYCRR Part 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B:            Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

**Item C:            Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)**

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Item D:                    Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)**

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

**Item E:                    Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**Item F:                    Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

**Item G:                    Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

**Item H:                    Property Rights - 6 NYCRR Part 201-6.5(a)(6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

**Item I:                    Severability - 6 NYCRR Part 201-6.5(a)(9)**

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item J:                    Permit Shield - 6 NYCRR Part 201-6.5(g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i.            The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii.          The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii.        The applicable requirements of Title IV of the Act;
- iv.        The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item K:                    Reopening for Cause - 6 NYCRR Part 201-6.5(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i.            If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years,

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item L:**

**Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this

**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item M:            Federally Enforceable Requirements - 40 CFR 70.6(b)**  
All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A:            General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Regulatory Analysis**

<b>Location Facility/EU/EP/Process/ES</b>	<b>Regulation</b>	<b>Short Description</b>	<b>Condition</b>
FACILITY	ECL 19-0301	Powers and Duties of the Department with respect to air pollution control	176
U-00001/E0001/001/S0009	40CFR 52-A.21	Prevention of Significant Deterioration	51
U-00001/E0001/002/S0009	40CFR 52-A.21	Prevention of Significant Deterioration	99
U-00001/E0001/CNG/S0010	40CFR 52-A.21	Prevention of Significant	147

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**



U-00001/E0001/CNG/S0011	40CFR 52-A.21	Deterioration Prevention of Significant Deterioration	161
U-00001/E0001/001/S0009	40CFR 60-A	General provisions	55
U-00001/E0001/002/S0009	40CFR 60-A	General provisions	102
U-00001/E0001/001/S0009	40CFR 60-A.11	General provisions - compliance with standards and maintenance requirements	67
U-00001/E0001/002/S0009	40CFR 60-A.11	General provisions - compliance with standards and maintenance requirements	114
U-00001/E0001/001/S0009	40CFR 60-A.12	General provisions - Circumvention	68
U-00001/E0001/002/S0009	40CFR 60-A.12	General provisions - Circumvention	115
U-00001/E0001/001/S0009	40CFR 60-A.13	General provisions - Monitoring requirements	69
U-00001/E0001/002/S0009	40CFR 60-A.13	General provisions - Monitoring requirements	116
U-00001/E0001/001/S0009	40CFR 60-A.13 (c)	General provisions - Monitoring requirements	70
U-00001/E0001/002/S0009	40CFR 60-A.13 (c)	General provisions - Monitoring requirements	117
U-00001/E0001/001/S0009	40CFR 60-A.13 (e)	General provisions - Monitoring requirements	71
U-00001/E0001/002/S0009	40CFR 60-A.13 (e)	General provisions - Monitoring requirements	118
U-00001/E0001/001/S0009	40CFR 60-A.13 (f)	General provisions - Monitoring requirements	72
U-00001/E0001/002/S0009	40CFR 60-A.13 (f)	General provisions - Monitoring requirements	119
U-00001	40CFR 60-A.13 (h)	General provisions - Monitoring requirements	41
U-00001/E0001/001/S0009	40CFR 60-A.14	General provisions - Modification	73
U-00001/E0001/002/S0009	40CFR 60-A.14	General provisions - Modification	120
U-00001/E0001/001/S0009	40CFR 60-A.15	General provisions - Reconstruction	74
U-00001/E0001/002/S0009	40CFR 60-A.15	General provisions - Reconstruction	121
FACILITY	40CFR 60-A.4	General provisions - Address	29
U-00001/E0001/001/S0009	40CFR 60-A.7 (a)	Notification and Recordkeeping	56
U-00001/E0001/002/S0009	40CFR 60-A.7 (a)	Notification and Recordkeeping	103
U-00001/E0001/001/S0009	40CFR 60-A.7 (b)	Notification and Recordkeeping	57
U-00001/E0001/002/S0009	40CFR 60-A.7 (b)	Notification and Recordkeeping	104
U-00001/E0001/001/S0009	40CFR 60-A.7 (c)	Notification and Recordkeeping	58
U-00001/E0001/002/S0009	40CFR 60-A.7 (c)	Notification and Recordkeeping	105
U-00001/E0001/001/S0009	40CFR 60-A.7 (d)	Notification and Recordkeeping	59
U-00001/E0001/002/S0009	40CFR 60-A.7 (d)	Notification and Recordkeeping	106
U-00001	40CFR 60-A.7 (f)	Notification and Recordkeeping	40

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005 Renewal Number: 1**

**08/21/2007**



U-00001/E0001/001/S0009	40CFR 60-A.8 (a)	Performance Tests	60
U-00001/E0001/002/S0009	40CFR 60-A.8 (a)	Performance Tests	107
U-00001/E0001/001/S0009	40CFR 60-A.8 (b)	Performance Tests	61
U-00001/E0001/002/S0009	40CFR 60-A.8 (b)	Performance Tests	108
U-00001/E0001/001/S0009	40CFR 60-A.8 (c)	Performance Tests	62
U-00001/E0001/002/S0009	40CFR 60-A.8 (c)	Performance Tests	109
U-00001/E0001/001/S0009	40CFR 60-A.8 (d)	Performance Tests	63
U-00001/E0001/002/S0009	40CFR 60-A.8 (d)	Performance Tests	110
U-00001/E0001/001/S0009	40CFR 60-A.8 (e)	Performance Tests	64
U-00001/E0001/002/S0009	40CFR 60-A.8 (e)	Performance Tests	111
U-00001/E0001/001/S0009	40CFR 60-A.8 (f)	Performance Tests	65
U-00001/E0001/002/S0009	40CFR 60-A.8 (f)	Performance Tests	112
U-00001/E0001/001/S0009	40CFR 60-A.9	General provisions - Availability of information	66
U-00001/E0001/002/S0009	40CFR 60-A.9	General provisions - Availability of information	113
U-00001/E0001/002/S0009	40CFR 60-Db.42b(j)	Exemption from Standards for Sulfur Dioxide.	122
U-00001/E0001/002/S0009	40CFR 60-Db.43b(b)	Standard for Particulate Matter Firing Oil.	123
U-00001/E0001/001/S0009	40CFR 60-Db.43b(f)	Standard for Particulate Matter Opacity.	75
U-00001/E0001/002/S0009	40CFR 60-Db.43b(f)	Standard for Particulate Matter Opacity.	124
U-00001/E0001/001/S0009	40CFR 60-Db.43b(g)	Standard for Particulate Matter Exemption.	76
U-00001/E0001/002/S0009	40CFR 60-Db.43b(g)	Standard for Particulate Matter Exemption.	125
U-00001/E0001/001/S0009	40CFR 60-Db.44b(a) (1)	Standard for Nitrogen Oxides Firing Natural Gas and Distillate Oil. (see narrative)	77
U-00001/E0001/002/S0009	40CFR 60-Db.44b(a) (1)	Standard for Nitrogen Oxides Firing Natural Gas and Distillate Oil. (see narrative)	126
U-00001/E0001/001/S0009	40CFR 60-Db.44b(h)	Standards for Nitrogen Oxides Provisions.	78
U-00001/E0001/002/S0009	40CFR 60-Db.44b(h)	Standards for Nitrogen Oxides Provisions.	127
U-00001/E0001/001/S0009	40CFR 60-Db.44b(i)	Averaging Period.	79
U-00001/E0001/002/S0009	40CFR 60-Db.44b(i)	Averaging Period.	128
U-00001/E0001/001/S0009	40CFR 60-Db.44b(j)	Averaging Periods Based on Performance Testing. (see narrative)	80
U-00001/E0001/002/S0009	40CFR 60-Db.44b(j)	Averaging Periods Based on Performance Testing. (see narrative)	129
U-00001/E0001/002/S0009	40CFR 60-Db.45b(j)	Compliance and Performance Test Methods and Procedures for Sulfur Dioxide.	130
U-00001/E0001/001/S0009	40CFR 60-Db.46b	Compliance and Performance Test Methods and Procedures for Particulate Matter and and Nitrogen Oxides.	81
U-00001/E0001/002/S0009	40CFR 60-Db.46b	Compliance and Performance Test Methods and Procedures for Particulate Matter and	131

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

U-00001/E0001/001/S0009	40CFR 60-Db.46b(d)	and Nitrogen Oxides. Compliance and Performance Test Methods and Procedures for Particulate Matter and and Nitrogen Oxides.	82
U-00001/E0001/002/S0009	40CFR 60-Db.46b(d)	Compliance and Performance Test Methods and Procedures for Particulate Matter and and Nitrogen Oxides.	132
U-00001/E0001/001/S0009	40CFR 60-Db.46b(e) (4)	Compliance and Performance Test Methods for Nitrogen Oxides	83
U-00001/E0001/002/S0009	40CFR 60-Db.46b(e) (4)	Compliance and Performance Test Methods for Nitrogen Oxides	133
U-00001/E0001/CNG/S0010	40CFR 60-Db.46b(f)	Compliance and Performance Test Methods and Procedures for Particulate Matter and and Nitrogen Oxides.	150, 151
U-00001/E0001/CNG/S0011	40CFR 60-Db.46b(f)	Compliance and Performance Test Methods and Procedures for Particulate Matter and and Nitrogen Oxides.	163, 164
U-00001/E0001/002/S0009	40CFR 60-Db.47b(f)	Exemption from Emission Monitoring for Sulfur Dioxide.	134
U-00001/E0001/001/S0009	40CFR 60-Db.48b(a)	Emissions Monitoring for Particulate Matter and Nitrogen Oxides.	84
U-00001/E0001/002/S0009	40CFR 60-Db.48b(a)	Emissions Monitoring for Particulate Matter and Nitrogen Oxides.	135
U-00001/E0001/001/S0009	40CFR 60-Db.48b(c)	Emission Monitoring for Particulate Matter and Nitrogen Oxides.	85
U-00001/E0001/002/S0009	40CFR 60-Db.48b(c)	Emission Monitoring for Particulate Matter and Nitrogen Oxides.	136
U-00001/E0001/001/S0009	40CFR 60-Db.48b(f)	Emission Monitoring for Particulate Matter and Nitrogen Oxides.	86
U-00001/E0001/002/S0009	40CFR 60-Db.48b(f)	Emission Monitoring for Particulate Matter and Nitrogen Oxides.	137
U-00001/E0001/001/S0009	40CFR 60-Db.49b(a)	Reporting and Recordkeeping Requirements.	87
U-00001/E0001/002/S0009	40CFR 60-Db.49b(a)	Reporting and Recordkeeping Requirements.	138
U-00001/E0001/001/S0009	40CFR 60-Db.49b(b)	Reporting and Recordkeeping Requirements.	88
U-00001/E0001/002/S0009	40CFR 60-Db.49b(b)	Reporting and Recordkeeping Requirements.	139
U-00001/E0001/001/S0009	40CFR 60-Db.49b(d)	Reporting and Recordkeeping Requirements.	89

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

U-00001/E0001/002/S0009	40CFR 60-Db.49b(d)	Reporting and Recordkeeping Requirements.	140
U-00001/E0001/001/S0009	40CFR 60-Db.49b(f)	Reporting and Recordkeeping Requirements.	90
U-00001/E0001/002/S0009	40CFR 60-Db.49b(f)	Reporting and Recordkeeping Requirements.	141
U-00001/E0001/001/S0009	40CFR 60-Db.49b(g)	Reporting and Recordkeeping Requirements.	91
U-00001/E0001/002/S0009	40CFR 60-Db.49b(g)	Reporting and Recordkeeping Requirements.	142
U-00001/E0001/001/S0009	40CFR 60-Db.49b(h)	Reporting and Recordkeeping Requirements.	92
U-00001/E0001/002/S0009	40CFR 60-Db.49b(h)	Reporting and Recordkeeping Requirements.	143
U-00001/E0001/001/S0009	40CFR 60-Db.49b(i)	Reporting and Recordkeeping Requirements.	93
U-00001/E0001/002/S0009	40CFR 60-Db.49b(i)	Reporting and Recordkeeping Requirements.	144
U-00001/E0001/002/S0009	40CFR 60-Db.49b(j)	Reporting and Recordkeeping Requirements.	145
U-00001/E0001/002/S0009	40CFR 60-Db.49b(r)	Reporting and Recordkeeping Requirements.	146
U-00001/E0001/CNG/S0010	40CFR 60-GG.333	Standard for Sulfur Dioxide	152, 153
U-00001/E0001/CNG/S0010	40CFR 60-GG.333(a)	Standard for Sulfur Dioxide	154
U-00001/E0001/CNG/S0010	40CFR 60-KKKK.4320(a)	Stationary Combustion Turbine NSPS - Table 1 NOx emission limits	155
U-00001/E0001/CNG/S0010	40CFR 60-KKKK.4340(a)	Stationary Combustion Turbine NSPS - Continuous compliance with NOx limit	156
U-00001/E0001/CNG/S0011	40CFR 60-KKKK.4340(a)	Stationary Combustion Turbine NSPS - Continuous compliance with NOx limit	165
U-00001/E0001/CNG/S0010	40CFR 60-KKKK.4365(a)	Stationary Combustion Turbine NSPS - Exemption from monitoring total sulfur content of fuel	157
U-00001/E0001/CNG/S0011	40CFR 60-KKKK.4365(a)	Stationary Combustion Turbine NSPS - Exemption from monitoring total sulfur content of fuel	166
U-00001/E0001/CNG/S0010	40CFR 60-KKKK.4375(b)	Stationary Combustion Turbine NSPS - Reporting	158
U-00001/E0001/CNG/S0011	40CFR 60-KKKK.4375(b)	Stationary Combustion Turbine NSPS - Reporting	167
U-00001/E0001/CNG/S0010	40CFR 60-KKKK.4400(a)	Stationary Combustion Turbine NSPS -	159

# New York State Department of Environmental Conservation

## Permit Review Report

Permit ID: 2-6204-00064/00005 Renewal Number: 1

08/21/2007



U-00001/E0001/CNG/S0011	40CFR 60-KKKK.4400 (a)	Performance test methods Stationary Combustion Turbine NSPS -	168
U-00001/E0001/CNG/S0010	40CFR 60-KKKK.4400 (b)	Performance test methods Stationary Combustion Turbine NSPS - Performance testing for NOx	160
U-00001/E0001/CNG/S0011	40CFR 60-KKKK.4400 (b)	Stationary Combustion Turbine NSPS - Performance testing for NOx	169
FACILITY	40CFR 68	Chemical accident prevention provisions	21
FACILITY	40CFR 82-F	Protection of Stratospheric Ozone - recycling and emissions reduction	22
FACILITY	6NYCRR 200.6	Acceptable ambient air quality.	1
FACILITY	6NYCRR 200.7	Maintenance of equipment.	10
FACILITY	6NYCRR 201-1.4	Unavoidable noncompliance and violations	177
FACILITY	6NYCRR 201-1.7	Recycling and Salvage	11
FACILITY	6NYCRR 201-1.8	Prohibition of reintroduction of collected contaminants to the air	12
FACILITY	6NYCRR 201-3.2 (a)	Exempt Activities - Proof of eligibility	13
FACILITY	6NYCRR 201-3.3 (a)	Trivial Activities - proof of eligibility	14
FACILITY	6NYCRR 201-6	Title V Permits and the Associated Permit Conditions	23, 30, 31
FACILITY	6NYCRR 201-6.5 (a) (4)	General conditions	15
FACILITY	6NYCRR 201-6.5 (a) (7)	General conditions	
Fees 2 FACILITY	6NYCRR 201-6.5 (a) (8)	General conditions	16
FACILITY	6NYCRR 201-6.5 (c)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	3
FACILITY	6NYCRR 201-6.5 (c) (2)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	4
FACILITY	6NYCRR 201-6.5 (c) (3) (ii)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	5
FACILITY	6NYCRR 201-6.5 (d) (5)	Compliance schedules	17
FACILITY	6NYCRR 201-6.5 (e)	Compliance Certification	6
FACILITY	6NYCRR 201-6.5 (f) (6)	Off Permit Changes	18
FACILITY	6NYCRR 201-6.5 (g)	Permit shield	24
FACILITY	6NYCRR 201-7	Federally Enforceable Emissions Caps	32, 33
U-00001	6NYCRR 201-7	Federally Enforceable Emissions Caps	34, 35, 36
U-00001/E0001/001/S0009	6NYCRR 201-7	Federally Enforceable Emissions Caps	51
U-00001/E0001/002/S0009	6NYCRR 201-7	Federally Enforceable Emissions Caps	99

# New York State Department of Environmental Conservation



## Permit Review Report

Permit ID: 2-6204-00064/00005 Renewal Number: 1

08/21/2007

U-00001/E0001/CNG/S0010	6NYCRR 201-7	Federally Enforceable Emissions Caps	147
U-00001/E0001/CNG/S0011	6NYCRR 201-7	Federally Enforceable Emissions Caps	161
FACILITY	6NYCRR 202-1.1	Required emissions tests.	19
FACILITY	6NYCRR 202-2.1	Emission Statements - Applicability	7
FACILITY	6NYCRR 202-2.5	Emission Statements - record keeping requirements.	8
FACILITY	6NYCRR 211.2	General Prohibitions - air pollution prohibited.	178
FACILITY	6NYCRR 211.3	General Prohibitions - visible emissions limited	20
U-00002	6NYCRR 212.3 (a)	General Process Emission Sources - emissions from existing emission sources	170, 171
U-00002/-/003/S0006	6NYCRR 212.3 (a)	General Process Emission Sources - emissions from existing emission sources	172
U-00002/-/003/S0007	6NYCRR 212.3 (a)	General Process Emission Sources - emissions from existing emission sources	173
U-00002/-/003/S0008	6NYCRR 212.3 (a)	General Process Emission Sources - emissions from existing emission sources	174
U-00002/E0002/003	6NYCRR 212.3 (a)	General Process Emission Sources - emissions from existing emission sources	175
FACILITY	6NYCRR 215	Open Fires	9
FACILITY	6NYCRR 225.1 (a) (3)	Sulfur in Fuel Limitations (SIP)	26
FACILITY	6NYCRR 225-1.8	Reports, sampling and analysis.	25
U-00001/-/002	6NYCRR 227.2 (b) (1)	Particulate emissions.	42
U-00001	6NYCRR 227-1.2 (a) (1)	Particulate Emissions from Liquid Fuels.	37
U-00001	6NYCRR 227-1.2 (b)	Particulate Emissions from 2 or More Connected Furnaces.	38
U-00001	6NYCRR 227-1.3	Smoke Emission Limitations.	39
U-00001/E0001	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	43
FACILITY	6NYCRR 227-1.4 (a)	Stack Monitoring. (see narrative)	179
FACILITY	6NYCRR 227-1.4 (b)	Stack Monitoring	27
U-00001/E0001/001	6NYCRR 227-2.4 (b) (1)	Control Requirements for large boilers which are not case by case.	44
U-00001/E0001/002	6NYCRR 227-2.4 (b) (1)	Control Requirements for large boilers which are not case by case.	94
U-00001/E0001/001/S0001	6NYCRR 227-2.4 (d)	RACT for Oxides of Nitrogen - small boilers.	45



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005 Renewal Number: 1**

**08/21/2007**

U-00001/E0001/001/S0002	6NYCRR 227-2.4 (d)	RACT for Oxides of Nitrogen - small boilers.	47
U-00001/E0001/001/S0003	6NYCRR 227-2.4 (d)	RACT for Oxides of Nitrogen - small boilers.	49
U-00001/E0001/001/S0009	6NYCRR 227-2.4 (d)	RACT for Oxides of Nitrogen - small boilers.	52
U-00001/E0001/CNG/S0010	6NYCRR 227-2.4 (e) (2)	RACT requirements for combined cycle combustion turbines.	148
U-00001/E0001/CNG/S0011	6NYCRR 227-2.4 (e) (2)	RACT requirements for combined cycle combustion turbines.	162
U-00001/E0001/001/S0009	6NYCRR 227-2.6 (c)	Stack Test Requirements.	53
U-00001/E0001/002/S0009	6NYCRR 227-2.6 (c)	Stack Test Requirements.	100
FACILITY	6NYCRR 227-2.6 (c) (2)	CEMS requirements	28
U-00001/E0001/001/S0001	6NYCRR 227-2.6 (c) (2)	CEMS requirements	46
U-00001/E0001/001/S0002	6NYCRR 227-2.6 (c) (2)	CEMS requirements	48
U-00001/E0001/001/S0003	6NYCRR 227-2.6 (c) (2)	CEMS requirements	50
U-00001/E0001/001/S0009	6NYCRR 227-2.6 (c) (2)	CEMS requirements	54
U-00001/E0001/002/S0001	6NYCRR 227-2.6 (c) (2)	CEMS requirements	95
U-00001/E0001/002/S0002	6NYCRR 227-2.6 (c) (2)	CEMS requirements	96, 97
U-00001/E0001/002/S0003	6NYCRR 227-2.6 (c) (2)	CEMS requirements	98
U-00001/E0001/002/S0009	6NYCRR 227-2.6 (c) (2)	CEMS requirements	101
U-00001/E0001/CNG/S0010	6NYCRR 227-2.6 (c) (2)	CEMS requirements	149
U-00001	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	34, 35, 36

**Applicability Discussion:**

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-301.

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6NYCRR Part 200-.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6NYCRR Part 200-.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6NYCRR Part 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6NYCRR Part 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6NYCRR Part 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6NYCRR Part 201-3.2(a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-3.3(a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6NYCRR 201-6.5(a)(4)

This mandatory requirement applies to all Title V facilities. It requires the

## New York State Department of Environmental Conservation

### Permit Review Report

Permit ID: 2-6204-00064/00005 Renewal Number: 1



08/21/2007

permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

#### 6NYCRR 201-6.5(a)(7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

#### 6NYCRR 201-6.5(a)(8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

#### 6NYCRR Part 201-6.5(c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

#### 6NYCRR Part 201-6.5(c)(2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

#### 6NYCRR Part 201-6.5(c)(3)(ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

#### 6NYCRR 201-6.5(d)(5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

#### 6NYCRR Part 201-6.5(e)

## New York State Department of Environmental Conservation

### Permit Review Report

Permit ID: 2-6204-00064/00005    Renewal Number: 1



08/21/2007

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

#### 6NYCRR 201-6.5(f)(6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

#### 6NYCRR Part 201-6.5(g)

Permit Exclusion Provisions - specifies those actions, such as administrative orders, suits, claims for natural resource damages, etc that are not affected by the federally enforceable portion of the permit, unless they are specifically addressed by it.

#### 6NYCRR Part 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

#### 6NYCRR Part 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

#### 6NYCRR Part 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

#### 6NYCRR Part 211-.2

This regulation prohibits any emissions of air contaminants to the outdoor atmosphere which may be detrimental to human, plant or animal life or to property, or which unreasonably interferes with the comfortable enjoyment of life or property regardless of the existence of any specific air quality standard or emission limit.

#### 6 NYCRR Part 211.3

This condition requires that the opacity (i.e., the degree to which emissions other than water reduce the transmission of light) of the emissions from any air contamination source be less than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent.

#### 6 NYCRR Part 215

Prohibits open fires at industrial and commercial sites.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

40 CFR Part 68.

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

**Facility Specific Requirements**

In addition to Title V, NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST has been determined to be subject to the following regulations:

40CFR 52-A.21

This citation applies to facilities that are subject to Prevention of Significant Deterioration provisions; ie: facilities that are located in an attainment area and that emit pollutants which are listed in 40 CFR 52.21(b)(23)(i) .

40CFR 60-A

This regulation contains the General Provisions of 40 CFR 60. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements

40CFR 60-A.11

This regulation specifies the type of opacity monitoring requirements in relation to compliance with the standards and maintenance requirements.

40CFR 60-A.12

This regulation prohibits an owner or operator from concealing emissions in violation of applicable standards by any means.

40CFR 60-A.13

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**



40CFR 60-A.13 (c)

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

40CFR 60-A.13 (e)

This regulation specifies minimum frequency of operation requirements for continuous monitoring systems required by 40 CFR Part 60.

40CFR 60-A.13 (f)

This regulation specifies Specifications and Test Procedures for for continuous monitoring systems required by 40 CFR Part 60. Appendix B in Stationary Sources

40CFR 60-A.13 (h)

This regulation specifies the data averaging requirements for continuous monitoring systems subject to 40 CFR Part 60.

40CFR 60-A.14

This regulation defines the term modification and what is and is not considered to be a modification, for the purpose of rule applicability.

40CFR 60-A.15

This regulation defines the term reconstruction and what is and is not considered to be a reconstruction project, for the purpose of rule applicability.

40CFR 60-A.4

This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Quality Assurance (BQA).

40CFR 60-A.7 (a)

This regulation requires any owner or operator subject to a New Source Performance Standard (NSPS) to furnish the Administrator with notification of the dates of: construction or reconstruction, initial startup, any physical or operational changes, commencement of performance testing for continuous monitors and anticipated date for opacity observations as required.

40CFR 60-A.7 (b)

This regulation requires the owner or operator to maintain records of the occurrence and duration of any startup, shutdown, or malfunction of the source or control equipment or continuous monitoring system.

40CFR 60-A.7 (c)

This requirement details the information to be submitted in excess emissions and monitoring systems performance reports which must be submitted at least semi-annually for sources with compliance monitoring systems.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**



40CFR 60-A.7 (d)

This condition specifies the required information and format for a summary report form and details when either a summary form and/or excess emissions reports are required.

40CFR 60-A.7 (f)

This condition specifies requirements for maintenance of files of all measurements, including continuous monitoring system (CMS), monitoring device, and performance testing measurements; all CMS performance evaluations; all CMS or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices for at least two years.

40CFR 60-A.8 (a)

This regulation contains the requirements for the completion date and reporting of Performance Testing (stack testing), at the facility. Within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup, the owner or operator of the facility must conduct performance test(s) and furnish a written report of the test results.

40CFR 60-A.8 (b)

This regulation contains the requirements for Performance test methods and procedures, to be used by the owner or operator, of the affected facility.

40CFR 60-A.8 (c)

This condition contains the requirements for operating conditions, of the emission source, during performance testing.

40CFR 60-A.8 (d)

This regulation contains the requirements for advance notification of Performance (stack) testing.

40CFR 60-A.8 (e)

This regulation requires the facility to provide appropriate sampling ports, safe platforms and utilities as necessary for Performance (stack) testing.

40CFR 60-A.8 (f)

This regulation requires that Performance (stack) tests consist of three runs unless otherwise specified. The rule also designates the allowable averaging methods for the analysis of the results.

40CFR 60-A.9

This rule citation allows the public access to any information submitted to the EPA Administrator (or state contact), in conjunction with a project subject to this section of the regulation.

40CFR 60-Db.42b (j)

This subdivision contains an exemption from the percent reduction requirements if the affected facility fires very low sulfur content oil.

40CFR 60-Db.43b (b)

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**



This regulation establishes limits for particulate matter emissions for a facility that combusts oil or mixtures of oil with other fuels.

40CFR 60-Db.43b (f)

This regulation specifies maximum allowable opacity for affected affected sources. The opacity of the emission may not exceed 20%, except for one six minute period when the maximum opacity may not exceed 27%.

40CFR 60-Db.43b (g)

This regulation specifies that the particulate matter and opacity standards apply at all times, except during periods of startup, shutdown or malfunction.

40CFR 60-Db.44b (a) (1)

These standards apply to all boilers firing natural gas and/or distillate oil except as provided in 40 CFR 60.44b(a)(4) Duct Burners Used in a Combined Cycle System.

40CFR 60-Db.44b (h)

This regulation specifies that the NSPS nitrogen oxide standards apply at all time including periods of startup, shutdown, or malfunction.

40CFR 60-Db.44b (i)

This subdivision requires that the facility use a 30 day rolling average to determine compliance with any applicable standards in this Subpart.

40CFR 60-Db.44b (j)

1) Combust, alone or in combination, only natural gas, distillate oil, or residual oil with a nitrogen content less than 0.30% by weight,

2) Have a combined annual capacity factor of 10% or less of natural gas, distillate oil, and residual oil with a nitrogen content of 0.30% by weight, and

3) Are subject to federally enforceable conditions limiting the above mentioned conditions.

40CFR 60-Db.45b (j)

This regulation specifies that owner or operators that combust very low sulfur oil are not subject to compliance and performance testing requirements for Sulfur Dioxide if they obtain fuel receipts as described in 40 CFR 60.49b(r)

40CFR 60-Db.46b

This section sets the compliance and performance test methods and procedures for emissions of particulate matter and oxides of nitrogen.

40CFR 60-Db.46b (d)

This regulation sets forth the analytical methods to be used to determine the emissions of particulates and opacity of emissions from the facility.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

40CFR 60-Db.46b (e) (4)

This paragraph sets the compliance and performance test methods and procedures for emissions of oxides of nitrogen.

40CFR 60-Db.46b (f)

This section sets the compliance and performance test methods and procedures for emissions of particulate matter and oxides of nitrogen.

40CFR 60-Db.47b (f)

Facilities combusting very low sulfur oil are not subject to emission monitoring requirements of the section if they obtain fuel receipts as described in 40 CFR 60-Db.49b(r).

40CFR 60-Db.48b (a)

This subdivision requires the installation of a continuous opacity monitor.

40CFR 60-Db.48b (c)

This regulation requires that the continuous monitoring system (CMS) and data recorder for nitrogen oxides be operated during all periods of operation of the affected facility except for CMS breakdowns and repairs. Data must be recorded during calibration checks, and zero and span adjustments.

40CFR 60-Db.48b (f)

This regulation requires that standby methods of obtaining minimum emissions data for oxides of nitrogen be specified by the source owner or operator.

40CFR 60-Db.49b (a)

This subdivision requires reporting and recordkeeping for affected steam generating units - initial notification.

40CFR 60-Db.49b (b)

This subdivision requires reporting and recordkeeping for affected steam generating units - initial performance and CEM testing.

40CFR 60-Db.49b (d)

This subdivision requires reporting and recordkeeping for affected steam generating units - annual fuel capacity factors.

40CFR 60-Db.49b (f)

This subdivision specifies that monitored opacity records must be kept at the facility.

40CFR 60-Db.49b (g)

This subdivision requires reporting and recordkeeping for affected steam generating units - specific oxides of nitrogen requirements.

40CFR 60-Db.49b (h)

This subdivision specifies that the facility must submit excess emission reports.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**

40CFR 60-Db.49b (i)

This subdivision specifies that the facility submit reports on oxides of nitrogen emissions in accordance with the required recordkeeping provisions of 40 CFR 60.49b(g).

40CFR 60-Db.49b (j)

This subdivision specifies that the facility submit reports on sulfur dioxide emission records.

40CFR 60-Db.49b (r)

This regulation specifies that owner or operators that combust very low sulfur oil are required to obtain fuel receipts. The oil need not meet the fuel nitrogen content specification in the definition of distillate oil. Reports shall be submitted to the Administrator certifying that only very low sulfur oil meeting this definition was combusted

40CFR 60-GG.333

This regulation sets the emission limit of sulfur dioxide from a gas turbine at 0.015 % by volume at 15% excess oxygen.

40CFR 60-GG.333 (a)

This regulation sets the emission limit of sulfur dioxide from a gas turbine at 0.015 % by volume at 15% excess oxygen

40CFR 60-KKKK.4320 (a)

What emission limits must the facility meet for Nitrogen Oxide.

40CFR 60-KKKK.4340 (a)

This condition describes how to demonstrate compliance for Nitrogen Oxides with this rule

40CFR 60-KKKK.4365 (a)

This condition describes what reports must be submitted for each affected unit

40CFR 60-KKKK.4375 (b)

This condition describes what reports must be submitted for each affected unit.

40CFR 60-KKKK.4400 (a)

This condition describes how to conduct the initial and subsequent performance tests for Nitrogen Oxides.

40CFR 60-KKKK.4400 (b)

This explains about the NOx limit performance test details for the turbine and the duct burner.

6NYCRR 201-7

This regulation sets forth an emission cap that cannot be exceeded by the facility. In this permit that cap is

6NYCRR 212.3 (a)

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**



This rule requires compliance with the degree of control specified in Tables 2, 3 and 4 for existing (on or before July 1, 1973) process emission sources.

6NYCRR 225 .1 (a) (3)

This regulation limits the amount of sulfur that can be in fuel burned at a stationary source. It references Table 1 of the 1979 version of the sulfur in fuel limitations expressed in terms of percent by weight for fuel oil and pounds per million Btu gross heat content for solid fuel. **NOTE: This citation has been replaced by requirements cited under 225-1.2(a)(2) and is no longer part of current State regulations, however, it remains part of New York State's approved State Implementation Plan (SIP).**

6NYCRR 225-1.8

This regulation requires an owner or operator of a facility which purchases and fires coal and/or oil to submit reports to the commissioner containing fuel analysis data, information on the quantity of the fuel received, burned, and results of any stack sampling, stack monitoring and any other procedures to ensure compliance with the provisions of 6 NYCRR Part 225-1.

6NYCRR 227 .2 (b) (1)

This regulation is from the 1972 version of Part 227 and still remains as part of New York's SIP. The rule establishes a particulate limit of 0.10 lbs/mmBtu based on a 2 hour average emission for any oil fired stationary combustion installation.

6NYCRR 227-1.2 (a) (1)

This regulation establishes a particulate emission limit in terms of lbs per mmBtu of heat input for stationary combustion units of greater than 250 mmBtu/hr heat input capacity which fire coal, oil, or coal derived fuels.

6NYCRR 227-1.2 (b)

This regulation requires the total heating capacity connected to a stack to be used to determine the permissible particulate emission rate.

6NYCRR 227-1.3

This regulation requires a limitation and compliance monitoring for opacity from a stationary combustion installation.

6NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6NYCRR 227-1.4 (a)

Subdivisions (a) and (f) of this section (227-1.4) have not been approved by EPA and have not been included in the NYS SIP.

6NYCRR 227-1.4 (b)

This regulation requires the specific contents of excess emissions reports for opacity from facilities that



**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**

**08/21/2007**

employ continuous opacity monitors (COMs).

6NYCRR 227-2.4 (b) (1)

This paragraph provides a table for gas only, gas and/or oil firing capable, pulverized coal, and overfeed stoker emission limits. Compliance is determined by a stack test.

6NYCRR 227-2.4 (d)

This rule specifies that the reasonably available control technology (RACT) requirement for small boilers (< or = 50 million BTUs/hr) at Title V facilities consists of an annual tune-up.

6NYCRR 227-2.4 (e) (2)

The regulation sets the upper limit for NOx emissions generated by gas turbines

6NYCRR 227-2.6 (c)

This condition gives information of the requirements of the stack test, time frame to submit the protocol and the references for the procedures of conducting the tests

6NYCRR 227-2.6 (c) (2)

This regulation requires the facility to submit a compliance test protocol to the Department at least 90 days prior to emission testing.

6NYCRR 231-2

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

**Non Applicability Analysis**

**List of non-applicable rules and regulations:**

<b>Location Facility/EU/EP/Process/ES</b>	<b>Short Description</b>	<b>Regulation</b>
U-00001	Review of Major Stationary Sources and Major Modifications - Source Applicability	40CFR 52-A.21(i) (1)
	Reason: For this project the facility is capping the potential to emit (PTE) of the new boiler to 39.5 TPY NOx and 39.5 TPY SO2, by limiting the fuel usage. The total annual NOx and SO2 emissions shall not exceed 39.5 TPY each. This should be determined by the facility by documenting daily fuel consumption and submittal of annual emission statement.	
U-00001	New Source Review in Nonattainment Areas and Ozone Transport Region	6NYCRR 231-2
	Reason: The facility added fourth boiler on 01/01/2006. But the facility is capping the MAP (maximum annual Potential) of the facility as the same as before by limiting the fuel usage. Since there is no MAP increase, this is not subject to Subpart 231-2.	



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6204-00064/00005 Renewal Number: 1

08/21/2007

NOTE: Non-applicability determinations are cited as a permit condition under 6 NYCRR Part 201-6.5(g). This information is optional and provided only if the applicant is seeking to obtain formal confirmation, within an issued Title V permit, that specified activities are not subject to the listed federal applicable or state only requirement. The applicant is seeking to obtain verification that a requirement does not apply for the stated reason(s) and the Department has agreed to include the non-applicability determination in the issued Title V permit which in turn provides a shield against any potential enforcement action.

Compliance Certification

Summary of monitoring activities at NY - PRESBYTERIAN HOSPITAL-525 E 68TH ST:

Table with 3 columns: Location (Facility/EU/EP/Process/ES), Type of Monitoring, and Cond No. The table lists various monitoring procedures and their corresponding condition numbers, such as 'record keeping/maintenance procedures' with condition numbers ranging from 70 to 145.



# New York State Department of Environmental Conservation

## Permit Review Report

Permit ID: 2-6204-00064/00005    Renewal Number: 1

08/21/2007

U-00001/E0001/002/S0009	record keeping/maintenance procedures	146
U-00001/E0001/CNG/S0010	intermittent emission testing	154
U-00001/E0001/CNG/S0010	intermittent emission testing	155
U-00001/E0001/CNG/S0010	record keeping/maintenance procedures	156
U-00001/E0001/CNG/S0011	record keeping/maintenance procedures	165
U-00001/E0001/CNG/S0010	record keeping/maintenance procedures	157
U-00001/E0001/CNG/S0011	record keeping/maintenance procedures	166
U-00001/E0001/CNG/S0010	record keeping/maintenance procedures	158
U-00001/E0001/CNG/S0011	record keeping/maintenance procedures	167
FACILITY	record keeping/maintenance procedures	5
FACILITY	record keeping/maintenance procedures	6
U-00001	work practice involving specific operations	34
U-00001	work practice involving specific operations	35
U-00001	record keeping/maintenance procedures	36
U-00001/E0001/001/S0009	work practice involving specific operations	51
U-00001/E0001/002/S0009	work practice involving specific operations	99
U-00001/E0001/CNG/S0010	work practice involving specific operations	147
U-00001/E0001/CNG/S0011	work practice involving specific operations	161
FACILITY	record keeping/maintenance procedures	7
U-00002	record keeping/maintenance procedures	171
FACILITY	work practice involving specific operations	26
FACILITY	record keeping/maintenance procedures	25
U-00001/-/002	intermittent emission testing	42
U-00001	intermittent emission testing	37
U-00001	continuous emission monitoring (cem)	39
U-00001/E0001	monitoring of process or control device parameters as surrogate	43
FACILITY	monitoring of process or control device parameters as surrogate	179
FACILITY	record keeping/maintenance procedures	27
U-00001/E0001/001	intermittent emission testing	44
U-00001/E0001/002	intermittent emission testing	94
U-00001/E0001/001/S0001	record keeping/maintenance procedures	45
U-00001/E0001/001/S0002	record keeping/maintenance procedures	47
U-00001/E0001/001/S0003	record keeping/maintenance procedures	49
U-00001/E0001/001/S0009	record keeping/maintenance procedures	52
U-00001/E0001/CNG/S0010	intermittent emission testing	148
U-00001/E0001/CNG/S0011	intermittent emission testing	162
U-00001/E0001/001/S0009	intermittent emission testing	53
U-00001/E0001/002/S0009	intermittent emission testing	100
FACILITY	record keeping/maintenance procedures	28
U-00001/E0001/001/S0001	record keeping/maintenance procedures	46
U-00001/E0001/001/S0002	record keeping/maintenance procedures	48
U-00001/E0001/001/S0003	record keeping/maintenance procedures	50
U-00001/E0001/001/S0009	record keeping/maintenance procedures	54
U-00001/E0001/002/S0001	record keeping/maintenance procedures	95
U-00001/E0001/002/S0002	record keeping/maintenance procedures	96
U-00001/E0001/002/S0002	record keeping/maintenance procedures	97
U-00001/E0001/002/S0003	record keeping/maintenance procedures	98
U-00001/E0001/002/S0009	record keeping/maintenance procedures	101
U-00001/E0001/CNG/S0010	record keeping/maintenance procedures	149

### Basis for Monitoring

Condition # 1-3 (6 NYCRR 201-6.5(c)(3)(ii)): This facility-wide monitoring condition has been added

## New York State Department of Environmental Conservation

### Permit Review Report

Permit ID: 2-6204-00064/00005 Renewal Number: 1

08/21/2007



to all Title V permits issued in New York State to clarify that all required monitoring reports are to be submitted at least every 6 months on a calendar year basis in order to comply with Title V requirements regardless of the reporting requirement that may be listed for an individual permit monitoring condition. Any monitoring conditions that may have more frequent reporting requirements will remain in effect as displayed in the condition.

Condition # 26 (6 NYCRR 201-6.5(e)): This facility-wide monitoring condition has been added in order to comply with the Title V annual compliance certification requirements and specifies the mailing addresses for submitting the compliance reports.

Condition # 29 (6 NYCRR 202-2.1): This facility-wide monitoring condition is a requirement for all Title V facilities. These facilities must submit an annual emission statement by April 15th of each year.

Condition # 33 (6 NYCRR 225-1.8) & Condition # 34 (6 NYCRR 225.1(a)(3)) :- These facility level monitoring conditions limit the sulfur content of fuel oil used at the facility and specify sampling and record keeping requirements. The sulfur content must be determined by the seller. The facility must maintain a log of the sulfur content of oil on a per delivery basis for at least three years.

Conditions 1-5 (6 NYCRR 227-1.2(a)(1)): This is an Emission Unit level condition which requires performance of a stack test once per permit term on the boilers at the facility to ensure compliance with the particulate emissions limit of 0.10 pounds per million Btu. In addition, this permit requires the facility to conduct daily monitoring and maintain records of fuel flow. For the next stack test, the facility will identify at least two operating parameters that will be monitored daily to demonstrate ongoing compliance with the particulate emissions limit. During the test, acceptable ranges for these parameters will be established. These parameters and ranges will be added to the permit.

Conditions # 39 (6 NYCRR 227-1.3): This is an Emission Unit level condition for monitoring of opacity limits using a Continuous Opacity Monitoring (CEM) system.

Conditions # 41 and # 42 (both under 6 NYCRR 227-2.4(b)(1)) are the Emission Unit level conditions that specify the NOx RACT limits for the large boilers at the facility. Compliance will be based on a stack test once per permit term for each fuel feed to ensure compliance with the NOx emission limits. In addition, this permit requires the facility to conduct daily monitoring and maintain records of fuel flow. For the next stack test, the facility will identify at least two operating parameters that will be monitored daily to demonstrate ongoing compliance with the NOx emission limits. During the test, acceptable ranges for these parameters will be established. These parameters and ranges will be added to the permit.

Condition # 1-7 (6 NYCRR 212.3(a)): This monitoring conditions have been added at the Emission Unit level to specify the monitoring, record keeping and reporting requirements for the emissions of ethylene oxide from the two sterilizers at the facility.

Condition 1-6 (6 NYCRR 227.2(b)(1)): This condition is an emission unit level and process level intermittent emission testing condition for particulates that applies to EU: U-00001 and Proc: 002. This condition is from the 1972 version of Part 227 and still remains as part of New York's SIP. This condition establishes a particulate limit of 0.10 lbs/mmBtu based on a 2 hour average emission for any oil fired stationary combustion installation.

**New York State Department of Environmental Conservation**

**Permit Review Report**

**Permit ID: 2-6204-00064/00005    Renewal Number: 1**



**08/21/2007**