

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

Facility Identification Data

Name: RAVENSWOOD GENERATING STATION
Address: 38-54 VERNON BLVD
QUEENS, NY 11101

Owner/Firm

Name: KEYSpan - RAVENSWOOD SERVICES CORP
Address: 175 EAST OLD COUNTRY RD
HICKSVILLE, NY 11801, USA
Owner Classification: Corporation/Partnership

Permit Contacts

Division of Environmental Permits:
Name: ELIZABETH A CLARKE
Address: ONE HUNTERS POINT PLAZA
47-40 21ST ST
LONG ISLAND CITY, NY 11101-5407
Phone:7184824997

Division of Air Resources:
Name: PARESH SHAH
Address: ONE HUNTERS POINT PLAZA
47-40 21ST ST
LONG ISLAND CITY, NY 11101

Air Permitting Contact:
Name: ROBERT D TEETZ
Address: KEYSpan
175 EAST OLD COUNTRY RD
HICKSVILLE, NY 11801-4280
Phone:5165452577

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

Application for renewal of Air Title V Facility.

Attainment Status

RAVENSWOOD GENERATING STATION is located in the town of QUEENS in the county of QUEENS.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor

Facility Description

THIS FACILITY CONSISTS OF THREE (3) STEAM BOILER TURBINE/GENERATOR SETS AND SEVENTEEN (17) SIMPLE CYCLE COMBUSTION TURBINES WITH A COMBINED NOMINAL RATING OF 2,288 MW AND THREE (3) EMERGENCY GENERATORS. NATURAL GAS IS THE PRIMARY FUEL FOR ALL UNITS, WITH LOW-SULFUR #6 RESIDUAL OIL AND/OR DISTILLATE FUEL USED WHEN GAS IS UNAVAILABLE.

Permit Structure and Description of Operations

The Title V permit for RAVENSWOOD GENERATING STATION is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process.

A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device.

[NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
- incinerator - devices which burn waste material for disposal
- control - emission control devices
- process - any device or contrivance which may emit air contaminants that is not included in the above categories.

RAVENSWOOD GENERATING STATION is defined by the following emission unit(s):
Emission unit U00010 - THIS UNIT CONSISTS OF DUAL, TANGENTIALLY FIRED FURNACES COMPRISING A SINGLE BOILER. STEAM FROM THIS BOILER OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 390 MW. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTION MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH THE PRIMARY FUEL.

CLOSE COUPLED OVER-FIRED AIR (CCOFA) COMPARTMENTS HAVE BEEN ADDED TO THE UPPER AND LOWER WINDBOX SECTIONS OF THIS EMISSION UNIT. CCOFA IS A PROVEN NOx REDUCTION TECHNOLOGY AND WAS INSTALLED AS PART OF KEYSpan'S PLAN TO MEET PHASE III OF THE NOx BUDGET REQUIREMENTS. INSTALLATION OCCURRED DURING THE FALL 2000 SCHEDULED OUTAGE.

Emission unit U00010 is associated with the following emission points (EP):
00010

It is further defined by the following process(es):

Process: P01 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF #6 RESIDUAL OIL IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER. A non-hazardous additive may be used to improve combustion.

Process: P02 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P03 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE CO-FIRING OF WASTE FUEL A WITH #6 RESIDUAL OIL AND/OR NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P04 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS INVOLVES THE INCINERATION OF NON-HAZARDOUS BOILER CHEMICAL CLEANING SOLUTIONS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



Emission unit U00020 - THIS UNIT CONSISTS OF DUAL, TANGENTIALLY FIRED FURNACES COMPRISING A SINGLE BOILER. STEAM FROM THIS BOILER OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 390 MW. THIS BOILER IS EQUIPPED WITH A CLOSE-COUPLED-OVERFIRED-AIR (CCOFA) SYSTEM TO REDUCE THE FORMATION OF NITROGEN OXIDES. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTIONS MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH PRIMARY FUEL.

Emission unit U00020 is associated with the following emission points (EP):
00020

It is further defined by the following process(es):

Process: P05 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF #6 RESIDUAL OIL IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER. A non-hazardous additive may be used to improve combustion.

Process: P06 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P07 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE CO-FIRING OF WASTE FUEL A WITH #6 RESIDUAL OIL AND/OR NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P08 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS INVOLVES THE INCINERATION OF NON-HAZARDOUS BOILER CHEMICAL CLEANING SOLUTIONS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Emission unit U00030 - THIS UNIT CONSISTS OF DUAL BOILERS, EACH HEATED BY DUAL, TANGENTIALLY FIRED FURNACES. STEAM FROM THESE BOILERS OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 972 MW. KEYSpan WILL BE INSTALLING A CLOSE-COUPLED-OVERFIRED-AIR (CCOFA) SYSTEM BY LATE 2001 TO FURTHER REDUCE THE FORMATION OF NITROGEN OXIDES. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTION MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH THE PRIMARY FUEL.

Emission unit U00030 is associated with the following emission points (EP):
00030

It is further defined by the following process(es):

Process: P09 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF #6 RESIDUAL OIL IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER. A non-hazardous additive may be used to improve combustion.

Process: P10 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P11 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE CO-FIRING OF WASTE FUEL A WITH #6 RESIDUAL OIL AND/OR NATURAL GAS IN A

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P12 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS INVOLVES THE INCINERATION OF NON-HAZARDOUS BOILER CHEMICAL CLEANING SOLUTIONS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Emission unit UCT001 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. THIS UNIT IS A "BLACK-START" COMBUSTION TURBINE DESIGNED TO PROVIDE SUFFICIENT POWER TO BRING THE ENTIRE POWER STATION BACK ON-LINE FOLLOWING A CATASTROPHIC SYSTEM COLLAPSE. A DIESEL ENGINE, EMISSION POINT GT0S1, EMISSION UNIT U-CT0S1 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT001 is associated with the following emission points (EP):

GT001

It is further defined by the following process(es):

Process: P21 is located at GROUND FLOOR, Building GT1 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT004 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S4, EMISSION UNIT U-CT0S4 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT004 is associated with the following emission points (EP):

CT004

It is further defined by the following process(es):

Process: P24 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P25 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P26 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT005 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S5, EMISSION UNIT U-CT0S5 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT005 is associated with the following emission points (EP):

CT005

It is further defined by the following process(es):

Process: P29 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P30 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P31 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT006 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S6, EMISSION UNIT U-CT0S6 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT006 is associated with the following emission points (EP):

CT006

It is further defined by the following process(es):

Process: P34 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P35 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P36 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT007 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S7, EMISSION UNIT U-CT0S7 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT007 is associated with the following emission points (EP):

CT007

It is further defined by the following process(es):

Process: P39 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P40 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P41 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT008 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

Emission unit UCT008 is associated with the following emission points (EP):
CT008

It is further defined by the following process(es):

Process: P44 is located at GROUND FLOOR, Building CT8 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P45 is located at GROUND FLOOR, Building CT8 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P46 is located at GROUND FLOOR, Building CT8 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT009 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

Emission unit UCT009 is associated with the following emission points (EP):
CT009

It is further defined by the following process(es):

Process: P47 is located at GROUND FLOOR, Building CT9 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P48 is located at GROUND FLOOR, Building CT9 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P49 is located at GROUND FLOOR, Building CT9 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT010 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

Emission unit UCT010 is associated with the following emission points (EP):
CT010

It is further defined by the following process(es):

Process: P50 is located at GROUND FLOOR, Building CT10 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P51 is located at GROUND FLOOR, Building CT10 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P52 is located at GROUND FLOOR, Building CT10 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT011 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

Emission unit UCT011 is associated with the following emission points (EP):
CT011

It is further defined by the following process(es):

Process: P53 is located at GROUND FLOOR, Building CT11 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P54 is located at GROUND FLOOR, Building CT11 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Process: P55 is located at GROUND FLOOR, Building CT11 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT0S1 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT001. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S1 is associated with the following emission points (EP):
GT0S1

It is further defined by the following process(es):

Process: P22 is located at GROUND FLOOR, Building CT1 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



Process: P23 is located at GROUND FLOOR, Building CT1 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S4 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT004. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S4 is associated with the following emission points (EP):

CT0S4

It is further defined by the following process(es):

Process: P27 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P28 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S5 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT005. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S5 is associated with the following emission points (EP):

CT0S5

It is further defined by the following process(es):

Process: P32 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P33 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S6 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT006. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S6 is associated with the following emission points (EP):

CT0S6

It is further defined by the following process(es):

Process: P37 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P38 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S7 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT007. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S7 is associated with the following emission points (EP):
CT0S7

It is further defined by the following process(es):

Process: P42 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P43 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT201 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT201 is associated with the following emission points (EP):
CT201

It is further defined by the following process(es):

Process: P56 is located at GROUND FLOOR, Building CT21 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P57 is located at GROUND FLOOR, Building CT21 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



identified in the Emission Unit portion of this permit.

Process: P58 is located at GROUND FLOOR, Building CT21 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT202 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT202 is associated with the following emission points (EP):
CT202

It is further defined by the following process(es):

Process: P59 is located at GROUND FLOOR, Building CT22 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P60 is located at GROUND FLOOR, Building CT22 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P61 is located at GROUND FLOOR, Building CT22 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT203 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT203 is associated with the following emission points (EP):

CT203

It is further defined by the following process(es):

Process: P62 is located at GROUND FLOOR, Building CT23 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P63 is located at GROUND FLOOR, Building CT23 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P64 is located at GROUND FLOOR, Building CT23 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT204 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT204 is associated with the following emission points (EP):

CT204

It is further defined by the following process(es):

Process: P65 is located at GROUND FLOOR, Building CT24 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



Process: P66 is located at GROUND FLOOR, Building CT24 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P67 is located at GROUND FLOOR, Building CT24 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT301 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT301 is associated with the following emission points (EP):
CT301

It is further defined by the following process(es):

Process: P68 is located at GROUND FLOOR, Building CT31 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P69 is located at GROUND FLOOR, Building CT31 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P70 is located at GROUND FLOOR, Building CT31 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT302 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT302 is associated with the following emission points (EP):

CT302

It is further defined by the following process(es):

Process: P71 is located at GROUND FLOOR, Building CT32 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P72 is located at GROUND FLOOR, Building CT32 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P73 is located at GROUND FLOOR, Building CT32 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT303 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT303 is associated with the following emission points (EP):

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

CT303

It is further defined by the following process(es):

Process: P74 is located at GROUND FLOOR, Building CT33 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P75 is located at GROUND FLOOR, Building CT33 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P76 is located at GROUND FLOOR, Building CT33 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT304 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT304 is associated with the following emission points (EP):

CT304

It is further defined by the following process(es):

Process: P77 is located at GROUND FLOOR, Building CT34 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P78 is located at GROUND FLOOR, Building CT34 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P79 is located at GROUND FLOOR, Building CT34 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDES MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Title V/Major Source Status

RAVENSWOOD GENERATING STATION is subject to Title V requirements. This determination is based on the following information:

This is a TV facility.

Program Applicability

The following chart summarizes the applicability of RAVENSWOOD GENERATING STATION with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	NO
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's)

MACT Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code	Description
4911	ELECTRIC SERVICES

SCC Codes

SCC or Source Classification Code is a code developed and used by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code	Description
1-01-013-02	EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION ELECTRIC UTILITY BOILER - LIQUID WASTE Waste Oil
1-01-006-04	EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION ELECTRIC UTILITY BOILER - NATURAL GAS Tangentially Fired Units
1-01-004-04	EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION ELECTRIC UTILITY BOILER - RESIDUAL OIL Grade 6 Oil: Tangential Firing
2-01-009-01	INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION ELECTRIC UTILITY IC ENGINE - KEROSENE/NAPHTHA (JET FUEL) Turbine
2-01-001-02	INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - DISTILLATE OIL (DIESEL) Reciprocating
2-01-001-01	INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - DISTILLATE OIL (DIESEL) Turbine
2-01-002-01	INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

	ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - NATURAL GAS
	Turbine
2-02-001-02	INTERNAL COMBUSTION ENGINES - INDUSTRIAL
	INDUSTRIAL INTERNAL COMBUSTION ENGINE - DISTILLATE OIL (DIESEL)
	Reciprocating
2-02-009-02	INTERNAL COMBUSTION ENGINES - INDUSTRIAL
	INDUSTRIAL INTERNAL COMBUSTION ENGINE - KEROSENE/NAPHTHA (JET FUEL)
	Reciprocating
5-03-007-01	SOLID WASTE DISPOSAL - INDUSTRIAL
	SOLID WASTE DISPOSAL: INDUSTRIAL - LIQUID WASTE General

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Series code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE	
		lbs/yr	Range
000123-91-1	1,4-DIETHYLENE DIOXIDE (HAP)	> 0	but < 10 tpy
007440-38-2	ARSENIC (HAP)	> 0	but < 10 tpy
007440-43-9	CADMIUM (HAP)	> 0	but < 10 tpy
000630-08-0	CARBON MONOXIDE	>= 250	tpy
007440-47-3	CHROMIUM (HAP)	> 0	but < 10 tpy
007440-50-8	COPPER	> 0	but < 2.5 tpy
0NY100-00-0	HAP	>= 50	tpy but < 100 tpy
007439-89-6	IRON	> 0	but < 2.5 tpy
007439-92-1	LEAD (HAP)	> 0	but < 10 tpy
007439-97-6	MERCURY (HAP)	> 0	but < 10 tpy
007440-02-0	NICKEL METAL AND INSOLUBLE COMPOUNDS (HAP)	>= 10	tpy
0NY210-00-0	OXIDES OF NITROGEN	>= 250	tpy

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

0NY075-00-0	PARTICULATES	>= 250 tpy
0NY075-00-5	PM-10	>= 250 tpy
007446-09-5	SULFUR DIOXIDE	>= 250 tpy
0NY998-00-0	VOC	>= 250 tpy
007440-66-6	ZINC	> 0 but < 2.5 tpy

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years,

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L:

Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Short Description	Condition
FACILITY	ECL 19-0301	Powers and Duties of the Department with respect to air pollution control	85
FACILITY	40CFR 68	Chemical accident prevention provisions	21
FACILITY	40CFR 82-F	Protection of Stratospheric Ozone - recycling and emissions	22

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

FACILITY	6NYCRR 200.6	reduction Acceptable ambient air quality.	1
FACILITY	6NYCRR 200.7	Maintenance of equipment.	10
FACILITY	6NYCRR 201-1.4	Unavoidable noncompliance and violations	86
FACILITY	6NYCRR 201-1.7	Recycling and Salvage	11
FACILITY	6NYCRR 201-1.8	Prohibition of reintroduction of collected contaminants to the air	12
FACILITY	6NYCRR 201-3.2(a)	Exempt Activities - Proof of eligibility	13
FACILITY	6NYCRR 201-3.3(a)	Trivial Activities - proof of eligibility	14
FACILITY	6NYCRR 201-6	Title V Permits and the Associated Permit Conditions	23, 52, 53
FACILITY	6NYCRR 201-6.5(a) (4)	General conditions	15
FACILITY	6NYCRR 201-6.5(a) (7)	General conditions	
Fees 2			
FACILITY	6NYCRR 201-6.5(a) (8)	General conditions	16
FACILITY	6NYCRR 201-6.5(c)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	3
FACILITY	6NYCRR 201-6.5(c) (2)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	4
FACILITY	6NYCRR 201-6.5(c) (3)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	24
FACILITY	6NYCRR 201-6.5(c) (3) (ii)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	5
FACILITY	6NYCRR 201-6.5(d) (5)	Compliance schedules	17
FACILITY	6NYCRR 201-6.5(e)	Compliance Certification	6
FACILITY	6NYCRR 201-6.5(f) (6)	Off Permit Changes	18
FACILITY	6NYCRR 201-6.5(g)	Permit shield	25
FACILITY	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	54, 55
U-CT201/CT201	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	70
U-CT202/CT202	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	72
U-CT203/CT203	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	74
U-CT204/CT204	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	76
U-CT301/CT301	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	78
U-CT302/CT302	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	80
U-CT303/CT303	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	82
U-CT304/CT304	6NYCRR 201-7.2	Emissions capping using synthetic minor permits	84
FACILITY	6NYCRR 202-1.1	Required emissions tests.	19
FACILITY	6NYCRR 202-2.1	Emission Statements - Applicability	7

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

FACILITY	6NYCRR 202-2.5	Emission Statements - record keeping requirements.	8
FACILITY	6NYCRR 204-1.6	Standard Requirements	26
FACILITY	6NYCRR 204-2.1	Authorization and Responsibilities of the NOx Authorized Account Representative	27
FACILITY	6NYCRR 204-4.1	Compliance Certification Report	28, 29, 30
FACILITY	6NYCRR 204-7.1	Submission of NOx Allowance Transfers	31
FACILITY	6NYCRR 204-8.1	General Requirements	32, 33, 34
FACILITY	6NYCRR 204-8.2	Initial Certification and Recertification Procedures	35, 36
FACILITY	6NYCRR 204-8.3	Out of Control Periods	37
FACILITY	6NYCRR 204-8.4	Notifications	38
FACILITY	6NYCRR 204-8.7	Additional Requirements to Provide Heat Input Data for Allocations Purposes	39
FACILITY	6NYCRR 207	Control Measures for an Air Pollution Episode	40
FACILITY	6NYCRR 211.2	General Prohibitions - air pollution prohibited.	87
FACILITY	6NYCRR 211.3	General Prohibitions - visible emissions limited	20
FACILITY	6NYCRR 215	Open Fires	9
FACILITY	6NYCRR 225-1.2(a)(2)	Sulfur in Fuel Limitations Post 12/31/87.	41, 42
FACILITY	6NYCRR 225-1.8	Reports, sampling and analysis.	43
FACILITY	6NYCRR 225-1.8(d)	Reports, sampling, and analysis	44
FACILITY	6NYCRR 225-2.3(b)	Eligibility to burn waste fuel A.	45
FACILITY	6NYCRR 225-2.4(b)	Eligibility to burn waste fuels A and B.	46, 47, 48, 49
U-00010	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	56
U-00020	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	59
U-00030	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	62
U-CT008	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	65
U-CT009	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	66
U-CT010	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	67
U-CT011	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	68
U-CT201	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	69
U-CT202	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	71
U-CT203	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	73

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

U-CT204	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	75
U-CT301	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	77
U-CT302	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	79
U-CT303	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	81
U-CT304	6NYCRR 227-1.2(a)(1)	Particulate Emissions from Liquid Fuels.	83
FACILITY	6NYCRR 227-1.3(a)	Smoke Emission Limitations.	50
U-00010/00010	6NYCRR 227-1.4(a)	Stack Monitoring. (see narrative)	105
U-00020/00020	6NYCRR 227-1.4(a)	Stack Monitoring. (see narrative)	123
U-00030/00030	6NYCRR 227-1.4(a)	Stack Monitoring. (see narrative)	141
U-00010/00010	6NYCRR 227-1.4(b)	Stack Monitoring	58
U-00020/00020	6NYCRR 227-1.4(b)	Stack Monitoring	61
U-00030/00030	6NYCRR 227-1.4(b)	Stack Monitoring	64
FACILITY	6NYCRR 227-2.5(b)	System-wide averaging option.	51
U-00010	6NYCRR 227-2.6(a)(1)	Testing, monitoring, and reporting requirements for very large boilers.	57
U-00020	6NYCRR 227-2.6(a)(1)	Testing, monitoring, and reporting requirements for very large boilers.	60
U-00030	6NYCRR 227-2.6(a)(1)	Testing, monitoring, and reporting requirements for very large boilers.	63
U-CT201/CT201	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	70
U-CT202/CT202	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	72
U-CT203/CT203	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	74
U-CT204/CT204	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	76
U-CT301/CT301	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	78
U-CT302/CT302	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	80
U-CT303/CT303	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	82
U-CT304/CT304	6NYCRR 231-2	New Source Review in Nonattainment Areas and Ozone Transport Region	84
U-00010	6NYCRR 237-1.6(a)	Standard permit requirements	88
U-00020	6NYCRR 237-1.6(a)	Standard permit requirements	106
U-00030	6NYCRR 237-1.6(a)	Standard permit requirements	124
U-CT201	6NYCRR 237-1.6(a)	Standard permit	142

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

U-CT202	6NYCRR 237-1.6(a)	requirements Standard permit requirements	150
U-CT203	6NYCRR 237-1.6(a)	Standard permit requirements	158
U-CT204	6NYCRR 237-1.6(a)	Standard permit requirements	166
U-CT301	6NYCRR 237-1.6(a)	Standard permit requirements	174
U-CT302	6NYCRR 237-1.6(a)	Standard permit requirements	182
U-CT303	6NYCRR 237-1.6(a)	Standard permit requirements	190
U-CT304	6NYCRR 237-1.6(a)	Standard permit requirements	198
U-00010	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	89
U-00020	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	107
U-00030	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	125
U-CT201	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	143
U-CT202	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	151
U-CT203	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	159
U-CT204	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	167
U-CT301	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	175
U-CT302	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	183
U-CT303	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	191
U-CT304	6NYCRR 237-1.6(c)	Nitrogen oxides requirements	199
U-00010	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	90
U-00020	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	108
U-00030	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	126
U-CT201	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	144
U-CT202	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	152
U-CT203	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	160
U-CT204	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	168
U-CT301	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	176
U-CT302	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	184
U-CT303	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	192
U-CT304	6NYCRR 237-1.6(e)	Recordkeeping and reporting requirements	200
U-00010	6NYCRR 237-1.6(f)	Liability	91
U-00020	6NYCRR 237-1.6(f)	Liability	109
U-00030	6NYCRR 237-1.6(f)	Liability	127

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

U-CT201	6NYCRR 237-1.6(f)	Liability	145
U-CT202	6NYCRR 237-1.6(f)	Liability	153
U-CT203	6NYCRR 237-1.6(f)	Liability	161
U-CT204	6NYCRR 237-1.6(f)	Liability	169
U-CT301	6NYCRR 237-1.6(f)	Liability	177
U-CT302	6NYCRR 237-1.6(f)	Liability	185
U-CT303	6NYCRR 237-1.6(f)	Liability	193
U-CT304	6NYCRR 237-1.6(f)	Liability	201
U-00010	6NYCRR 237-1.6(g)	Effect on other authorities	92
U-00020	6NYCRR 237-1.6(g)	Effect on other authorities	110
U-00030	6NYCRR 237-1.6(g)	Effect on other authorities	128
U-CT201	6NYCRR 237-1.6(g)	Effect on other authorities	146
U-CT202	6NYCRR 237-1.6(g)	Effect on other authorities	154
U-CT203	6NYCRR 237-1.6(g)	Effect on other authorities	162
U-CT204	6NYCRR 237-1.6(g)	Effect on other authorities	170
U-CT301	6NYCRR 237-1.6(g)	Effect on other authorities	178
U-CT302	6NYCRR 237-1.6(g)	Effect on other authorities	186
U-CT303	6NYCRR 237-1.6(g)	Effect on other authorities	194
U-CT304	6NYCRR 237-1.6(g)	Effect on other authorities	202
U-00010	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	93
U-00020	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	111
U-00030	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	129
U-CT201	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	147
U-CT202	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	155
U-CT203	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	163
U-CT204	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	171
U-CT301	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	179
U-CT302	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	187
U-CT303	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	195
U-CT304	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	203

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

U-00010	6NYCRR 237-4.1	Compliance certification report.	94
U-00020	6NYCRR 237-4.1	Compliance certification report.	112
U-00030	6NYCRR 237-4.1	Compliance certification report.	130
U-CT201	6NYCRR 237-4.1	Compliance certification report.	148
U-CT202	6NYCRR 237-4.1	Compliance certification report.	156
U-CT203	6NYCRR 237-4.1	Compliance certification report.	164
U-CT204	6NYCRR 237-4.1	Compliance certification report.	172
U-CT301	6NYCRR 237-4.1	Compliance certification report.	180
U-CT302	6NYCRR 237-4.1	Compliance certification report.	188
U-CT303	6NYCRR 237-4.1	Compliance certification report.	196
U-CT304	6NYCRR 237-4.1	Compliance certification report.	204
U-00010	6NYCRR 237-8	MONITORING AND REPORTING	95
U-00020	6NYCRR 237-8	MONITORING AND REPORTING	113
U-00030	6NYCRR 237-8	MONITORING AND REPORTING	131
U-CT201	6NYCRR 237-8	MONITORING AND REPORTING	149
U-CT202	6NYCRR 237-8	MONITORING AND REPORTING	157
U-CT203	6NYCRR 237-8	MONITORING AND REPORTING	165
U-CT204	6NYCRR 237-8	MONITORING AND REPORTING	173
U-CT301	6NYCRR 237-8	MONITORING AND REPORTING	181
U-CT302	6NYCRR 237-8	MONITORING AND REPORTING	189
U-CT303	6NYCRR 237-8	MONITORING AND REPORTING	197
U-CT304	6NYCRR 237-8	MONITORING AND REPORTING	205
U-00010	6NYCRR 238-1.6(a)	Permit Requirements	96
U-00020	6NYCRR 238-1.6(a)	Permit Requirements	114
U-00030	6NYCRR 238-1.6(a)	Permit Requirements	132
U-00010	6NYCRR 238-1.6(c)	Sulfur Dioxide requirements	97
U-00020	6NYCRR 238-1.6(c)	Sulfur Dioxide requirements	115
U-00030	6NYCRR 238-1.6(c)	Sulfur Dioxide requirements	133
U-00010	6NYCRR 238-1.6(e)	Recordkeeping and Reporting Requirements	98
U-00020	6NYCRR 238-1.6(e)	Recordkeeping and Reporting Requirements	116
U-00030	6NYCRR 238-1.6(e)	Recordkeeping and Reporting Requirements	134
U-00010	6NYCRR 238-1.6(f)	Liability	
U-00020	6NYCRR 238-1.6(f)	Liability	

99
117



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

U-00030		6NYCRR 238-1.6(f)	Liability	
	135			
U-00010		6NYCRR 238-1.6(g)	Effect on Other Authorities	100
U-00020		6NYCRR 238-1.6(g)	Effect on Other Authorities	118
U-00030		6NYCRR 238-1.6(g)	Effect on Other Authorities	136
U-00010		6NYCRR 238-2.1	Authorization/responsibilities of the authorized account representative	101
U-00020		6NYCRR 238-2.1	Authorization/responsibilities of the authorized account representative	119
U-00030		6NYCRR 238-2.1	Authorization/responsibilities of the authorized account representative	137
U-00010		6NYCRR 238-4.1	Compliance certification report	102
U-00020		6NYCRR 238-4.1	Compliance certification report	120
U-00030		6NYCRR 238-4.1	Compliance certification report	138
U-00010		6NYCRR 238-7.1	Submission of SO2 allowance transfers	103
U-00020		6NYCRR 238-7.1	Submission of SO2 allowance transfers	121
U-00030		6NYCRR 238-7.1	Submission of SO2 allowance transfers	139
U-00010		6NYCRR 238-8	Monitoring and Reporting	104
U-00020		6NYCRR 238-8	Monitoring and Reporting	122
U-00030		6NYCRR 238-8	Monitoring and Reporting	140

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-301.

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6NYCRR Part 200-.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6NYCRR Part 200-.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6NYCRR Part 201-1.4

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6NYCRR Part 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6NYCRR Part 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6NYCRR Part 201-3.2(a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-3.3(a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

6NYCRR 201-6.5(a)(4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6NYCRR 201-6.5(a)(7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6NYCRR 201-6.5(a)(8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6NYCRR Part 201-6.5(c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6NYCRR Part 201-6.5(c)(2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6NYCRR Part 201-6.5(c)(3)

This regulation specifies that the permit incorporate all reporting requirements associated with an applicable federal rule, the submittal of any required monitoring reports at least every 6 months, and the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6NYCRR Part 201-6.5(c)(3)(ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6NYCRR 201-6.5(d)(5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6NYCRR Part 201-6.5(e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6NYCRR 201-6.5(f)(6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6NYCRR Part 201-6.5(g)

Permit Exclusion Provisions - specifies those actions, such as administrative orders, suits, claims for natural resource damages, etc that are not affected by the federally enforceable portion of the permit, unless they are specifically addressed by it.

6NYCRR Part 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6NYCRR Part 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

6NYCRR Part 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6NYCRR Part 211-.2

This regulation prohibits any emissions of air contaminants to the outdoor atmosphere which may be detrimental to human, plant or animal life or to property, or which unreasonably interferes with the comfortable enjoyment of life or property regardless of the existence of any specific air quality standard or emission limit.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

6 NYCRR Part 211.3

This condition requires that the opacity (i.e., the degree to which emissions other than water reduce the transmission of light) of the emissions from any air contamination source be less than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent.

6 NYCRR Part 215

Prohibits open fires at industrial and commercial sites.

40 CFR Part 68.

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, RAVENSWOOD GENERATING STATION has been determined to be subject to the following regulations:

6NYCRR 201-7.2

This is for capping.

6NYCRR 204-1.6

This condition requires the designated representative of the permittee to make submissions for the NO_x Budget Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.

6NYCRR 204-2.1

This condition states the submission requirements for the NO_x Budget Trading Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

6NYCRR 204-4.1

This condition covers the compliance certification report requirements for the NOx Budget Program.

6NYCRR 204-7.1

This condition lists the requirements for transfer of allowances in the NOx Budget Program.

6NYCRR 204-8.1

This condition lists the general requirements for the NOx Budget trading program. They include, but are not limited to monitoring requirements, certification, record keeping and reporting.

6NYCRR 204-8.2

This condition covers the procedures for initially certifying and recertifying the monitoring systems of the unit meet the requirements of the NOx Budget Program

6NYCRR 204-8.3

This condition states the requirements for data substitution during times when the monitoring systems do not meet applicable quality assurance requirements.

6NYCRR 204-8.4

This condition lists the addresses where monitoring plans and their modifications, compliance certifications, recertifications, quarterly QA/QC reports and petitions for alternative monitoring shall be sent.

6NYCRR 204-8.7

This condition is a requirement for monitoring and reporting if a particular monitoring scenario is utilized.

6NYCRR 207

This regulation requires the owner or operator to submit an episode action plan to the Department in accordance with the requirements of 6NYCRR Part 207. The plan must contain detailed steps which will be taken by the facility to reduce air contaminant emissions during each stage of an air pollution episode. Once approved, the facility shall take whatever actions are prescribed by the episode action plan when an air pollution episode is in effect.

6NYCRR 225-1.2 (a) (2)

This regulation prohibits any person from selling, offering for sale, purchasing or using any fuel which contains sulfur in a quantity exceeding the limitations set forth in Table 1, Table 2, or Table 3 of this section.

6NYCRR 225-1.8

This regulation requires an owner or operator of a facility which purchases and fires coal and/or oil to submit reports to the commissioner containing fuel analysis data, information on the quantity of the fuel received, burned, and results of any stack sampling, stack monitoring and any other procedures to ensure compliance with the provisions of 6 NYCRR Part 225-1.

6NYCRR 225-1.8 (d)

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006



This requires that sampling, compositing and analysis of fuel samples must be done in accordance with methods acceptable to the commissioner.

6NYCRR 225-2.3 (b)

This regulation requires that each piece of equipment which fires Waste Fuel A demonstrate, at a minimum, 99% combustion efficiency in burning Waste fuel A.

6NYCRR 225-2.4 (b)

This regulation sets the limits for the compounds that may be in Waste Fuel A or B. These are: PCB less than 50 parts per million (ppm); Total Halogens less than 1,000 ppm; Sulfur less than the limits in Part 225-1; Lead less than 250 ppm; and a minimum gross heat content of 125,000 BTU/Gallon

6NYCRR 227-1.2 (a) (1)

This regulation establishes a particulate emission limit in terms of lbs per mmBtu of heat input for stationary combustion units of greater than 250 mmBtu/hr heat input capacity which fire coal, oil, or coal derived fuels.

6NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6NYCRR 227-1.4 (a)

Subdivisions (a) and (f) of this section (227-1.4) have not been approved by EPA and have not been included in the NYS SIP.

6NYCRR 227-1.4 (b)

This regulation requires the specific contents of excess emissions reports for opacity from facilities that employ continuous opacity monitors (COMs).

6NYCRR 227-2.5 (b)

The system-wide average shall consist of a weighted average allowable emission rate based upon the weighted average of actual emissions from units that are operating. Excess reductions utilized in the system-wide average may only be counted from the lowest allowable emission rate. Simply put, if there is a more stringent emission limit than RACT already in place on the unit, then excess reductions may only be counted from below that emission rate.

6NYCRR 227-2.6 (a) (1)

This regulation establishes the monitoring requirements for NOx RACT affected very large boilers (boilers with a heat input of greater than 250 mmBtu/hr).

6NYCRR 231-2

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

6NYCRR 237-1.6 (a)

This condition requires the applicant to submit a NOx budget application for a permit and to operate in compliance with that permit.

6NYCRR 237-1.6 (c)

This subdivision outlines the standard requirements of the Acid Deposition Reduction NOx Budget Trading Program for oxides of nitrogen.

6NYCRR 237-1.6 (e)

This requires the owners and operators of the NOx budget source and each NOx budget unit at the source to keep pertinent documents at the site for a period of 5 years; and lists which documents are pertinent.

6NYCRR 237-1.6 (f)

This describes the liability issues regarding the requirements of the ADR NOx Budget Trading Program .

6NYCRR 237-1.6 (g)

This item states that no provision of the ADR NOx Budget Trading Program, a NOx budget permit application, or a NOx budget permit, will exempt or exclude the owners and operators from compliance with any other provisions of applicable State and federal law and regulations.

6NYCRR 237-2

This condition requires the permittee to select and authorize one person to manage, and represent the owners of any NOx budget unit; and specifies the responsibilities of this NOx authorized account representative

6NYCRR 237-4.1

This item specifies the requirements of the compliance certification report.

6NYCRR 237-8

This item requires the owners and operators of a NOx budget unit to comply with the monitoring and reporting requirements of NYCRR 237-8 and Subpart H of 40 CFR part 75; and allows NOx budget units which are also NOx budget units under NYCRR Part 204 to be summarily referenced in order to demonstrate compliance with the requirements of this item.

6NYCRR 238-1.6 (a)

This condition requires the applicant to submit a SO2 budget application for a permit and to operate in compliance with that permit.

6NYCRR 238-1.6 (c)

This Item requires the owners and operators of each SO2 budget source and each SO2 budget unit to hold SO2 allowances available for compliance deductions under NYCRR 238-6.5; and how such allowances will be managed.

6NYCRR 238-1.6 (e)



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

This item requires the owners and operators of the SO2 budget source to keep on site at the source pertinent documents for a period of 5 years from the date the document is created.

6NYCRR 238-1.6 (f)

This subdivision outlines the liability of an affected source.

6NYCRR 238-1.6 (g)

This subdivision outlines the liability of an affected source as subject to other requirements.

6NYCRR 238-2.1

This section outlines the authorization and responsibilities of the SO2 authorized account representative.

6NYCRR 238-4.1

This section lists all of the requirements for the submission of the compliance certification report.

6NYCRR 238-7.1

This section outlines the requirements for the submission of SO2 allowance transfers.

6NYCRR 238-8

This condition requires the owner or operator of the facility to comply with the reporting and record keeping requirements of 40 CFR Part 75.

Compliance Certification

Summary of monitoring activities at RAVENSWOOD GENERATING STATION:

Location Facility/EU/EP/Process/ES	Type of Monitoring	Cond No.
FACILITY	record keeping/maintenance procedures	24
FACILITY	record keeping/maintenance procedures	5
FACILITY	record keeping/maintenance procedures	6
U-CT201/CT201	record keeping/maintenance procedures	70
U-CT202/CT202	record keeping/maintenance procedures	72
U-CT203/CT203	record keeping/maintenance procedures	74
U-CT204/CT204	record keeping/maintenance procedures	76
U-CT301/CT301	record keeping/maintenance procedures	78
U-CT302/CT302	record keeping/maintenance procedures	80
U-CT303/CT303	record keeping/maintenance procedures	82
U-CT304/CT304	record keeping/maintenance procedures	84
FACILITY	record keeping/maintenance procedures	7
FACILITY	record keeping/maintenance procedures	30
FACILITY	record keeping/maintenance procedures	36
FACILITY	record keeping/maintenance procedures	38
FACILITY	record keeping/maintenance procedures	39
FACILITY	work practice involving specific operations	41
FACILITY	work practice involving specific operations	42
FACILITY	record keeping/maintenance procedures	43
FACILITY	work practice involving specific operations	45



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1

12/07/2006

FACILITY	work practice involving specific operations	46
FACILITY	work practice involving specific operations	47
FACILITY	work practice involving specific operations	48
FACILITY	work practice involving specific operations	49
U-00010	intermittent emission testing	56
U-00020	intermittent emission testing	59
U-00030	intermittent emission testing	62
U-CT008	intermittent emission testing	65
U-CT009	intermittent emission testing	66
U-CT010	intermittent emission testing	67
U-CT011	intermittent emission testing	68
U-CT201	intermittent emission testing	69
U-CT202	intermittent emission testing	71
U-CT203	intermittent emission testing	73
U-CT204	intermittent emission testing	75
U-CT301	intermittent emission testing	77
U-CT302	intermittent emission testing	79
U-CT303	intermittent emission testing	81
U-CT304	intermittent emission testing	83
FACILITY	monitoring of process or control device parameters as surrogate	50
U-00010/00010	monitoring of process or control device parameters as surrogate	105
U-00020/00020	monitoring of process or control device parameters as surrogate	123
U-00030/00030	monitoring of process or control device parameters as surrogate	141
U-00010/00010	record keeping/maintenance procedures	58
U-00020/00020	record keeping/maintenance procedures	61
U-00030/00030	record keeping/maintenance procedures	64
U-00010	record keeping/maintenance procedures	89
U-00020	record keeping/maintenance procedures	107
U-00030	record keeping/maintenance procedures	125
U-CT201	record keeping/maintenance procedures	143
U-CT202	record keeping/maintenance procedures	151
U-CT203	record keeping/maintenance procedures	159
U-CT204	record keeping/maintenance procedures	167
U-CT301	record keeping/maintenance procedures	175
U-CT302	record keeping/maintenance procedures	183
U-CT303	record keeping/maintenance procedures	191
U-CT304	record keeping/maintenance procedures	199
U-00010	record keeping/maintenance procedures	94
U-00020	record keeping/maintenance procedures	112
U-00030	record keeping/maintenance procedures	130
U-CT201	record keeping/maintenance procedures	148
U-CT202	record keeping/maintenance procedures	156
U-CT203	record keeping/maintenance procedures	164
U-CT204	record keeping/maintenance procedures	172
U-CT301	record keeping/maintenance procedures	180
U-CT302	record keeping/maintenance procedures	188
U-CT303	record keeping/maintenance procedures	196
U-CT304	record keeping/maintenance procedures	204
U-00010	record keeping/maintenance procedures	95
U-00020	record keeping/maintenance procedures	113
U-00030	record keeping/maintenance procedures	131
U-CT201	record keeping/maintenance procedures	149
U-CT202	record keeping/maintenance procedures	157
U-CT203	record keeping/maintenance procedures	165
U-CT204	record keeping/maintenance procedures	173

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 2-6304-00024/00035 Renewal Number: 1



12/07/2006

U-CT301	record keeping/maintenance procedures	181
U-CT302	record keeping/maintenance procedures	189
U-CT303	record keeping/maintenance procedures	197
U-CT304	record keeping/maintenance procedures	205
U-00010	record keeping/maintenance procedures	97
U-00020	record keeping/maintenance procedures	115
U-00030	record keeping/maintenance procedures	133
U-00010	record keeping/maintenance procedures	98
U-00020	record keeping/maintenance procedures	116
U-00030	record keeping/maintenance procedures	134
U-00010	record keeping/maintenance procedures	102
U-00020	record keeping/maintenance procedures	120
U-00030	record keeping/maintenance procedures	138
U-00010	record keeping/maintenance procedures	104
U-00020	record keeping/maintenance procedures	122
U-00030	record keeping/maintenance procedures	140

Basis for Monitoring