

Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

## **Facility Identification Data**

Name: RAVENSWOOD GENERATING STATION

Address: 38-54 VERNON BLVD

QUEENS, NY 11101

#### Owner/Firm

Name: TC RAVENSWOOD LLC Address: 110 TURNPIKE RD STE 203 WESTBOROUGH, MA 01581, USA

Owner Classification: Corporation/Partnership

## **Permit Contacts**

Division of Environmental Permits: Name: ELIZABETH A CLARKE

Address: NYSDEC 47-40 21ST ST

LONG ISLAND CITY, NY 11101-5407

Phone:7184824997

Division of Air Resources: Name: PARESH SHAH Address: NYSDEC 47-40 21ST ST LONG ISLAND CITY, NY 11101

Phone:

Air Permitting Contact: Name: KEN YAGER

Address: RAVENSWOOD GENERATING STATION

38-54 VERNON BLVD

LONG ISLAND CITY, NY 11101

Phone:7187062702

# Permit Description Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

#### **Summary Description of Proposed Project**

Application for renewal of Air Title V Facility.

**Attainment Status** 



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

RAVENSWOOD GENERATING STATION is located in the town of QUEENS in the county of OUEENS.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

#### Criteria Pollutant

#### **Attainment Status**

\_\_\_\_

Particulate Matter (PM)	ATTAINMENT
Particulate Matter< 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

-----

----

#### **Facility Description:**

This facility consists of three (3) steam boiler turbine/generator sets and seventeen (17) simple cycle combustion turbines with a combined nominal rating of 2,288 mw and three (3) emergency generators. Natural gas is the primary fuel for all units, with low-sulfur oil fuel used on a limited basis.

# **Permit Structure and Description of Operations**

The Title V permit for RAVENSWOOD GENERATING STATION

is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

combustion - devices which burn fuel to generate heat, steam or power

incinerator - devices which burn waste material for disposal

control - emission control devices

process - any device or contrivance which may emit air contaminants

that is not included in the above categories.

RAVENSWOOD GENERATING STATION is defined by the following emission unit(s):

<sup>\*</sup> Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

<sup>\*\*</sup> NOx has a separate ambient air quality standard in addition to being an ozone precursor.



Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

Emission unit U00010 - THIS UNIT CONSISTS OF DUAL, TANGENTIALLY FIRED FURNACES COMPRISING A SINGLE BOILER. STEAM FROM THIS BOILER OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 390 MW. THE FURNACES OPERATE ON NATUAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTION MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH THE PRIMARY FUEL.

CLOSE COUPLED OVER-FIRED AIR (CCOFA) COMPARTMENTS HAVE BEEN ADDED TO THE UPPER AND LOWER WINDBOX SECTIONS OF THIS EMISSION UNIT. CCOFA IS A PROVEN NOX REDUCTION TECHNOLOGY AND WAS INSTALLED AS PART OF KEYSPAN'S PLAN TO MEET PHASE III OF THE NOX BUDGET REQUIREMENTS. INSTALLATION OCCURRED DURING THE FALL 2000 SCHEDULED OUTAGE.

Emission unit  $\,$  U00010  $\,$  is associated with the following emission points (EP):  $\,$  00010

Process: P01 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF #6 RESIDUAL OIL IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER. A non-hazardous additive may be used to improve combustion.

The facility also may use bio-residual fuel which is equivalent to residual fuel oil in all respect.

Process: P02 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P03 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE CO-FIRING OF WASTE FUEL A WITH #6 RESIDUAL OIL AND/OR NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P04 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS INVOLVES THE INCINERATION OF NON-HAZARDOUS BOILER CHEMICAL CLEANING SOLUTIONS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Emission unit U00020 - THIS UNIT CONSISTS OF DUAL, TANGENTIALLY FIRED FURNACES COMPRISING A SINGLE BOILER. STEAM FROM THIS BOILER OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 390 MW. THIS BOILER IS EQUIPPED WITH A CLOSE-COUPLED-OVERFIRED-AIR (CCOFA) SYSTEM TO REDUCE THE FORMATION OF NITROGEN OXIDES. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

BOILER CLEANING SOLUTIONS MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH PRIMARY FUEL.

Emission unit U00020 is associated with the following emission points (EP): 00020

Process: P05 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF #6 RESIDUAL OIL IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER. A non-hazardous additive may be used to improve combustion.

Process: P06 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

The facility also may use bio-residual fuel which is equivalent to residual fuel oil in all respect.

Process: P07 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE CO-FIRING OF WASTE FUEL A WITH #6 RESIDUAL OIL AND/OR NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P08 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS INVOLVES THE INCINERATION OF NON-HAZARDOUS BOILER CHEMICAL CLEANING SOLUTIONS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Emission unit U00030 - THIS UNIT CONSISTS OF DUAL BOILERS, EACH HEATED BY DUAL, TANGENTIALLY FIRED FURNACES. STEAM FROM THESE BOILERS OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 972 MW. KEYSPAN WILL BE INSTALLING A CLOSE-COUPLED-OVERFIRED-AIR (CCOFA) SYSTEM BY LATE 2001 TO FURTHER REDUCE THE FORMATION OF NITROGEN OXIDES. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTION MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH THE PRIMARY FUEL.

Emission unit U00030 is associated with the following emission points (EP): 00030

Process: P09 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF #6 RESIDUAL OIL IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER. A non-hazardous additive may be used to improve combustion.

The facility also may use bio-residual fuel which is equivalent to residual fuel oil in all respect.

Process: P10 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Process: P11 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS IS THE CO-FIRING OF WASTE FUEL A WITH #6 RESIDUAL OIL AND/OR NATURAL GAS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.



Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

Process: P12 is located at GROUND FLOOR, Building GEN STA - THIS PROCESS INVOLVES THE INCINERATION OF NON-HAZARDOUS BOILER CHEMICAL CLEANING SOLUTIONS IN A TANGENTIALLY FIRED STEAM-ELECTRIC BOILER.

Emission unit UCT001 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. THIS UNIT IS A "BLACK-START" COMBUSTION TURBINE DESIGNED TO PROVIDE SUFFICIENT POWER TO BRING THE ENTIRE POWER STATION BACK ON-LINE FOLLOWING A CATASTROPHIC SYSTEM COLLAPSE. A DIESEL ENGINE, EMISSION POINT GT0S1, EMISSION UNIT U-CT0S1 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT001 is associated with the following emission points (EP): GT001

Process: P21 is located at GROUND FLOOR, Building GT1 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT004 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S4, EMISSION UNIT U-CT0S4 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT004 is associated with the following emission points (EP): CT004

Process: P24 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P25 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P26 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT005 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S5, EMISSION UNIT U-CT0S5 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT005 is associated with the following emission points (EP):



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

#### CT005

Process: P29 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P30 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P31 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT006 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S6, EMISSION UNIT U-CT0S6 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT006 is associated with the following emission points (EP): CT006

Process: P34 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P35 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P36 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT007 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S7, EMISSION UNIT U-CT0S7 IS UTILIZED TO START THIS COMBUSTION TURBINE.

Emission unit UCT007 is associated with the following emission points (EP):

Process: P39 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P40 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P41 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Emission unit UCT008 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

Emission unit UCT008 is associated with the following emission points (EP): CT008

Process: P44 is located at GROUND FLOOR, Building CT8 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P45 is located at GROUND FLOOR, Building CT8 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P46 is located at GROUND FLOOR, Building CT8 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT009 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

Emission unit UCT009 is associated with the following emission points (EP): CT009

Process: P47 is located at GROUND FLOOR, Building CT9 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P48 is located at GROUND FLOOR, Building CT9 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE



Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

ADDED TO PREVENT FOULING.

Process: P49 is located at GROUND FLOOR, Building CT9 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT010 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

Emission unit UCT010 is associated with the following emission points (EP): CT010

Process: P50 is located at GROUND FLOOR, Building CT10 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P51 is located at GROUND FLOOR, Building CT10 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P52 is located at GROUND FLOOR, Building CT10 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT011 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM.

Emission unit UCT011 is associated with the following emission points (EP): CT011

Process: P53 is located at GROUND FLOOR, Building CT11 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE.

Process: P54 is located at GROUND FLOOR, Building CT11 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Process: P55 is located at GROUND FLOOR, Building CT11 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING.

Emission unit UCT0S1 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT001. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCTOS1 is associated with the following emission points (EP): GTOS1

Process: P22 is located at GROUND FLOOR, Building CT1 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P23 is located at GROUND FLOOR, Building CT1 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S4 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT004. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S4 is associated with the following emission points (EP):

Process: P27 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P28 is located at GROUND FLOOR, Building CT4 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S5 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT005. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S5 is associated with the following emission points (EP): CT0S5

Process: P32 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P33 is located at GROUND FLOOR, Building CT5 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S6 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT006. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S6 is associated with the following emission points (EP): CT0S6

Process: P37 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P38 is located at GROUND FLOOR, Building CT6 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT0S7 - THIS UNIT IS A 430 HP DIESEL ENGINE USED TO START THE "BLACK-START" COMBUSTION TURBINE, DESIGNATED EMISSION UNIT U-CT007. THIS UNIT ONLY OPERATES DURING START-UP OF THE COMBUSTION TURBINE, GENERALLY LESS THAN 15 MINUTES PER EVENT.

Emission unit UCT0S7 is associated with the following emission points (EP): CT0S7

Process: P42 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Process: P43 is located at GROUND FLOOR, Building CT7 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A DIESEL ENGINE. THIS ENGINE IS USED TO START THE ASSOCIATED COMBUSTION TURBINE. DURING EACH START-UP THE ENGINE OPERATES FOR LESS THAN 15 MINUTES.

Emission unit UCT201 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT201 is associated with the following emission points (EP): CT201

Process: P56 is located at GROUND FLOOR, Building CT21 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utalized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P57 is located at GROUND FLOOR, Building CT21 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P58 is located at GROUND FLOOR, Building CT21 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT202 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT202 is associated with the following emission points (EP): CT202

Process: P59 is located at GROUND FLOOR, Building CT22 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P60 is located at GROUND FLOOR, Building CT22 - THIS PROCESS IS THE



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P61 is located at GROUND FLOOR, Building CT22 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT203 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT203 is associated with the following emission points (EP): CT203

Process: P62 is located at GROUND FLOOR, Building CT23 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P63 is located at GROUND FLOOR, Building CT23 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P64 is located at GROUND FLOOR, Building CT23 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission



Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

Unit portion of this permit.

Emission unit UCT204 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT204 is associated with the following emission points (EP): CT204

Process: P65 is located at GROUND FLOOR, Building CT24 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P66 is located at GROUND FLOOR, Building CT24 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P67 is located at GROUND FLOOR, Building CT24 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT301 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT301 is associated with the following emission points (EP): CT301

Process: P68 is located at GROUND FLOOR, Building CT31 - THIS PROCESS IS THE



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P69 is located at GROUND FLOOR, Building CT31 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P70 is located at GROUND FLOOR, Building CT31 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT302 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT302 is associated with the following emission points (EP): CT302

Process: P71 is located at GROUND FLOOR, Building CT32 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P72 is located at GROUND FLOOR, Building CT32 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P73 is located at GROUND FLOOR, Building CT32 - THIS PROCESS IS THE



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT303 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT303 is associated with the following emission points (EP): CT303

Process: P74 is located at GROUND FLOOR, Building CT33 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P75 is located at GROUND FLOOR, Building CT33 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P76 is located at GROUND FLOOR, Building CT33 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utalized for NOx reduction, as required. Thruputs listed under each process are intended to be examples of possible unit utalization. Actual operation be be inaccordance with the emission limitations identified in the Emission Unit portion of this permit.

Emission unit UCT304 - THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. TWO TURBINE ENGINES DRIVE A SINGLE GENERATOR AND EXHAUST THROUGH A COMMON STACK. Inlet water spray may be utilized for NOx reduction. Based on stack test results for carbon monoxide, operation of this unit shall be restricted such that the 365 day rolling summation of CO mass emissions shall not exceed that which would have been released during 4,171 (3,672 hr in ozone



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

season plus 499 non-ozone season operation) hours of operation without inlet spray.

Emission unit UCT304 is associated with the following emission points (EP): CT304

Process: P77 is located at GROUND FLOOR, Building CT34 - THIS PROCESS IS THE COMBUSTION OF PIPELINE NATURAL GAS IN A COMBUSTION TURBINE. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P78 is located at GROUND FLOOR, Building CT34 - THIS PROCESS IS THE COMBUSTION OF #2 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

Process: P79 is located at GROUND FLOOR, Building CT34 - THIS PROCESS IS THE COMBUSTION OF #1 DISTILLATE OIL IN A COMBUSTION TURBINE. IN ORDER TO IMPROVE COMBUSTION A FUEL ADDITIVE MAY BE MIXED WITH THE DISTILLATE OIL PRIOR TO COMBUSTION. IN ADDITION, WHEN FUEL OIL IS STORED FOR EXTENDED PERIODS, A BIOCIDE MAY BE ADDED TO PREVENT FOULING. Inlet water spray may be utilized for NOx reduction, as required. Throughputs listed under each process are intended to be examples of possible unit utilization. Actual operation to be in accordance with the emission limitations identified in the Emission Unit portion of this permit.

#### Title V/Major Source Status

RAVENSWOOD GENERATING STATION is subject to Title V requirements. This determination is based on the following information:

Facility is of a major status because of its PTE Nox emissions.

# **Program Applicability**

The following chart summarizes the applicability of RAVENSWOOD GENERATING STATION with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability	
PSD	NO	
NSR (non-attainment)	NO	-
NESHAP (40 CFR Part 61)	NO	
NESHAP (MACT - 40 CFR Part 63)	YES	
NSPS	NO	
TITLE IV	NO	



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

## NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS)

for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA)

which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

MACT Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to

be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.



Permit ID: 2-6304-00024/00035 Renewal Number: 2

11/16/2012

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

#### **Compliance Status**

Facility is in compliance with all requirements.

#### SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis

of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code Description

4911 ELECTRIC SERVICES

## **SCC Codes**

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents

a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

escription
e

1-01-004-04	EXTERNAL COMBUSTION BOILERS - ELECTRIC
	GENERATION
	ELECTRIC UTILITY BOILER - RESIDUAL OIL
	Grade 6 Oil: Tangential Firing
1-01-006-04	EXTERNAL COMBUSTION BOILERS - ELECTRIC
	GENERATION
	ELECTRIC UTILITY BOILER - NATURAL GAS
	Tangentially Fired Units
1-01-013-02	EXTERNAL COMBUSTION BOILERS - ELECTRIC
	GENERATION
	ELECTRIC UTILITY BOILER - LIQUID WASTE
	Waste Oil
2-01-001-01	INTERNAL COMBUSTION ENGINES - ELECTRIC
	GENERATION
	ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE
	- DISTILLATE OIL (DIESEL)
	Turbine
2-01-001-02	INTERNAL COMBUSTION ENGINES - ELECTRIC
	GENERATION
	ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE
	- DISTILLATE OIL (DIESEL)
	Reciprocating
2-01-002-01	INTERNAL COMBUSTION ENGINES - ELECTRIC
	GENERATION
	ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE



Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

	- NATURAL GAS
	Turbine
2-01-009-01	INTERNAL COMBUSTION ENGINES - ELECTRIC
	GENERATION
	ELECTRIC UTILITY IC ENGINE -
	KEROSENE/NAPHTHA (JET FUEL)
	Turbine
2-02-001-02	INTERNAL COMBUSTION ENGINES - INDUSTRIAL
	INDUSTRIAL INTERNAL COMBUSTION ENGINE -
	DISTILLATE OIL(DIESEL)
	Reciprocating
2-02-009-02	INTERNAL COMBUSTION ENGINES - INDUSTRIAL
	INDUSTRIAL INTERNAL COMBUSTION ENGINE -
	KEROSENE/NAPHTHA (JET FUEL)
	Reciprocating
5-03-007-01	SOLID WASTE DISPOSAL - INDUSTRIAL
	SOLID WASTE DISPOSAL: INDUSTRIAL - LIQUID
	WASTE
	General

## **Facility Emissions Summary**

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	<b>Contaminant Name</b>		PTE	
		lbs/vr		Range
000123-91-1	1,4-DIETHYLENE	v		> 0 but < 10 tpy
	DIOXIDE			
007440-38-2	ARSENIC			> 0 but < 10 tpy
007440-43-9	CADMIUM			> 0 but < 10 tpy
000630-08-0	CARBON MONOXIDE			>= 250 tpy but <
				75,000 tpy
007440-47-3	CHROMIUM			> 0 but < 10 tpy
007440-50-8	COPPER			> 0 but < 2.5 tpy
0NY100-00-0	HAP			>= 50 tpy but < 100
				tpy
007439-89-6	IRON			> 0 but < 2.5 tpy
007439-92-1	LEAD			> 0 but < 10 tpy
007439-97-6	MERCURY			> 0 but < 10 tpy
007440-02-0	NICKEL METAL AND			>= 10 tpy
	INSOLUBLE COMPOUNDS			



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

0NY210-00-0	OXIDES OF NITROGEN	>= 250 tpy but <
		75,000 tpy
0NY075-00-0	PARTICULATES	· • •
0111075-00-0	PARTICULATES	>= 250 tpy but <
		75,000 tpy
0NY075-00-5	PM-10	>= 250 tpy but <
		75,000 tpy
007446-09-5	SULFUR DIOXIDE	>= 250 tpy but <
		75,000 tpy
0344000 00 0	1100	· • •
0NY998-00-0	VOC	>= 250 tpy but <
		75,000 tpy
007440-66-6	ZINC	> 0 but < 2.5 tpy
00/110 00 0	2110	- 0 Duc \ 2.5 cpy

#### NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

## Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

- (a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
  - (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
  - (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
  - (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.
- (b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.
- (c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

# Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

# Item C: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

## Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth,



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

## Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

# Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

# Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

# Item H: Property Rights - 6 NYCRR 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

#### Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

# Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

#### Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 2 01-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

### Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

under the Clean Air Act brought by the United States or any person.

# Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

#### NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

# Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

## **Regulatory Analysis**

Location Facility/EU/EP/Pro		Condition	Short Description
 FACILITY	ECL 19-0301	69	Powers and Duties of the Department with respect to air pollution control
FACILITY	40CFR 63-ZZZZ.6603(a)	54	Reciprocating Internal Combustion Engine (RICE) NESHAP - requirements for existing engines at area sources of HAP emissions
FACILITY	40CFR 68	20	Chemical accident prevention provisions
FACILITY	40CFR 82-F	21	Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	6NYCRR 200.6	1	Acceptable ambient air quality.
FACILITY	6NYCRR 200.7	10	Maintenance of



# Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

FACILITY	6NYCRR 201-1.4	70	equipment. Unavoidable
111012111	0110146 201 111	. •	noncompliance and
FACILITY	6NYCRR 201-1.7	11	violations Recycling and Salvage
FACILITY	6NYCRR 201-1.8	12	Prohibition of
			reintroduction of
			collected contaminants to the
			air
FACILITY	6NYCRR 201-3.2(a)	13	Exempt Activities -
DA GIT IMV	(NIXADD 201 2 2 (a)	1.4	Proof of eligibility
FACILITY	6NYCRR 201-3.3(a)	14	Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6	22, 55, 56	Title V Permits and
			the Associated Permit
FACILITY	6NYCRR 201-6.5(a)(4)	15	Conditions General conditions
FACILITY	6NYCRR 201-6.5(a)(7)	2	General conditions
			Fees
FACILITY FACILITY	6NYCRR 201-6.5(a)(8) 6NYCRR 201-6.5(c)	16 3	General conditions Permit conditions for
TACIBITI	0N1CRR 201 0.5(C)	J	Recordkeeping and
			Reporting of
EXCII ITV	6NYCRR 201-6.5(c)(2)	4	Compliance Monitoring Permit conditions for
FACILITY	6NICRR 201-6.5(C)(2)	4	Recordkeeping and
			Reporting of
DA GIL IDV	CNT/CDD 001 ( 5 ( -) /2)	0.3	Compliance Monitoring
FACILITY	6NYCRR 201-6.5(c)(3)	23	Permit conditions for Recordkeeping and
			Reporting of
	CHILDRE CO.	_	Compliance Monitoring
FACILITY	6NYCRR 201- 6.5(c)(3)(ii	5	Permit conditions for Recordkeeping and
	3.3 (3, (3, (11		Reporting of
	CITIODD 004 6 5 (1) (5)	4.5	Compliance Monitoring
FACILITY FACILITY	6NYCRR 201-6.5(d)(5) 6NYCRR 201-6.5(e)	17 6	Compliance schedules Compliance
111011111	0N1CIAC 201 0.5 (C)	Ŭ	Certification
FACILITY	6NYCRR 201-6.5(f)(6)	18	Off Permit Changes
FACILITY FACILITY	6NYCRR 201-6.5(g) 6NYCRR 201-7.2	24 57, 58	Permit shield Emissions capping
TACIBITI	ONICKE ZOI 7.2	37, 30	using synthetic minor
			permits
U-CT201/CT201	6NYCRR 201-7.2	61	Emissions capping using synthetic minor
			permits
U-CT202/CT202	6NYCRR 201-7.2	62	Emissions capping
			using synthetic minor permits
U-CT203/CT203	6NYCRR 201-7.2	63	Emissions capping
			using synthetic minor
U-CT204/CT204	6NYCRR 201-7.2	64	permits Emissions capping
0 61204/61204	ONICKE ZOI 7.2	04	using synthetic minor
			permits
U-CT301/CT301	6NYCRR 201-7.2	65	Emissions capping using synthetic minor
			permits
U-CT302/CT302	6NYCRR 201-7.2	66	Emissions capping
			using synthetic minor permits
U-CT303/CT303	6NYCRR 201-7.2	67	Emissions capping



using synthetic minor

# New York State Department of Environmental Conservation Permit Review Report

# Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

			permits
U-CT304/CT304	6NYCRR 201-7.2	68	Emissions capping
0-01304/01304	0N1CKK 201-7.2	00	using synthetic minor
			permits
FACILITY	6NYCRR 202-1.1	19	Required emissions
TACIBITI	ONICIAL ZUZ I.I	19	tests.
FACILITY	6NYCRR 202-2.1	7	Emission Statements -
111011111	on ciac 202 2.1	,	Applicability
FACILITY	6NYCRR 202-2.5	8	Emission Statements -
111011111	01V1Cltt 202 2.5	ŭ	record keeping
			requirements.
FACILITY	6NYCRR 207	25	Control Measures for
11101111		23	an Air Pollution
			Episode
FACILITY	6NYCRR 211.1	26	General Prohibitions
			- air pollution
			prohibited
FACILITY	6NYCRR 211.2	71	General Prohibitions
			- visible emissions
			limited.
FACILITY	6NYCRR 215.2	9	Open Fires -
			Prohibitions
FACILITY	6NYCRR 225-1.2(a)(2)	27, 28	Sulfur in Fuel
			Limitations Post
			12/31/87.
FACILITY	6NYCRR 225-1.8	29	Reports, sampling and
			analysis.
FACILITY	6NYCRR 225-1.8(d)	30	Reports, sampling,
			and analysis
FACILITY	6NYCRR 225-2.3(b)	31	Eligibility to burn
			waste fuel A.
FACILITY	6NYCRR 225-2.4(b)	32, 33, 34, 35	Eligibility to burn
			waste fuels A and B.
U-00010	6NYCRR 227-1.2(a)(1)	59	Particulate Emissions
			from Liquid Fuels.
U-CT008	6NYCRR 227-1.2(a)(1)	60	Particulate Emissions
			from Liquid Fuels.
FACILITY	6NYCRR 227-1.3(a)	36	Smoke Emission
TT 00010/0010	CTTTGDD 005 4 4/ )		Limitations.
U-00010/00010	6NYCRR 227-1.4(a)	77	Stack Monitoring.
TI 00000 /00000	CHRISTIP DOES 1 4/-)	F.0	(see narrative)
U-00020/00020	6NYCRR 227-1.4(a)	79	Stack Monitoring. (see narrative)
11 00020 (00020	(NYGDD 227 1 4/-)	0.1	
U-00030/00030	6NYCRR 227-1.4(a)	81	Stack Monitoring. (see narrative)
FACILITY	6NYCRR 227-1.4(b)	37	Stack Monitoring
FACILITY	6NYCRR 227-2.5(b)	72	System averaging
FACILITI	6NICRR 227-2.5(D)	12	plan.
U-00010	6NYCRR 227-2.6(a)	76	Applicable testing
0-00010	01VICKK 227-2.0(a)	70	and/or monitoring
			requirements.
U-00020	6NYCRR 227-2.6(a)	78	Applicable testing
0 00020	5111 5141 527 210 (a)	, 0	and/or monitoring
			requirements.
U-00030	6NYCRR 227-2.6(a)	80	Applicable testing
			and/or monitoring
			requirements.
U-CT201/CT201	6NYCRR 231-2	61	New Source Review in
•			Nonattainment Areas
			and Ozone Transport
			Region
U-CT202/CT202	6NYCRR 231-2	62	New Source Review in
•			Nonattainment Areas



# Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

			and Ozone Transport
U-CT203/CT203	6NYCRR 231-2	63	Region New Source Review in Nonattainment Areas
			and Ozone Transport
U-CT204/CT204	6NYCRR 231-2	64	Region New Source Review in
			Nonattainment Areas and Ozone Transport
U-CT301/CT301	6NYCRR 231-2	65	Region New Source Review in
0-01301/01301	6NICKR 231-2	65	Nonattainment Areas
			and Ozone Transport Region
U-CT302/CT302	6NYCRR 231-2	66	New Source Review in Nonattainment Areas
			and Ozone Transport
U-CT303/CT303	6NYCRR 231-2	67	Region New Source Review in
			Nonattainment Areas and Ozone Transport
TT GTT0.0.4 / GTT0.0.4	CHILDRE CO. C	60	Region
U-CT304/CT304	6NYCRR 231-2	68	New Source Review in Nonattainment Areas
			and Ozone Transport Region
FACILITY	6NYCRR 242-1.5	73, 74, 75	CO2 Budget Trading
			Program - Standard requirements
FACILITY	6NYCRR 243-1.6(a)	38	Permit Requirements - CAIR NOx Ozone Season
FACILITY	6NYCRR 243-1.6(b)	39	Trading Program Monitoring
FACILITI	6NICKR 243-1.6(D)	33	Requirements - CAIR
			NOx Ozone Season Trading Program
FACILITY	6NYCRR 243-1.6(c)	40	NOx Ozone Season Emission Requirements
			- CAIR NOx Ozone
			Season Trading Program
FACILITY	6NYCRR 243-1.6(d)	41	Excess Emission Requirements - CAIR
			NOx Ozone Season Trading Program
FACILITY	6NYCRR 243-1.6(e)	42	Recordkeeping and
			reporting requirements - CAIR
			NOx Ozone Season Trading Program
FACILITY	6NYCRR 243-2.1	43	Authorization and responsibilities -
			CAIR Designated
FACILITY	6NYCRR 243-2.4	44	Representative Certificate of
			representation - CAIR Designated
FACTI TTV	6NYCRR 243-8.1	45	Representative
FACILITY	UNICAR 243-0.1	40	General Requirements - Monitoring and
FACILITY	6NYCRR 243-8.5(d)	46	Reporting Quarterly reports re:
			recordkeeping and reporting -
			£ J



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

FACILITY	6NYCRR 243-8.5(e)	47	Monitoring and Reporting Compliance certification re: recordkeeping and reporting - Monitoring and Reporting
FACILITY	6NYCRR 244-1	48	CAIR NOx Ozone Annual Trading Program General Provisions
FACILITY	6NYCRR 244-2	49	CAIR Designated Representative for CAIR NOx Sources
FACILITY	6NYCRR 244-8	50	Monitoring and Reporting CAIR NOx Allowances
FACILITY	6NYCRR 245-1	51	CAIR SO2 Trading Program General Provisions
FACILITY	6NYCRR 245-2	52	CAIR Designated Representative for CAIR SO2 Sources
FACILITY	6NYCRR 245-8	53	Monitoring and Reporting for CAIR SO2 Trading Program

#### **Applicability Discussion:**

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

#### ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

## 6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

## 6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

## 6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

## 6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

#### 6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

## 6 NYCRR 201-3.2 (a)



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

#### 6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

## 6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

## 6 NYCRR 201-6.5 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

## 6 NYCRR 201-6.5 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

#### 6 NYCRR 201-6.5 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

## 6 NYCRR 201-6.5 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

## 6 NYCRR 201-6.5 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

## 6 NYCRR 201-6.5 (c) (3)

This regulation specifies that the permit incorporate all reporting requirements associated with an applicable federal rule, the submittal of any required monitoring reports at least every 6 months, and the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

# 6 NYCRR 201-6.5 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

#### 6 NYCRR 201-6.5 (d) (5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

## 6 NYCRR 201-6.5 (e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

## 6 NYCRR 201-6.5 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

## 6 NYCRR 201-6.5 (g)

Permit Exclusion Provisions - specifies those actions, such as administrative orders, suits, claims for natural resource damages, etc that are not affected by the federally enforceable portion of the permit, unless they are specifically addressed by it.

## 6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

### 6 NYCRR 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calENDar year.

## 6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

#### 6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

#### 6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

#### 40 CFR Part 68

This Part lists the regulated substances and there applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

# 40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act AmENDments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

#### **Facility Specific Requirements**

In addition to Title V, RAVENSWOOD GENERATING STATION has been determined to be subject to the following regulations:

## 40 CFR 63.6603 (a)

These conditions list the emission limits, operating limits, and work practices that existing engines located at an area source of HAP emissions must meet.

The engines must meet work practices, emission limits, and operating limits on carbon monoxide or formaldehyde for the specific type of engine listed in table 2d of subpart ZZZZ.

#### 6 NYCRR 201-7.2

This section of Part 201-7 specifies the criteria that need to be met in order to restrict emissions to avoid Title V or other applicable requirements using federally enforceable permit conditions permit.

#### 6 NYCRR 211.1

This regulation requires that no person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

## 6 NYCRR 225-1.2 (a) (2)



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

This regulation prohibits any person from selling, offering for sale, purchasing or using any fuel which contains sulfur in a quantity exceeding the limitations set forth in Table 1, Table 2, or Table 3 of this section.

#### 6 NYCRR 225-1.8

This regulation requires an owner or operator of a facility which purchases and fires coal and/or oil to s ubmit reports to the commissioner containing fuel analysis data, information on the quantity of the fuel received, burned, and results of any stack sampling, stack monitoring and any other procedures to ensure compliance with the provisions of 6 NYCRR Part 225-1.

## 6 NYCRR 225-1.8 (d)

This requires that sampling, compositing and analysis of fuel samples must be done in accordance with methods acceptable to the commissioner.

## 6 NYCRR 225-2.3 (b)

This regulation requires that each piece of equipment which fires Waste Fuel A demonstrate, at a minimum, 99% combustion efficiency in burning Waste fuel A.

## 6 NYCRR 225-2.4 (b)

This regulation sets the limits for the compounds that may be in Waste Fuel A or B. These are: PCB less than 50 parts per million (ppm); Total Halogens less than 1,000 ppm; Sulfur less than the limits in Part 225-1; Lead less than 250 ppm; and a minimum gross heat content of 125,000 BTU/Gallon

#### 6 NYCRR 227-1.2 (a) (1)

This regulation establishes a particulate emission limit in terms of lbs per mmBtu of heat input for stationary combustion units of greater than 250 mmBtu/hr heat input capacity which fire coal, oil, or coal derived fuels.

# 6 NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

#### 6 NYCRR 227-1.4 (a)

Subdivisions (a) and (f) of this section (227-1.4) have not been approved by EPA and have not been included in the NYS SIP.

## 6 NYCRR 227-1.4 (b)

This regulation requires the specific contents of excess emissions reports for opacity from facilities that employ continuous opacity monitors (COMs).

#### 6 NYCRR 227-2.5 (b)



Permit ID: 2-6304-00024/00035 Renewal Number: 2

11/16/2012

System averaging plan NOx RACT compliance option.

#### 6 NYCRR 227-2.6 (a)

Applicable testing and/or monitoring requirements for emission sources subject to NOx RACT.

## 6 NYCRR 242-1.5

His regulation requires that the facility hold enough carbon dioxide allowances in their carbon dioxide budget at least equal to the amount of carbon dioxide emitted from the facility each year.

# 6 NYCRR 243-1.6 (a)

This condition requires the facility to acknowledge that they are subject to this CAIR regulation and provide owner and contact information. It also requires them to update this information as it changes or provide supplemental information at the Departments request.

#### 6 NYCRR 243-1.6 (b)

This condition obligates the owners and operators of the facility to comply with the monitoring and reporting requirements of the CAIR regulations.

#### 6 NYCRR 243-1.6 (c)

This citation explains the general provisions of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program. This ozone season NOx cap and trade program runs from May 1 through September 30 each year, starting in 2009. Each source shall hold a tonnage equivalent in CAIR NOx Ozone Season allowances that is not less than the total tons of NOx emissions for the ozone season.

## 6 NYCRR 243-1.6 (d)

This citation for the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains some of the penalties that can be imposed on a CAIR NOx Ozone Season source that does not surrender enough CAIR NOx Ozone Season allowances to cover their NOx Ozone Season emissions.

# 6 NYCRR 243-1.6 (e)

This citation for the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program requires that all reports be submitted as required by this program, and that copies of all records and submissions made for this program be kept on site for at least five years.

#### 6 NYCRR 243-2.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that an CAIR NOx Ozone Season designated representative must be selected to submit, sign and certify each submission on behalf of the source for the this program.



Permit ID: 2-6304-00024/00035 Renewal Number: 2

11/16/2012

#### 6 NYCRR 243-2.4

This condition describes the required elements of the "Certificate of Representation" for the CAIR program and the certifying language required with submissions to the Department.

#### 6 NYCRR 243-8.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that CAIR NOx Ozone Season Trading Program sources must install, certify and operate monitoring systems the meet the monitoring, recordkeeping, and reporting requirements in Subpart 6 NYCRR 243-8 and in Subpart H of 40 CFR Part 75.

# 6 NYCRR 243-8.5 (d)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains what requirements the quarterly reports must meet.

## 6 NYCRR 243-8.5 (e)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains the compliance certification requirements the source must follow for each quarterly report.

#### 6 NYCRR Part 207

This regulation requires the owner or operator to submit an episode action plan to the Department in accordance with the requirements of 6NYCRR Part 207. The plan must contain detailed steps which will be taken by the facility to reduce air contaminant emissions during each stage of an air pollution episode. Once approved, the facility shall take whatever actions are prescribed by the episode action plan when an air pollution episode is in effect.

# 6 NYCRR Subpart 231-2

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

#### 6 NYCRR Subpart 244-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) Nitrogen Oxide (NOx) Annual Trading Program. The control period for this annual NOx cap and trade program runs from January 1 to December 31each year, starting in 2009. Each source shall hold a tonnage equivalent in CAIR NOx allowances that is not less than the total tons of NOx emissions for the control period.

#### 6 NYCRR Subpart 244-2

Each Clean Air Interstate Rule (CAIR) NOx source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR NOx Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate



Permit ID: 2-6304-00024/00035 Renewal Number: 2 11/16/2012

representative.

## 6 NYCRR Subpart 244-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR NOx unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 244-8 and in 40 CFR Part 75, Subparts F and G. A certified NOx emission monitoring system must be used to measure NOx emissions. NOx emission reports must be certified and submitted quarterly.

# 6 NYCRR Subpart 245-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) sulfur dioxide (SO2) Trading Program. The control period for this annual SO2 cap and trade program runs from January 1 to December 31, starting in the year 2010. Each source shall hold a tonnage equivalent in CAIR SO2 allowances that is not less than the total tons of SO2 emissions for the control period.

## 6 NYCRR Subpart 245-2

Each Clean Air Interstate Rule (CAIR) SO2 source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR SO2 Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate representative.

# 6 NYCRR Subpart 245-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR SO2 unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. A certified SO2 emission monitoring system must be used to measure SO2 emissions. SO2 emission reports must be certified and submitted quarterly.

# Compliance Certification Summary of monitoring activities at RAVENSWOOD GENERATING STATION:

Location Facility/EU/EP/Process/ES	Cond No	o. Type of Monitoring
FACILITY	54	record keeping/maintenance procedures
FACILITY	23	record keeping/maintenance procedures
FACILITY	5	record keeping/maintenance procedures
FACILITY	6	record keeping/maintenance procedures
U-CT201/CT201	61	record keeping/maintenance procedures
U-CT202/CT202	62	record keeping/maintenance procedures
U-CT203/CT203	63	record keeping/maintenance procedures
U-CT204/CT204	64	record keeping/maintenance procedures
U-CT301/CT301	65	record keeping/maintenance procedures
U-CT302/CT302	66	record keeping/maintenance procedures
U-CT303/CT303	67	record keeping/maintenance procedures



## Permit ID: 2-6304-00024/00035

## Renewal Number: 2 11/16/2012

U-CT304/CT304	68	record keeping/maintenance procedures
FACILITY	7	record keeping/maintenance procedures
FACILITY	27	work practice involving specific operations
FACILITY	28	work practice involving specific operations
FACILITY	29	record keeping/maintenance procedures
FACILITY	31	work practice involving specific operations
FACILITY	32	work practice involving specific operations
FACILITY	33	work practice involving specific operations
FACILITY	34	work practice involving specific operations
FACILITY	35	work practice involving specific operations
U-00010	59	intermittent emission testing
U-CT008	60	intermittent emission testing
FACILITY	36	monitoring of process or control device parameters
		as surrogate
U-00010/00010	77	monitoring of process or control device parameters
		as surrogate
U-00020/00020	79	monitoring of process or control device parameters
		as surrogate
U-00030/00030	81	monitoring of process or control device parameters
		as surrogate
FACILITY	37	record keeping/maintenance procedures
FACILITY	72	record keeping/maintenance procedures
U-00010	76	record keeping/maintenance procedures
U-00020	78	record keeping/maintenance procedures
U-00030	80	record keeping/maintenance procedures
FACILITY	74	record keeping/maintenance procedures
FACILITY	75	record keeping/maintenance procedures
FACILITY	48	record keeping/maintenance procedures
FACILITY	49	record keeping/maintenance procedures
FACILITY	50	record keeping/maintenance procedures
FACILITY	53	record keeping/maintenance procedures

## **Basis for Monitoring**

6 NYCRR201- 6.5: Ravenswood Generating Station maintains records of all required monitoring, record keeping, and reporting for a period of five years.

6 NYCRR 211.3- The facility maintains continuous opacity monitors on some emission units and also conducts annual Method 9 observations.

## U-OOOIO, U-00020, U-00030

6 NYCRR 227- 1.4(b): A continuous opacity monitor is installed at each applicable emission unit and maintained in accordance with Appendix B of 40 CPR Part 60.

# U-OOOIO, U-00020, U-00030

6 NYCRR 227-2.6(a)(I): Each of the applicable boilers has a NOx CEMS installed and operating in accordance with DEC and EPA regulations. An annual RATA test is performed on each CEM system and submitted in accordance with 40 CFR Part 75 regulations.

## 6 NYCRR 227-2.5(b)

The facility will continue to comply with the current NOx RACT averaging plan.



Permit ID: 2-6304-00024/00035

Renewal Number: 2 11/16/2012

lJ-CTOS I, U-CTOS4, U-CTOS5, U-CTOS6, U-CTOS7, 40 CFR 63.6603, The black start engines are maintained in accordance with the MACT conditions which require checking the oil, checking the air filter, and checking the belts/hoses.