

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

Facility Identification Data

Name: RAVENSWOOD GENERATING STATION

Address: 38-54 VERNON BLVD

QUEENS, NY 11101

Owner/Firm

Name: HELIX RAVENSWOOD LLC

Address: 38-54 VERNON BLVD

LONG ISLAND CITY, NY 11101, USA

Owner Classification: Corporation/Partnership

Permit Contacts

Division of Environmental Permits:

Name: DENISE L GRATTAN

Address: 1 HUNTERS POINT PLAZA

47-40 21ST ST

LONG ISLAND CITY, NY 11101

Phone:7184824997

Division of Air Resources:

Name: PARESH SHAH

Address: NYSDEC - REGION 2

47-40 21ST ST

LONG ISLAND CITY, NY 11101

Air Permitting Facility Owner Contact:

Name: ROBERTA ZWIER

Address: HELIX RAVENSWOOD LLC

38-54 VERNON BLVD

LONG ISLAND CITY, NY 11101

Phone:8323347457

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

The proposed minor permit modification to include new carbon dioxide limits as required by the 6 NYCRR 251 Performance Standards for Major Electric Generating Facilities. Ravenswood proposes to add a permit condition for 6 NYCRR 251.3 (b) as a new Applicable State Requirement to the currently active Title V Permit (2-6304-00024/00039).

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

Facility is currently in compliance with the proposed limits, and emissions will not increase.

Attainment Status

RAVENSWOOD GENERATING STATION is located in the town of QUEENS in the county of QUEENS.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor.

Facility Description:

The facility consists of one GE 7FA combustion turbine, one heat recovery steam generator (HRSG) equipped with a duct burner for supplemental firing and one steam turbine. The turbine fires natural gas with up to 30 days of distillate oil, the duct burner only fires natural gas.

The plant has a nominal generating capacity of approximately 250 megawatts.

Permit Structure and Description of Operations

The Title V permit for RAVENSWOOD GENERATING STATION is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:
 combustion - devices which burn fuel to generate heat, steam or power
 incinerator - devices which burn waste material for disposal

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

control - emission control devices
process - any device or contrivance which may emit air contaminants that is not included in the above categories.

RAVENSWOOD GENERATING STATION is defined by the following emission unit(s):

Emission unit UCC001 - EMISSION UNIT UCC001 REPRESENTS ONE GE S107FA COMBUSTION TURBINE RATED AT 1779 MMBTU/HR WHEN FIRING NATURAL GAS (THE PRIMARY FUEL) AT 54.6 DEGREES FAHRENHEIT AND 2028 MMBTU/HR WHEN FIRING DISTILLATE OIL (BACK-UP FUEL) AT -5 DEGREES FAHRENHEIT. THE COMBUSTION TURBINE IS EQUIPPED WITH A DUCT BURNER RATED AT 644 MMBTU/HR (HIGH HEATING VALUE) WHILE FIRING NATURAL GAS. THE COMBINED CYCLE FACILITY GENERATES APPROXIMATELY 250 MW OF POWER.

DISTILLATE OIL USED IN THIS EMISSION UNIT WILL BE ULTRA-LOW-SULFUR FUEL OIL (< 0.0015% SULFUR BY WEIGHT). AS REFERENCED IN SOME OTHER PERMIT CONDITIONS, DISTILLATE OIL IS INTERCHANGABLE WITH KEROSENE.

Emission unit UCC001 is associated with the following emission points (EP):
CC001

Process: PC1 is located at GROUND, Building CCRAV01 - EMISSION UNIT UCC001 REPRESENTS A GE S107FA COMBUSTION TURBINE RATED AT 1779 MMBTU/HR WHEN FIRING NATURAL GAS (THE PRIMARY FUEL) AT 54.6 DEGREES FAHRENHEIT OPERATING AT 40-100% LOAD. PROCESS PC1 FOR EMISSION UNIT UCC001 REPRESENTS NATURAL GAS FIRING IN THE TURBINE AND NO DUCT BURNER FIRING. FOR THIS PROCESS DRY LOW NO_x BURNERS AND SELECTIVE CATALYTIC REDUCTION ARE USED TO CONTROL NO_x EMISSIONS. EMISSIONS OF VOC AND CO ARE CONTROLLED THROUGH THE USE OF AN OXIDATION CATALYST. TOTAL THROUGHPUT VALUES LISTED BELOW REPRESENT MAXIMUM NATURAL GAS USE FOR THE SHORT-TERM (HOURLY) BASIS WHILE THE ANNUAL QUANTITY PER YEAR OF NATURAL GAS REPRESENTS TURBINE OPERATIONS AT THE AVERAGE ANNUAL TEMPERATURE (54.6 DEGREES FAHRENHEIT).

Process: PC2 is located at GROUND, Building CCRAV01 - EMISSION UNIT UCC001 REPRESENTS A GE S107FA COMBUSTION TURBINE RATED AT 2028 MMBTU/HR WHEN FIRING DISTILLATE OIL (BACK-UP FUEL) AT -5 DEGREES FAHRENHEIT OPERATING AT 40-100% LOAD. PROCESS PC2 FOR EMISSION UNIT UCC001 REPRESENTS DISTILLATE OIL FIRING IN THE TURBINE AND NO DUCT BURNER FIRING. FOR THIS PROCESS DRY LOW NO_x BURNERS AND SELECTIVE CATALYTIC REDUCTION ARE USED TO CONTROL NO_x EMISSIONS. EMISSIONS OF VOC AND CO ARE CONTROLLED THROUGH THE USE OF AN OXIDATION CATALYST. DISTILLATE OIL USE WILL BE LIMITED TO 11.32 MILLION GALLONS PER YEAR, WHICH IS EQUIVALENT TO 720 HOURS PER YEAR OF OPERATION. MAXIMUM TOTAL THROUGHPUT OF DISTILLATE OIL ON AN HOURLY BASIS, REPRESENTS TURBINE OPERATIONS AT -5 DEGREES FAHRENHEIT AT FULL LOAD.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

DISTILLATE FUEL USED IS ULTRA LOW SULFUR FUEL OIL. AS REFERENCED IN SOME OTHER PERMIT CONDITIONS, DISTILLATE OIL IS INTERCHANGABLE WITH KEROSENE.

Process: PC3 is located at GROUND, Building CCRAV01 - EMISSION UNIT UCC001 REPRESENTS A GE S107FA COMBUSTION TURBINE RATED AT 1779 MMBTU/HR WHEN FIRING NATURAL GAS (THE PRIMARY FUEL) AT 54.6 DEGREES FAHRENHEIT OPERATING AT 40-100% LOAD. THE COMBUSTION TURBINE IS EQUIPPED WITH A DUCT BURNER RATED AT 644 MMBTU/HR WHILE FIRING NATURAL GAS. PROCESS PC3 FOR EMISSION UNIT UCC001 REPRESENTS NATURAL GAS FIRING IN THE GAS TURBINE AND DUCT BURNER. FOR THIS PROCESS DRY LOW NO_x BURNERS AND SELECTIVE CATALYTIC REDUCTION ARE USED TO CONTROL NO_x EMISSIONS. EMISSIONS OF VOC AND CO ARE CONTROLLED THROUGH THE USE OF AN OXIDATION CATALYST. TOTAL THROUGHPUT VALUES LOCATED BELOW REPRESENT NATURAL GAS USE FOR THE SHORT-TERM (HOURLY) BASIS WHILE THE ANNUAL QUANTITY PER YEAR OF NATURAL GAS REPRESENTS TURBINE OPERATIONS AT THE AVERAGE ANNUAL TEMPERATURE (54.6 DEGREES FAHRENHEIT).

Process: PC4 is located at GROUND, Building CCRAV01 - EMISSION UNIT UCC001 REPRESENTS A GE S107FA COMBUSTION TURBINE RATED AT 2028 MMBTU/HR WHEN FIRING DISTILLATE OIL (BACK-UP FUEL) AT -5 DEGREES FAHRENHEIT OPERATING AT 85-100% LOAD. THE COMBUSTION TURBINE IS EQUIPPED WITH A DUCT BURNER RATED AT 644 MMBTU/HR WHILE FIRING NATURAL GAS. PROCESS PC4 FOR EMISSION UNIT UCC001 REPRESENTS DISTILLATE OIL FIRING IN THE GAS TURBINE, WHILE NATURAL GAS IS FIRED IN THE DUCT BURNER. FOR THIS PROCESS DRY LOW NO_x BURNERS AND SELECTIVE CATALYTIC REDUCTION ARE USED TO CONTROL NO_x EMISSIONS. EMISSIONS OF VOC AND CO ARE CONTROLLED THROUGH THE USE OF AN OXIDATION CATALYST. DISTILLATE OIL USE WILL BE LIMITED TO 11.32 MILLION GALLONS PER YEAR, WHICH IS EQUIVALENT TO 720 HOURS PER YEAR OF OPERATION. MAXIMUM TOTAL THROUGHPUT OF DISTILLATE OIL, ON AN HOURLY BASIS, REPRESENTS TURBINE OPERATIONS AT -5 D F AT FULL LOAD.

DISTILLATE FUEL USED IS ULTRA LOW SULFUR FUEL OIL. AS REFERENCED IN SOME OTHER PERMIT CONDITIONS, DISTILLATE OIL IS INTERCHANGABLE WITH KEROSENE.

Title V/Major Source Status

RAVENSWOOD GENERATING STATION is subject to Title V requirements. This determination is based on the following information:

Facility has PTE emissions of a major source category.

Program Applicability

The following chart summarizes the applicability of RAVENSWOOD GENERATING STATION with regards to the principal air pollution

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

regulatory programs:

Regulatory Program	Applicability
PSD	YES
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	YES
TITLE IV	YES
TITLE V	YES
TITLE VI	NO
RACT	NO
SIP	YES

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52.21, 6 NYCRR 231-7, 231-8) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR 231-5, 231-6) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61, 6 NYCRR 200.10) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

MACT Maximum Achievable Control Technology (40 CFR 63, 6 NYCRR 200.10) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60, 6 NYCRR 200.10) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78, 6 NYCRR 201-6) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subpart A thru G, 6 NYCRR 200.10) -

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212-3, 220-1.6, 220-1.7, 220-2.3, 220-2.4, 226, 227-2, 228, 229, 230, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH, 6 NYCRR 200.10) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements.

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code

Description

4911

ELECTRIC SERVICES

SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code

Description

2-01-002-01

INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION
ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - NATURAL GAS
Turbine

2-01-009-01

INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION
ELECTRIC UTILITY IC ENGINE - KEROSENE/NAPHTHA (JET FUEL)
Turbine

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE for each contaminant that is displayed represents the facility-wide PTE in tons per year (tpy) or pounds per year (lbs/yr). In some instances the PTE represents a federally enforceable emissions cap or limitation for that contaminant. The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant	PTE lbs/yr	PTE tons/yr	Actual lbs/yr	Actual tons/yr
007664-41-7	AMMONIA	146242			
007440-36-0	ANTIMONY	37			
007440-38-2	ARSENIC	18			
007440-39-3	BARIUM	1.5			
007440-41-7	BERYLLIUM	2.2			
007726-95-6	BROMINE	13			
007440-43-9	CADMIUM	2.2			
000124-38-9	CARBON DIOXIDE		1287311.7		651559.18
0NY750-00-0	CARBON DIOXIDE EQUIVALENTS		1288924.9		652037.23
000630-08-0	CARBON MONOXIDE	194619			
007440-47-3	CHROMIUM	5.2			
007440-48-4	COBALT	0.4			
007440-50-8	COPPER	15			
000050-00-0	FORMALDEHYDE	15070			
007439-92-1	LEAD	43			
007439-96-5	MANGANESE	8.8			
007439-97-6	MERCURY	0.05			
007440-02-0	NICKEL METAL AND INSOLUBLE COMPOUNDS	2.8			
0NY210-00-0	OXIDES OF NITROGEN	284000			
007723-14-0	PHOSPHORUS (YELLOW)	13813			
0NY075-02-5	PM 2.5	518758			
0NY075-00-5	PM-10	518758			
007782-49-2	SELENIUM	11			
007446-09-5	SULFUR DIOXIDE	150701			
007664-93-9	SULFURIC ACID	46696			
0NY100-00-0	TOTAL HAP	21225			
007440-62-2	VANADIUM	111			

Division of Air Resources
Permit Review Report

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

0NY998-00-0	VOC	198400
007440-66-6	ZINC	18

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.2(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR Part 201-6.2(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.4(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.4(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

Item H: Severability - 6 NYCRR Part 201-6.4(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR Part 201-6.4(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR Part 201-6.4(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;
- (3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement. item_02

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6
NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Condition	Short Description
-- FACILITY	ECL 19-0301	72	Powers and Duties of the Department with respect to air pollution control
U-CC001	40CFR 52-A.21(j)	37, 38, 39	Best Available Control Technology
U-CC001/CC001/PC1	40CFR 52-A.21(j)	54, 55, 56, 57	Best Available Control Technology
U-CC001/CC001/PC2	40CFR 52-A.21(j)	58, 59, 60, 61	Best Available Control Technology
U-CC001/CC001/PC3	40CFR 52-A.21(j)	63, 64, 65, 66	Best Available Control Technology
U-CC001/CC001/PC4	40CFR 52-A.21(j)	67, 68, 69, 70	Best Available Control Technology

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

U-CC001	40CFR 60-GG.334 (a)	40		Monitoring of Operations for Turbines Employing Water Injection to Control NOx
U-CC001	40CFR 60-GG.334 (b)	41		Monitoring of Operations: CEMS
FACILITY	40CFR 68	18		Chemical accident prevention provisions
U-CC001/-/PC1	40CFR 75-B.11 (d)	44		Continuous emission monitoring - specific provisions for monitoring SO2 emissions gas-fired units and oil-fired units
U-CC001/-/PC3	40CFR 75-B.11 (d)	49		Continuous emission monitoring - specific provisions for monitoring SO2 emissions gas-fired units and oil-fired units
U-CC001/CC001	40CFR 75-B.11 (e)	53		Continuous emission monitoring - specific provisions for monitoring SO2 emissions units with SO2 CEM gaseous fuel
U-CC001/CC001/PC2	40CFR 75-B.11 (e)	62		Continuous emission monitoring - specific provisions for monitoring SO2 emissions units with SO2 CEM gaseous fuel
U-CC001/CC001/PC4	40CFR 75-B.11 (e)	71		Continuous emission monitoring - specific provisions for monitoring SO2 emissions units with SO2 CEM gaseous fuel
FACILITY	40CFR 82-F	19		Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	6NYCRR 200.6	1		Acceptable ambient air quality.
FACILITY	6NYCRR 200.7	10, 1	-1	Maintenance of equipment.
FACILITY	6NYCRR 201-1.4	1	-4	Unavoidable noncompliance and violations
FACILITY	6NYCRR 201-1.7	11		Recycling and Salvage
FACILITY	6NYCRR 201-1.8	12		Prohibition of reintroduction of collected contaminants to the air
FACILITY	6NYCRR 201-3.2 (a)	13		Exempt Activities - Proof of eligibility
FACILITY	6NYCRR 201-3.3 (a)	14		Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6	20, 26, 27		Title V Permits and the Associated Permit Conditions

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

U-CC001	6NYCRR 201-6	28, 29, 30, 31, 32, 33, 34	Title V Permits and the Associated Permit Conditions
FACILITY	6NYCRR 201-6.4 (a) (4)	15	General Conditions - Requirement to Provide Information
FACILITY	6NYCRR 201-6.4 (a) (7)	2	General Conditions - Fees
FACILITY	6NYCRR 201-6.4 (a) (8)	16	General Conditions - Right to Inspect
FACILITY	6NYCRR 201-6.4 (c)	3	Recordkeeping and Reporting of Compliance Monitoring
FACILITY	6NYCRR 201-6.4 (c) (2)	4	Records of Monitoring, Sampling and Measurement
FACILITY	6NYCRR 201- 6.4 (c) (3) (ii)	5	Reporting Requirements - Deviations and Noncompliance
FACILITY	6NYCRR 201-6.4 (d) (4)	21	Compliance Schedules - Progress Reports
FACILITY	6NYCRR 201-6.4 (e)	6	Compliance Certification
FACILITY	6NYCRR 201-6.4 (f)	1 -2	Operational Flexibility
FACILITY	6NYCRR 201-6.4 (f) (6)	17	Off Permit Changes
FACILITY	6NYCRR 201-6.5 (a)	1 -5, 1 -6	State Enforceable Requirements
FACILITY	6NYCRR 202-1.1	22	Required emissions tests.
FACILITY	6NYCRR 202-2.1	7	Emission Statements - Applicability
FACILITY	6NYCRR 202-2.4 (a) (3)	1 -3	Emission statement methods and procedures
FACILITY	6NYCRR 202-2.5	8	Emission Statements - record keeping requirements.
FACILITY	6NYCRR 211.1	74	General Prohibitions - air pollution prohibited
FACILITY	6NYCRR 211.2	23	General Prohibitions - visible emissions limited.
FACILITY	6NYCRR 215.2	9	Open Fires - Prohibitions
FACILITY	6NYCRR 225-1.2 (g)	24	Sulfur-in-Fuel Limitations
FACILITY	6NYCRR 225-1.2 (h)	25	Sulfur-in-Fuel Limitations
U-CC001/CC001	6NYCRR 227-1.3	52	Smoke Emission Limitations.
U-CC001	6NYCRR 231-2	35, 36	New Source Review in Nonattainment Areas and Ozone Transport Region
U-CC001/-/PC1	6NYCRR 231-2.5	42, 43	Lowest achievable emission rate, LAER
U-CC001/-/PC2	6NYCRR 231-2.5	45, 46	Lowest achievable emission rate, LAER
U-CC001/-/PC3	6NYCRR 231-2.5	47, 48	Lowest achievable emission rate, LAER
U-CC001/-/PC4	6NYCRR 231-2.5	50, 51	Lowest achievable emission rate, LAER

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

FACILITY	6NYCRR 242-1.5	75, 76	CO2 Budget Trading Program - Standard requirements
U-CC001	6NYCRR 251.3(b)	1 -7	Emission limits for non-modified sources.

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6 NYCRR 201-3.2 (a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.4 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6 NYCRR 201-6.4 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6 NYCRR 201-6.4 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.4 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.4 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.4 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6 NYCRR 201-6.4 (d) (4)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6 NYCRR 201-6.4 (e)

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6 NYCRR 201-6.4 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

40 CFR Part 68

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, RAVENSWOOD GENERATING STATION has been determined to be subject to the following regulations:

40 CFR 52.21 (j)

BACT determinations are made on a case-by-case basis and can be no less stringent than any requirement that exists in the current State Implementation Plan (SIP) or 40 CFR 60 and 61. Emission and operational

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

limitations required from a BACT determination will have to be entered into the special permit conditions, separately by the permit reviewer.

40 CFR 60.334 (a)

This regulation requires the owner or operator of any stationary gas turbine subject to the provisions of 40CFR60 Subpart GG that is using water injection to control NOx emissions to install and operate a continuous monitoring system to monitor and record fuel consumption and the ratio of water to fuel fired in the turbine

40 CFR 60.334 (b)

This regulation allows the owner/operator of a gas turbine to use a CEMS to monitor NOx emissions instead of monitoring fuel and water/steam usage.

40 CFR 75.11 (d)

This section deals with the measurements of SO₂ in gas-fired and oil-fired systems only. It specifies requirements in addition to the general operating requirements in § 75.10 and provides for alternative methods for estimating hourly SO₂ mass emissions.

40 CFR 75.11 (e)

This section applies to the measurement of SO₂ during the combustion of gaseous fuel "natural gas" only. It provides additional requirements to the general requirements, and alternative methods of determining SO₂ emissions.

6 NYCRR 201-6.4 (f)

This section describes the potential for certain operational changes to be made by the facility owner or operator without first obtaining a permit modification. Changes made pursuant to this provision must meet all of the criteria described in this section to qualify for consideration as operational flexibility. The Department reserves the right to require the facility owner or operator to obtain a permit modification prior to making any changes at the facility pursuant to this section.

6 NYCRR 201-6.5 (a)

This subdivision states that the Department shall include state enforceable conditions in Title V permits. State enforceable conditions related to regulations developed pursuant to the Climate Leadership and Community Protection Act (CLCPA) and Article 75 of New York State Environmental Conservation Law may be included in future versions of this permit, as applicable.

6 NYCRR 202-2.4 (a) (3)

Once a facility is required to submit annual emission statements electronically, emission statements must be submitted to the department per the specified schedule, in this regulation beginning the reporting year that a Title V permit containing a condition mandating electronic submittal is issued.

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

6 NYCRR 211.1

This regulation requires that no person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

6 NYCRR 225-1.2 (g)

Sulfur-in-fuel limitations for the purchase of distillate oil on or after July 1, 2014.

6 NYCRR 225-1.2 (h)

Sulfur-in-fuel limitation for the firing of distillate oil on or after July 1, 2016.

6 NYCRR 227-1.3

This regulation requires a limitation and compliance monitoring for opacity from a stationary combustion installation.

6 NYCRR 231-2.5

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In the New York City metropolitan area, carbon monoxide is also a non-attainment contaminant. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

Emission controls equivalent to the lowest achievable emission rate (LAER) must be implemented for each contaminant for which Subpart 231-2 is applicable for a given source project or new major facility. LAER is defined as the most stringent emission limitation achieved in practice or which can be expected to be achieved in practice for a category of emission sources taking into consideration each air contaminant which must be controlled (6 NYCRR 200.1(ak)).

6 NYCRR 242-1.5

This regulation requires that the facility hold enough carbon dioxide allowances in their carbon dioxide budget at least equal to the amount of carbon dioxide emitted from the facility each year.

6 NYCRR 251.3 (b)

Emission limits for non-modified sources.

6 NYCRR Subpart 231-2

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

Compliance Certification

Summary of monitoring activities at RAVENSWOOD GENERATING STATION:

Location Facility/EU/EP/Process/ES	Cond No.	Type of Monitoring

U-CC001	37	record keeping/maintenance procedures
U-CC001	38	monitoring of process or control device parameters as surrogate
U-CC001	39	monitoring of process or control device parameters as surrogate
U-CC001/CC001/PC1	54	intermittent emission testing
U-CC001/CC001/PC1	55	intermittent emission testing
U-CC001/CC001/PC1	56	continuous emission monitoring (cem)
U-CC001/CC001/PC1	57	continuous emission monitoring (cem)
U-CC001/CC001/PC2	58	intermittent emission testing
U-CC001/CC001/PC2	59	intermittent emission testing
U-CC001/CC001/PC2	60	continuous emission monitoring (cem)
U-CC001/CC001/PC2	61	continuous emission monitoring (cem)
U-CC001/CC001/PC3	63	intermittent emission testing
U-CC001/CC001/PC3	64	intermittent emission testing
U-CC001/CC001/PC3	65	continuous emission monitoring (cem)
U-CC001/CC001/PC3	66	continuous emission monitoring (cem)
U-CC001/CC001/PC4	67	intermittent emission testing
U-CC001/CC001/PC4	68	intermittent emission testing
U-CC001/CC001/PC4	69	continuous emission monitoring (cem)
U-CC001/CC001/PC4	70	continuous emission monitoring (cem)
U-CC001	40	continuous emission monitoring (cem)
U-CC001	41	record keeping/maintenance procedures
U-CC001/-/PC1	44	monitoring of process or control device parameters as surrogate
U-CC001/-/PC3	49	monitoring of process or control device parameters as surrogate
U-CC001/CC001	53	record keeping/maintenance procedures
U-CC001/CC001/PC2	62	monitoring of process or control device parameters as surrogate
U-CC001/CC001/PC4	71	monitoring of process or control device parameters as surrogate
U-CC001	28	monitoring of process or control device parameters as surrogate
U-CC001	29	monitoring of process or control device parameters as surrogate
U-CC001	30	monitoring of process or control device parameters as surrogate
U-CC001	31	continuous emission monitoring (cem)
U-CC001	32	continuous emission monitoring (cem)
U-CC001	33	monitoring of process or control device parameters as surrogate
U-CC001	34	record keeping/maintenance procedures
FACILITY	5	record keeping/maintenance procedures
FACILITY	6	record keeping/maintenance procedures

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

FACILITY	1-5	record keeping/maintenance procedures
FACILITY	1-6	monitoring of process or control device parameters as surrogate
FACILITY	7	record keeping/maintenance procedures
FACILITY	24	work practice involving specific operations
FACILITY	25	work practice involving specific operations
U-CC001/CC001	52	record keeping/maintenance procedures
U-CC001	35	intermittent emission testing
U-CC001	36	continuous emission monitoring (cem)
U-CC001/-/PC1	42	intermittent emission testing
U-CC001/-/PC1	43	continuous emission monitoring (cem)
U-CC001/-/PC2	45	intermittent emission testing
U-CC001/-/PC2	46	continuous emission monitoring (cem)
U-CC001/-/PC3	47	continuous emission monitoring (cem)
U-CC001/-/PC3	48	intermittent emission testing
U-CC001/-/PC4	50	continuous emission monitoring (cem)
U-CC001/-/PC4	51	intermittent emission testing
FACILITY	75	record keeping/maintenance procedures
FACILITY	76	record keeping/maintenance procedures
U-CC001	1-7	monitoring of process or control device parameters as surrogate

Basis for Monitoring

- PM: Monitoring based on 6 NYCRR Part 227
- NOx: Monitoring based on 6 NYCRR Part 227
- SO2: Monitoring based on 6 NYCRR Part 225
- OPacity: Monitoring based on 6 NYCRR Part 227

In July 2019, DEC reviewed the 1-hour NO2 Modeling Report submitted by AKRF on behalf of Ravenswood Generating Station located at 38-54 Vernon Blvd. in Queens, NY. The modeling methodologies used in the ambient air quality modeling analysis are acceptable. The results of this refined modeling analysis demonstrate that the modeled 1-hour NO2 impacts will not cause or contribute to an exceedance of the National Ambient Air Quality Standards.

July 2021, DEC reviewed 1 hour NO2 modeling report for both the permits (2-6304-00024/00035 and 2-6304-00024/00039) located at 38-54 Vernon Blvd, Queens, NY. The modeling methodologies used in the ambient air quality modeling analysis are acceptable. The results of this refined modeling analysis demonstrate that the modeled 1-hour NO2 impacts will not cause or contribute to an exceedance of the National Ambient Air Quality Standards.

231-2 is applicable: modification was done in 2004

40 cfr 52.21 (j): The requirements of this section apply to the construction of any new major stationary source (as defined in paragraph (b)(1) of this section) or any project at an existing major stationary source in an area designated as attainment or unclassifiable under sections 107(d)(1)(A)(ii) or (iii) of the Act. When this Title V permit were issued originally in 2001, the new source was permitted.

251condition: The proposed minor permit modification to include new carbon dioxide limits as required by the 6 NYCRR 251 Performance Standards for Major Electric Generating Facilities.

General Monitoring Requirements: Title V facilities are required to submit semiannual reports and annual compliance certifications, which the Department uses to determine if the facility has complied with the requirements of their permit. Title V facilities are also required to submit an annual emission

**Division of Air Resources
Permit Review Report**

Permit ID: 2-6304-00024/00039

Renewal Number: 3

Modification Number: 1 10/16/2023

statement which quantifies the actual amount of emissions that the facility emitted for the previous year.

Fuel Monitoring Requirements: The facility is required to conduct and submit a nitrogen and sulfur analysis on their fuel semiannually to both the Department and EPA. The applicant may submit a fuel vendor certification instead of conducting the fuel analysis.

Opacity Requirements: The facility is required to annually conduct and certify compliance with a 20 percent opacity limit.

Recordkeeping Requirements: All Title V facilities are required to maintain copies of their records on-site for a minimum period of five years.

201-6.5 (a) condition:

To reduce the GHG emissions under the CLCPA, facility plans to do the following:

1. Facility propose to reduce the distillate oil allowance use from 720 hours per year to 540 hours per year. The reduction of distillate oil run time is expected to result in the potential to emit reductions of approximately 11,500 tons/yr. of CO₂ +eq. and 251 lbs./yr. of HAP. Please note that the facility proposes distillate oil use reduction under normal operating conditions. However, in the event of an electric grid reliability issue or system emergency, the facility may be called on to use distillate fuel for an unforeseen number of hours.
2. The facility proposes to engage an independent assessment and related tuning of the Combustion Turbine once per three years. A focused tuning event is expected to result in 0.5% to 1% efficiency improvement to the unit's heat rate. This tuning related improvement is anticipated to result in the potential to emit reductions of approximately 4,900 to 9,800 tons/yr. of CO₂ +eq. and approximately 87 to 174 lbs./yr. of HAP.