



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

**Facility Identification Data**

Name: LONG ISLAND JEWISH MEDICAL CENTER-QUEENS

Address: 270-05 76TH AVE

NEW HYDE PARK, NY 11040

**Owner/Firm**

Name: LONG ISLAND JEWISH MEDICAL CENTER

Address: 270-05 76TH AVE

NEW HYDE PARK, NY 11040-1433, USA

Owner Classification: Corporation/Partnership

**Permit Contacts**

Division of Environmental Permits:

Name: ELIZABETH A CLARKE

Address: NYSDEC

47-40 21ST ST

LONG ISLAND CITY, NY 11101-5407

Phone:7184824997

Division of Air Resources:

Name: SIDERIS A CARAMINTZOS

Address: NYSDEC

1 HUNTER'S PT PLZ 47-40 21ST ST

LONG ISLAND CITY, NY 11101-5407

Air Permitting Facility Owner Contact:

Name: ROBERT RAIMONDI

Address: LONG ISLAND JEWISH MEDICAL CENTER

270-05 76TH AVE

NEW HYDE PARK, NY 11040

Phone:7184707410

**Permit Description**

**Introduction**

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

**Summary Description of Proposed Project**

Application for renewal of Air Title V Facility.

In this renewal application, the applicant is requesting to remove the Oxides of Nitrogen RACT variance for for the two cogeneration units, emission sources 00CG1 and 00CG2, since these sources, based on the



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

recent stack test, meet the Subpart 227-2 NOx limit of 1.5 g/bhp-hr.

**Attainment Status**

LONG ISLAND JEWISH MEDICAL CENTER-QUEENS is located in the town of QUEENS in the county of QUEENS.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	SEVERE NON-ATTAINMENT
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

\* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

\*\* NOx has a separate ambient air quality standard in addition to being an ozone precursor.

**Facility Description:**

The facility is a hospital associated with the North Shore Long Island Jewish Health System. The hospital operates three (3) dual fired boilers each rated at 63 mmBTU/hr, burning #2 fuel oil and natural gas, two cogen units rated at 12.219 mmbtu/hr (1.4 MW) burning natural gas, a dual use generator (emergency power back up engine) and seven (7) emergency generators burning fuel oil and three exempt boilers. The permitted central plant boilers are currently capped to under 25 tons to avoid new source review. In addition to the permitted central plant boilers, the hospital has an emergency generator in the central plant that was previously not permitted and is included as an emission unit in this application.

**Permit Structure and Description of Operations**

The Title V permit for LONG ISLAND JEWISH MEDICAL CENTER-QUEENS is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types: combustion - devices which burn fuel to generate heat, steam or power



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

incinerator - devices which burn waste material for disposal  
control - emission control devices  
process - any device or contrivance which may emit air contaminants  
that is not included in the above categories.

LONG ISLAND JEWISH MEDICAL CENTER-QUEENS is defined by the following emission unit(s):

Emission unit U000CP - Three (3) boilers with emission sources 00CP1, 00CP2, 00CP3 combined to one (1) stack, emission point 000CP.

Two cogeneration systems; sources 00CG1 and 00CG2 exhausting through the existing stack, emission point 000CP. Each of these sources is equipped with catalytic oxidation controls, designated as 01CG1 02CG2 respectively.

Emission unit U000CP is associated with the following emission points (EP):  
000CP

Process: 1CF is located at CENTRAL PLANT, Building CENTRAL - FIRING NUMBER 2 FUEL OIL.

Process: 1CG is located at CENTRAL PLANT, Building CENTRAL - FIRING NATURAL GAS.

Process: 2CF is located at CENTRAL PLANT, Building CENTRAL - FIRING NUMBER 2 FUEL OIL.

Process: 2CG is located at CENTRAL PLANT, Building CENTRAL - FIRING NATURAL GAS.

Process: 3CF is located at CENTRAL PLANT, Building CENTRAL - FIRING NUMBER 2 FUEL OIL.

Process: 3CG is located at CENTRAL PLANT, Building CENTRAL - FIRING NATURAL GAS.

Emission unit UGENCP - This emission unit includes one dual-use generator (emergency and assist for the cogen units); designated as 0GEN1, exhausting to emission point 000G1.

Emission unit UGENCP is associated with the following emission points (EP):  
000G1

Process: CF3 is located at Building CENTRAL - Firing No. 2 oil.

Emission unit UOEGCP - This emission unit is for the existing emergency generator (source EGEN1) installed in the central plant that was part of the central plant boiler installation. This emergency generator has a dedicated exhaust stack (emission point 00EG1).

Emission unit UOEGCP is associated with the following emission points (EP):  
00EG1

Process: ECF Firing no. 2 fuel oil.

Emission unit EMRGEN - Six emergency generators not included in any other emission unit.



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

Process: EMG Diesel #2 oil

**Title V/Major Source Status**

LONG ISLAND JEWISH MEDICAL CENTER-QUEENS is subject to Title V requirements. This determination is based on the following information:

The facility is a major facility because the Oxides of Nitrogen emissions exceed 25 tons per year on a 12 month rolling basis.

**Program Applicability**

The following chart summarizes the applicability of LONG ISLAND JEWISH MEDICAL CENTER-QUEENS with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	YES
NSPS	YES
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

**NOTES:**

**PSD** Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**NSR** New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

**NESHAP** National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

**MACT** Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

**NSPS** New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

**Title IV Acid Rain Control Program (40 CFR 72 thru 78)** - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

**Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G)** - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

**RACT** Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

**SIP** State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

**Compliance Status**

Facility is in compliance with all requirements.

**SIC Codes**

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis

of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

**SIC Code**

**Description**

8062

GENERAL MEDICAL & SURGICAL HOSPITALS

**SCC Codes**

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information.Each SCC



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

represents

a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code	Description
1-03-005-02	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - DISTILLATE OIL 10-100MMBTU/HR **
1-03-006-02	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS 10-100 MMBtu/Hr
2-03-001-01	INTERNAL COMBUSTION ENGINES - COMMERCIAL/INSTITUTIONAL COMMERCIAL/INSTITUTIONAL IC ENGINE - DISTILLATE OIL (DIESEL) Reciprocating
2-03-002-04	INTERNAL COMBUSTION ENGINES - COMMERCIAL/INSTITUTIONAL COMMERCIAL/INSTITUTIONAL IC ENGINE - NATURAL GAS COGENERATION

**Facility Emissions Summary**

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE lbs/yr	Range
0NY508-00-1	40 CFR 60 SUBPART IIII - HYDROCARBONS		>= 100 tpy but < 250 tpy
000630-08-0	CARBON MONOXIDE		>= 50 tpy but < 100 tpy
0NY100-00-0	HAP		> 0 but < 2.5 tpy
007439-92-1	LEAD		> 0 but < 10 tpy

New York State Department of Environmental Conservation  
Permit Review Report



Permit ID: 2-6307-00290/00001

Renewal Number: 2

09/14/2012

0NY210-00-0	OXIDES OF NITROGEN	>= 50 tpy but < 100 tpy
0NY075-00-0	PARTICULATES	>= 2.5 tpy but < 10 tpy
0NY075-00-5	PM-10	>= 2.5 tpy but < 10 tpy
007446-09-5	SULFUR DIOXIDE	>= 2.5 tpy but < 10 tpy
0NY998-00-0	VOC	>= 10 tpy but < 25 tpy

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A: Emergency Defense - 6 NYCRR 201-1.5**

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)**

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

**Item C: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.3(a)(4)**

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)**

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based

New York State Department of Environmental Conservation  
**Permit Review Report**



**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

- Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)**  
The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)**  
This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
- Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.5(a)(5)**  
It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.
- Item H: Property Rights - 6 NYCRR 201-6.5(a)(6)**  
This permit does not convey any property rights of any sort or any exclusive privilege.
- Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)**  
If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.
- Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)**  
All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:
- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;



New York State Department of Environmental Conservation  
**Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

**Item L: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

**Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**Item A: General Provisions for State Enforceable Permit Terms and Condition - 6  
NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Regulatory Analysis**

<b>Location Facility/EU/EP/Process/ES</b>	<b>Regulation</b>	<b>Condition</b>	<b>Short Description</b>
-- FACILITY	ECL 19-0301	68	Powers and Duties of the Department with respect to air pollution control
U-000CP/-/1CF/00CP1	40CFR 60-Dc.42c (d)	42	Standard for Sulfur Dioxide Firing Oil. (see narrative)
U-000CP/-/2CF/00CP2	40CFR 60-Dc.42c (d)	46	Standard for Sulfur Dioxide Firing Oil. (see narrative)
U-000CP/-/3CF/00CP3	40CFR 60-Dc.42c (d)	48	Standard for Sulfur Dioxide Firing Oil. (see narrative)
U-000CP/000CP/1CF/00CP1	40CFR 60-Dc.43c (c)	56	Standard for Opacity.
U-000CP/000CP/2CF/00CP2	40CFR 60-Dc.43c (c)	59	Standard for Opacity.
U-000CP/000CP/3CF/00CP3	40CFR 60-Dc.43c (c)	62	Standard for Opacity.
U-000CP/000CP/1CF	40CFR 60-Dc.43c (d)	55	Time Period Requirements for

New York State Department of Environmental Conservation  
**Permit Review Report**



**Permit ID: 2-6307-00290/00001**  
**Renewal Number: 2**  
**09/14/2012**

U-000CP/000CP/2CF	40CFR 60-Dc.43c (d)	58	Opacity Time Period Requirements for Opacity
U-000CP/000CP/3CF	40CFR 60-Dc.43c (d)	61	Time Period Requirements for Opacity
U- 000CP/000CP/1CF/00CP1	40CFR 60-Dc.44c (h)	57	Alternative Compliance and Performance Test Methods and Procedures for Sulfur Dioxide.
U- 000CP/000CP/2CF/00CP2	40CFR 60-Dc.44c (h)	60	Alternative Compliance and Performance Test Methods and Procedures for Sulfur Dioxide.
U- 000CP/000CP/3CF/00CP3	40CFR 60-Dc.44c (h)	63	Alternative Compliance and Performance Test Methods and Procedures for Sulfur Dioxide.
U-000CP	40CFR 60-Dc.48c (a)	36	Reporting and Recordkeeping Requirements.
U-000CP	40CFR 60-Dc.48c (c)	37	Reporting and Recordkeeping Requirements
U-000CP	40CFR 60-Dc.48c (f) (1)	38	Reporting and Recordkeeping Requirements (distillate oil).
U-000CP	40CFR 60-Dc.48c (g)	39	Reporting and Recordkeeping Requirements.
U-000CP	40CFR 60-Dc.48c (i)	40	Reporting and Recordkeeping Requirements.
U-000CP	40CFR 60-Dc.48c (j)	41	Reporting period
U- GENCP/000G1/CF3/0GEN1	40CFR 60-IIII.4204 (a)	64, 65, 66, 67	Emission standards - Pre-2007 Non- emergency Stationary CI-IC Engines
E-MRGEN/-/EMG/EMRG1	40CFR 60-IIII.4205 (b)	33	Emission Standards - 2007 or later Emergency Non Fire Pump Stationary CI-IC Engines Displacing < 30 liters/cylinder
FACILITY	40CFR 63-ZZZZ	28	Reciprocating Internal Combustion Engine (RICE) NESHAP
U-000CP/-/1CG/00CG1	40CFR 63- ZZZZ.6590 (a) (2)	43	Reciprocating Internal Combustion Engine (RICE) NESHAP - Applicability - New RICE
U-000CP/-/1CG/01CG1	40CFR 63- ZZZZ.6590 (a) (2)	44	Reciprocating Internal Combustion Engine (RICE) NESHAP - Applicability - New



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

U-000CP/-/1CG/01CG2	40CFR 63- ZZZZ.6590 (a) (2)	45	RICE Reciprocating Internal Combustion Engine (RICE) NESHAP - Applicability - New RICE
U-000CP/-/2CG/00CG2	40CFR 63- ZZZZ.6590 (a) (2)	47	Reciprocating Internal Combustion Engine (RICE) NESHAP - Applicability - New RICE
U-000CP/-/1CG/00CG1	40CFR 63- ZZZZ.6595 (a) (7)	49	Reciprocating Internal Combustion Engine (RICE) NESHAP - Compliance Dates
U-000CP/-/1CG/01CG1	40CFR 63- ZZZZ.6595 (a) (7)	50	Reciprocating Internal Combustion Engine (RICE) NESHAP - Compliance Dates
U-000CP/-/1CG/01CG2	40CFR 63- ZZZZ.6595 (a) (7)	51	Reciprocating Internal Combustion Engine (RICE) NESHAP - Compliance Dates
U-000CP/-/2CG/00CG2	40CFR 63- ZZZZ.6595 (a) (7)	52	Reciprocating Internal Combustion Engine (RICE) NESHAP - Compliance Dates
FACILITY	40CFR 68	20	Chemical accident prevention provisions
FACILITY	40CFR 82-F	21	Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	6NYCRR 200.6	1	Acceptable ambient air quality.
FACILITY	6NYCRR 200.7	10	Maintenance of equipment.
FACILITY	6NYCRR 201-1.4	69, 70	Unavoidable noncompliance and violations
FACILITY	6NYCRR 201-1.7	11	Recycling and Salvage
FACILITY	6NYCRR 201-1.8	12	Prohibition of reintroduction of collected contaminants to the air
FACILITY	6NYCRR 201-3.2 (a)	13	Exempt Activities - Proof of eligibility
FACILITY	6NYCRR 201-3.3 (a)	14	Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6	22, 29, 30	Title V Permits and the Associated Permit Conditions
FACILITY	6NYCRR 201-6.5 (a) (4)	15	General conditions
FACILITY	6NYCRR 201-6.5 (a) (7)	2	General conditions Fees
FACILITY	6NYCRR 201-6.5 (a) (8)	16	General conditions
FACILITY	6NYCRR 201-6.5 (c)	3	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring
FACILITY	6NYCRR 201-6.5 (c) (2)	4	Permit conditions for Recordkeeping and Reporting of

New York State Department of Environmental Conservation  
**Permit Review Report**



**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

FACILITY	6NYCRR 201-6.5(c) (3) (ii)	5	Compliance Monitoring Permit conditions for Recordkeeping and Reporting of Compliance Monitoring
FACILITY	6NYCRR 201-6.5(d) (5)	17	Compliance schedules
FACILITY	6NYCRR 201-6.5(e)	6	Compliance Certification
FACILITY	6NYCRR 201-6.5(f) (6)	18	Off Permit Changes
FACILITY	6NYCRR 201-7.1	23, 31, 32	Federally Enforceable Emissions Caps
FACILITY	6NYCRR 202-1.1	19	Required emissions tests.
FACILITY	6NYCRR 202-2.1	7	Emission Statements - Applicability
FACILITY	6NYCRR 202-2.5	8	Emission Statements - record keeping requirements.
FACILITY	6NYCRR 211.1	24	General Prohibitions - air pollution prohibited
FACILITY	6NYCRR 211.2	71	General Prohibitions - visible emissions limited.
FACILITY	6NYCRR 215.2	9	Open Fires - Prohibitions
FACILITY	6NYCRR 225.1(a) (3)	25	Sulfur in Fuel Limitations (SIP)
FACILITY	6NYCRR 225.7(a)	26	Reports, Sampling and Analysis
U-000CP	6NYCRR 227.2(b) (1)	35	Particulate emissions.
U-000CP/000CP	6NYCRR 227-1.3	53	Smoke Emission Limitations.
FACILITY	6NYCRR 227-1.3(a)	27	Smoke Emission Limitations.
U-000CP/000CP	6NYCRR 227-2.4(c) (1) (i)	54	1994 NOx RACT presumptive limit.
FACILITY	6NYCRR 227-2.4(d)	72	Small boilers, small combustion turbines, and small stationary internal combustion engines.
U-000CP/-/1CG/00CG1	6NYCRR 227-2.4(d)	73	Small boilers, small combustion turbines, and small stationary internal combustion engines.
U-000CP/-/2CG/00CG2	6NYCRR 227-2.4(d)	74	Small boilers, small combustion turbines, and small stationary internal combustion engines.
U-000CP/000CP/1CG/00CG1	6NYCRR 227-2.4(f) (1)	76	Emission limit for natural gas fired engines.
U-000CP/000CP/2CG/00CG2	6NYCRR 227-2.4(f) (1)	77	Emission limit for natural gas fired engines.
U-000CP/000CP	6NYCRR 227-2.5(a)	75	Fuel switching option.
U-GENCP/000G1/CF3/0GEN1	6NYCRR 227-2.5(c)	78	Alternative RACT option.
U-000CP	6NYCRR 227-2.6(c)	34	Stack Test

New York State Department of Environmental Conservation  
Permit Review Report



Permit ID: 2-6307-00290/00001  
Renewal Number: 2  
09/14/2012

FACILITY

6NYCRR 231-2

23

Requirements.  
New Source Review in  
Nonattainment Areas  
and Ozone Transport  
Region

**Applicability Discussion:**

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6 NYCRR 201-3.2 (a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.5 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6 NYCRR 201-6.5 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6 NYCRR 201-6.5 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.5 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.5 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.5 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6 NYCRR 201-6.5 (d) (5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6 NYCRR 201-6.5 (e)



**New York State Department of Environmental Conservation**  
**Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6 NYCRR 201-6.5 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6 NYCRR 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calENDar year.

6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

40 CFR Part 68

This Part lists the regulated substances and there applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act AmENDments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

**Facility Specific Requirements**

In addition to Title V, LONG ISLAND JEWISH MEDICAL CENTER-QUEENS has been determined to be subject to the following regulations:

40 CFR 60.4204 (a)



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

Owners and operators of pre-2007 model year non emergency stationary CI ICE 2 with a displacement of less than 10 liters per cylinder must comply with table 1 of this subchapter.

40 CFR 60.4205 (b)

This requirement applies to owners and operators of 2007 model year and later emergency stationary CI IC engines with a displacement less than 30 liters/cylinder that are not fire pump engines. An applicable source must comply with the emission standards for new nonroad CI engines for all pollutants (HC, PM, NO<sub>x</sub>, NMHC + NO<sub>x</sub> and CO) for the same model year and maximum engine power as per 40 CFR 60.4202.

40 CFR 60.42c (d)

This regulation requires that on or after the date on which the initial performance test is completed or required to be completed under section 60.8 of 40 CFR 60 Subpart A, no owner or operator of an affected facility that combusts oil, shall combust oil with a sulfur content in excess of 0.5 percent by weight.

40 CFR 60.43c (c)

This regulation requires that on or after the date on which the initial performance test is completed or is required to be completed, an affected facility that combusts coal, wood, or oil and has a heat input of 30 million Btu per hour (8.7 MW) or greater, shall not cause any gases to be discharged to the atmosphere, that exhibit an opacity greater than 20% (based on a 6-minute average) or exceeds 27% for one 6-minute period per hour.

40 CFR 60.43c (d)

This regulation requires that the particulate matter and opacity standards of section 40 CFR 60-Dc.43c apply at all times, except during periods of startup, shutdown, and malfunction.

40 CFR 60.44c (h)

This regulation requires facilities demonstrating compliance through vendor certification to follow the compliance procedures listed in the appropriate paragraphs of 40 CFR 60-Dc.48c.

40 CFR 60.48c (a)

This regulation requires the owner and operator of each affected facility to submit notification of the date of construction or reconstruction, anticipated startup, and actual startup of the facility. The notification must include the following information:

- (1) The design heat input capacity of the affected facility and identification of fuels to be combusted in the affected facility.
- (2) If applicable, a copy of any Federally enforceable requirement that limits the annual capacity factor for any fuel or mixture of fuels under 40 CFR 60.42c., or 40 CFR 60.43c.
- (3) The annual capacity factor at which the owner or operator anticipates operating the affected facility based on all fuels fired and based on each individual fuel fired.



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

40 CFR 60.48c (c)

This regulation requires the owner or operator of each coal-fired, oil-fired, or wood-fired affected facility subject to the opacity limits under 40 CFR 60.43c(c) to submit excess emission reports for any excess emissions from the affected facility that occur during the reporting period.

40 CFR 60.48c (f) (1)

Fuel supplier certifications for distillate oil shall include the name of the oil supplier and a statement from the oil supplier that the oil complies with the specification under the definition of distillate oil in 40 CFR 60-Dc.41c

40 CFR 60.48c (g)

The owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each day.

40 CFR 60.48c (i)

This regulation requires the source owner or operator to retain all records for a minimum of two years for compliance with the NSPS. This does not supercede any requirement that is more stringent, including the Title V requirement to maintain records for for a minimum of 5 years.

40 CFR 60.48c (j)

This regulation states that the reporting period for the reports required under this subpart is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period

40 CFR 63.6590 (a) (2)

This condition defines which reciprocating internal combustion engines (RICE) will be treated as a new affected source. If the engine started up after December 19, 2002 then it will be considered a new source for the purposes of this NESHAP rule.

40 CFR 63.6595 (a) (7)

If the facility starts up a new or reconstructed stationary RICE located at an area source of HAP emissions after January 18, 2008, the facility must comply with the applicable emission limitations and operating limitations in subpart ZZZZ upon startup.



New York State Department of Environmental Conservation  
Permit Review Report

Permit ID: 2-6307-00290/00001

Renewal Number: 2

09/14/2012

40 CFR Part 63, Subpart ZZZZ

If a facility is in compliance with 40 CFR 60 Subpart IIII and 40 CFR 60 Subpart JJJJ it is in compliance with 40 CFR 63 Subpart ZZZZ.

6 NYCRR 201-7.1

This regulation sets forth an emission cap that cannot be exceeded by the facility. In this permit that cap is

6 NYCRR 211.1

This regulation prohibits emissions causing nuisance and interfere with enjoyment of life.

6 NYCRR 225.1 (a) (3)

This regulation limits the amount of sulfur that can be in fuel burned at a stationary source. It references Table 1 of the 1979 version of the sulfur in fuel limitations expressed in terms of percent by weight for fuel oil and pounds per million Btu gross heat content for solid fuel. **NOTE: This citation has been replaced by requirements cited under 225-1.2(a)(2) and is no longer part of current State regulations, however, it remains part of New York State's approved State Implementation Plan (SIP).**

6 NYCRR 225.7 (a)

The commissioner may require an owner of an air contamination source to retain for up to three years, and to submit to him, fuel analyses, information on the quantity of fuel received, burned or sold, and results of stack sampling, stack monitoring and other procedures to ensure compliance with the provisions of the Part. **NOTE: This citation has been replaced by requirements cited under 225-1.8(a) and is no longer a part of current State regulations, however, it remains as part of New York State's approved State Implementation Plan (SIP).**

6 NYCRR 227.2 (b) (1)

This regulation is from the 1972 version of Part 227 and still remains as part of New York's SIP. The rule establishes a particulate limit of 0.10 lbs/mmBtu based on a 2 hour average emission for any oil fired stationary combustion installation.

6 NYCRR 227-1.3

This regulation requires a limitation and compliance monitoring for opacity from a stationary combustion installation.

6 NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than



**New York State Department of Environmental Conservation  
Permit Review Report**

**Permit ID: 2-6307-00290/00001**

**Renewal Number: 2**

**09/14/2012**

27% opacity.

6 NYCRR 227-2.4 (c) (1) (i)

Existing NOx RACT presumptive limit that expires on 6/30/14.

6 NYCRR 227-2.4 (d)

This section includes NOx RACT requirements for small boilers, small combustion turbines, and small stationary internal combustion engines.

6 NYCRR 227-2.4 (f) (1)

Presumptive NOx RACT emission limit for natural gas fired stationary internal combustion engines.

6 NYCRR 227-2.5 (a)

Fuel switching NOx RACT compliance option.

6 NYCRR 227-2.5 (c)

Alternative NOx RACT compliance option, based on economic and technical feasibility determination.

6 NYCRR 227-2.6 (c)

6 NYCRR Subpart 231-2

The provisions of Subpart 231-2 apply to new or modified major facilities. The contaminants of concern state-wide are nitrogen oxides and volatile organic compounds since New York State is located in the ozone transport region and because there are ozone non-attainment areas within the state. In addition, particulate matter less than 10 microns in size (PM-10) is a non-attainment contaminant in Manhattan County.

**Compliance Certification**

**Summary of monitoring activities at LONG ISLAND JEWISH MEDICAL CENTER-QUEENS:**

New York State Department of Environmental Conservation  
**Permit Review Report**



**Permit ID: 2-6307-00290/00001**  
**Renewal Number: 2**  
**09/14/2012**

Location Facility/EU/EP/Process/ES	Cond No.	Type of Monitoring
---		
U-000CP/-/1CF/00CP1	42	work practice involving specific operations
U-000CP/-/2CF/00CP2	46	work practice involving specific operations
U-000CP/-/3CF/00CP3	48	work practice involving specific operations
U-000CP/000CP/1CF/00CP1	56	monitoring of process or control device parameters as surrogate
U-000CP/000CP/2CF/00CP2	59	monitoring of process or control device parameters as surrogate
U-000CP/000CP/3CF/00CP3	62	monitoring of process or control device parameters as surrogate
U-000CP/000CP/1CF/00CP1	57	monitoring of process or control device parameters as surrogate
U-000CP/000CP/2CF/00CP2	60	monitoring of process or control device parameters as surrogate
U-000CP/000CP/3CF/00CP3	63	monitoring of process or control device parameters as surrogate
U-000CP	36	record keeping/maintenance procedures
U-000CP	37	record keeping/maintenance procedures
U-000CP	38	record keeping/maintenance procedures
U-000CP	39	record keeping/maintenance procedures
U-000CP	40	record keeping/maintenance procedures
U-GENCP/000G1/CF3/0GEN1	64	intermittent emission testing
U-GENCP/000G1/CF3/0GEN1	65	intermittent emission testing
U-GENCP/000G1/CF3/0GEN1	66	intermittent emission testing
U-GENCP/000G1/CF3/0GEN1	67	intermittent emission testing
E-MRGEN/-/EMG/EMRG1	33	record keeping/maintenance procedures
FACILITY	5	record keeping/maintenance procedures
FACILITY	6	record keeping/maintenance procedures
FACILITY	23	monitoring of process or control device parameters as surrogate
FACILITY	7	record keeping/maintenance procedures
FACILITY	25	work practice involving specific operations
FACILITY	26	record keeping/maintenance procedures
U-000CP	35	work practice involving specific operations
U-000CP/000CP	53	record keeping/maintenance procedures
FACILITY	27	monitoring of process or control device parameters as surrogate
U-000CP/000CP	54	intermittent emission testing
FACILITY	72	record keeping/maintenance procedures
U-000CP/-/1CG/00CG1	73	record keeping/maintenance procedures
U-000CP/-/2CG/00CG2	74	record keeping/maintenance procedures
U-000CP/000CP/1CG/00CG1	76	intermittent emission testing
U-000CP/000CP/2CG/00CG2	77	intermittent emission testing
U-000CP/000CP	75	record keeping/maintenance procedures
U-GENCP/000G1/CF3/0GEN1	78	intermittent emission testing
U-000CP	34	intermittent emission testing

----

**Basis for Monitoring**