



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

Facility Identification Data

Name: FRIESLAND CAMPINA DOMO

Address: 40196 ST HWY 10

DELHI, NY 13753

Owner/Firm

Name: FRIESLANDCAMPINA USA LP

Address: 40196 ST RTE 10

DELHI, NY 13753, USA

Owner Classification: Corporation/Partnership

Permit Contacts

Division of Environmental Permits:

Name: MARTHA A BELLINGER

Address: NYSDEC REG 4

65561 ST RTE 10 STE 1

STAMFORD, NY 12167

Phone:6076527741

Division of Air Resources:

Name: EDWARD A PELLEGRINI

Address: NYSDEC

1130 N WESTCOTT RD

SCHENECTADY, NY 12306

Air Permitting Contact:

Name: DENNIS K REINSHAGEN

Address: DMV USA LP DBA FRIESLANDCAMPINA DOMO

40196 ST RTE 10

DELHI, NY 13753

Phone:6077460115

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

Application for renewal of Air Title V Facility.

Attainment Status

FRIESLAND CAMPINA DOMO is located in the town of DELHI in the county of DELAWARE.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	TRANSPORT REGION (NON-ATTAINMENT)
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor.

Facility Description:

DMV manufactures hydrolyzed proteins used for food and medical purposes. Significant air emission sources at the facility include: two "small" oil fired boilers, one spray tower dryer, one "V-Bottom" dryer, one diffusion tank, and several process reactors and digesters. In addition to these sources, DMV has various operations that are exempt under 6 NYCRR Part 201.

Permit Structure and Description of Operations

The Title V permit for FRIESLAND CAMPINA DOMO is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
- incinerator - devices which burn waste material for disposal
- control - emission control devices
- process - any device or contrivance which may emit air contaminants that is not included in the above categories.

FRIESLAND CAMPINA DOMO is defined by the following emission unit(s):

Emission unit 1BLEND - This emission unit consists of a powdered protein mix station (wet blender)



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

and a clean in place (CIP) station.

Emission unit 1BLEND is associated with the following emission points (EP):

10046

Process: 005 is located at GROUND FLOOR, Building 1 - This process consists of a covered mix tank where powdered proteins are added to water. Emissions result from bag dumping and loading operations. A hood is used to capture the protein powder that results from the bags being emptied into the blender. Emissions are exhausted through Emission Point 10046.

Process: 006 is located at GROUND FLOOR, Building 1 - This process consists of a heated water bath (CIP station) that uses acids and caustics in the cleaning process. Emissions are exhausted through Emission Point 10046.

Emission unit 1BOILR - This emission unit consists of two No. 4 fuel oil fired boilers used to provide building heat and process steam. Boilers No. 1 and No. 2 vent to a common exhaust.

Emission unit 1BOILR is associated with the following emission points (EP):

10001

Process: B01 is located at Ground Floor, Building 1 - This process consists of one boiler firing No. 4 fuel oil. Boiler No. 1 is rated at 16.7 mmBtu/hr. Emissions are exhausted through EP 10001.

Process: B02 is located at Ground Floor, Building 1 - This process consists of one boiler firing No. 4 fuel oil. Boiler No. 2 is rated at 29.3 mmBtu/hr. Emissions are exhausted through EP 10001.

Emission unit 1DRYER - This emission unit consists of a spray tower dryer and V-Bottom dryer. The dryers are used to dry protein powders.

Emission unit 1DRYER is associated with the following emission points (EP):

10003, 10004

Process: 003 is located at GROUND FLOOR, Building 1 - This process consists of a steam heated vertical spray tower dryer used to dry hydrolyzed protein powder (product). Four main cyclones are used to capture product for bagging and one wet scrubber is used for emissions control. Emissions are exhausted through Emission Point 10003.

Process: 004 is located at GROUND FLOOR, Building 1 - This process consists of a liquid propane gas fired (direct fired) horizontal dryer used to dry hydrolyzed protein powder (product). Four main cyclones are used to capture product for bagging and one fabric filter is used for emissions control. Emissions are exhausted through Emission Point 10004.

Emission unit 1PUMPS - This emission unit consists of a waste water diffusion tank and two vacuum pumps.

Emission unit 1PUMPS is associated with the following emission points (EP):

10005, 10041



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

Process: 008 is located at GROUND FLOOR, Building 1 - This process consists of a holding tank with air diffusers. Air is diffused through waste water to remove toluene. Emissions are exhausted through Emission Point 10005.

Process: 009 is located at GROUND FLOOR, Building 1 - This process consists of two vacuum pumps that service the high temperature short time (HTST) reaction vessel. Emissions are exhausted through Emission Point 10041.

Emission unit 1TANKS - This emission unit consists of several tanks, digesters and mix vessels that are exhausted to a wet scrubber. In addition, this emission unit consists of an enzyme "weigh out" process with a dedicated wet scrubber.

Emission unit 1TANKS is associated with the following emission points (EP):
10006, 10007

Process: 007 is located at GROUND FLOOR, Building 1 - Process 007 consists of several tanks, digesters and mix vessels that are exhausted to a wet scrubber. Emissions are exhausted through Emission Point 10006.

Process: E08 Process 008 consists of an enzyme "weigh out" process that is exhausted to a wet scrubber. Emissions are exhausted through Emission Point 10007.

Title V/Major Source Status

FRIESLAND CAMPINA DOMO is subject to Title V requirements. This determination is based on the following information:

DMV USA LP is subject to Title V requirements. This determination is based on the following information:

The facility is major because the potential to emit (PTE) for several contaminants is greater than the Title V applicability thresholds. The PTE for sulfur dioxide (SO2) from the facility is greater than 100 tons per year which is the Title V applicability threshold. The PTE for toluene is greater than 10 tons per year which is the Title V threshold. The PTE for total hazardous air pollutants (HAP) is greater than 25 tons per year which is the Title V thresholds.

Program Applicability

The following chart summarizes the applicability of FRIESLAND CAMPINA DOMO with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	YES

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	NO
SIP	YES

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

MACT Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements.

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis

of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code

Description

2023

CONDENSED AND EVAPORATED MILK

SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information.Each SCC represents

a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code

Description

1-02-005-04

EXTERNAL COMBUSTION BOILERS - INDUSTRIAL
INDUSTRIAL BOILER - DISTILLATE OIL
Grade 4 Oil

3-02-999-98

FOOD AND AGRICULTURE
FOOD AND AGRICULTURE - OTHER NOT SPECIFIED
Other Not Classified

3-99-999-94

MISCELLANEOUS MANUFACTURING INDUSTRIES
MISCELLANEOUS INDUSTRIAL PROCESSES
Other Not Classified

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant , including air pollution

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

control equipment and/or restrictions on the hours of operation, or on the type or amount of material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE	
		lbs/yr	Range
007440-38-2	ARSENIC	> 0	but < 10 tpy
000071-43-2	BENZENE	> 0	but < 10 tpy
007440-41-7	BERYLLIUM	> 0	but < 10 tpy
007440-43-9	CADMIUM	> 0	but < 10 tpy
000630-08-0	CARBON MONOXIDE	>= 2.5	tpy but < 10 tpy
007440-47-3	CHROMIUM	> 0	but < 10 tpy
007440-48-4	COBALT	> 0	but < 10 tpy
000071-55-6	ETHANE, 1,1,1-TRICHLORO	> 0	but < 10 tpy
000100-41-4	ETHYLBENZENE	> 0	but < 10 tpy
000050-00-0	FORMALDEHYDE	> 0	but < 10 tpy
0NY100-00-0	HAP	>= 40	tpy but < 50 tpy
007647-01-0	HYDROGEN CHLORIDE	> 0	but < 10 tpy
007439-92-1	LEAD	> 0	but < 10 tpy
007439-96-5	MANGANESE	> 0	but < 10 tpy
007439-97-6	MERCURY	> 0	but < 10 tpy
000091-20-3	NAPHTHALENE	> 0	but < 10 tpy
007440-02-0	NICKEL METAL AND INSOLUBLE COMPOUNDS	> 0	but < 10 tpy
0NY210-00-0	OXIDES OF NITROGEN	>= 25	tpy but < 40 tpy
0NY075-00-0	PARTICULATES	>= 50	tpy but < 100 tpy
0NY075-00-5	PM-10	>= 50	tpy but < 100 tpy
130498-29-2	POLYCYCLIC AROMATIC HYDROCARBONS	> 0	but < 10 tpy
007446-09-5	SULFUR DIOXIDE	>= 100	tpy but < 250 tpy
007664-93-9	SULFURIC ACID	>= 2.5	tpy but < 10 tpy
000108-88-3	TOLUENE	>= 10	tpy
0NY998-00-0	VOC	>= 40	tpy but < 50 tpy
001330-20-7	XYLENE, M, O & P MIXT.	> 0	but < 10 tpy

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

- (a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:
- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
 - (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
 - (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
 - (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.
- (b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.
- (c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

Department pursuant to the provisions of Part 201-6.7 and Part 621.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 4-1228-00027/00015
Renewal Number: 2
02/24/2011

Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Condition	Short Description
-- FACILITY	ECL 19-0301	72	Powers and Duties of the Department with respect to air
FACILITY	40CFR 60-A.11	55	pollution control General provisions - compliance with standards and maintenance requirements
FACILITY	40CFR 60-A.12	56	General provisions - Circumvention
FACILITY	40CFR 60-A.13	57	General provisions - Monitoring requirements
FACILITY	40CFR 60-A.14	58	General provisions - Modification
FACILITY	40CFR 60-A.15	59	General provisions - Reconstruction
FACILITY	40CFR 60-A.4	38	General provisions - Address
FACILITY	40CFR 60-A.7(a)	39, 40	Notification and Recordkeeping
FACILITY	40CFR 60-A.7(b)	41	Notification and Recordkeeping
FACILITY	40CFR 60-A.7(c)	42	Notification and Recordkeeping
FACILITY	40CFR 60-A.7(d)	43	Notification and Recordkeeping
FACILITY	40CFR 60-A.7(e)	44	Notification and Recordkeeping
FACILITY	40CFR 60-A.7(f)	45	Notification and Recordkeeping
FACILITY	40CFR 60-A.7(g)	46	Notification and Recordkeeping
FACILITY	40CFR 60-A.8(a)	47	Performance Tests
FACILITY	40CFR 60-A.8(b)	48, 49	Performance Tests
FACILITY	40CFR 60-A.8(c)	50	Performance Tests
FACILITY	40CFR 60-A.8(d)	51	Performance Tests
FACILITY	40CFR 60-A.8(e)	52	Performance Tests
FACILITY	40CFR 60-A.8(f)	53	Performance Tests
FACILITY	40CFR 60-A.9	54	General provisions -

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 4-1228-00027/00015
Renewal Number: 2
02/24/2011

FACILITY	40CFR 60-Dc.42c (d)	60	Availability of information
FACILITY	40CFR 60-Dc.42c (h)	61	Standard for Sulfur Dioxide Firing Oil. (see narrative)
FACILITY	40CFR 60-Dc.42c (i)	62	Exemption from Averaging Requirements
FACILITY	40CFR 60-Dc.46c (e)	63	Standard for Sulfur Dioxide Period of Requirements.
FACILITY	40CFR 60-Dc.48c (d)	64	Exemption from Emission Monitoring for Sulfur Dioxide. Reporting and Recordkeeping Requirements.
FACILITY	40CFR 60-Dc.48c (e) (11)	65	Reporting and Recordkeeping requirements - fuel supplier certifications
FACILITY	40CFR 60-Dc.48c (f) (2)	66	Reporting and Recordkeeping Requirements (residual oil).
FACILITY	40CFR 60-Dc.48c (g) (2)	67	Alternative recordkeeping
FACILITY	40CFR 60-Dc.48c (i)	68	Reporting and Recordkeeping Requirements.
FACILITY	40CFR 60-Dc.48c (j)	69	Reporting period
FACILITY	40CFR 68	20	Chemical accident prevention provisions
FACILITY	40CFR 82-F	21	Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	6NYCRR 200.6	1	Acceptable ambient air quality.
FACILITY	6NYCRR 200.7	9	Maintenance of equipment.
FACILITY	6NYCRR 201-1.4	73	Unavoidable noncompliance and violations
FACILITY	6NYCRR 201-1.7	10	Recycling and Salvage
FACILITY	6NYCRR 201-1.8	11	Prohibition of reintroduction of collected contaminants to the air
FACILITY	6NYCRR 201-3.2 (a)	12	Exempt Activities - Proof of eligibility
FACILITY	6NYCRR 201-3.3 (a)	13	Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6	22, 70, 71	Title V Permits and the Associated Permit Conditions
FACILITY	6NYCRR 201-6.5 (a) (4)	14	General conditions
FACILITY	6NYCRR 201-6.5 (a) (7)	2	General conditions
FACILITY	6NYCRR 201-6.5 (a) (8)	15	Fees
FACILITY	6NYCRR 201-6.5 (c)	3	General conditions
FACILITY			Permit conditions for Recordkeeping and



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

FACILITY	6NYCRR 201-6.5 (c) (2)	4	Reporting of Compliance Monitoring Permit conditions for Recordkeeping and Reporting of
FACILITY	6NYCRR 201-6.5 (c) (3) (ii)	5	Compliance Monitoring Permit conditions for Recordkeeping and Reporting of
FACILITY	6NYCRR 201-6.5 (d) (5)	16	Compliance Monitoring Compliance schedules
FACILITY	6NYCRR 201-6.5 (e)	23	Compliance Certification
FACILITY	6NYCRR 201-6.5 (f) (6)	17	Off Permit Changes
FACILITY	6NYCRR 202-1.1	18	Required emissions tests.
FACILITY	6NYCRR 202-2.1	6	Emission Statements - Applicability
FACILITY	6NYCRR 202-2.5	7	Emission Statements - record keeping requirements.
FACILITY	6NYCRR 211.2	74	General Prohibitions - air pollution prohibited.
FACILITY	6NYCRR 211.3	19	General Prohibitions - visible emissions limited
FACILITY	6NYCRR 212.4 (a)	24	General Process Emission Sources - emissions from new sources and/or modifications
FACILITY	6NYCRR 212.4 (c)	25, 26, 27, 28, 29	General Process Emission Sources - emissions from new processes and/or modifications
FACILITY	6NYCRR 212.6 (a)	30, 31	General Process Emission Sources - opacity of emissions limited
FACILITY	6NYCRR 215.2	8	Open Fires - Prohibitions
FACILITY	6NYCRR 225-1.8 (a)	32	Reports, sampling and analysis.
FACILITY	6NYCRR 227.2 (b) (1)	36, 37	Particulate emissions.
FACILITY	6NYCRR 227-1.3 (a)	33, 34	Smoke Emission Limitations.
FACILITY	6NYCRR 227-1.6	35	Corrective Action.

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6 NYCRR 201-3.2 (a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.5 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

6 NYCRR 201-6.5 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6 NYCRR 201-6.5 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.5 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.5 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.5 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6 NYCRR 201-6.5 (d) (5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6 NYCRR 201-6.5 (e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6 NYCRR 201-6.5 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6 NYCRR 202-2.1



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calENDar year.

6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6 NYCRR 211.2

This regulation prohibits any emissions of air contaminants to the outdoor atmosphere which may be detrimental to human, plant or animal life or to property, or which unreasonably interferes with the comfortable enjoyment of life or property regardless of the existence of any specific air quality standard or emission limit.

6 NYCRR 211.3

This condition requires that the opacity (i.e., the degree to which emissions other than water reduce the transmission of light) of the emissions from any air contamination source be less than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent.

6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

40 CFR Part 68

This Part lists the regulated substances and there applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act AmENDments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, FRIESLAND CAMPINA DOMO has been determined to be subject to the following regulations:

40 CFR 60.11

This regulation specifies the type of opacity monitoring requirements in relation to compliance with the standards and maintenance requirements.

40 CFR 60.12

This regulation prohibits an owner or operator from concealing emissions in violation of applicable standards by any means.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

40 CFR 60.13

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

40 CFR 60.14

This regulation defines the term modification and what is and is not considered to be a modification, for the purpose of rule applicability.

40 CFR 60.15

This regulation defines the term reconstruction and what is and is not considered to be a reconstruction project, for the purpose of rule applicability.

40 CFR 60.4

This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Quality Assurance (BQA).

40 CFR 60.42c (d)

This regulation requires that on or after the date on which the initial performance test is completed or required to be completed under section 60.8 of 40 CFR 60 Subpart A, no owner or operator of an affected facility that combusts oil, shall combust oil with a sulfur content in excess of 0.5 percent by weight.

40 CFR 60.42c (h)

This regulation requires that compliance with emission limits and/or fuel oil sulfur limitations be based on a certification from the fuel supplier as stated in paragraph 40 CFR 60-Dc.48c(f)(1), (2), or (3) as applicable

40 CFR 60.42c (i)

This regulation requires that the sulfur dioxide emission limits, percentage reductions, and fuel oil sulfur limitations apply at all times, including periods of startup, shutdown, and malfunction.

40 CFR 60.46c (e)

This regulation allows facilities subject to paragraphs 40 CFR 60-Dc.42c(h)(1), (2), or (3) who show compliance through vendor certification, to be exempt from the monitoring requirements of section 40 CFR 60-Dc.46c

40 CFR 60.48c (d)

This regulation requires the owner or operator of the facility subject to the SO₂ emission limits, fuel oil sulfur limits, or percent reduction requirements under §60.42c, to submit semi-annual reports to the EPA



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

40 CFR 60.48c (e) (11)

If fuel supplier certifications are used to demonstrate compliance with the distillate oil specifications under 40 CFR 60-Dc.41c, then reports shall include a certified statement signed by the owner or operator that the records of fuel supplier certifications submitted represent all of the fuel combusted during the reporting period.

40 CFR 60.48c (f) (2)

This condition sets forth the requirements to be met by the fuel supplier. These requirements apply to both distillate and residual oil.

40 CFR 60.48c (g) (2)

This regulation allows the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in 40 CFR 60.48c(f) to demonstrate compliance with the SO₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

40 CFR 60.48c (i)

This regulation requires the source owner or operator to retain all records for a minimum of two years for compliance with the NSPS. This does not supercede any requirement that is more stringent, including the Title V requirement to maintain records for for a minimum of 5 years.

40 CFR 60.48c (j)

This regulation states that the reporting period for the reports required under this subpart is each six-month period. All reports shall be submitted to the Administrator and shall be postmarked by the 30th day following the end of the reporting period

40 CFR 60.7 (a)

This regulation requires any owner or operator subject to a New Source Performance Standard (NSPS) to furnish the Administrator with notification of the dates of: construction or reconstruction, initial startup, any physical or operational changes, commencement of performance testing for continuous monitors and anticipated date for opacity observations as required.

40 CFR 60.7 (b)

This regulation requires the owner or operator to maintain records of the occurrence and duration of any startup, shutdown, or malfunction of the source or control equipment or continuous monitoring system.

40 CFR 60.7 (c)

This requirement details the information to be submitted in excess emissions and monitoring systems performance reports which must be submitted at least semi-annually for sources with compliance



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

monitoring systems.

40 CFR 60.7 (d)

This condition specifies the required information and format for a summary report form and details when either a summary form and/or excess emissions reports are required.

40 CFR 60.7 (e)

This condition specifies how sources that remain in continuous compliance, and are subject to monthly or quarterly reporting, can reduce reporting frequency to semiannually.

40 CFR 60.7 (f)

This condition specifies requirements for maintenance of files of all measurements, including continuous monitoring system (CMS), monitoring device, and performance testing measurements; all CMS performance evaluations; all CMS or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices for at least two years.

40 CFR 60.7 (g)

This condition allows source owners to use reporting required for state or local agencies to satisfy the paragraph (a) reporting requirements of this section of this rule.

40 CFR 60.8 (a)

This regulation contains the requirements for the completion date and reporting of Performance Testing (stack testing), at the facility. Within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup, the owner or operator of the facility must conduct performance test(s) and furnish a written report of the test results.

40 CFR 60.8 (b)

This regulation contains the requirements for Performance test methods and procedures, to be used by the owner or operator, of the affected facility.

40 CFR 60.8 (c)

This condition contains the requirements for operating conditions, of the emission source, during performance testing.

40 CFR 60.8 (d)

This regulation contains the requirements for advance notification of Performance (stack) testing.

40 CFR 60.8 (e)

This regulation requires the facility to provide appropriate sampling ports, safe platforms and utilities as



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

necessary for Performance (stack) testing.

40 CFR 60.8 (f)

This regulation requires that Performance (stack) tests consist of three runs unless otherwise specified. The rule also designates the allowable averaging methods for the analysis of the results.

40 CFR 60.9

This rule citation allows the public access to any information submitted to the EPA Administrator (or state contact), in conjunction with a project subject to this section of the regulation.

6 NYCRR 212.4 (a)

This rule requires compliance with the degree of control specified in Tables 2, 3 and 4 for new (after July 1, 1973) process emission sources.

6 NYCRR 212.4 (c)

This rule requires existing sources (in operation after July 1, 1973) of solid particulates with environmental rating of B or C which are not subject to Table 5 "Processes for which Permissible Emission Rate is Based on Process Weight, to be limited to a particulate emission rate not to exceed 0.05 grains per dry standard cubic foot.

6 NYCRR 212.6 (a)

This rule specifies an opacity limitation of less than 20% for any six consecutive minute period for all process emission sources.

6 NYCRR 225-1.8 (a)

Upon request the owner or operator of a facility which purchases and fires coal or oil shall submit reports to the commissioner containing a fuel analysis, information on the quantity of the fuel received, burned, and results of any stack sampling, stack monitoring and any other procedures to ensure compliance with the provisions of 6 NYCRR Part 225-1. All records shall be available for a minimum of three years

6 NYCRR 227.2 (b) (1)

This regulation is from the 1972 version of Part 227 and still remains as part of New York's SIP. The rule establishes a particulate limit of 0.10 lbs/mmBtu based on a 2 hour average emission for any oil fired stationary combustion installation.

6 NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6 NYCRR 227-1.6



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

This regulation states that any person found to have violated any provision of this Part shall not cause, permit or allow operation of the stationary combustion installation involved in the violation unless:

- (1) it is equipped with approved emission control equipment;
- (2) it is rehabilitated or upgraded in an approved manner; or
- (3) the fuel is changed to an acceptable type.

In addition, the commissioner may seal such stationary combustion installation so as to prevent any operation if the conditions of paragraph (a)(1)-(3) above are not met within the time provided by the order of final determination issued in the case of the violation.

No person shall cause, permit or allow operation of any stationary combustion installation sealed by the commissioner in accordance with this section.

No person except the commissioner or his representative shall remove, tamper with or destroy any seal affixed to any stationary combustion installation.

Compliance Certification

Summary of monitoring activities at FRIESLAND CAMPINA DOMO:

Location Facility/EU/EP/Process/ES	Cond No.	Type of Monitoring

FACILITY	42	record keeping/maintenance procedures
FACILITY	60	work practice involving specific operations
FACILITY	64	record keeping/maintenance procedures
FACILITY	65	record keeping/maintenance procedures
FACILITY	66	record keeping/maintenance procedures
FACILITY	67	record keeping/maintenance procedures
FACILITY	68	record keeping/maintenance procedures
FACILITY	5	record keeping/maintenance procedures
FACILITY	23	record keeping/maintenance procedures
FACILITY	6	record keeping/maintenance procedures
FACILITY	25	intermittent emission testing
FACILITY	26	monitoring of process or control device parameters as surrogate
FACILITY	27	monitoring of process or control device parameters as surrogate
FACILITY	28	monitoring of process or control device parameters as surrogate
FACILITY	29	record keeping/maintenance procedures
FACILITY	30	monitoring of process or control device parameters as surrogate
FACILITY	31	record keeping/maintenance procedures
FACILITY	32	record keeping/maintenance procedures
FACILITY	36	work practice involving specific operations



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

FACILITY	37	intermittent emission testing
FACILITY	33	intermittent emission testing
FACILITY	34	record keeping/maintenance procedures

Basis for Monitoring

Condition 26 --- 6 NYCRR Part 212.4(c) - This monitoring condition has been included to address the particulate emission requirements of 6 NYCRR Part 212 - General Process Emission Sources. The requirement to log the pressure drop across the fabric filter once daily is justified by the fact that the rule does not specify any monitoring frequency to determine compliance with the regulation. Operating and maintaining the emission sources as stated in the monitoring condition will demonstrate compliance with the regulation.

Condition 27--- 6 NYCRR Part 212.4(c) - This monitoring condition has been included to address the particulate emission requirements of 6 NYCRR Part 212 - General Process Emission Sources. The requirement to log the wet scrubber outlet water pressure once daily is justified by the fact that the rule does not specify any monitoring frequency to determine compliance with the regulation. Operating and maintaining the emission sources as stated in the monitoring condition will demonstrate compliance with the regulation.

Condition 28--- 6 NYCRR Part 212.4(c) - This monitoring condition has been included to address the particulate emission requirements of 6 NYCRR Part 212 - General Process Emission Sources. The requirement to log the wet scrubber outlet water pressure once daily is justified by the fact that the rule does not specify any monitoring frequency to determine compliance with the regulation. Operating and maintaining the emission sources as stated in the monitoring condition will demonstrate compliance with the regulation.

Condition 29--- 6 NYCRR Part 212.4(c) - This monitoring condition has been included to address the particulate emission requirements of 6 NYCRR Part 212 - General Process Emission Sources. The requirement to observe visible emissions once daily is justified by the fact that the rule does not specify any monitoring frequency to determine compliance with the regulation. Operating and maintaining the emission sources as stated in the monitoring condition will demonstrate compliance with the regulation.

Condition 31 --- 6 NYCRR Part 212.6(a) - This monitoring condition has been included to address the visible emissions requirements of 6 NYCRR Part 212 - General Process Emission Sources. The daily monitoring frequency is justified by the fact that the rule does not specify any monitoring frequency and any visible emissions that occur are not expected to cause any exceedances. Past experience has shown that the operations contained in the process referenced in this condition are unlikely to produce visible emissions of any magnitude.

Condition 32 --- 6 NYCRR Part 225-1.8(a) - This regulation requires the owner to maintain records of fuel analyses, quantity of fuel burned, quantity of fuel received, and results of stack tests or monitoring. Specifically, this condition requires the owner to maintain oil supplier certifications on a per delivery basis. The certifications shall include at a minimum supplier name, date of shipment, quantity of fuel received, oil sulfur content, and the method used to determine sulfur content.

Condition 34 --- 6 NYCRR Part 227-1.3(a) - This monitoring condition has been included to address the visible emissions requirements of 6 NYCRR Part 227 - Stationary Combustion Installations. The facility shall monitor the opacity on a daily basis using instantaneous observations. Monitoring the



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-1228-00027/00015

Renewal Number: 2

02/24/2011

opacity in this manner and recording the results in accordance with the condition will be used to determine the compliance status with the regulation.

Condition 36 --- 6 NYCRR Part 227.2(b)(1) - This regulation requires stationary combustion installations firing oil to meet a 0.1 pound per million Btu particulate emission limit. The facility performed a stack test on April 1, 2004 to demonstrate compliance with the particulate emission limit. The results of the stack test indicated the particulate emissions were 0.057 pounds per million Btu of heat input. The boilers were firing #4 fuel oil with a sulfur content of less than 0.50 percent by weight during the stack test. The sulfur content of the fuel oil has an affect on the particulate emissions.

Therefore, the boilers are limited to firing #4 fuel oil with a sulfur content of less than 0.50 percent by weight in order to demonstrate compliance, on a continuous basis, with the particulate emission limit. Compliance with the 0.50 percent by weight sulfur content limit in this condition also demonstrates compliance with the sulfur content limits (1.5 percent by weight and 0.50 percent by weight) contained in 6 NYCRR Part 225-1.2(a)(2) and 40 CFR 60.42c(d).

Condition 37 --- 6 NYCRR Part 227.2(b)(1) - This regulation requires stationary combustion installations firing oil to meet a 0.1 pound per million Btu particulate emission limit. This condition requires the facility to perform a stack test once during the term of the permit to demonstrate compliance with the particulate emission limit.

Condition 60 --- 40 CFR 60.42c(d) - This regulation requires that on or after the date on which the initial performance test is completed or required to be completed under section 60.8 of 40 CFR 60 Subpart A, no owner or operator of an affected facility that combusts oil, shall combust oil with a sulfur content in excess of 0.5 percent by weight. The facility shall monitor the sulfur content for each delivery to demonstrate compliance with the regulatory limit. Compliance with this regulation and condition assures compliance with the sulfur content limit (1.5 percent by weight) contained 6 NYCRR Part 225-1.2(a)(2) since the limit in this regulation and condition is more restrictive.

Condition 64 --- 40 CFR 60.48c(d) - This regulation requires the owner to submit semiannual reports. The reports shall include the name of the fuel oil supplier, the sulfur content of the fuel oil, the location wher ethe sample was obtained, and the method used to determine the sulfur content.

Condition 65 --- 40 CFR 60.48c(e)(11) - This regulation requires the owner to maintain records of fuel oil supplier name, the location of the oil when the sample for analysis was collected, the sulfur content of oil from which the shipment came or the shipment itself, and the method used to determine sulfur content for each shipment of oil received.

Condition 66 --- 40 CFR 60.48c(f)(2) - This regulation requires the owner to maintain records of fuel oil supplier name, the location of the oil when the sample for analysis was collected, the sulfur content of oil from which the shipment came or the shipment itself, and the method used to determine sulfur content for each shipment of oil received.

Condition 67 --- 40 CFR 60.48c(g)(2) - This regulation requires the facility to maintain records of the amounts of each fuel combusted during each month.