



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

Facility Identification Data

Name: BEAVER FALLS GENERATING FACILITY
Address: 9644 MAIN ST
BEAVER FALLS, NY 13305

Owner/Firm

Name: LAKESIDE BEAVER FALLS LLC
Address: 1200 HARGER RD
SUITE 718
OAK BROOK, IL 60523, USA
Owner Classification: Corporation/Partnership

Permit Contacts

Division of Environmental Permits:
Name: LAWRENCE R AMBEAU
Address: NYSDEC - STATE OFFICE BLDG
317 WASHINGTON ST
WATERTOWN, NY 13601
Phone: 3157852245

Division of Air Resources:
Name: MATTHEW J POLGE
Address: NYSDEC
317 WASHINGTON ST
WATERTOWN, NY 13601
Phone: 3157852513

Air Permitting Contact:
Name: EDWARD L JORDAN
Address: LAKESIDE BEAVER FALLS LLC
9644 MAIN ST
BEAVER FALLS, NY 13305
Phone: 3153469121

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

Application for renewal of a Title V permit.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

Attainment Status

BEAVER FALLS GENERATING FACILITY is located in the town of CROGHAN in the county of LEWIS.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
-----	-----
-----	-----
Particulate Matter (PM)	ATTAINMENT
Particulate Matter< 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone*	TRANSPORT REGION (NON-ATTAINMENT)
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT
-----	-----
-----	-----

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor.

Facility Description:

Facility consists of a Siemens V64.3 gas turbine, deltak heat recovery steam generator, Coen duct burner, and Ansaldo steam generator. Facility supplies electricity to the open market and process steam to a thermal host. Unit is equipped with SCR to control NOx emissions.

Permit Structure and Description of Operations

The Title V permit for BEAVER FALLS GENERATING FACILITY

is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

combustion - devices which burn fuel to generate heat, steam or power
incinerator - devices which burn waste material for disposal
control - emission control devices
process - any device or contrivance which may emit air contaminants
that is not included in the above categories.

BEAVER FALLS GENERATING FACILITY is defined by the following emission unit(s):



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

Emission unit U00002 - TWO EMERGENCY DIESEL POWERED GENERATORS. THE EMISSION LIMITS (LBS/HR) IN THIS APPLICATION ARE FOR OPERATION OF ONE EMERGENCY DIESEL GENERATOR.

Emission unit U00002 is associated with the following emission points (EP):
00002, 00003, 00004

Process: 201 is located at OPERATING FLOOR, Building GENBLDG - DISTILLATE FUEL OIL COMBUSTION IN THE EMERGENCY DIESEL GENERATORS.

Emission unit U00004 - AUXILIARY BOILER WITH FLUE GAS RECIRCULATION FOR CONTROL OF NOX EMISSIONS. THIS BOILER IS USED FOR GENERATION OF THERMAL ENERGY.

Process: 401 is located at OPERATING FLOOR, Building GENBLDG - NATURAL GAS COMBUSTION IN THE AUXILIARY BOILER.

Emission unit U00001 - A SIEMENS V64.2 GAS TURBINE, A HEAT RECOVERY STEAM GENERATOR WITH A DUCT BURNERS, AND AIR POLLUTION CONTROL EQUIPMENT FOR COGENERATION OF ELECTRICITY AND THERMAL ENERGY.

Emission unit U00001 is associated with the following emission points (EP):
00001

Process: 101 is located at OPERATING FLOOR, Building GENBLDG - NO. 2 DISTILLATE FUEL OIL COMBUSTION IN THE GAS TURBINE WITHOUT SIMULTANEOUS OPERATION OF DUCT BURNER.

Process: 102 is located at OPERATING FLOOR, Building GENBLDG - NO. 2 DISTILLATE FUEL OIL COMBUSTION IN GAS TURBINE WITH SIMULTANEOUS OPERATION OF DUCT BURNER FIRING NATURAL GAS.

Process: 103 is located at OPERATING FLOOR, Building GENBLDG - NATURAL GAS COMBUSTION IN GAS TURBINE WITHOUT SIMULTANEOUS OPERATION OF DUCT BURNER.

Process: 104 is located at OPERATING FLOOR, Building GENBLDG - NATURAL GAS COMBUSTION IN GAS TURBINE AND DUCT BURNER SIMULTANEOUSLY.

Process: 108 is located at OPERATING FLOOR, Building GENBLDG - THIS PROCESS (108) ALLOWS FOR THE OPERATION OF THE EVAPORATIVE COOLER WHILE COMBUSTING FUEL IN THE GAS TURBINE WITH/WITHOUT SIMULTANEOUS OPERATION OF DUCT BURNER.

Title V/Major Source Status

BEAVER FALLS GENERATING FACILITY is subject to Title V requirements. This determination is based on the following information:

The facility is major for oxides of nitrogen (NO_x) and carbon monoxide (CO).

Program Applicability



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

The following chart summarizes the applicability of BEAVER FALLS GENERATING FACILITY with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	YES
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	YES
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	YES
SIP	YES

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

MACT Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

Title IV Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements.

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis

of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code

Description

4911
4931

ELECTRIC SERVICES
ELEC & OTHER SERVICES COMBINED

SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents

a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code

Description

1-02-006-02

2-02-001-01

EXTERNAL COMBUSTION BOILERS - INDUSTRIAL
INDUSTRIAL BOILER - NATURAL GAS
10-100 MMBtu/Hr
INTERNAL COMBUSTION ENGINES - INDUSTRIAL
INDUSTRIAL INTERNAL COMBUSTION ENGINE -
DISTILLATE OIL (DIESEL)

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

2-02-001-03	Turbine INTERNAL COMBUSTION ENGINES - INDUSTRIAL INDUSTRIAL INTERNAL COMBUSTION ENGINE - DISTILLATE OIL (DIESEL)
2-02-002-01	Turbine: Cogeneration INTERNAL COMBUSTION ENGINES - INDUSTRIAL INDUSTRIAL INTERNAL COMBUSTION ENGINE - NATURAL GAS
2-02-002-03	Turbine INTERNAL COMBUSTION ENGINES - INDUSTRIAL INDUSTRIAL INTERNAL COMBUSTION ENGINE - NATURAL GAS
2-02-004-01	Turbine: Cogeneration INTERNAL COMBUSTION ENGINES - INDUSTRIAL INDUSTRIAL INTERNAL COMBUSTION LARGE BORE ENGINE Diesel

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE lbs/yr	Range
007664-41-7	AMMONIA		>= 25 tpy but < 40 tpy
007440-36-0	ANTIMONY		> 0 but < 10 tpy
007440-38-2	ARSENIC		> 0 but < 10 tpy
007440-41-7	BERYLLIUM		> 0 but < 10 tpy
007440-43-9	CADMIUM		> 0 but < 10 tpy
000630-08-0	CARBON MONOXIDE		>= 100 tpy but < 250 tpy
007440-47-3	CHROMIUM		> 0 but < 10 tpy
007440-48-4	COBALT		> 0 but < 10 tpy
0NY100-00-0	HAP		> 0 but < 2.5 tpy
007439-92-1	LEAD		> 0 but < 10 tpy
007439-96-5	MANGANESE		> 0 but < 10 tpy
007439-97-6	MERCURY		> 0 but < 10 tpy
007440-02-0	NICKEL METAL AND INSOLUBLE COMPOUNDS		> 0 but < 10 tpy
0NY210-00-0	OXIDES OF NITROGEN		>= 100 tpy but < 250



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

ONY075-00-0	PARTICULATES	tpy >= 25 tpy but < 40
ONY075-00-5	PM-10	tpy >= 25 tpy but < 40
007782-49-2	SELENIUM	tpy > 0 but < 10 tpy
007446-09-5	SULFUR DIOXIDE	>= 50 tpy but < 100
ONY998-00-0	VOC	tpy >= 50 tpy but < 100
		tpy

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

**Item A: General Provisions for State Enforceable Permit Terms and Condition - 6
 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Condition	Short Description

FACILITY	ECL 19-0301	100	Powers and Duties of the Department with respect to air pollution control
FACILITY	40CFR 52-A.21	24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 63, 64	Prevention of Significant Deterioration
U-00001	40CFR 52-A.21	69, 70, 71, 72, 73, 74	Prevention of Significant Deterioration
U-00001/-/103	40CFR 52-A.21	88, 89	Prevention of Significant Deterioration
U-00001/-/104	40CFR 52-A.21	90, 91	Prevention of Significant Deterioration
U-00002	40CFR 52-A.21	92, 93, 94, 95, 96, 97	Prevention of Significant Deterioration



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

U-00001	40CFR 60-A.11	84	General provisions - compliance with standards and maintenance requirements
U-00001	40CFR 60-A.13	85	General provisions - Monitoring requirements
U-00001	40CFR 60-A.4	79	General provisions - Address
U-00001	40CFR 60-A.7(b)	80	Notification and Recordkeeping
FACILITY	40CFR 60-A.7(c)	65	Notification and Recordkeeping
U-00001	40CFR 60-A.7(d)	81	Notification and Recordkeeping
U-00001	40CFR 60-A.7(f)	82	Notification and Recordkeeping
U-00001	40CFR 60-A.9	83	General provisions - Availability of information
U-00004	40CFR 60-Dc.48c(g)	98	Reporting and Recordkeeping Requirements.
U-00004	40CFR 60-Dc.48c(i)	99	Reporting and Recordkeeping Requirements.
U-00001	40CFR 60-GG.334(b)	86	Monitoring of Operations: CEMS
U-00001	40CFR 60-GG.334(h)(3)	87	Allowance not to monitor sulfur or nitrogen for natural gas
FACILITY	40CFR 68	21	Chemical accident prevention provisions
FACILITY	40CFR 82-F	22	Protection of Stratospheric Ozone - recycling and emissions reduction
FACILITY	6NYCRR 200.6	1	Acceptable ambient air quality.
FACILITY	6NYCRR 200.7	10	Maintenance of equipment.
FACILITY	6NYCRR 201-1.4	101	Unavoidable noncompliance and violations
FACILITY	6NYCRR 201-1.7	11	Recycling and Salvage
FACILITY	6NYCRR 201-1.8	12	Prohibition of reintroduction of collected contaminants to the air
FACILITY	6NYCRR 201-3.2(a)	13	Exempt Activities - Proof of eligibility
FACILITY	6NYCRR 201-3.3(a)	14	Trivial Activities - proof of eligibility
FACILITY	6NYCRR 201-6	23, 66, 67	Title V Permits and the Associated Permit Conditions
FACILITY	6NYCRR 201-6.5(a)(4)	15	General conditions
FACILITY	6NYCRR 201-6.5(a)(7)	2	General conditions
FACILITY	6NYCRR 201-6.5(a)(8)	16	Fees
FACILITY	6NYCRR 201-6.5(c)	3	General conditions
			Permit conditions for

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

FACILITY	6NYCRR 201-6.5(c)(2)	4	Recordkeeping and Reporting of Compliance Monitoring Permit conditions for Recordkeeping and Reporting of Compliance Monitoring Permit conditions for Recordkeeping and Reporting of Compliance Monitoring
FACILITY	6NYCRR 201-6.5(c)(3)(ii)	5	Compliance Monitoring Permit conditions for Recordkeeping and Reporting of Compliance Monitoring
FACILITY	6NYCRR 201-6.5(d)(5)	17	Compliance schedules
FACILITY	6NYCRR 201-6.5(e)	6	Compliance Certification
FACILITY	6NYCRR 201-6.5(f)(6)	18	Off Permit Changes
FACILITY	6NYCRR 201-7	24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 68	Federally Enforceable Emissions Caps
U-00001	6NYCRR 201-7	69, 70, 71, 72, 73, 74	Federally Enforceable Emissions Caps
U-00001/-/103	6NYCRR 201-7	88, 89	Federally Enforceable Emissions Caps
U-00001/-/104	6NYCRR 201-7	90, 91	Federally Enforceable Emissions Caps
U-00002	6NYCRR 201-7	92, 93	Federally Enforceable Emissions Caps
FACILITY	6NYCRR 202-1.1	19	Required emissions tests.
FACILITY	6NYCRR 202-2.1	7	Emission Statements - Applicability
FACILITY	6NYCRR 202-2.5	8	Emission Statements - record keeping requirements.
FACILITY	6NYCRR 211.2	102	General Prohibitions - visible emissions limited.
FACILITY	6NYCRR 211.3	20	General Prohibitions - visible emissions limited
FACILITY	6NYCRR 215.2	9	Open Fires - Prohibitions
U-00001	6NYCRR 225-1.2(a)(2)	75	Sulfur in Fuel Limitations Post 12/31/87.
U-00001	6NYCRR 225-1.8(a)	76	Reports, sampling and analysis.
U-00001	6NYCRR 225-1.8(d)	77	Reports, sampling, and analysis
U-00001	6NYCRR 227.2(b)(1)	78	Particulate emissions.
FACILITY	6NYCRR 227-2.1(a)	45	Further filtering of applicability
FACILITY	6NYCRR 237-1.4(a)	103	Generators equal to or greater than 25 MWe
FACILITY	6NYCRR 237-1.6(a)	104	Standard permit requirements
FACILITY	6NYCRR 237-1.6(c)	105	Nitrogen oxides requirements
FACILITY	6NYCRR 237-1.6(e)	106	Recordkeeping and reporting requirements



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

FACILITY	6NYCRR 237-1.6 (f)	107	Liability
FACILITY	6NYCRR 237-2	108	NOx Authorized account representative for NOx budget sources Compliance certification report.
FACILITY	6NYCRR 237-4.1	109	
FACILITY	6NYCRR 237-7.1	110	Submission of NOx allowance transfers
FACILITY	6NYCRR 237-8	111	MONITORING AND REPORTING
FACILITY	6NYCRR 243-1.6 (a)	46	Permit Requirements - CAIR NOx Ozone Season Trading Program Monitoring Requirements - CAIR NOx Ozone Season Trading Program NOx Ozone Season Emission Requirements - CAIR NOx Ozone Season Trading Program
FACILITY	6NYCRR 243-1.6 (b)	47	Excess Emission Requirements - CAIR NOx Ozone Season Trading Program Recordkeeping and reporting requirements - CAIR NOx Ozone Season Trading Program
FACILITY	6NYCRR 243-1.6 (c)	48	Authorization and responsibilities - CAIR Designated Representative Certificate of representation - CAIR Designated Representative
FACILITY	6NYCRR 243-1.6 (d)	49	General Requirements - Monitoring and Reporting Quarterly reports re: recordkeeping and reporting - Monitoring and Reporting Compliance certification re: recordkeeping and reporting - Monitoring and Reporting
FACILITY	6NYCRR 243-1.6 (e)	50	CAIR NOx Ozone Annual Trading Program General Provisions
FACILITY	6NYCRR 243-2.1	51	CAIR Designated Representative for CAIR NOx Sources Monitoring and Reporting CAIR NOx
FACILITY	6NYCRR 243-2.4	52	
FACILITY	6NYCRR 243-8.1	53, 54	
FACILITY	6NYCRR 243-8.5 (d)	55	
FACILITY	6NYCRR 243-8.5 (e)	56	
FACILITY	6NYCRR 244-1	57	
FACILITY	6NYCRR 244-2	58	
FACILITY	6NYCRR 244-8	59	

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

FACILITY	6NYCRR 245-1	60	Allowances CAIR SO2 Trading Program General Provisions
FACILITY	6NYCRR 245-2	61	CAIR Designated Representative for CAIR SO2 Sources
FACILITY	6NYCRR 245-8	62	Monitoring and Reporting for CAIR SO2 Trading Program

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6 NYCRR 201-3.2 (a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.5 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6 NYCRR 201-6.5 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6 NYCRR 201-6.5 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.5 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.5 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.5 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6 NYCRR 201-6.5 (d) (5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports,



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6 NYCRR 201-6.5 (e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6 NYCRR 201-6.5 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6 NYCRR 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calENDar year.

6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

40 CFR Part 68

This Part lists the regulated substances and there applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act AmENDments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

Facility Specific Requirements

In addition to Title V, BEAVER FALLS GENERATING FACILITY has been determined to be subject to the following regulations:

40 CFR 52.21

This citation applies to facilities that are subject to Prevention of Significant Deterioration provisions;

ie: facilities that are located in an attainment area and that emit pollutants which are listed in

40 CFR 52.21(b)(23)(i) .

40 CFR 60.11

This regulation specifies the type of opacity monitoring requirements in relation to compliance with the standards and maintenance requirements.

40 CFR 60.13

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

40 CFR 60.334 (b)

This regulation allows the owner/operator of a gas turbine to use a CEMS to monitor NOx emissions instead of monitoring fuel and water/steam usage.

40 CFR 60.334 (h) (3)

This regulation allows the owner or operator of a gas turbine to not monitor the fuel for sulfur or nitrogen content if the fuel meets the 40 CFR 60.331(u) definition of natural gas.

40 CFR 60.4

This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Quality Assurance (BQA).

40 CFR 60.48c (g)

The owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each day.

40 CFR 60.48c (i)

This regulation requires the source owner or operator to retain all records for a minimum of two years for compliance with the NSPS. This does not supersede any requirement that is more stringent, including the Title V requirement to maintain records for for a minimum of 5 years.

40 CFR 60.7 (b)

This regulation requires the owner or operator to maintain records of the occurrence and duration of any startup, shutdown, or malfunction of the source or control equipment or continuous monitoring system.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

40 CFR 60.7 (c)

This requirement details the information to be submitted in excess emissions and monitoring systems performance reports which must be submitted at least semi-annually for sources with compliance monitoring systems.

40 CFR 60.7 (d)

This condition specifies the required information and format for a summary report form and details when either a summary form and/or excess emissions reports are required.

40 CFR 60.7 (f)

This condition specifies requirements for maintenance of files of all measurements, including continuous monitoring system (CMS), monitoring device, and performance testing measurements; all CMS performance evaluations; all CMS or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices for at least two years.

40 CFR 60.9

This rule citation allows the public access to any information submitted to the EPA Administrator (or state contact), in conjunction with a project subject to this section of the regulation.

6 NYCRR 225-1.2 (a) (2)

This regulation prohibits any person from selling, offering for sale, purchasing or using any fuel which contains sulfur in a quantity exceeding the limitations set forth in Table 1, Table 2, or Table 3 of this section.

6 NYCRR 225-1.8 (a)

Upon request the owner or operator of a facility which purchases and fires coal or oil shall submit reports to the commissioner containing a fuel analysis, information on the quantity of the fuel received, burned, and results of any stack sampling, stack monitoring and any other procedures to ensure compliance with the provisions of 6 NYCRR Part 225-1. All records shall be available for a minimum of three years

6 NYCRR 225-1.8 (d)

This requires that sampling, compositing and analysis of fuel samples must be done in accordance with methods acceptable to the commissioner.

6 NYCRR 227.2 (b) (1)

This regulation is from the 1972 version of Part 227 and still remains as part of New York's SIP. The rule establishes a particulate limit of 0.10 lbs/mmBtu based on a 2 hour average emission for any oil fired stationary combustion installation.

6 NYCRR 227-2.1 (a)



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

This condition notes that a facility is subject to the reasonably available control technology (RACT) for oxides of nitrogen (NOx).

6 NYCRR 237-1.4 (a)

This condition specifies that any emission unit or facility with a unit; that at any time on or after January 1, 1999, serves a generator with a nameplate capacity equal to or greater than 25 MWe, and sells any amount of electricity, is a NOx budget unit and subject to the requirements of NYCRR 237

6 NYCRR 237-1.6 (a)

This condition requires the applicant to submit a NOx budget application for a permit and to operate in compliance with that permit.

6 NYCRR 237-1.6 (c)

This subdivision outlines the standard requirements of the Acid Deposition Reduction NOx Budget Trading Program for oxides of nitrogen.

6 NYCRR 237-1.6 (e)

This requires the owners and operators of the NOx budget source and each NOx budget unit at the source to keep pertinent documents at the site for a period of 5 years; and lists which documents are pertinent.

6 NYCRR 237-1.6 (f)

This describes the liability issues regarding the requirements of the ADR NOx Budget Trading Program .

6 NYCRR 237-4.1

This item specifies the requirements of the compliance certification report.

6 NYCRR 237-7.1

This item specifies what information and actions are necessary in order to record the transfer of NOx allowances. t

6 NYCRR 243-1.6 (a)

This condition requires the facility to acknowledge that they are subject to this CAIR regulation and provide owner and contact information. It also requires them to update this information as it changes or provide supplemental information at the Departments request.

6 NYCRR 243-1.6 (b)

This condition obligates the owners and operators of the facility to comply with the monitoring and reporting requirements of the CAIR regulations.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

6 NYCRR 243-1.6 (c)

This citation explains the general provisions of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program. This ozone season NOx cap and trade program runs from May 1 through September 30 each year, starting in 2009. Each source shall hold a tonnage equivalent in CAIR NOx Ozone Season allowances that is not less than the total tons of NOx emissions for the ozone season.

6 NYCRR 243-1.6 (d)

This citation for the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains some of the penalties that can be imposed on a CAIR NOx Ozone Season source that does not surrender enough CAIR NOx Ozone Season allowances to cover their NOx Ozone Season emissions.

6 NYCRR 243-1.6 (e)

This citation for the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program requires that all reports be submitted as required by this program, and that copies of all records and submissions made for this program be kept on site for at least five years.

6 NYCRR 243-2.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that an CAIR NOx Ozone Season designated representative must be selected to submit, sign and certify each submission on behalf of the source for the this program.

6 NYCRR 243-2.4

This condition describes the required elements of the "Certificate of Representation" for the CAIR program and the certifying language required with submissions to the Department.

6 NYCRR 243-8.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that CAIR NOx Ozone Season Trading Program sources must install, certify and operate monitoring systems the meet the monitoring, recordkeeping, and reporting requirements in Subpart 6 NYCRR 243-8 and in Subpart H of 40 CFR Part 75.

6 NYCRR 243-8.5 (d)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains what requirements the quarterly reports must meet.

6 NYCRR 243-8.5 (e)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains the compliance certification requirements the source must follow for each quarterly report.

6 NYCRR Subpart 201-7

This regulation sets forth an emission cap that cannot be exceeded by the facility. In this permit that cap is



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

6 NYCRR Subpart 237-2

This condition requires the permittee to select and authorize one person to manage, and represent the owners of any NOx budget unit; and specifies the responsibilities of this NOx authorized account representative

6 NYCRR Subpart 237-8

This item requires the owners and operators of a NOx budget unit to comply with the monitoring and reporting requirements of 6 NYCRR 237-8 and Subpart H of 40 CFR part 75; and allows NOx budget units which are also NOx budget units under 6 NYCRR Part 204 to be summarily referenced in order to demonstrate compliance with the requirements of this item.

6 NYCRR Subpart 244-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) Nitrogen Oxide (NOx) Annual Trading Program. The control period for this annual NOx cap and trade program runs from January 1 to December 31 each year, starting in 2009. Each source shall hold a tonnage equivalent in CAIR NOx allowances that is not less than the total tons of NOx emissions for the control period.

6 NYCRR Subpart 244-2

Each Clean Air Interstate Rule (CAIR) NOx source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR NOx Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate representative.

6 NYCRR Subpart 244-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR NOx unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 244-8 and in 40 CFR Part 75, Subparts F and G. A certified NOx emission monitoring system must be used to measure NOx emissions. NOx emission reports must be certified and submitted quarterly.

6 NYCRR Subpart 245-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) sulfur dioxide (SO2) Trading Program. The control period for this annual SO2 cap and trade program runs from January 1 to December 31, starting in the year 2010. Each source shall hold a tonnage equivalent in CAIR SO2 allowances that is not less than the total tons of SO2 emissions for the control period.

6 NYCRR Subpart 245-2

Each Clean Air Interstate Rule (CAIR) SO2 source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR SO2 Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate representative.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

6 NYCRR Subpart 245-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR SO₂ unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. A certified SO₂ emission monitoring system must be used to measure SO₂ emissions. SO₂ emission reports must be certified and submitted quarterly.

Compliance Certification

Summary of monitoring activities at BEAVER FALLS GENERATING FACILITY:

Location Facility/EU/EP/Process/ES	Cond No.	Type of Monitoring

FACILITY	63	record keeping/maintenance procedures
FACILITY	64	record keeping/maintenance procedures
U-00002	94	record keeping/maintenance procedures
U-00002	95	record keeping/maintenance procedures
U-00002	96	record keeping/maintenance procedures
U-00002	97	record keeping/maintenance procedures
FACILITY	65	record keeping/maintenance procedures
U-00004	98	record keeping/maintenance procedures
U-00004	99	record keeping/maintenance procedures
U-00001	87	record keeping/maintenance procedures
FACILITY	5	record keeping/maintenance procedures
FACILITY	6	record keeping/maintenance procedures
FACILITY	24	continuous emission monitoring (cem)
FACILITY	25	continuous emission monitoring (cem)
FACILITY	26	continuous emission monitoring (cem)
FACILITY	27	continuous emission monitoring (cem)
FACILITY	28	continuous emission monitoring (cem)
FACILITY	29	continuous emission monitoring (cem)
FACILITY	30	continuous emission monitoring (cem)
FACILITY	31	continuous emission monitoring (cem)
FACILITY	32	intermittent emission testing
FACILITY	33	continuous emission monitoring (cem)
FACILITY	34	intermittent emission testing
FACILITY	35	intermittent emission testing
FACILITY	36	intermittent emission testing
FACILITY	37	continuous emission monitoring (cem)
FACILITY	38	continuous emission monitoring (cem)
FACILITY	39	continuous emission monitoring (cem)
FACILITY	40	continuous emission monitoring (cem)
FACILITY	41	continuous emission monitoring (cem)
FACILITY	42	continuous emission monitoring (cem)
FACILITY	43	continuous emission monitoring (cem)
FACILITY	44	work practice involving specific operations
U-00001	69	work practice involving specific operations
U-00001	70	record keeping/maintenance procedures
U-00001	71	work practice involving specific operations
U-00001	72	work practice involving specific operations
U-00001	73	work practice involving specific operations
U-00001	74	intermittent emission testing
U-00001/-/103	88	intermittent emission testing
U-00001/-/103	89	continuous emission monitoring (cem)
U-00001/-/104	90	intermittent emission testing

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013

U-00001/-/104	91	continuous emission monitoring (cem)
U-00002	92	work practice involving specific operations
U-00002	93	work practice involving specific operations
FACILITY	7	record keeping/maintenance procedures
U-00001	75	work practice involving specific operations
U-00001	76	record keeping/maintenance procedures
U-00001	78	intermittent emission testing
FACILITY	105	record keeping/maintenance procedures
FACILITY	109	record keeping/maintenance procedures
FACILITY	111	record keeping/maintenance procedures
FACILITY	59	record keeping/maintenance procedures
FACILITY	62	record keeping/maintenance procedures

Basis for Monitoring

1. Condition 5 - This condition requires the facility to submit semi-annual reports.
2. Condition 6 - This condition requires the facility to submit annual compliance certification reports.
3. Condition 7 - This condition requires the facility to submit annual emission statements.
4. Condition 24 - This condition limits NOx mass emissions for process 101.
5. Condition 25 - This condition limits CO mass emissions during shutdown for processes 101 and 102.
6. Condition 26 - This condition limits NOx mass emissions during shutdown for processes 103 and 104.
7. Condition 27 - This condition limits CO mass emissions during startup for processes 101 and 102.
8. Condition 28 - This condition limits NOx mass emissions during startup for processes 103 and 104.
9. Condition 29 - This condition limits NOx mass emissions during shutdown for processes 101 and 102.
10. Condition 30 - This condition limits CO mass emissions during shutdown for processes 103 and 104.
11. Condition 31 - This condition limits NOx mass emissions during startup for processes 101 and 102.
12. Condition 32 - This condition requires the facility to perform VOCs stack testing for processes 102 and 104.
13. Condition 33 - This condition limits NOx mass emissions during steady state operation for process 102.
14. Condition 34 - This condition requires the facility to perform VOCs stack testing for processes 101 and 103.
15. Condition 35 - This condition requires the facility to perform PM/PM10 stack testing for process 102.
16. Condition 36 - This condition requires the facility to perform PM/PM10 stack testing for process 101.
17. Condition 37 - This condition limits CO mass emissions during startup for processes 103 and 104.

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

18. Condition 38 - This condition limits CO mass emissions during steady state operation for processes 102 and 104.
19. Condition 39 - This condition limits CO mass emissions during steady state operation for processes 101 and 103.
20. Condition 40 - This condition limits CO concentration emissions during steady state operation for processes 101 and 103.
21. Condition 41 - This condition limits CO concentration emissions during steady state operation for processes 102 and 104.
22. Condition 42 - This condition limits NOx concentration emissions during steady state operation for processes 101 and 102.
23. Condition 43 - This condition limits NOx concentration emissions during steady state operation for processes 103 and 104.
24. Condition 44 - This condition limits fuel oil sulfur to 0.08% by weight.
25. Condition 59 - This condition requires the facility to submit quarterly reports under Part 244 providing the NOx mass emissions and heat input.
26. Condition 62 - This condition requires the facility to submit quarterly reports under Part 245 providing the sulfur dioxide mass emissions and heat input.
27. Condition 63 - This condition requires the facility to monitor and record the ambient air temperature.
28. Condition 64 - This condition requires the facility to post a summary emission and operating limits in the facility control room.
29. Condition 65 - Under 40 CFR 60, Subpart A, the subject facility must submit semi-annual excess emissions reports.
30. Condition 69 - This condition limits the annual amount of fuel oil that can be combusted at the facility.
31. Condition 70 - This condition requires the facility to limit the amount of operating hours that the evaporative cooler can be used.
32. Condition 71 - This condition provides a minimum electrical output that the combustion turbine can operated at while firing fuel oil.
33. Condition 72 - This condition provides a minimum electrical output that the combustion turbine can operated at while firing natural gas.
34. Condition 73 - To limit sulfur dioxide emissions, the facility fuel oil usage is limited to 2000 hours per year.
35. Condition 74 - This condition requires the facility to stack test once per permit term to determine ammonia emissions.
36. Condition 75 - This condition limits fuel oil combusted at the facility to 0.08% by weight.
37. Condition 76 - This condition requires the facility to maintain fuel oil supplier certifications in lieu of testing to determine fuel oil sulfur content.
38. Condition 78 - This condition requires the facility to stack test for PM to meet the limit of 0.10 lb/mmmbtu once per permit term.
39. Condition 87 - This condition allows the facility to use gas supplier contracts or

New York State Department of Environmental Conservation
Permit Review Report



Permit ID: 6-2320-00018/00010
Renewal Number: 2
04/02/2013

certifications to monitor sulfur in natural gas instead of natural gas sampling.

40. Condition 88 - This condition requires the facility to stack test for PM/PM10 once per permit term for process 103.

41. Condition 89 - This condition requires the facility to continuously monitor and limit NOx emissions for process 103.

42. Condition 90 - This condition requires the facility to stack test for PM/PM10 once per permit term for process 104.

43. Condition 91 - This condition requires the facility to continuously monitor and limit NOx emissions for process 104.

44. Condition 92 - This condition limits each emergency diesel generator operation to 0.5 hours per day.

45. Condition 93 - This condition limits each emergency diesel generator operation to 52 hours per year.

46. Condition 94 - This condition prohibits the two emergency diesel generators from operating simultaneously except for startup, shutdown, and malfunctions.

47. Condition 95 - This condition requires the emergency diesel generators to fire distillate No. 2 fuel oil only.

48. Condition 96 - This condition prohibits the two emergency diesel generators from operating simultaneously with the combustion turbine except for startup, shutdown, and malfunctions.

49. Condition 97 - This condition allows only one emergency diesel generator to operate with the auxiliary boiler.

50. Condition 98 - This condition requires the facility to record and maintain records of the amount and type of fuel fired in the auxiliary boiler.

51. Condition 99 - This condition requires the facility to retain the records from condition 98 for five years.

52. Condition 105 - This condition requires the facility to hold sufficient NOx allowances to cover the facility NOx emissions under Part 237.

53. Condition 109 - This condition requires the facility to submit an annual certification report under Part 237.

54. Condition 111 - This condition requires the facility to comply with the monitoring requirements of Part 237-8 and comply with 40 CFR Part 75.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 6-2320-00018/00010

Renewal Number: 2

04/02/2013