

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

Facility Identification Data

Name: STERLING ENERGY FACILITY
Address: 110 E SENECA ST
SHERRILL, NY 13461

Owner/Firm

Name: STERLING POWER PARTNERS LP
Address: 110 EAST SENECA ST
SHERRILL, NY 13461-1008, USA
Owner Classification: Corporation/Partnership

Permit Contacts

Division of Environmental Permits:
Name: LAWRENCE R AMBEAU
Address: DIVISION OF ENVIRONMENTAL PERMITS
STATE OFFICE BLDG, 317 WASHINGTON ST
WATERTOWN, NY 13601
Phone:3157852513

Division of Air Resources:
Name: MATTHEW J POLGE
Address: 317 WASHINGTON ST.
WATERTOWN, NY 13601
Phone:3157852513

Air Permitting Contact:
Name: KEVIN W WIGELL
Address: STERLING POWER PARTNERS L P
110 E. SENECA ST.
SHERRILL, NY 13461

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

Application for renewal of Air Title V Facility.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

Attainment Status

STERLING ENERGY FACILITY is located in the town of SHERRILL in the county of ONEIDA. The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone* ATTAINMENT)	TRANSPORT REGION (NON-ATTAINMENT)
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor

Facility Description

COGENERATION FACILITY CONSISTING OF ONE GAS TURBINE/HRSG UNIT WITH STEAM INJECTION, ONE AUXILIARY BOILER FIRING NATURAL GAS, AND ONE 1100 KW AUXILIARY GENERATOR FIRING DISTILLATE OIL. THE FACILITY IS INTENDED TO PROVIDE STEAM TO A HOST FACILITY. THE FACILITY IS NOT SUBJECT TO PSD; HOWEVER IT IS SUBJECT TO NSPS.

Permit Structure and Description of Operations

The Title V permit for STERLING ENERGY FACILITY is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process.

A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device.

[NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
- incinerator - devices which burn waste material for disposal
- control - emission control devices
- process - any device or contrivance which may emit air contaminants that is not included in the above categories.

STERLING ENERGY FACILITY is defined by the following emission unit(s):

Emission unit 1CMBTN - Single General Electric Frame 6 Gas Turbine Unit and HRSG with steam injection; one auxiliary boiler firing natural gas; one auxiliary generator firing distillate fuel oil; and one distillate oil fired starting engine for the gas turbine.

Emission unit 1CMBTN is associated with the following emission points (EP):
00001, 00002, 00003, 00006

It is further defined by the following process(es):

Process: ALL is located at GROUND, Building 1 - GAS TURBINE/HRSG, FIRING NATURAL GAS; AUXILIARY BOILER, FIRING NATURAL GAS; AUXILIARY GENERATOR, FIRING DISTILLATE OIL; AND THE STARTING ENGINE, FIRING DISTILLATE OIL, ALL OPERATING SIMULTANEOUSLY.

Process: AXB is located at GROUND, Building 1 - AUXILIARY BOILER FIRING NATURAL GAS; OPERATING WITHOUT OTHER COMBUSTION EMISSION SOURCES IN OPERATION.

Process: BGN is located at GROUND, Building 1 - AUXILIARY BOILER FIRING NATURAL GAS; OPERATING SIMULTANEOUS WITH AUXILIARY GENERATOR FIRING DISTILLATE OIL.

Process: BGS is located at GROUND, Building 1 - AUXILIARY BOILER FIRING NATURAL GAS; OPERATING SIMULTANEOUSLY WITH THE AUXILIARY GENERATOR FIRING DISTILLATE OIL AND THE STARTING ENGINE, FIRING DISTILLATE OIL.

Process: BLS is located at GROUND, Building 1 - AUXILIARY BOILER FIRING NATURAL GAS; OPERATING SIMULTANEOUSLY WITH THE STARTING ENGINE, FIRING DISTILLATE OIL.

Process: ENG is located at GROUND, Building 1 - STARTING ENGINE FIRING DISTILLATE OIL; OPERATING WITHOUT OTHER COMBUSTION EMISSION SOURCES IN OPERATION.

Process: GBG is located at GROUND, Building 1 - GAS TURBINE/HRSG FIRING NATURAL GAS; OPERATING SIMULTANEOUSLY WITH AUXILIARY BOILER FIRING NATURAL GAS.

Process: GEN is located at GROUND, Building 1 - AUXILIARY GENERATOR FIRING DISTILLATE OIL; OPERATING WITHOUT OTHER COMBUSTION EMISSION SOURCES IN OPERATION.

Process: GNE is located at GROUND, Building 1 - AUXILIARY GENERATOR, FIRING DISTILLATE OIL; OPERATING SIMULTANEOUSLY WITH THE STARTING ENGINE, FIRING DISTILLATE OIL

Process: GTO is located at ground, Building 1 - GE Frame 6 Gast Turbine/HRSG, firing natural gas; without other combustion emission sources operating.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006



Process: GTS is located at GROUND, Building 1 - GAS TURBINE/HRSG, FIRING NATURAL GAS; AND OPERATING SIMULTANEOUSLY WITH THE STARTING ENGINE FIRING DISTILLATE OIL.

Process: TBG is located at GROUND, Building 1 - GAS TURBINE/HRSG, FIRING NATURAL GAS; OPERATING SIMULTANEOUSLY WITH THE AUXILIARY BOILER, FIRING NATURAL GAS; AND THE AUXILIARY GENERATOR, FIRING DISTILLATE OIL.

Process: TBS is located at GROUND, Building 1 - GAS TURBINE/HRSG, FIRING NATURAL GAS; OPERATING SIMULTANEOUSLY WITH THE AUXILIARY BOILER, FIRING NATURAL GAS; AND THE STARTING ENGINE, FIRING DISTILLATE OIL.

Process: TGN is located at GROUND, Building 1 - GAS TURBINE/HRSG, FIRING NATURAL GAS; OPERATING SIMULTANEOUSLY WITH THE AUXILIARY GENERATOR FIRING DISTILLATE OIL.

Process: TGS is located at GROUND, Building 1 - GAS TURBINE/HRSG, FIRING NATURAL GAS; OPERATING SIMULTANEOUSLY WITH THE AUXILIARY GENERATOR, FIRING DISTILLATE OIL; AND THE STARTING ENGINE, FIRING DISTILLATE OIL.

Title V/Major Source Status

STERLING ENERGY FACILITY is subject to Title V requirements. This determination is based on the following information:

Sterling Energy Facility is subject to the requirements of Title V. The facility is Title V major for NOx and CO.

Program Applicability

The following chart summarizes the applicability of STERLING ENERGY FACILITY with regards to the principal air pollution regulatory programs:

Regulatory Program	Applicability
PSD	YES
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	YES
TITLE IV	YES
TITLE V	YES
TITLE VI	NO

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006



RACT	YES
SIP	YES

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's)

MACT Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code	Description
4931	ELEC & OTHER SERVICES COMBINED

SCC Codes

SCC or Source Classification Code is a code developed and used by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code	Description
1-03-006-01	EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS Over 100 MMBtu/Hr
1-02-006-02	EXTERNAL COMBUSTION BOILERS - INDUSTRIAL INDUSTRIAL BOILER - NATURAL GAS 10-100 MMBtu/Hr
2-03-001-01	INTERNAL COMBUSTION ENGINES - COMMERCIAL/INSTITUTIONAL COMMERCIAL/INSTITUTIONAL IC ENGINE - DISTILLATE OIL (DIESEL) Reciprocating
2-03-001-07	INTERNAL COMBUSTION ENGINES - COMMERCIAL/INSTITUTIONAL COMMERCIAL/INSTITUTIONAL IC ENGINE - DISTILLATE OIL (DIESEL)

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006

2-03-002-03 RECIPROCATING: EXHAUST
INTERNAL COMBUSTION ENGINES -
COMMERCIAL/INSTITUTIONAL
COMMERCIAL/INSTITUTIONAL IC ENGINE - NATURAL
GAS

2-01-001-07 TURBINE: COGENERATION
INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION
ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - DISTILLATE OIL
(DIESEL)

2-02-002-03 RECIPROCATING: EXHAUST
INTERNAL COMBUSTION ENGINES - INDUSTRIAL
INDUSTRIAL INTERNAL COMBUSTION ENGINE - NATURAL
GAS
Turbine: Cogeneration

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Series code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE	
		lbs/yr	Range
000630-08-0	CARBON MONOXIDE		>= 100 tpy but < 250 tpy
000050-00-0	FORMALDEHYDE (HAP)		> 0 but < 10 tpy
0NY100-00-0	HAP		> 0 but < 2.5 tpy
007439-92-1	LEAD (HAP)		> 0 but < 10 tpy
000067-56-1	METHYL ALCOHOL (HAP)		> 0 but < 10 tpy
0NY210-00-0	OXIDES OF NITROGEN	498000	
0NY075-00-0	PARTICULATES		>= 10 tpy but < 25 tpy
0NY075-00-5	PM-10		>= 10 tpy but < 25 tpy
007446-09-5	SULFUR DIOXIDE		>= 2.5 tpy but < 10 tpy
0NY998-00-0	VOC		>= 10 tpy but < 25 tpy

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any

**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location Facility/EU/EP/Process/ES	Regulation	Short Description	Condition
FACILITY	ECL 19-0301	Powers and Duties of the Department with respect to air pollution control	83
FACILITY	40CFR 52-A.21	Prevention of Significant Deterioration	39, 40
1-CMBTN	40CFR 52-A.21	Prevention of Significant Deterioration	50
1-CMBTN/00001	40CFR 52-A.21	Prevention of Significant Deterioration	52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62
1-CMBTN/00002	40CFR 52-A.21	Prevention of Significant Deterioration	70, 71, 72, 73

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006

1-CMBTN/00003	40CFR 52-A.21	Prevention of Significant Deterioration	81
1-CMBTN/00006	40CFR 52-A.21	Prevention of Significant Deterioration	82
1-CMBTN/00001	40CFR 60-A.11	General provisions - compliance with standards and maintenance requirements	64
1-CMBTN/00002	40CFR 60-A.11	General provisions - compliance with standards and maintenance requirements	75
1-CMBTN/00001	40CFR 60-A.13	General provisions - Monitoring requirements	65
1-CMBTN/00002	40CFR 60-A.13	General provisions - Monitoring requirements	76
FACILITY	40CFR 60-A.4	General provisions - Address	41
FACILITY	40CFR 60-A.7(b)	Notification and Recordkeeping	42
FACILITY	40CFR 60-A.7(d)	Notification and Recordkeeping	43
FACILITY	40CFR 60-A.7(f)	Notification and Recordkeeping	44
1-CMBTN/00001	40CFR 60-A.9	General provisions - Availability of information	63
1-CMBTN/00002	40CFR 60-A.9	General provisions - Availability of information	74
1-CMBTN/00002	40CFR 60-Db.44b(h)	Standards for Nitrogen Oxides Provisions.	77
1-CMBTN/00002	40CFR 60-Db.44b(i)	Averaging Period.	78
1-CMBTN/00002	40CFR 60-Db.48b(g)	Alternative Emission Monitoring for Nitrogen Oxides.	79
1-CMBTN/00002	40CFR 60-Db.49b(g)	Reporting and Recordkeeping Requirements.	80
FACILITY	40CFR 60-GG	Stationary gas turbines over 10 million Btu per hour	45
1-CMBTN/00001	40CFR 60-GG.334(b)	Monitoring of Operations: CEMS	66
1-CMBTN/00001	40CFR 60-GG.334(h)(1)	Sulfur Content of Fuel	67
1-CMBTN/00001	40CFR 60-GG.334(h)(3)	Allowance not to monitor sulfur or nitrogen for natural gas	68
1-CMBTN/00001	40CFR 60-GG.334(j)	Reporting Requirements	69
FACILITY	40CFR 68	Chemical accident prevention provisions	21
1-CMBTN	40CFR 72-A.6(a)(3)(vi)	IPP no longer exempt.	51
FACILITY	40CFR 82	Protection of Stratospheric Ozone	46
FACILITY	40CFR 82-F	Protection of Stratospheric Ozone - recycling and emissions reduction	22
FACILITY	6NYCRR 200.6	Acceptable ambient air quality.	1
FACILITY	6NYCRR 200.7	Maintenance of equipment.	10
FACILITY	6NYCRR 201-1.4	Unavoidable noncompliance and violations	84

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006

FACILITY	6NYCRR 201-1.7	Recycling and Salvage	11
FACILITY	6NYCRR 201-1.8	Prohibition of reintroduction of collected contaminants to the air	12
FACILITY	6NYCRR 201-3.2(a)	Exempt Activities - Proof of eligibility	13
FACILITY	6NYCRR 201-3.3(a)	Trivial Activities - proof of eligibility	14
FACILITY	6NYCRR 201-6	Title V Permits and the Associated Permit Conditions	23, 47, 48
FACILITY	6NYCRR 201-6.5(a)(4)	General conditions	15
FACILITY	6NYCRR 201-6.5(a)(7)	General conditions	
Fees			
FACILITY	6NYCRR 201-6.5(a)(8)	General conditions	16
FACILITY	6NYCRR 201-6.5(c)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	3
FACILITY	6NYCRR 201-6.5(c)(2)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	4
FACILITY	6NYCRR 201-6.5(c)(3)(ii)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	5
FACILITY	6NYCRR 201-6.5(d)(5)	Compliance schedules	17
FACILITY	6NYCRR 201-6.5(e)	Compliance Certification	6
FACILITY	6NYCRR 201-6.5(f)(6)	Off Permit Changes	18
FACILITY	6NYCRR 201-6.5(g)	Permit shield	24
FACILITY	6NYCRR 202-1.1	Required emissions tests.	19
FACILITY	6NYCRR 202-1.2	Notification.	25
FACILITY	6NYCRR 202-2.1	Emission Statements - Applicability	7
FACILITY	6NYCRR 202-2.5	Emission Statements - record keeping requirements.	8
FACILITY	6NYCRR 204-2.1	Authorization and Responsibilities of the NOx Authorized Account Representative	26
FACILITY	6NYCRR 204-4.1	Compliance Certification Report	27, 28
FACILITY	6NYCRR 204-7.1	Submission of NOx Allowance Transfers	29
FACILITY	6NYCRR 204-8.1	General Requirements	30, 31, 32
FACILITY	6NYCRR 204-8.2	Initial Certification and Recertification Procedures	33, 34
FACILITY	6NYCRR 204-8.3	Out of Control Periods	35
FACILITY	6NYCRR 204-8.4	Notifications	36
FACILITY	6NYCRR 211.2	General Prohibitions - air pollution prohibited.	85
FACILITY	6NYCRR 211.3	General Prohibitions - visible emissions limited	20
FACILITY	6NYCRR 215	Open Fires	9
FACILITY	6NYCRR 225-1.8	Reports, sampling and analysis.	37



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006

1-CMBTN	6NYCRR 227-1.3 (a)	Smoke Emission Limitations.	49
FACILITY	6NYCRR 227-2.1	Applicability.	38
FACILITY	6NYCRR 237-1.4 (a)	Generators equal to or greater than 25 MWe	86
FACILITY	6NYCRR 237-1.6 (a)	Standard permit requirements	87
FACILITY	6NYCRR 237-1.6 (c)	Nitrogen oxides requirements	88
FACILITY	6NYCRR 237-1.6 (e)	Recordkeeping and reporting requirements	89
FACILITY	6NYCRR 237-1.6 (f)	Liability	90
FACILITY	6NYCRR 237-1.6 (g)	Effect on other authorities	91
FACILITY	6NYCRR 237-2	NOx Athorized account representative for NOx budget sources	92
FACILITY	6NYCRR 237-4.1	Compliance certification report.	93
FACILITY	6NYCRR 237-7.1	Submission of NOx allowance transfers	94
FACILITY	6NYCRR 237-8	MONITORING AND REPORTING	95
FACILITY	6NYCRR 238-1.4	Applicability	96
FACILITY	6NYCRR 238-1.6 (a)	Permit Requirements	97
FACILITY	6NYCRR 238-1.6 (c)	Sulfur Dioxide requirements	98
FACILITY	6NYCRR 238-1.6 (e)	Recordkeeping and Reporting Requirements	99
FACILITY	6NYCRR 238-1.6 (f)	Liability	
FACILITY	100 6NYCRR 238-1.6 (g)	Effect on Other Authorities	101
FACILITY	6NYCRR 238-2.1	Authorization/responsibilities of the authorized account representative	102
FACILITY	6NYCRR 238-4.1	Compliance certification report	103
FACILITY	6NYCRR 238-7.1	Submission of SO2 allowance transfers	104
FACILITY	6NYCRR 238-8	Monitoring and Reporting	105

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-301.

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6NYCRR Part 200-.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6NYCRR Part 200-.7

Anyone owning or operating an air contamination source which is equipped with an

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6NYCRR Part 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6NYCRR Part 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6NYCRR Part 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6NYCRR Part 201-3.2(a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-3.3(a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with

**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6NYCRR 201-6.5(a)(4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6NYCRR 201-6.5(a)(7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6NYCRR 201-6.5(a)(8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6NYCRR Part 201-6.5(c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6NYCRR Part 201-6.5(c)(2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6NYCRR Part 201-6.5(c)(3)(ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

any corrective actions or preventive measures taken.

6NYCRR 201-6.5(d)(5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6NYCRR Part 201-6.5(e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6NYCRR 201-6.5(f)(6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6NYCRR Part 201-6.5(g)

Permit Exclusion Provisions - specifies those actions, such as administrative orders, suits, claims for natural resource damages, etc that are not affected by the federally enforceable portion of the permit, unless they are specifically addressed by it.

6NYCRR Part 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6NYCRR Part 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

6NYCRR Part 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6NYCRR Part 211-.2

This regulation prohibits any emissions of air contaminants to the outdoor atmosphere which may be detrimental to human, plant or animal life or to property, or which unreasonably interferes with the comfortable enjoyment of life or property regardless of the existence of any specific air quality standard or emission limit.

6 NYCRR Part 211.3

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

This condition requires that the opacity (i.e., the degree to which emissions other than water reduce the transmission of light) of the emissions from any air contamination source be less than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent.

6 NYCRR Part 215

Prohibits open fires at industrial and commercial sites.

40 CFR Part 68.

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, STERLING ENERGY FACILITY has been determined to be subject to the following regulations:

40CFR 52-A.21

This citation applies to facilities that are subject to Prevention of Significant Deterioration provisions; ie: facilities that are located in an attainment area and that emit pollutants which are listed in 40 CFR 52.21(b)(23)(i) .

40CFR 60-A.11

This regulation specifies the type of opacity monitoring requirements in relation to compliance with the standards and maintenance requirements.

40CFR 60-A.13

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

40CFR 60-A.4

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006



This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Quality Assurance (BQA).

40CFR 60-A.7 (b)

This regulation requires the owner or operator to maintain records of the occurrence and duration of any startup, shutdown, or malfunction of the source or control equipment or continuous monitoring system.

40CFR 60-A.7 (d)

This condition specifies the required information and format for a summary report form and details when either a summary form and/or excess emissions reports are required.

40CFR 60-A.7 (f)

This condition specifies requirements for maintenance of files of all measurements, including continuous monitoring system (CMS), monitoring device, and performance testing measurements; all CMS performance evaluations; all CMS or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices for at least two years.

40CFR 60-A.9

This rule citation allows the public access to any information submitted to the EPA Administrator (or state contact), in conjunction with a project subject to this section of the regulation.

40CFR 60-Db.44b (h)

This regulation specifies that the NSPS nitrogen oxide standards apply at all time including periods of startup, shutdown, or malfunction.

40CFR 60-Db.44b (i)

This subdivision requires that the facility use a 30 day rolling average to determine compliance with any applicable standards in this Subpart.

40CFR 60-Db.48b (g)

This regulation sets the specific minimum record keeping requirements for affected facilities with nitrogen oxide emission limits.

40CFR 60-Db.49b (g)

This subdivision requires reporting and recordkeeping for affected steam generating units - specific oxides of nitrogen requirements.

40CFR 60-GG

This condition states that the facility is subject to the New Source Performance Standards (NSPS) for combustion turbines.

40CFR 60-GG.334 (b)

This regulation allows the owner/operator of a gas turbine to use a CEMS to monitor NOx emissions instead of monitoring fuel and water/steam usage.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

40CFR 60-GG.334 (h) (1)

This regulation requires the owner or operator of a gas turbine to monitor the sulfur content of the fuel burned in the turbine.

40CFR 60-GG.334 (h) (3)

This regulation allows the owner or operator of a gas turbine to not monitor the fuel for sulfur or nitrogen content if the fuel meets the 40 CFR 60.331(u) definition of natural gas.

40CFR 60-GG.334 (j)

This regulation sets forth the reporting requirements for affected units that continuously monitor parameters or emissions or those that periodically determine the sulfur and/or nitrogen content of the fuel burned in a gas turbine.

40CFR 72-A.6 (a) (3) (vi)

Was an exempt IPP under 40 CFR 72.6(b)(6) but, at any time after the later of November 15, 1990 or the date the facility commences commercial operation, fails to meet the definition of independent power production facility.

(b)(6) An independent power production facility that:

- (i) Has, as of November 15, 1990, one or more qualifying power purchase commitments to sell at least 15 percent of its total planned net output capacity; and
- (ii) Consists of one or more units designated by the owner or operator with total installed net output capacity not exceeding 130 percent of its total planned net output capacity. If the emission rates of the units are not the same, the Administrator may exercise discretion to designate which units are exempt.

40CFR 82

The purpose of this regulation is to implement standards on the protection of stratospheric ozone through the control of chloroflourocarbons (CFCs).

6NYCRR 201-6.5 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6NYCRR 202-1.2

This regulation specifies that the department is to be notified at least 30 days in advance of any required stack test. The notification is to include a list of the procedures to be used that are acceptable to the department. Finally, free access to observe the stack test is to be provided to the department's representative.

6NYCRR 204-2.1

This condition states the submission requirements for the NOx Budget Trading Program. The Program is designed to mitigate the interstate transport of ground level ozone and nitrogen oxides, a ground level ozone precursor.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

6NYCRR 204-4.1

This condition covers the compliance certification report requirements for the NOx Budget Program.

6NYCRR 204-7.1

This condition lists the requirements for transfer of allowances in the NOx Budget Program.

6NYCRR 204-8.1

This condition lists the general requirements for the NOx Budget trading program. They include, but are not limited to monitoring requirements, certification, record keeping and reporting.

6NYCRR 204-8.2

This condition covers the procedures for initially certifying and recertifying the monitoring systems of the unit meet the requirements of the NOx Budget Program

6NYCRR 204-8.3

This condition states the requirements for data substitution during times when the monitoring systems do not meet applicable quality assurance requirements.

6NYCRR 204-8.4

This condition lists the addresses where monitoring plans and their modifications, compliance certifications, recertifications, quarterly QA/QC reports and petitions for alternative monitoring shall be sent.

6NYCRR 225-1.8

This regulation requires an owner or operator of a facility which purchases and fires coal and/or oil to submit reports to the commissioner containing fuel analysis data, information on the quantity of the fuel received, burned, and results of any stack sampling, stack monitoring and any other procedures to ensure compliance with the provisions of 6 NYCRR Part 225-1.

6NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6NYCRR 227-2.1

This condition notes that a facility is subject to the reasonably available control technology (RACT) for oxides of nitrogen (NOx).

6NYCRR 237-1.4 (a)

This condition specifies that any emission unit or facility with a unit; that at any time on or after January 1, 1999, serves a generator with a nameplate capacity equal to or greater than 25 MWe, and sells any amount of electricity, is a NOx budget unit and subject to the requirements of NYCRR 237

6NYCRR 237-1.6 (a)

This condition requires the applicant to submit a NOx budget application for a permit and to operate in

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

compliance with that permit.

6NYCRR 237-1.6 (c)

This subdivision outlines the standard requirements of the Acid Deposition Reduction NOx Budget Trading Program for oxides of nitrogen.

6NYCRR 237-1.6 (e)

This requires the owners and operators of the NOx budget source and each NOx budget unit at the source to keep pertinent documents at the site for a period of 5 years; and lists which documents are pertinent.

6NYCRR 237-1.6 (f)

This describes the liability issues regarding the requirements of the ADR NOx Budget Trading Program .

6NYCRR 237-1.6 (g)

This item states that no provision of the ADR NOx Budget Trading Program, a NOx budget permit application, or a NOx budget permit, will exempt or exclude the owners and operators from compliance with any other provisions of applicable State and federal law and regulations.

6NYCRR 237-2

This condition requires the permittee to select and authorize one person to manage, and represent the owners of any NOx budget unit; and specifies the responsibilities of this NOx authorized account representative

6NYCRR 237-4.1

This item specifies the requirements of the compliance certification report.

6NYCRR 237-7.1

This item specifies what information and actions are necessary in order to record the transfer of NOx allowances. t

6NYCRR 237-8

This item requires the owners and operators of a NOx budget unit to comply with the monitoring and reporting requirements of NYCRR 237-8 and Subpart H of 40 CFR part 75; and allows NOx budget units which are also NOx budget units under NYCRR Part 204 to be summarily referenced in order to demonstrate compliance with the requirements of this item.

6NYCRR 238-1.4

This citation identifies the facility as having one or more SO2 budget units as defined by Federal Law, and as such is subject to the requirements of 6 NYCRR 238

6NYCRR 238-1.6 (a)

This condition requires the applicant to submit a SO2 budget application for a permit and to operate in compliance with that permit.

6NYCRR 238-1.6 (c)



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1

07/05/2006

This Item requires the owners and operators of each SO2 budget source and each SO2 budget unit to hold SO2 allowances available for compliance deductions under NYCRR 238-6.5; and how such allowances will be managed.

6NYCRR 238-1.6 (e)

This item requires the owners and operators of the SO2 budget source to keep on site at the source pertinent documents for a period of 5 years from the date the document is created.

6NYCRR 238-1.6 (f)

This subdivision outlines the liability of an affected source.

6NYCRR 238-1.6 (g)

This subdivision outlines the liability of an affected source as subject to other requirements.

6NYCRR 238-2.1

This section outlines the authorization and responsibilities of the SO2 authorized account representative.

6NYCRR 238-4.1

This section lists all of the requirements for the submission of the compliance certification report.

6NYCRR 238-7.1

This section outlines the requirements for the submission of SO2 allowance transfers.

6NYCRR 238-8

This condition requires the owner or operator of the facility to comply with the reporting and record keeping requirements of 40 CFR Part 75.

Non Applicability Analysis

List of non-applicable rules and regulations:

Location	Short Description	Regulation
Facility/EU/EP/Process/ES		
FACILITY	Combustion Turbine NESHAP	40CFR 63-YYY
Reason: THIS FACILITY IS A PTE MINOR SOURCE OF HAZARDOUS AIR POLLUTANTS AND THEREFORE NOT SUBJECT TO THE MACT FOR COMBUSTION TURBINES.		

NOTE: Non-applicability determinations are cited as a permit condition under 6 NYCRR Part 201-6.5(g). This information is optional and provided only if the applicant is seeking to obtain formal confirmation, within an issued Title V permit, that specified activities are not subject to the listed federal applicable or state only requirement. The applicant is seeking to obtain verification that a requirement does not apply for the stated reason(s) and the Department has agreed to include the non-applicability determination in the issued Title V permit which in turn provides a shield against any potential enforcement action.

Compliance Certification

**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

Summary of monitoring activities at STERLING ENERGY FACILITY:

Location Facility/EU/EP/Process/ES	Type of Monitoring	Cond No.
FACILITY	work practice involving specific operations	39
FACILITY	record keeping/maintenance procedures	40
1-CMBTN	work practice involving specific operations	50
1-CMBTN/00001	continuous emission monitoring (cem)	52
1-CMBTN/00001	continuous emission monitoring (cem)	53
1-CMBTN/00001	continuous emission monitoring (cem)	54
1-CMBTN/00001	continuous emission monitoring (cem)	55
1-CMBTN/00001	work practice involving specific operations	56
1-CMBTN/00001	continuous emission monitoring (cem)	57
1-CMBTN/00001	continuous emission monitoring (cem)	58
1-CMBTN/00001	continuous emission monitoring (cem)	59
1-CMBTN/00001	continuous emission monitoring (cem)	60
1-CMBTN/00001	continuous emission monitoring (cem)	61
1-CMBTN/00001	continuous emission monitoring (cem)	62
1-CMBTN/00002	intermittent emission testing	70
1-CMBTN/00002	intermittent emission testing	71
1-CMBTN/00002	intermittent emission testing	72
1-CMBTN/00002	intermittent emission testing	73
1-CMBTN/00003	work practice involving specific operations	81
1-CMBTN/00006	work practice involving specific operations	82
FACILITY	record keeping/maintenance procedures	42
FACILITY	record keeping/maintenance procedures	43
FACILITY	record keeping/maintenance procedures	44
1-CMBTN/00002	record keeping/maintenance procedures	80
1-CMBTN/00001	work practice involving specific operations	67
1-CMBTN/00001	record keeping/maintenance procedures	68
1-CMBTN/00001	record keeping/maintenance procedures	69
FACILITY	record keeping/maintenance procedures	5
FACILITY	record keeping/maintenance procedures	6
FACILITY	record keeping/maintenance procedures	7
FACILITY	record keeping/maintenance procedures	28
FACILITY	record keeping/maintenance procedures	34
FACILITY	record keeping/maintenance procedures	36
FACILITY	record keeping/maintenance procedures	37
1-CMBTN	monitoring of process or control device parameters as surrogate	49
FACILITY	record keeping/maintenance procedures	88
FACILITY	record keeping/maintenance procedures	93
FACILITY	record keeping/maintenance procedures	95
FACILITY	record keeping/maintenance procedures	98
FACILITY	record keeping/maintenance procedures	99
FACILITY	record keeping/maintenance procedures	103
FACILITY	record keeping/maintenance procedures	105

Basis for Monitoring

BASIS FOR MONITORING

Condition 5 - This condition requires the facility to submit semiannual reports.

Condition 6 - This condition requires the facility to submit annual compliance certifications.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

- Condition 7 - This condition requires the facility to submit annual emission statements.
- Condition 28- This condition requires the facility to submit an annual NOx Budget certification report.
- Condition 34- This condition requires the facility to record and report the NOx mass emissions and the heat input.
- Condition 36- This condition requires the facility to submit any changes in the monitoring plan, monitoring equipment or certification to EPA and DEC.
- Condition 37- This condition requires the facility to maintain fuel oil analyses and fuel oil quantity records for each batch of fuel oil delivered to the facility and maintain those records for five years.
- Condition 39- This condition limits the sulfur in the fuel oil to 0.20% by weight.
- Condition 40- This condition requires the combustion turbine and the auxiliary boiler to only burn natural gas.
- Condition 42- This condition requires the facility to maintain records of any startup, shutdown or malfunction.
- Condition 43- For each pollutant monitored, the facility must submit a summary report to EPA quarterly.
- Condition 44- This condition requires the subject facility to maintain records at the facility for a period of two years including all continuous monitoring measurements.
- Condition 49- This condition requires the subject facility to limit opacity to 20%.
- Condition 50- This condition limits annual facility NOx emissions to 498,000 pounds per year.
- Condition 52- This condition limits CO mass emissions from the turbine during shutdown.
- Condition 53- This condition limits CO emissions from the turbine during a warm startup.
- Condition 54- This condition limits NOx mass emissions from the turbine during a cold startup
- Condition 55- This condition limits the NOx mass from the turbine during normal operations.
- Condition 56- This condition limits simultaneous operation of the combustion turbine and the auxiliary boiler to 12 hours per month.
- Condition 57- This condition limits NOx concentration emissions from the turbine during normal operation.
- Condition 58- This condition limits NOx mass emissions from the turbine during shutdown.
- Condition 59- This condition limits the CO concentration from the turbine during normal operations.
- Condition 60- This condition limits NOx mass emissions from the turbine during a warm startup
- Condition 61- This condition limits CO mass emissions from the turbine during a cold startup.
- Condition 62- This condition limits CO emissions from the turbine during normal operations.
- Condition 67- This condition limits the sulfur in natural gas.
- Condition 68- This condition allows the facility to show supplier certifications for natural gas specifications instead of daily testing of sulfur.
- Condition 69- This condition requires the facility to submit excess emissions reports.
- Condition 70- This condition limits NOx emissions from the auxiliary boiler.
- Condition 71- This condition limits CO mass emissions from the auxiliary boiler.
- Condition 72- This condition limits CO concentration emissions from the auxiliary boiler.
- Condition 73- This condition limits NOx concentration emissions from the auxiliary boiler.
- Condition 80- This condition requires the facility to maintain several records for each day of auxiliary boiler operation and this condition identifies those records.
- Condition 81- This condition limits auxiliary generator operation per year.
- Condition 82- This condition limits starting diesel operation per year.
- Condition 88- This condition requires the facility to maintain NOx allowances for each ton of emissions.
- Condition 93- This condition requires the facility to submit a NOx budget certification report.
- Condition 95- This condition requires the facility to comply with the monitoring and reporting

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 6-3014-00011/00022 Renewal Number: 1



07/05/2006

requirements of 6 NYCRR Part 237-8.

Condition 98- This condition requires the facility to maintain SO₂ allowances for each ton of emissions.

Condition 99- This condition requires the facility to maintain records in accordance with Part 238-8.

Condition 103- This condition requires the facility to submit an SO₂ budget certification report.

Condition 105- This condition requires the facility to comply with the monitoring and reporting requirements of 6 NYCRR Part 238-8.