

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

Facility Identification Data

Name: OSWEGO CO ENERGY RECOVERY FAC
Address: 2801 ST RTE 481
FULTON, NY 13069

Owner/Firm

Name: OSWEGO COUNTY
Address: 46 E BRIDGE ST
OSWEGO, NY 13126-2118, USA
Owner Classification: Municipal

Permit Contacts

Division of Environmental Permits:
Name: JOSEPH M DLUGOLENSKI
Address: 615 ERIE BLVD WEST
SYRACUSE, NY 13204-2400

Division of Air Resources:
Name: DAVID A WEAVER
Address: 615 ERIE BOULEVARD WEST
SYRACUSE, NY 13204-2400

Air Permitting Contact:
Name: FRANK J VISSER
Address: OSWEGO CO ENERGY RECOVERY FACILITY
2801 ST RTE 481
FULTON, NY 13069
Phone:3155919280

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

Application for renewal of Air Title V Facility.

Attainment Status

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007



OSWEGO CO ENERGY RECOVERY FAC is located in the town of VOLNEY in the county of OSWEGO.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

Criteria Pollutant	Attainment Status
Particulate Matter (PM)	ATTAINMENT
Particulate Matter < 10µ in diameter (PM10)	ATTAINMENT
Sulfur Dioxide (SO2)	ATTAINMENT
Ozone* ATTAINMENT)	TRANSPORT REGION (NON-ATTAINMENT)
Oxides of Nitrogen (NOx)**	ATTAINMENT
Carbon Monoxide (CO)	ATTAINMENT

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor

Facility Description

This facility is a Municipal Solid Waste Incineration facility. Municipal solid waste is incinerated in four incinerator units each with a maximum daily capacity of 50 tons per day. The facility is equipped with two waste heat boilers and two spray dry scrubbers followed by fabric filters for air pollution control. The main rule governing emissions and operational requirements for this facility is 40 CFR 60 Subpart BBBB incorporated by reference in 6 NYCRR Part 219-8.

Permit Structure and Description of Operations

The Title V permit for OSWEGO CO ENERGY RECOVERY FAC is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process.

A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007

state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device.

[NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
- incinerator - devices which burn waste material for disposal
- control - emission control devices
- process - any device or contrivance which may emit air contaminants that is not included in the above categories.

OSWEGO CO ENERGY RECOVERY FAC is defined by the following emission unit(s):

Emission unit 1INCIN - This unit consists of four identical municipal solid waste incineration trains located within the existing incinerator building. The four incinerators combine into two flues each of which is controlled by a spray dryer scrubber and a fabric filter. The two flues are housed by one stack structure outside the APC building where they exhaust to the atmosphere. The flues are identified as emission points 00005 and 00006.

Emission unit 1INCIN is associated with the following emission points (EP): 00005, 00006, BYP01, BYP02, BYP03, BYP04

It is further defined by the following process(es):

Process: RTF is located at MAIN, Building 2 - MSW is incinerated in four existing incinerators provided with retrofitted air pollution control equipment consisting of spray dryer scrubbers and fabric filters. The incinerators are exhausted through two flues identified as emission points 00005 and 00006.

Each of the four incinerators (INCRT) includes a primary chamber burner (PBURN) and a secondary chamber burner (SBURN). Both burners are fueled by natural gas.

Each of the two air pollution control trains includes a spray dryer scrubber (SDSCB) and a fabric filter (FBFIL).

Title V/Major Source Status

OSWEGO CO ENERGY RECOVERY FAC is subject to Title V requirements. This determination is based on the following information:

This facility is a major source of Oxides of Nitrogen, Sulfur Dioxide, and Hazardous Air Pollutant air emissions.

Program Applicability

The following chart summarizes the applicability of OSWEGO CO ENERGY RECOVERY FAC with regards to the principal air pollution regulatory programs:

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

Regulatory Program	Applicability
PSD	NO
NSR (non-attainment)	NO
NESHAP (40 CFR Part 61)	NO
NESHAP (MACT - 40 CFR Part 63)	NO
NSPS	YES
TITLE IV	NO
TITLE V	YES
TITLE VI	NO
RACT	NO
SIP	YES

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR Part 231) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's)

MACT Maximum Achievable Control Technology (40 CFR 63) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60) - standards of performance for

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007



specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subparts A thru G) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212.10, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code	Description
4953	REFUSE SYSTEMS
9999	NONCLASSIFIABLE ESTABLISHMENTS

SCC Codes

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

SCC or Source Classification Code is a code developed and used by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information. Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code	Description
5-01-001-03	SOLID WASTE DISPOSAL - GOVERNMENT SOLID WASTE DISPOSAL: GOVERNMENT - MUNICIPAL INCINERATION Refuse Derived Fuel

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Series code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE Range represents an emission range for a contaminant. Any PTE quantity that is displayed represents a facility-wide emission cap or limitation for that contaminant. If no PTE quantity is displayed, the PTE Range is provided to indicate the approximate magnitude of facility-wide emissions for the specified contaminant in terms of tons per year (tpy). The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

Cas No.	Contaminant Name	PTE	
		lbs/yr	Range
001746-01-6	2,3,7,8-TETRACHLORODIBENZO-P-D IOXIN (HAP)		> 0 but < 10 tpy
007440-36-0	ANTIMONY (HAP)		> 0 but < 10 tpy
007440-38-2	ARSENIC (HAP)		> 0 but < 10 tpy
068131-74-8	ASHES (RESIDUES)		> 0 but < 2.5 tpy
007440-41-7	BERYLLIUM (HAP)		> 0 but < 10 tpy
007440-43-9	CADMIUM (HAP)		> 0 but < 10 tpy
000630-08-0	CARBON MONOXIDE		>= 2.5 tpy but < 10 tpy
007440-47-3	CHROMIUM (HAP)		> 0 but < 10 tpy
007440-50-8	COPPER		> 0 but < 2.5 tpy
0NY100-00-0	HAP		>= 250 tpy
068476-44-8	HYDROCARBONS C>4		> 0 but < 2.5 tpy

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007



007647-01-0	HYDROGEN CHLORIDE (HAP)	>= 10 tpy
007664-39-3	HYDROGEN FLUORIDE (HAP)	> 0 but < 10 tpy
007439-92-1	LEAD (HAP)	> 0 but < 10 tpy
007439-97-6	MERCURY (HAP)	> 0 but < 10 tpy
007440-02-0	NICKEL METAL AND INSOLUBLE COMPOUNDS (HAP)	> 0 but < 10 tpy
0NY210-00-0	OXIDES OF NITROGEN	>= 100 tpy but < 250 tpy
0NY075-00-0	PARTICULATES	>= 10 tpy but < 25 tpy
0NY075-00-5	PM-10	>= 10 tpy but < 25 tpy
001336-36-3	POLYCHLORINATED BIPHENYL (HAP)	> 0 but < 10 tpy
007446-09-5	SULFUR DIOXIDE	>= 250 tpy
007664-93-9	SULFURIC ACID	> 0 but < 2.5 tpy
0NY998-00-0	VOC	> 0 but < 2.5 tpy
007440-66-6	ZINC	>= 2.5 tpy but < 10 tpy

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6NYCRR Part 201-1.5

An emergency constitutes an affirmative defense to an action brought for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An emergency occurred and that the facility owner and/or operator can identify the cause(s) of the emergency;
- (2) The equipment at the permitted facility causing the emergency was at the time being properly operated;
- (3) During the period of the emergency the facility owner and/or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
- (4) The facility owner and/or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner and/or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: Public Access to Recordkeeping for Title V Facilities - 6NYCRR Part 201-1.10(b)

The Department will make available to the public any permit

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item C: Timely Application for the Renewal of Title V Permits - 6 NYCRR Part 201-6.3(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item D: Certification by a Responsible Official - 6 NYCRR Part 201-6.3(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item E: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.5(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item F: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.5(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item G: Cessation or Reduction of Permitted Activity Not a Defense - 6NYCRR Part 201-6.5(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

Item H: Property Rights - 6 NYCRR Part 201-6.5(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item I: Severability - 6 NYCRR Part 201-6.5(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item J: Permit Shield - 6 NYCRR Part 201-6.5(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

Item K: Reopening for Cause - 6 NYCRR Part 201-6.5(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item L: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item M: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

Location	Regulation	Short Description	Condition
-----------------	-------------------	--------------------------	------------------

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007



Facility/EU/EP/Process/ES

FACILITY	ECL 19-0301	Powers and Duties of the Department with respect to air pollution control	80
1-INCIN	40CFR 60-A	General provisions	29
1-INCIN	40CFR 60-A.11 (d)	General provisions - compliance with standards and maintenance requirements	30
1-INCIN	40CFR 60-A.13	General provisions - Monitoring requirements	31
1-INCIN	40CFR 60-BBBB.1660	Plant-Specific Training	34
1-INCIN	40CFR 60-BBBB.1665	Information that must be included in the Plant-Specific Operating Manual.	35
1-INCIN	40CFR 60-BBBB.1670	Location for keeping the plant specific operating manual	36
1-INCIN	40CFR 60-BBBB.1675	Operator Certification For Chief Facility Operator and Shift Supervisor - Class I & Class II MWC Units	37
1-INCIN	40CFR 60-BBBB.1680	Employees that may operate MWC units	38
1-INCIN	40CFR 60-BBBB.1685	Operation of MWC Unit In Absence of Certified Operator(s)	39
1-INCIN	40CFR 60-BBBB.1690	MWC Unit Operating Practices Requirements	40, 41
1-INCIN	40CFR 60-BBBB.1695	Operating requirements during periods of startup, shutdown, and malfunction.	42
1-INCIN	40CFR 60-BBBB.1705 (a) (2)	Emission Unit Permissible Emissions - Class II MWC Units	43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54
1-INCIN	40CFR 60-BBBB.1705 (a) (3)	Carbon Monoxide emission limits for Mass burn rotary waterwall Class I and Modular starved air Class II, small MWC plants.	55
1-INCIN	40CFR 60-BBBB.1710	Emission Limits During Periods of Start-Up, Shutdown, and Malfunction	56
1-INCIN	40CFR 60-BBBB.1720	Continous Emission Monitoring Systems (CEMs) for Gaseous Pollutants.	57
1-INCIN	40CFR 60-BBBB.1730	Operation of CEMs	58
1-INCIN	40CFR 60-BBBB.1750	Continous Emission Monitoring System Data Collection	59
1-INCIN	40CFR 60-BBBB.1755	Conversion of 1 hr. arithmetic averages into appropriate averaging	60

New York State Department of Environmental Conservation



Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007

1-INCIN	40CFR 60-BBBB.1760	time and units Continous Opacity Monitoring System Requirements	61
1-INCIN	40CFR 60-BBBB.1775	Stack Testing Requirements	62
1-INCIN	40CFR 60-BBBB.1795 (a)	Alternative Stack Testing Schedule - Class II MWC Units	63
1-INCIN	40CFR 60-BBBB.1795 (b)	Alternative Dioxins/Furans Stack Testing Schedule - Class I and Class II MWC Units	64
1-INCIN	40CFR 60-BBBB.1805	MWC Load Level, Temperature and Carbon Feed Rate Monitoring Requirements	65
1-INCIN	40CFR 60-BBBB.1830	Types of records that must be kept	66
1-INCIN	40CFR 60-BBBB.1835	Retention of records	67
1-INCIN	40CFR 60-BBBB.1840	Operator training and certification records	68
1-INCIN	40CFR 60-BBBB.1845	Stack testing records	69
1-INCIN	40CFR 60-BBBB.1850	Records for continuously monitored pollutants or parameters.	70
1-INCIN	40CFR 60-BBBB.1855	Records for municipal waste combustion units that use activated carbon to control dioxins/furans or mercury emissions.	71
1-INCIN	40CFR 60-BBBB.1860	Reports that must be submitted and required format.	72
1-INCIN	40CFR 60-BBBB.1865	Appropriate units of measurement for reporting emissions data.	73
1-INCIN	40CFR 60-BBBB.1880	Submission of annual compliance report	74
1-INCIN	40CFR 60-BBBB.1885	Contents of annual compliance report.	75
1-INCIN	40CFR 60-BBBB.1890	Reporting requirements for non-compliance with the requirements of Subpart BBBB.	76
1-INCIN	40CFR 60-BBBB.1895	Semiannual report submission dates.	77
1-INCIN	40CFR 60-BBBB.1900	Contents for semiannual out-of-compliance report.	78
1-INCIN	40CFR 60-BBBB.1905	Requests to change semiannual or annual reporting dates.	79
1-INCIN	40CFR 60-E.53 (a)	Monitoring of operations	32, 33
FACILITY	40CFR 68	Chemical accident prevention provisions	21
FACILITY	40CFR 82-F	Protection of Stratospheric Ozone - recycling and emissions reduction	22
FACILITY	6NYCRR 200.6	Acceptable ambient air quality.	1
FACILITY	6NYCRR 200.7	Maintenance of equipment.	10



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007

FACILITY	6NYCRR 201-1.4	Unavoidable noncompliance and violations	81
1-INCIN	6NYCRR 201-1.4	Unavoidable noncompliance and violations	83
FACILITY	6NYCRR 201-1.7	Recycling and Salvage	11
FACILITY	6NYCRR 201-1.8	Prohibition of reintroduction of collected contaminants to the air	12
FACILITY	6NYCRR 201-3.2(a)	Exempt Activities - Proof of eligibility	13
FACILITY	6NYCRR 201-3.3(a)	Trivial Activities - proof of eligibility	14
FACILITY	6NYCRR 201-6	Title V Permits and the Associated Permit Conditions	23, 25, 26
FACILITY	6NYCRR 201-6.5(a)(4)	General conditions	15
FACILITY Fees 2	6NYCRR 201-6.5(a)(7)	General conditions	
FACILITY	6NYCRR 201-6.5(a)(8)	General conditions	16
FACILITY	6NYCRR 201-6.5(c)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	3
FACILITY	6NYCRR 201-6.5(c)(2)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	4
FACILITY	6NYCRR 201-6.5(c)(3)(ii)	Permit conditions for Recordkeeping and Reporting of Compliance Monitoring	5
FACILITY	6NYCRR 201-6.5(d)(5)	Compliance schedules	17
FACILITY	6NYCRR 201-6.5(e)	Compliance Certification	6
FACILITY	6NYCRR 201-6.5(f)(6)	Off Permit Changes	18
FACILITY	6NYCRR 202-1	Emission Testing, Sampling and Analytical Determinations	24
FACILITY	6NYCRR 202-1.1	Required emissions tests.	19
FACILITY	6NYCRR 202-2.1	Emission Statements - Applicability	7
FACILITY	6NYCRR 202-2.5	Emission Statements - record keeping requirements.	8
FACILITY	6NYCRR 211.2	General Prohibitions - air pollution prohibited.	82
FACILITY	6NYCRR 211.3	General Prohibitions - visible emissions limited	20
FACILITY	6NYCRR 215	Open Fires	9
1-INCIN	6NYCRR 219-5.3(a)	incinerators built or installed after 01/26/67	27
1-INCIN	6NYCRR 219-5.4(a)	incinerators: capacity larger than 2,000 lb/hr	28
1-INCIN	6NYCRR 617.11(d)	Decision-making and findings requirements	84, 85

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

ECL 19-301.

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6NYCRR Part 200-.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6NYCRR Part 200-.7

Anyone owning or operating an air contamination source which is equipped with an emission control device must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6NYCRR Part 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6NYCRR Part 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6NYCRR Part 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6NYCRR Part 201-3.2(a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-3.3(a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department

**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6NYCRR Part 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6NYCRR 201-6.5(a)(4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6NYCRR 201-6.5(a)(7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.

6NYCRR 201-6.5(a)(8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6NYCRR Part 201-6.5(c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6NYCRR Part 201-6.5(c)(2)

This requirement specifies that all compliance monitoring and recordkeeping is to be

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6NYCRR Part 201-6.5(c)(3)(ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6NYCRR 201-6.5(d)(5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6NYCRR Part 201-6.5(e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6NYCRR 201-6.5(f)(6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6NYCRR Part 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6NYCRR Part 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

6NYCRR Part 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6NYCRR Part 211-.2



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007

This regulation prohibits any emissions of air contaminants to the outdoor atmosphere which may be detrimental to human, plant or animal life or to property, or which unreasonably interferes with the comfortable enjoyment of life or property regardless of the existence of any specific air quality standard or emission limit.

6 NYCRR Part 211.3

This condition requires that the opacity (i.e., the degree to which emissions other than water reduce the transmission of light) of the emissions from any air contamination source be less than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent.

6 NYCRR Part 215

Prohibits open fires at industrial and commercial sites.

40 CFR Part 68.

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, OSWEGO CO ENERGY RECOVERY FAC has been determined to be subject to the following regulations:

40CFR 60-A

This regulation contains the General Provisions of 40 CFR 60. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements

40CFR 60-A.11 (d)

This regulation specifies the type of opacity monitoring requirements in relation to compliance with the standards and maintenance requirements.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

40CFR 60-A.13

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

40CFR 60-BBBB.1660

This section describes what plant-specific training must be provided.

40CFR 60-BBBB.1665

This section describes eleven (11) items which the Permittee must include in the plant-specific operating manual:

:

40CFR 60-BBBB.1670

This condition indicates where the plant specific operating manual should be located, and the parties that the manual should be available for review or inspection by.

40CFR 60-BBBB.1675

This section describes the type and the timeframe of operator certification required for all chief facility operators and shift supervisors at Class I & Class II MWC units.

40CFR 60-BBBB.1680

This section describes employees that may operate MWC units

40CFR 60-BBBB.1685

This section describes the operational requirements that must be followed if the certified chief facility operator and certified shift supervisor are both temporally off-site. Specific operational and notification requirements are specified depending on the length of time that a certified chief facility operator and certified shift supervisor are off-site.

40CFR 60-BBBB.1690

This section describes the municipal waste combustor (MWC) operating practices requirements for MWC unit load level, activated carbon feed rate and the particulate matter control device

40CFR 60-BBBB.1695

This section describes operating requirements during periods of startup, shutdown, and malfunction.

40CFR 60-BBBB.1705 (a) (2)

This section sets forth the permissible emissions from Class II small municipal waste combustor units for cadmium, lead, mercury, carbon monoxide, sulfur dioxide, hydrogen chloride, dioxins / furans, particulate matter, opacity and fugitive ash emissions.

40CFR 60-BBBB.1705 (a) (3)

This section sets forth the permissible emissions from Class I and Class II small municipal waste

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

combustor units for carbon monoxide.

40CFR 60-BBBB.1710

This section describes the emission limits during periods of start-up, shutdown, and malfunction.

40CFR 60-BBBB.1720

This section describes the continuous emission monitoring systems which must be installed for the gaseous pollutants (oxygen (or carbon dioxide), sulfur dioxide, and carbon monoxide).

40CFR 60-BBBB.1730

This section describes the operating / evaluation requirements for continuous emission monitoring systems that measure oxygen (or carbon dioxide), sulfur dioxide, nitrogen oxides (Class I municipal waste combustion units only), and carbon monoxide.

40CFR 60-BBBB.1750

This section sets forth continuous emission monitoring systems data collection requirements.

40CFR 60-BBBB.1755

This section describes how to convert 1 hr. arithmetic averages into appropriate averaging time and units

40CFR 60-BBBB.1760

This section sets forth continuous opacity monitoring system requirements.

40CFR 60-BBBB.1775

This section sets forth the stack testing requirements for emissions of dioxins/furans, cadmium, lead, mercury, particulate matter, opacity, hydrogen chloride, and fugitive ash.

40CFR 60-BBBB.1795 (a)

This section sets forth requirements for alternative dioxin/furans, cadmium, lead, mercury, particulate matter, opacity, hydrogen chloride, and fugitive ash emissions stack testing at Class II small municipal waste combustor plants.

40CFR 60-BBBB.1795 (b)

This section sets forth the requirements for alternative dioxins/furans emissions stack testing at Class I and Class II small municipal waste combustor plants. The section allows the Permittee to test less often for dioxins/furans emissions if all municipal waste combustion units have demonstrated levels of dioxins/furans emissions less than or equal to 15 nanograms per dry standard cubic meter (total mass) for Class I units, or 30 nanograms per dry standard cubic meter (total mass) for Class II units, for 2 consecutive years.

40CFR 60-BBBB.1805

This section sets forth municipal waste combustor load level, temperature and carbon feed rate monitoring requirements.

40CFR 60-BBBB.1830

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

This section sets forth the types of records that the permittee must keep.

40CFR 60-BBBB.1835

This section describes the location for keeping records and the duration that records shall be kept.

40CFR 60-BBBB.1840

This section describes the records that the permittee must keep for operator training and certification.

40CFR 60-BBBB.1845

This section describes the records that must be kept for stack tests.

40CFR 60-BBBB.1850

This section describes the records that must be kept for continuously monitored pollutants or parameters.

40CFR 60-BBBB.1855

This section describes the records that must be kept for municipal waste combustion units that use activated carbon to control dioxins/furans or mercury emissions.

40CFR 60-BBBB.1860

This section sets forth the reports that must be submitted to the department and the required format for the reports.

40CFR 60-BBBB.1865

This section specifies the appropriate units of measurement for reporting emissions data.

40CFR 60-BBBB.1880

This section describes when the permittee must submit its annual compliance report.

40CFR 60-BBBB.1885

This section describes the information that the permittee must include in its annual compliance report. Title V requires semiannual reporting on monitoring, therefore the condition requires a semiannual reporting frequency.

40CFR 60-BBBB.1890

This section sets forth the reporting requirements that the Permittee must follow if it finds that its facility is out of compliance with the requirements of Subpart BBBB.

40CFR 60-BBBB.1895

This section sets forth the dates that the permittee must submit its required semiannual compliance reports.

40CFR 60-BBBB.1900

This section describes the information that the permittee must include in any semiannual out-of-compliance report.

40CFR 60-BBBB.1905



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007

This section describes the requirements that must be met to change the semiannual or annual reporting dates.

40CFR 60-E.53 (a)

This section requires that the owner or operator of any incinerator meeting the applicability requirements of 40 CFR 60 Subpart E, record the daily charging rates and hours of operation of the incinerator.

6NYCRR 202-1

This subpart of Part 202 establishes the general criteria for verifying emissions by means of emissions sampling, testing and associated analytical determinations.

6NYCRR 219-5.3 (a)

This section requires that no incinerator, built or installed after January 26, 1967, regardless of size, will emit visible emissions having an average opacity during any six consecutive minutes of greater than 20 percent, under normal operating conditions.

6NYCRR 219-5.4 (a)

This section requires that all incinerators larger than 2,000 lb/hr capacity must be tested using emission tests acceptable to the department.

6NYCRR 617.11 (d)

617.11 DECISION-MAKING AND FINDINGS REQUIREMENTS.

(a) Prior to the lead agency's decision on an action that has been the subject of a final EIS, it shall afford agencies and the public a reasonable time period (not less than 10 calendar days) in which to consider the final EIS before issuing its written findings statement. If a project modification or change of circumstance related to the project requires a lead or involved agency to substantively modify its decision, findings may be amended and filed in accordance with subdivision 617.12(b) of this Part.

(b) In the case of an action involving an applicant, the lead agency's filing of a written findings statement and decision on whether or not to fund or approve an action must be made within 30 calendar days after the filing of the final EIS.

(c) No involved agency may make a final decision to undertake, fund, approve or disapprove an action that has been the subject of a final EIS, until the time period provided in subdivision 617.11(a) of this section has passed and the agency has made a written findings statement. Findings and a decision may be made simultaneously.

(d) Findings must:

- (1) consider the relevant environmental impacts, facts and conclusions disclosed in the final EIS;
- (2) weigh and balance relevant environmental impacts with social, economic and other considerations;
- (3) provide a rationale for the agency's decision;
- (4) certify that the requirements of this Part have been met;
- (5) certify that consistent with social, economic and other essential considerations from among the reasonable alternatives available, the action is one that avoids or minimizes adverse environmental impacts to the maximum extent practicable, and that adverse environmental impacts will be avoided or minimized to the maximum extent practicable by incorporating as conditions to the decision those mitigative measures that were identified as practicable.

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

(e) No state agency may make a final decision on an action that has been the subject of a final EIS and is located in the coastal area until the agency has made a written finding that the action is consistent with applicable policies set forth in 19 NYCRR 600.5. When the Secretary of State has approved a local government waterfront revitalization program, no state agency may make a final decision on an action, that is likely to affect the achievement of the policies and purposes of such program, until the agency has made a written finding that the action is consistent to the maximum extent practicable with that local waterfront revitalization program.

Compliance Certification

Summary of monitoring activities at OSWEGO CO ENERGY RECOVERY FAC:

Location Facility/EU/EP/Process/ES	Type of Monitoring	Cond No.
1-INCIN	record keeping/maintenance procedures	40
1-INCIN	monitoring of process or control device parameters as surrogate	41
1-INCIN	record keeping/maintenance procedures	42
1-INCIN	intermittent emission testing	43
1-INCIN	intermittent emission testing	44
1-INCIN	intermittent emission testing	45
1-INCIN	intermittent emission testing	46
1-INCIN	intermittent emission testing	47
1-INCIN	intermittent emission testing	48
1-INCIN	intermittent emission testing	49
1-INCIN	monitoring of process or control device parameters as surrogate	50
1-INCIN	monitoring of process or control device parameters as surrogate	51
1-INCIN	intermittent emission testing	52
1-INCIN	continuous emission monitoring (cem)	53
1-INCIN	continuous emission monitoring (cem)	54
1-INCIN	continuous emission monitoring (cem)	55
1-INCIN	record keeping/maintenance procedures	56
1-INCIN	record keeping/maintenance procedures	57
1-INCIN	record keeping/maintenance procedures	58
1-INCIN	record keeping/maintenance procedures	59
1-INCIN	record keeping/maintenance procedures	60
1-INCIN	record keeping/maintenance procedures	61
1-INCIN	record keeping/maintenance procedures	62
1-INCIN	record keeping/maintenance procedures	63
1-INCIN	intermittent emission testing	64
1-INCIN	record keeping/maintenance procedures	65
1-INCIN	record keeping/maintenance procedures	66
1-INCIN	record keeping/maintenance procedures	67
1-INCIN	record keeping/maintenance procedures	68
1-INCIN	record keeping/maintenance procedures	69
1-INCIN	record keeping/maintenance procedures	70
1-INCIN	record keeping/maintenance procedures	71
1-INCIN	record keeping/maintenance procedures	72
1-INCIN	record keeping/maintenance procedures	73
1-INCIN	record keeping/maintenance procedures	74
1-INCIN	record keeping/maintenance procedures	75
1-INCIN	record keeping/maintenance procedures	76
1-INCIN	record keeping/maintenance procedures	77
1-INCIN	record keeping/maintenance procedures	78



New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1

09/26/2007

1-INCIN	record keeping/maintenance procedures	79
1-INCIN	record keeping/maintenance procedures	32
1-INCIN	record keeping/maintenance procedures	33
1-INCIN	work practice involving specific operations	83
FACILITY	record keeping/maintenance procedures	5
FACILITY	record keeping/maintenance procedures	6
FACILITY	record keeping/maintenance procedures	24
FACILITY	record keeping/maintenance procedures	7
1-INCIN	continuous emission monitoring (cem)	27
1-INCIN	monitoring of process or control device parameters as surrogate	84
1-INCIN	monitoring of process or control device parameters as surrogate	85

Basis for Monitoring

Monitoring activities included in this permit are as prescribed by regulations applicable to this facility.

40 CFR 60 Subpart BBBB

Exceptions to the prescribed requirements and monitoring are related to the usage of carbon to control Dioxin/furan and mercury emissions as required by 40 CFR 60 Subpart BBBB. In particular, the requirement that the amount of carbon purchased and delivered, during a given calendar quarter, must be greater than or equal to the amount of carbon required to be used during that quarter. The facility is small enough (four 50 ton per day units) that quarterly carbon purchases are not feasible. Purchases and deliveries of carbon occur when the facility's carbon inventory is down approximately 30,000 pounds. This typically happens three times a year. This permit requires an evaluation to be performed for each purchase and delivery to the facility. The regulatory concept is maintained, but the time period for evaluation has adjusted to match the facility's operating methods. Conditions in this permit related to 40 CFR 60 Subpart BBBB sections 60.1690, 60.1855, 60.1885, and 60.1900 reflect the carbon usage evaluations specific to this facility.

Summaries of monitoring are also required to be submitted semi-annually rather than annually (60.1885). This has been done to comply with the required Title V semi-annual reports on monitoring (6NYCRR Part 201-6.5(c)(3)(ii)).

40 CFR 60 Subpart E

The facility is required to monitor daily hours of operation and daily waste charging rates.

6 NYCRR Part 219

The 20% opacity requirement for this regulation is less stringent than the 40 CFR 60 Subpart BBBB 10% opacity requirement. Compliance with the requirement in 40 CFR 60 Subpart BBBB, however, is only determined by a Method 9 test even though a COM is required. The 6 NYCRR Part 219 regulation does not have this restriction on determining compliance, therefore the 20% opacity requirement is included in this permit.

Conditions carried over from the original Permit to Construct include:

a condition listed under 6NYCRR Part 201-1.4 which requires an interlock system that does not allow the loading of waste when the air pollution control equipment is bypassed; and two conditions listed

New York State Department of Environmental Conservation

Permit Review Report

Permit ID: 7-3558-00013/00015 Renewal Number: 1



09/26/2007

under 6NYCRR Part 617.11(d) requiring a minimum residence time of 0.75 seconds in the secondary chamber and a minimum secondary chamber temperature of 1600 deg F.