

INSTALLATION NUMBER

OP	LOCATION	FACILITY	EMISSION POINT
			C

- A ADD
- C CHANGE
- D DELETE

READ INSTRUCTIONS
CONTAINED IN
FORM 78-11-4
BEFORE ANSWERING
ANY QUESTION



NEW YORK STATE
DEPARTMENT OF ENVIRONMENTAL CONSERVATION

New York City
Department of
Environmental
Protection



STATIONARY COMBUSTION INSTALLATION

APPLICATION FOR PERMIT TO CONSTRUCT OR CERTIFICATE TO OPERATE

S E C T I O N	1. NAME OF OWNER/FIRM Astoria Generating Company, LP			9. NAME OF AUTHORIZED AGENT			10. TELEPHONE			18. FACILITY NAME (IF DIFFERENT FROM OWNER/FIRM) Gowanus Generating Station			
	2. NUMBER AND STREET ADDRESS 18-01 20th Avenue			11. NUMBER AND STREET ADDRESS			20. FACILITY LOCATION (NUMBER AND STREET ADDRESS) 29th St & Second Avenue			22. ZIP 11232			
	3. CITY - TOWN - VILLAGE Long Island City		4. STATE NY	5. ZIP 11105-4271		12. CITY - TOWN - VILLAGE		13. STATE		14. ZIP		21. CITY - TOWN - VILLAGE Brooklyn	22. ZIP 11232
	6. OWNER CLASSIFICATION A <input type="checkbox"/> COMMERCIAL C <input checked="" type="checkbox"/> UTILITY F <input type="checkbox"/> MUNICIPAL I <input type="checkbox"/> RESIDENTIAL B <input type="checkbox"/> INDUSTRIAL D <input type="checkbox"/> FEDERAL G <input type="checkbox"/> EDUC INST. J <input type="checkbox"/> OTHER			E <input type="checkbox"/> STATE H <input type="checkbox"/> HOSPITAL	15. NAME OF PE OR ARCHITECT PREPARING PLANS Janet Bernardo			16. N.Y.S. PE OR ARCHITECT LICENSE NO. 16 078701	17. TELEPHONE (781) 431-1151		23. BUILDING NAME OR NUMBER LMS100 Power Block		24. FLOOR NAME OR NUMBER 1
	7. NAME & TITLE OF OWNERS REPRESENTATIVE Baranello, Mark			8. TELEPHONE (718) 499-6368		18. SIGNATURE OF OWNERS REPRESENTATIVE OR AGENT WHEN APPLYING FOR A PERMIT TO CONSTRUCT			25. START UP DATE MO/YR 06 / 2010		26. DRAWING NUMBER OF PLANS SUBMITTED Figure 1 Site Locus, Figure 2 Site Plan, Figure 3 LMS100		
27. PERMIT TO CONSTRUCT A <input type="checkbox"/> NEW SOURCE B <input checked="" type="checkbox"/> MODIFICATION			28. CERTIFICATE TO OPERATE A <input type="checkbox"/> NEW SOURCE C <input type="checkbox"/> EXISTING B <input checked="" type="checkbox"/> MODIFICATION										

Gas
Oil

S E C T I O N	29. EMISSION POINT ID.		30. GROUND ELEVATION (FT)		31. HEIGHT ABOVE STRUCTURES (FT)		32. STACK HEIGHT (FT)		33. INSIDE DIMENSION(S) (IN)		34. EXIT TEMPERATURE (°F)		35. EXIT VELOCITY (FT/SEC)		36. EXIT FLOW (ACFM)		37. HEAT INPUT (MILLION BTU/HR)		38. CONTINUOUS MONITOR(S)	
	0 0 1 0 0		0		46		100		162		774		105.85		909,052		885.8		A <input type="checkbox"/> OPAQITY D <input checked="" type="checkbox"/> OXYGEN B <input type="checkbox"/> SULFUR DIOXIDE E <input checked="" type="checkbox"/> CARBON DIOXIDE C <input checked="" type="checkbox"/> NITROGEN OXIDES F <input type="checkbox"/> OTHER	
0 0 1 0 0		0		46		100		162		786		103.56		889,453		839.2				

S E C T I O N	39. UNIT TYPE 03		40. UNIT MANUFACTURER'S NAME AND MODEL NUMBER General Electric LMS100 Combustion Turbine										41. UNIT HEAT INPUT 885.8 Gas 839.2 Oil		42. AIR INTAKE 1		43. SOURCE CODE	
	44. BURNER TYPE 69		45. NO OF BURNERS 1		46. BURNER MANUFACTURER'S NAME AND MODEL NUMBER General Electric LMS100						47. FUEL TYPE 52		48. AVG QUANTITY OF FUEL/HR 885		49. MAX QUANTITY OF FUEL/HR 885		50. QUANTITY OF FUEL/YR	
	51. HRS./DAY 24		52. DAYS/YEAR 365		53. % OPERATION BY SEASON Winter Spring Summer Fall				54. NAME OF SUPPLIER(S)									
	55. BURNER TYPE 51		56. NO OF BURNERS 1		57. BURNER MANUFACTURER'S NAME AND MODEL NUMBER General Electric LMS100						58. FUEL TYPE 32		59. AVG QUANTITY OF FUEL/HR 839		60. MAX QUANTITY OF FUEL/HR 839		61. QUANTITY OF FUEL/YR	
62. HRS./DAY 24		63. DAYS/YEAR 365		64. % OPERATION BY SEASON Winter Spring Summer Fall				65. NAME OF SUPPLIER(S)										

S E C T I O N	EMISSION CONTROL EQUIP I.D.	CONTROL TYPE	MANUFACTURER'S NAME AND MODEL NUMBER				DISPOSAL METHOD	DATE INSTALLED MO/YR	USEFUL LIFE
	66 LMSOC	98	Express Integrated Technologies or Equivalent – Oxidation Catalyst				69	70 6-2010	71
67 LMSCR	98	Express Integrated Technologies or Equivalent – Selective Catalytic Reduction				75	76 6-2010	77	

CALCULATIONS

See attached calculation spreadsheet

Natural Gas firing emissions

TO BE COMPLETED FOR ALL SOURCES USING ITEM 27 AND OTHER SOURCES AS DEFINED IN THE INSTRUCTION FORM 76-11-4

SECTION	CONTAMINANT		EMISSIONS				% CONTROL EFFICIENCY	HOURLY EMISSIONS (LBS/HR)	ANNUAL EMISSIONS (LBS/YR)		
	NAME	CAS NUMBER	ACTUAL	UNIT	HOW DET	PERMISS		ACTUAL	ACTUAL	10 ⁶	PERMISS.
78	TOTAL PARTICULATES	78 NY075-00-0	0.011	11	4		0	8.50	27178	0	
88	SULFUR DIOXIDE	88 7446-09-5	0.002	11	4		0	2.10	6715	0	
100	NITROGEN OXIDES	100 NY210-00-0	0.009	11	4		90.0	8.09	25867	0	
111	VOC	111 NY998-00-0	0.005	11	4		20.0	3.94	12598	0	
122	Carbon Monoxide	122 00630-08-0	0.013	11	4		95.5	11.82	37793	0	

Upon completion of construction sign the statement listed below and forward to the appropriate field representative

THE STATIONARY COMBUSTION INSTALLATION HAS BEEN CONSTRUCTED AND WILL BE OPERATED IN ACCORDANCE WITH STATED SPECIFICATIONS AND IN CONFORMANCE WITH ALL PROVISIONS OF EXISTING REGULATIONS.

133 SIGNATURE OF AUTHORIZED REPRESENTATIVE OR AGENT _____ DATE _____

134 LOCATION CODE _____ 135 FACILITY ID NO. _____ 136 U.T.M. (E) _____ 137 U.T.M. (N) _____ 138 SIC NUMBER _____ 139 DATE APPL. RECEIVED _____ 140 DATE APPL. REVIEWED _____ 141 REVIEWED BY: _____

PERMIT TO CONSTRUCT

142 DATE ISSUED: / / 143 EXPIRATION DATE: / / 144 SIGNATURE OF APPROVAL: _____ 145 FEE _____

146
 1. DEVIATION FROM APPROVED APPLICATION SHALL VOID THIS PERMIT
 2. THIS IS NOT A CERTIFICATE TO OPERATE
 3. TESTS AND/OR ADDITIONAL EMISSION CONTROL EQUIPMENT MAY BE REQUIRED PRIOR TO THE ISSUANCE OF A CERTIFICATE TO OPERATE

RECOMMENDED ACTION RE: C.O.

147 DATE ISSUED: / / 148 EXPIRATION DATE: / / 149 SIGNATURE OF APPROVAL: _____ 150 FEE _____

151
 1. INSPECTED BY _____ DATE _____
 2. INSPECTION DISCLOSED DIFFERENCES AS BUILT VS PERMIT, CHANGES INDICATED ON FORM
 3. ISSUE CERTIFICATE TO OPERATE FOR SOURCE
 4. APPLICATION FOR C.O. DENIED _____ DATE _____ INITIALS _____

152 SPECIAL CONDITIONS:

1. Installation Number: _____

2. _____

3. _____

4. _____

5. _____

6. _____

7. _____

CALCULATIONS

See attached calculation spreadsheet

ULSD firing emissions

TO BE COMPLETED FOR ALL SOURCES USING ITEM 27 AND OTHER SOURCES AS DEFINED IN THE INSTRUCTION FORM 76-11-4

SECTION	CONTAMINANT		EMISSIONS				% CONTROL EFFICIENCY	HOURLY EMISSIONS (LBS/HR)	ANNUAL EMISSIONS (LBS/YR)		
	NAME	CAS NUMBER	ACTUAL	UNIT	HOW DET	PERMISS		ACTUAL	ACTUAL	PERMISS.	PERMISS.
78	TOTAL PARTICULATES	78 NY075-00-0	0.0344	11	4		0	28.83	22733	0	
88	SULFUR DIOXIDE	88 7446-09-5	0.0015	11	4		0	1.29	1017	0	
100	NITROGEN OXIDES	100 NY210-00-0	0.0136	11	4		91.7	11.42	9004	0	
111	VOC	111 NY998-00-0	0.0058	11	4		37.5	4.85	3824	0	
122	Carbon Monoxide	122 00630-08-0	0.0142	11	4		96.0	11.92	9398	0	
	Lead	007439-92-1	0.000014	11	4		0	0.012	9.5	0	

Upon completion of construction sign the statement listed below and forward to the appropriate field representative

THE STATIONARY COMBUSTION INSTALLATION HAS BEEN CONSTRUCTED AND WILL BE OPERATED IN ACCORDANCE WITH STATED SPECIFICATIONS AND IN CONFORMANCE WITH ALL PROVISIONS OF EXISTING REGULATIONS.

133 SIGNATURE OF AUTHORIZED REPRESENTATIVE OR AGENT _____ DATE _____

134 LOCATION CODE _____ 135 FACILITY ID NO. _____ 136 U.T.M. (E) _____ 137 U.T.M. (N) _____ 138 SIC NUMBER _____ 139 DATE APPL. RECEIVED ____/____/____ 140 DATE APPL. REVIEWED ____/____/____ 141 REVIEWED BY: _____

PERMIT TO CONSTRUCT

142 DATE ISSUED ____/____/____ 143 EXPIRATION DATE ____/____/____ 144 SIGNATURE OF APPROVAL _____ 145 FEE _____

146
 1. DEVIATION FROM APPROVED APPLICATION SHALL VOID THIS PERMIT
 2. THIS IS NOT A CERTIFICATE TO OPERATE
 3. TESTS AND/OR ADDITIONAL EMISSION CONTROL EQUIPMENT MAY BE REQUIRED PRIOR TO THE ISSUANCE OF A CERTIFICATE TO OPERATE

RECOMMENDED ACTION RE: C.O.

147 DATE ISSUED ____/____/____ 148 EXPIRATION DATE ____/____/____ 149 SIGNATURE OF APPROVAL _____ 150 FEE _____

151
 1. INSPECTED BY _____ DATE _____
 2. INSPECTION DISCLOSED DIFFERENCES AS BUILT VS PERMIT, CHANGES INDICATED ON FORM
 3. ISSUE CERTIFICATE TO OPERATE FOR SOURCE
 4. APPLICATION FOR C.O. DENIED _____ DATE _____ INITIALS _____

152 SPECIAL CONDITIONS:

1. Installation Number: _____

2. _____

3. _____

4. _____

5. _____

6. _____

7. _____

NYC DEP Emissions Calculations
Summary Sheet

LMS100 Emission Analysis - Summary Sheets

Pollutant	LMS100 PTE
	Tons Per Year
NOx	13.94
CO	21.23
SO2	3.36
NO2 (as NOx)	13.94
PM	19.26
PM10	19.26
PM2.5	19.26
VOC	6.32
Pb	0.005
NH3	11.03

LMS100 PTE

Potential LMS100 Capacity Factor (CF) and Allowable Emissions

	Gas fired (lbs/hr)	Oil fired (lbs/hr)	Start Up PTE/Yr (Tons)	Shut Down PTE/Yr (Tons)	LMS100 35% Annual CF			LMS100 9% Oil CF			LMS100 36.5% NG CF		
					Hours per Year		Potential To Emit TPY	Hours per Year		Potential To Emit TPY	Hours per Year		Potential To Emit TPY
					Gas	Oil		Gas	Oil		Gas	Oil	
					2,452.80	613.2		0.00	788.4		3,197.4	0	
NOx	8.09	11.42	0.20	0.31	LMS100 Natural Gas Emissions TPY 10.44	LMS100 ULSD Emissions TPY 3.50	LMS100 Potential To Emit TPY 13.94	LMS100 Natural Gas Emissions TPY 0.51	LMS100 ULSD Emissions TPY 4.50	LMS100 Potential To Emit TPY 5.02	LMS100 Natural Gas Emissions TPY 13.45	LMS100 ULSD Emissions TPY 0.00	LMS100 Potential To Emit TPY 13.45
CO	11.82	11.92	0.99	1.35	16.83	3.65	20.49	2.34	4.70	7.04	21.23	0.00	21.23
SO2	2.10	1.29			2.58	0.40	2.97	0.00	0.51	0.51	3.36	0.00	3.36
PM10/PM2.5	8.50	28.83			10.42	8.84	19.26	0.00	11.37	11.37	13.59	0.00	13.59
VOC	3.94	4.85			4.83	1.49	6.32	0.00	1.91	1.91	6.30	0.00	6.30
Pb	0.00	0.012			0.00	0.004	0.004	0.00	0.005	0.005	0.00	0.00	0.000
NH3	5.98	12.06			7.33	3.70	11.03	0.00	4.75	4.75	9.56	0.00	9.56

Note: The shaded emissions above represents the potential-to-emit (PTE) in tons per year (TPY) for the LMS100

LMS100 PTE Emission Summary

Pollutant	LMS100 PTE Tons per Year
NOx	13.94
CO	21.23
SO2	3.36
PM10/PM2.5	19.26
VOC	6.32
Pb	0.005
NH3	11.03

NYC DEP LMS100 Start Up Shut-Down Emission Calculations

LMS100 Start-Up Emissions - PTE							
Number of Starts per Year							
240							
Pollutant	GE Guaranteed Emission Rate for Start Up Initial 10 minutes (Lbs)	Maximum LMS100 Emission Rate (Lbs/hr)	Start Up Hour = 10 minutes @ Start Up Rate + 50 minutes at Maximum Rate	Lbs per Start Up Hour	Additional PTE/hr (Lbs)	Start Up PTE/Yr (Lbs)	Start Up PTE/Yr (Tons)
NOx	3.01	8.09	0.83	9.75	1.66	398.80	0.20
CO	10.21	11.82	0.83	20.06	8.24	1,977.60	0.99

LMS100 Start Up Emissions per Start Up Event				
Start Up = 30 minutes/event				
Pollutant	GE Guaranteed Emission Rate for Start Up Initial 10 minutes (Lbs)	Maximum LMS100 Emission Rate (Lbs/hr)	Start Up Event = 10 minutes @ Start Up Rate + 20 minutes at Maximum Rate	Lbs per Start Up Event
NOx	3.01	8.09	0.33	5.71
CO	10.21	11.82	0.33	14.15

NYC DEP LMS100 Start Up Shut-Down Emission Calculations

LMS100 Shut-Down Emissions - PTE							
Number of Starts per Year							
240							
Pollutant	GE Guaranteed Emission Rate for Shut Down Final 10 Minutes (Lbs)	Maximum LMS100 Emission Rate (Lbs/hr)	Shut Down Hour = 10 minutes @ Shut Down Rate + 50 minutes @ Maximum Rate	Lbs per Shut Down Hour	Additional PTE/hr (Lbs)	Shut Down PTE/Yr (Lbs)	Shut Down PTE/Yr (Tons)
NOx	3.97	8.09	0.83	10.71	2.62	629.20	0.31
CO	13.21	11.82	0.83	23.06	11.24	2,697.60	1.35

LMS100 Shut Down Emissions per Shut Down Event				
Shut Down = 30 minutes/event				
Pollutant	GE Guaranteed Emission Rate for Shut Down Final 10 minutes (Lbs)	Maximum LMS100 Emission Rate (Lbs/hr)	Shut Down Event = 10 minutes @ Shut Down Rate + 20 minutes at Maximum Rate	Lbs per Shut Down Event
NOx	3.97	8.09	0.33	6.67
CO	13.21	11.82	0.33	17.15

**SPIP - Gowanus Generating Station
Natural Gas Firing
GE LMS100 Emission Inputs & Emission Rates - AQ Permitting
ESS Job Nº U160-000**

Operation	3,197.40	hrs/yr							
Stack Base Elevation	4.00	ft msl							
Stack Base Elevation	1.22	m msl							
Stack Height	100.00	feet							
Stack Height	30.48	meters							
Stack Diameter	13.50	feet							
Stack Diameter	4.11	meters							
Exhaust Area	143.14	sq feet							
Reference Temp	68.00	°F							
Case Number	300	203	303	301	204	304	302	205	305
Load (%)	100	100	100	75	75	75	50	50	50
Ambient Temp (°F)	-5	59	105	-5	59	105	-5	59	105
Air+Gas Flow (lb/hr)	1,732,698	1,699,142	1,465,993	1,463,575	1,456,181	1,253,267	1,162,871	1,155,972	999,715
Air+Gas Flow mol wt	28.12	28.05	27.92	28.23	28.15	28.05	28.35	28.24	28.16
Exhaust Flow (scfm)	395,492	388,830	336,986	332,754	332,008	286,778	263,263	262,765	227,856
Exhaust Flow (acfm)	889,507	909,052	818,089	750,933	763,964	693,096	602,841	613,438	560,757
Exit Velocity (ft/sec)	103.572	105.847	95.256	87.436	88.954	80.702	70.193	71.427	65.293
Exit Velocity (m/sec)	31.569	32.262	29.034	26.651	27.113	24.598	21.395	21.771	19.901
Exhaust Temp (°F)	727.5	774.4	821.8	731.5	755.0	816.1	749.1	772.6	839.4
Exhaust Temp (K)	659.6	685.6	711.9	661.8	674.8	708.8	671.5	684.6	721.7
Emissions (lb/hr)									
NO_x	7.75	8.09	6.88	6.16	6.34	5.49	4.56	4.66	4.11
CO	11.32	11.82	10.05	8.99	9.26	8.01	6.65	6.81	6.00
PM₁₀/PM_{2.5}	7.78	8.43	8.46	7.60	7.88	8.04	7.48	7.69	7.81
NH₃	5.73	5.98	5.09	4.55	4.68	4.05	3.37	3.45	3.03
S from Turbine		1.05			0.82			0.61	
SO₂	1.91	2.10	1.70	1.51	1.64	1.35	1.11	1.21	1.01
VOC	3.94	3.59	3.02	3.32	3.06	1.86	2.56	1.90	1.14
Pb									
H₂SO₄	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
Fuel Flow									
MMBtu/hr, LHV	787.7	805.3	700.5	623.9	631.3	556.6	453.5	464.8	415.3
MMBtu/hr, HHV	866.5	885.8	770.6	686.3	694.4	612.3	498.9	511.3	456.8
lb/MMBtu, HHV									
NO_x	0.00895	0.00913	0.00893	0.00897	0.00913	0.00896	0.00913	0.00912	0.00899
CO	0.01307	0.01334	0.01305	0.01311	0.01333	0.01309	0.01334	0.01333	0.01313
PM₁₀/PM_{2.5}	0.00898	0.00952	0.01098	0.01107	0.01134	0.01313	0.01499	0.01504	0.01710
NH₃	0.00661	0.00675	0.00660	0.00663	0.00675	0.00662	0.00675	0.00674	0.00664
S from Turbine		0.00118			0.00118			0.00118	
SO₂	0.00220	0.00237	0.00220	0.00220	0.00237	0.00220	0.00223	0.00237	0.00220
VOC	0.00455	0.00405	0.00392	0.00483	0.00441	0.00304	0.00513	0.00372	0.00249
Pb									
H₂SO₄	0.00006	0.00006	0.00006	0.00007	0.00007	0.00008	0.00010	0.00010	0.00011

Notes:

1. All emission rates provided by General Electric
2. Natural Gas = (1.1) LHV = HHV
3. Natural Gas Maximum Fuel Sulfur Content = 0.85 grains of Sulfur per 100 SCF

**SPIP - Gowanus Generating Station
ULSD Firing
GE LMS100 Emission Inputs & Emission Rates - AQ Permitting
ESS Job № U160-000**

Operation	788.40	hrs/yr							
Stack Base Elevation	4.00	ft msl							
Stack Base Elevation	1.22	m msl							
Stack Height	100.00	feet							
Stack Height	30.48	meters							
Stack Diameter	13.50	feet							
Stack Diameter	4.11	meters							
Exhaust Area	143.14	sq feet							
Reference Temp	68.00	°F							
Case Number	100B	103	103B	101B	104	104B	102B	105	105B
Load (%)	100	100	100	75	75	75	50	50	50
Ambient Temp (°F)	-5	59	105	-5	59	105	-5	59	105
Air+Gas Flow (lb/hr)	1,735,367	1,677,347	1,421,523	1,465,832	1,435,489	1,211,705	1,164,578	1,138,054	983,166
Air+Gas Flow mol wt	28.65	28.56	28.52	28.70	28.62	28.56	28.75	28.67	28.61
Exhaust Flow (scfm)	388,733	376,913	319,962	327,828	321,914	272,314	260,005	254,777	220,588
Exhaust Flow (acfm)	888,103	889,453	786,060	750,325	748,120	669,148	603,017	601,053	547,317
Exit Velocity (ft/sec)	103.408	103.565	91.527	87.366	87.109	77.914	70.214	69.985	63.728
Exit Velocity (m/sec)	31.519	31.567	27.897	26.629	26.551	23.748	21.401	21.331	19.424
Exhaust Temp (°F)	746.3	786.0	837.2	748.5	767.1	837.4	764.6	785.6	850.1
Exhaust Temp (K)	670.0	692.0	720.5	671.2	681.5	720.6	680.1	691.8	727.6
Emissions (lb/hr)									
NO_x	11.28	11.42	9.55	8.93	8.95	7.62	6.58	6.60	5.70
CO	11.77	11.92	9.96	9.32	9.34	7.95	6.86	6.89	5.95
PM₁₀/PM_{2.5}	28.59	28.83	24.71	22.73	22.62	19.79	16.92	16.85	14.92
NH₃	11.91	12.06	10.08	9.43	9.45	8.05	6.94	6.97	6.02
S from Turbine		0.65			0.51			0.37	
SO₂	1.28	1.29	1.08	1.01	1.01	0.86	0.74	0.75	0.64
VOC	4.85	4.70	3.99	4.09	4.01	3.39	3.24	3.18	2.75
Pb	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
H₂SO₄	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
Fuel Flow									
MMBtu/hr, LHV	794.6	791.7	671.6	629.2	621.2	536.3	463.4	457.9	401.3
MMBtu/hr, HHV	842.3	839.2	711.9	667.0	658.5	568.5	491.2	485.4	425.4
lb/MMBtu, HHV									
NO_x	0.01340	0.01361	0.01341	0.01339	0.01360	0.01340	0.01339	0.01360	0.01340
CO	0.01398	0.01420	0.01399	0.01397	0.01419	0.01399	0.01397	0.01419	0.01398
PM₁₀/PM_{2.5}	0.03394	0.03436	0.03471	0.03408	0.03436	0.03481	0.03445	0.03472	0.03507
NH₃	0.01414	0.01437	0.01416	0.01414	0.01436	0.01415	0.01414	0.01436	0.01415
S from Turbine		0.00077			0.00077			0.00077	
SO₂	0.00152	0.00154	0.00152	0.00151	0.00154	0.00151	0.00151	0.00154	0.00150
VOC	0.00575	0.00560	0.00560	0.00613	0.00609	0.00597	0.00660	0.00654	0.00646
Pb	0.00001	0.00001	0.00001	0.00001	0.00002	0.00002	0.00002	0.00002	0.00002
H₂SO₄	0.00002	0.00002	0.00003	0.00003	0.00003	0.00004	0.00004	0.00004	0.00005

Notes:

1. All emission rates provided by General Electric
2. Maximum Liquid Fuel Sulfur Content = 0.0015% S by weight
3. Liquid Fuel = (1.06) LHV = HHV



THE CITY OF NEW YORK DEPARTMENT OF ENVIRONMENTAL PROTECTION
59-17 Junction Boulevard, 9th Floor, Corona, New York 11368-5107
JOEL A. MIELE, SR., P.E., Commissioner

ROBERT C. AVALTRONI
Deputy Commissioner

Bureau of Air Noise & Hazardous
Materials

RECORDS CONTROL UNIT
(718) 595-3855

DATE: _____

INSTALLATION NUMBER

RE: Gowanus Generating Station, 29th St. & Second Avenue
(PREMISE ADDRESS)


Brooklyn
(BORO)

PROFESSIONAL CERTIFICATION

Being duly mindful of my responsibilities as a licenced Professional Engineer in the State of New York and acting as designated agent for the applicant, I hereby certify that the application, plans and all supplementary documents submitted in connection with this filing are complete and fully comply with all applicable laws, codes, rules, regulations and directives of the Department of Environmental Protection, Bureau of Air Noise & Hazardous Materials (*Formerly known as Bureau of Air Resources*) of the City of New York in effect at the time filed.

P.E. Seal & Signature

INSTRUCTIONS: Pursuant to Engineering Directive # 1-78, this certification must be submitted in triplicate with all APC 5-0, APC 5-R and APC5-PA applications and does not preclude the necessity to sign and seal the certification now contained on the application forms. This certification shall also be submitted in triplicate with all APC 5-0 applications submitted and certified by a Professional engineer.




SOUTH PIER IMPROVEMENT PROJECT
Astoria Generating Company, L.P., a USPowerGen Company
Brooklyn, New York

Site Locus

Engineers
Scientists
Consultants

Scale: 1" = 2,000'
Source:
1) NYS GIS Clearinghouse, USGS DRG, 1981

Figure 1




SOUTH PIER IMPROVEMENT PROJECT
 Astoria Generating Company, L.P., a USPowerGen Company
 Brooklyn, New York

Scale: 1" = 100'
 Source: 1) Getmapping USA, Ortho, 2001
 2) Astoria, Layout of Facility, 2007

**Preliminary
 Site Plan**

**Figure
 2**

GE's New Gas Turbine System: Designed to Change the Game in Power Generation



LMS100™

Systems



GE Power

Aircraft Engines
Technology

GE Power Systems
Technology



High Efficiency Gas Turbine



■ The LMS100™ is the first intercooled gas turbine system developed especially for the power generation industry, utilizing the best of two technologies -- heavy-duty frame gas turbine and aeroderivative gas turbine technology. The LMS100 will deliver 100MW at 46% thermal efficiency. This efficiency is 10 % higher than GE's highest simple cycle efficiency gas turbine available today. It is specifically designed for cyclic applications providing flexible power for peaking, mid-range and baseload.

Flexible Power: High Efficiency

- High Part-Power Efficiency, 50% Power
- High Simple Cycle Efficiency.....
- High STIG Efficiency.....
- High Combined Cycle Efficiency.....

Only GE Can Bring You the Best of Both Worlds

The LMS100 features a heavy-duty low pressure compressor derived from GE Power Systems' MS6001FA heavy-duty gas turbine compressor; its core which includes the high pressure compressor, combustor and high pressure turbine is derived from GE Aircraft Engines' CF6-80C2® and CF6-80E1® aircraft engines. The design of the new 2-stage intermediate pressure turbine and new 5-stage power turbine is based on the latest aeroderivative gas turbine technology. The exhaust and aft shaft for hot-end drive are designed using heavy-duty gas turbine practices.



The compressed air from the... cooled in either an air-to-air or... (intercooler) and ducted to th... The cooled flow means less w... efficiency and power output... air, used for turbine cooling, al... resulting in increased power


describe their requirements for generation facilities, customers following items as high on their

cks of power
cy at full and part-power
bility

bility
t-day power


ty
ns
a new gas turbine which met these
ould be an important addition to
n mix.

o has been designed to specifically
hese needs, changing the game in
erating industry.



The LMS100 is the Right Solution:

- Outstanding full- and part-power efficiency
- Low hot-day lapse rate
- High availability – aero modular maintenance
- Low maintenance cost
- Designed for cycling applications
 - No cost penalty for starts and stops
 - Load-following capability
- 10 Minutes to full power
 - Improves average efficiency in cycling
 - Potential for spinning reserve credits
 - Reduced start-up emissions
- Synchronous condenser capability



The LMS100 features an inlet and an LPC comprised of the first six stages of the MS6001FA compressor. These stages are followed by an aerodynamically designed volute which ducts the low pressure compressed air into the intercooler. This LPC provides high airflow capacity for the LMS100 Gas Turbine System.

Cooled air from the intercooler is ducted back through another aerodynamically designed volute into the aero supercore. The high efficiency aeroderivative supercore consists of:

- a high pressure compressor (HPC) based on the CF6-80C2 aircraft engine compressor, strengthened for the high (42:1) pressure ratio of the LMS100;
- a combustor which can be either a standard annular combustor (SAC) or an advanced dry low emissions (DLE2) combustor;
- a high pressure turbine (HPT) derived from the CF6-80E1 aircraft engine;
- a 2-stage intermediate pressure turbine (IPT) designed to drive the LPC through a mid-shaft and flexible coupling.

Following the IPT is a 5-stage aerodynamically coupled power turbine (PT) that has been designed specifically for the LMS100. The exhaust frame and aft drive shaft are based on a rugged heavy-duty gas turbine exhaust design.




Over 600 A
Technology
Nearly 8 M

3,786 CF6-80 Engines in Operation
With More Than 103 Million Operating Hours



The LPC air is ducted to an air-to-air or air-to-water heat exchanger where it is cooled before being ducted to the HPC. Both designs are industry standard heat exchangers with significant operating hours in multiple





Availability Features

Construction permits replacement of components without total disassembly. Access ports allow on-condition maintenance without turbine disassembly. Accessories are externally mounted for ease of on-site replacement.

- Split casing construction of the LPC and aeroderivative compressor allows detailed on-site inspection and blade replacement.
- Hot-section field maintenance can be done in several days.
- Accessories are externally mounted for ease of on-site replacement.

Rotable "Supercore" Enhances Power Plant Availability

GE has established a target availability of 97.5% for a mature GE-built LMS100 power plant. Its power plant target reliability is 98.5%. The rotable "supercore" consists of the HPC, Combustor, HPT and IPT modules.

LMS100 Service Intervals

The expected service intervals for the LMS100 based upon normal operation include:

- On-site hot-section replacement.....25,000 fired hours*
- Depot maintenance; overhaul of hot section and inspection of all systems, power turbine overhaul ...50,000 fired hours*
- Next on-site hot section replacement75,000 fired hours*
- Depot maintenance; overhaul of hot section and inspection of all systems, power turbine overhaul ...100,000 fired hours*

Rotable modules allow on-site maintenance and a power turbine can be replaced in 24 hours when needed.

Maintenance

All warranty and service agreements will be provided for the power plant or at its severest. These agreements are part of the Service Agreement. Rotable Modules

turbine package system was
 able operation, easy access for
 and quick installation. The auxiliary
 assembled on a single skid and
 prior to shipment. The auxiliary
 in front of the turbine base plate
 flexible connectors reducing
 connects by 25%. The complete
 er package can be shipped

ent System Design
 plant layout will be
 t will contain basic elements
 n inlet, an auxiliaries skid containing
 stem, lube oil system and starter
 skid, an intercooling system,
 cers, exhaust system and a

em
 asis has been placed on
 or increased reliability of the
 nt. The LMS100 control system
 nnel architecture with a
 ta link providing redundancy which
 ole failures without engine
 eroptic distributed I/O system
 he module will be unaffected by
 or radio frequency interference
 mate noisy wiring. Site intercond
 d by 90% compared to the typical
 rol system.

C will be equipped with dual fuel

Emissions Control

The LMS100 gas turbine system has all the advantages of an aeroderivative gas turbine in achieving low emissions. The LMS100 gas turbine with the SAC combustor (using water or steam for NOx control) and the advanced DLE combustor (DLE2) are designed to achieve 25 ppm NOx. This represents a 7 to 18% reduction in mass emissions rate (lbs/kwh) vs. the LM6000. In locations where less than 25 ppm NOx is required a low temperature SCR can be used. The high efficiency of the LMS100 results in exhaust temperatures below 800°F (427°C) which permits the use of low temperature SCRs without tempering air.

Noise Control

The gas turbine-generator will be rated at 85 dBA average at 3 feet (1 meter). An option for 80 dBA at 3 feet will be available.



Generator

The generator is dual rated for 50 or 60 Hz applications. Either an air-cooled or TWAC configuration can be provided.



Air-to-Air Intercooler

In locations where water is scarce or very expensive, the basic LMS100 power plant will contain a highly reliable air-to-air intercooler. This unit will be a tube and fin style heat exchanger in an A-frame configuration which is the same as typical steam condensing units in general conformance with API 661 standards. Similar units are in service in the Oil and Gas industry today. In high ambient temperature climates, an evaporative cooling system can be added for power augmentation. This system would use a small amount of water for short time periods as required.



Air-to-Water Intercooler


In locations where water is readily abundant or less expensive the intercooler can be of the air-to-water type also found in many industrial applications. The intercooler would be a tube and shell type heat exchanger.

Either type of intercooler will be connected through a system of pipe and expansion bellows, from the low pressure compressor volute to the intercooler and upon return to the high pressure compressor inlet volute.

LMS100 is Available in a Variety of Configurations

Four basic LMS100 configurations are available as this product is introduced. When combined with intercooler options and duty applications, the LMS100 will offer the customer 20 different configuration choices.

LMS100 SYSTEM CONFIGURATIONS					
Product Offerings	Fuel	Combustor	Diluent	Power Augmentation	M
LMS100 SAC, 50/60 Hz	Gas, Liquid or Dual Fuel	Single Annular (SAC)	Water	None	
LMS100 SAC Steam, 50/60 Hz	Gas	Single Annular (SAC)	Steam	None	
LMS100 SAC STIG, 50/60 Hz	Gas	Single Annular (SAC)	Steam	Steam Injection	



LMS100 Provides
 Outstanding Customer
 Value in
 80+ MW
 Applications

of the LMS100 make it a versatile power generation system offering customers operational flexibility in a wide variety of applications.

Peaking & Mid-Range...high efficiency, low cost, sustained hot day power, and no maintenance penalty for cycling. An ideal peaking solution. Throw in load following capability and high dispatch capability for mid-range applications.


Injection for power augmentation...high efficiency and power output as well as flexibility. With variable load, the LMS100 can inject all of the steam into the process to take advantage of low electricity prices or process steam requirements.

Scale...the low exhaust temperature allows for smaller exhaust system materials, smaller condensers and generators, leading to lower plant installed cost.

Another benefit from the lower exhaust temperature is more power from duct firing (up to 30MW).

- Combined Heat & Power ...the high power-to-steam ratio allows the LMS100 to meet the steam demand served by 40-50MW gas turbines while delivering more than twice the power. Using both exhaust and air-to-water intercooler energy, an LMS100 plant can reach >85% thermal efficiency.
- 50Hz and 60Hz Applications ...the LMS100 can operate at 50Hz and 60Hz operation without a gearbox, reducing system complexity, plot size and cost, while increasing reliability.
- Off-Frequency Operation ...the LMS100 will operate with very little power variation for up to 5% reduction in grid frequency, allowing grid support in times of high demand and load fluctuations.


When your power generation need exceeds 100MW, the LMS100 can provide an economic solution in a multi-unit arrangement by providing high efficiency power with unmatched flexibility.



Model	Heat Rate (BTU/KWH)	Efficiency %
DLE	7509	46
SAC (w/Water)	7813	44
SAC (w/Steam)	7167	48
STIG	6845	50

terminals

(BTU/lb)



Model	Output (MWe)	Heat Rate (KJ/KWH)
DLE	99	7921
SAC (w/Water)	102.5	8247
SAC (w/Steam)	102.2	7603
STIG	110.8	7263

Conditions:

Performance at the generator terminals

NOx = 25 ppm

15°C, 60% Relative Humidity

Losses: 0mm/0mm inlet/exhaust

Fuel: Spec Gas (LHV = 44.2MJ/KG)

