JUNE 2004 ADDENDUM TO JUNE 1998 DIVISION OF WATER TECHNICAL AND OPERATIONAL GUIDANCE SERIES (TOGS) NO. 1.1.1.

(Originator- Scott Stoner)

TABLE 1
NEW YORK STATE AMBIENT WATER QUALITY STANDARDS AND GUIDANCE VALUES

SUBSTANCE (CAS No.)	WATER CLASSES	STANDARD (ug/L)	GUIDANCE VALUE (ug/L)	TYPE	BASIS CODE
Metolachlor ESA (171118-09-5)	A, A-S, AA, AA-S GA		50 50	H(WS) H(WS)	Z Z
Metolachlor OA (152019-73-3)	A, A-S, AA, AA-S GA		50 50	H(WS) H(WS)	Z Z
Propylene glycol (57-55-6)	A, A-S, AA, AA-S GA		* *	H(WS) H(WS)	G G

Remark *Guidance value is 1,000 ug/L except that a guidance value of 300 ug/L applies at the point of intake of a public or private water supply that uses ozonation in its treatment process.

TABLE 5
NEW YORK STATE GROUNDWATER EFFLUENT LIMITATIONS (CLASS GA)

SUBSTANCE (CAS No.)	MAXIMUM ALLOWABLE CONCENTRATION (ug/L)	CATEGORY
Metolachlor ESA (171118-09-5)	50	B
Metolachlor OA (152019-73-3)	50	B
Propylene glycol (57-55-6)	1,000	B

In addition, metolachlor and propylene glycol are deleted from Table 3 of the June 1998 edition of TOGS 1.1.1.

Sandra L. Allen, Director
Division of Water