



PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 1-4726-00790/00004
Effective Date: 02/15/2018 Expiration Date: 02/14/2023

Permit Issued To: COVANTA HUNTINGTON, LLC
99 TOWN LINE RD
EAST NORTHPORT, NY 11731

Facility: HUNTINGTON RESOURCE RECOVERY FACILITY
99 TOWN LINE RD
E NORTHPORT, NY 11731

Contact: BRIAN AERNE
COVANTA HUNTINGTON LLC
99 TOWN LINE RD
EAST NORTHPORT, NY 11731
(631) 754-1100

Description:

NATURE OF THE BUSINESS AT THE FACILITY:

The Huntington Resource Recovery Facility (facility) located in East Northport, New York is a waste-to-energy facility consisting of three mass burn waterwall type municipal waste combustors with a nominal design capacity of 250 tons per day each. The facility combusts municipal solid wastes which include nonhazardous residential, commercial and governmental and/or institutional wastes, the combustible portion of construction and demolition (C&D) debris, nonhazardous industrial waste stream as approved by NYSDEC on a case by case basis. The heat generated in the combustion process is utilized to produce electricity.

(Primary SIC) - 4953

TYPE OF EQUIPMENT AND OPERATIONS AT THE FACILITY:

The facility is equipped with a 27.5 megawatt turbine generator. Air pollution control equipment at the facility includes dry scrubbers for acid gas control, fabric filters for particulate removal, and a selective non-catalytic reduction system for control of nitrogen oxides. In addition, the facility has selected to install carbon injection system to achieve full compliance with 40CFR60, Subpart Cb limits for mercury and dioxin. The facility employs a Continuous Emissions Monitoring System (CEMS) that provides continuous feed back on the effectiveness of the air pollution control equipment. The gas analyzers include oxides of nitrogen (NOx), sulfur dioxides (SO2), carbon monoxide (CO), oxygen (O2) and carbon dioxides (CO2). All three combustion trains are equipped with separate flues that are vented through a common stack. The facility uses propane gas as an auxiliary fuel during start-up, shutdown, and on an "as-needed" basis to maintain the minimum required combustion zone temperature and residence time.



AIR PERMIT APPLICABILITY:

The facility was originally permitted in April 1989 based on 6NYCRR Part 201 - Permits, federal regulation 40CFR52-A.21(j)(2) - Prevention of Significant Deterioration (PSD) arose from the reviews of PSD of air quality and Best Available Control Technology (BACT), 6NYCRR Part 219 - Incineration, 6NYCRR Part 231 - New Source Review in Nonattainment Areas arose from reviews of Lowest Achievable Emission Rate (LAER), and 6NYCRR Part 617 - State Environmental Quality Review. The facility is subject to federal regulation 40CFR60, Subpart Cb - Emission Guidelines and Compliance Schedules for Existing Municipal Waste Combustors.

OCCURRENCE OF CAPPING:

This permit includes a waste throughput capped at 350,400 tons per years. The Co-Permittees have accepted permit limitations to include maximum annual emissions for NOx and Volatile Organic Compounds (VOC) to ensure that the increase in throughput will not be subjected 6NYCRR Part 231-2 - New Source Review for Nonattainment Areas under the provision of a Source Project.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: ROGER EVANS
 NYSDEC - REGION 1 SUNY @ STONY BROOK
 50 CIRCLE RD
 STONY BROOK, NY 11790-3409

Authorized Signature: _____ Date: ___ / ___ / _____



Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.



LIST OF CONDITIONS

DEC GENERAL CONDITIONS

General Provisions

- Facility Inspection by the Department
- Relationship of this Permit to Other Department Orders and Determinations
- Applications for permit renewals, modifications and transfers
- Permit modifications, suspensions or revocations by the Department

Facility Level

- Submission of application for permit modification or renewal -
REGION 1 HEADQUARTERS



DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by



the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409
(631) 444-0365

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: COVANTA HUNTINGTON, LLC
99 TOWN LINE RD
EAST NORTHPORT, NY 11731

Facility: HUNTINGTON RESOURCE RECOVERY FACILITY
99 TOWN LINE RD
E NORTHPORT, NY 11731

Authorized Activity By Standard Industrial Classification Code:
4953 - REFUSE SYSTEMS

Permit Effective Date: 02/15/2018

Permit Expiration Date: 02/14/2023



LIST OF CONDITIONS

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 2 6 NYCRR 201-6.4 (a) (7): Fees
- 3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
- 4 6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
- 5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
- 6 6 NYCRR 201-6.4 (e): Compliance Certification
- 7 6 NYCRR 202-2.1: Compliance Certification
- 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 9 6 NYCRR 215.2: Open Fires - Prohibitions
- 10 6 NYCRR 200.7: Maintenance of Equipment
- 11 6 NYCRR 201-1.7: Recycling and Salvage
- 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 15 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
- 16 6 NYCRR 201-6.4 (a) (8): Right to Inspect
- 17 6 NYCRR 201-6.4 (f) (6): Off Permit Changes
- 18 6 NYCRR 202-1.1: Required Emissions Tests
- 19 40 CFR Part 68: Accidental release provisions.
- 20 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 21 6 NYCRR 200.3: False statement
- 22 6 NYCRR 200.7: Compliance Certification
- 23 6 NYCRR Subpart 201-6: Emission Unit Definition
- 24 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
- 25 6 NYCRR Subpart 201-7: Facility Permissible Emissions
- *26 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- *27 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- 28 6 NYCRR 202-1.3: Acceptable procedures
- 29 6 NYCRR 211.1: Air pollution prohibited
- 30 6 NYCRR 231-2.5: Compliance Certification
- 31 40CFR 52.21, Subpart A: Compliance Certification
- 32 40CFR 52.21, Subpart A: Compliance Certification
- 33 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 34 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 35 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 36 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 37 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 38 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 39 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 40 40CFR 52.21(j)(2), Subpart A: Compliance Certification
- 41 40CFR 60.33b(b)(3)(i), NSPS Subpart Cb: Compliance Certification
- 42 40CFR 60.33b(b)(3)(i), NSPS Subpart Cb: Compliance Certification
- 43 40CFR 60.33b(d), NSPS Subpart Cb: Compliance Certification



- 44 40CFR 60.34b(a), NSPS Subpart Cb: Compliance Certification
- 45 40CFR 60.36b, NSPS Subpart Cb: Compliance Certification
- 46 40CFR 60.39b(a), NSPS Subpart Cb: Compliance Certification
- 47 40CFR 60.39b(a), NSPS Subpart Cb: Compliance Certification
- 48 40CFR 60.39b(a), NSPS Subpart Cb: Compliance Certification
- 49 40 CFR Part 64: Compliance Certification

Emission Unit Level

- 50 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 51 6 NYCRR Subpart 201-6: Process Definition By Emission Unit
- 52 40CFR 60.33b(a)(1)(i), NSPS Subpart Cb: Compliance Certification
- 53 40CFR 60.33b(a)(1)(iii), NSPS Subpart Cb: Compliance Certification
- 54 40CFR 60.33b(a)(2)(i), NSPS Subpart Cb: Compliance Certification
- 55 40CFR 60.33b(a)(4), NSPS Subpart Cb: Compliance Certification
- 56 40CFR 60.33b(b)(3)(ii), NSPS Subpart Cb: Compliance Certification
- 57 40CFR 60.33b(b)(3)(ii), NSPS Subpart Cb: Compliance Certification
- 58 40CFR 60.33b(c)(1)(iii), NSPS Subpart Cb: Compliance Certification
- 59 40CFR 60.34b(b), NSPS Subpart Cb: Compliance Certification
- 60 40CFR 60.34b(b), NSPS Subpart Cb: Compliance Certification

EU=1-MBMWC,EP=00001,Proc=MW1,ES=00MWC

- 61 40CFR 60.35b, NSPS Subpart Cb: Operating Manual
- 62 40CFR 60.35b, NSPS Subpart Cb: Operator Training
- 63 40CFR 60.35b, NSPS Subpart Cb: Compliance Certification

EU=1-MBMWC,EP=00001,Proc=MW1,ES=00MWC

- 64 40CFR 60.38b, NSPS Subpart Cb: Compliance and performance testing.

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 65 ECL 19-0301: Contaminant List
- 66 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 67 6 NYCRR 617.11 (d): Compliance Demonstration
- 68 6 NYCRR 617.11 (d): Compliance Demonstration
- 69 6 NYCRR 617.11 (d): Compliance Demonstration
- 70 6 NYCRR 617.11 (d): Compliance Demonstration
- 71 6 NYCRR 617.11 (d): Compliance Demonstration
- 72 6 NYCRR 617.11 (d): Compliance Demonstration
- 73 6 NYCRR 617.11 (d): Compliance Demonstration
- 74 6 NYCRR 617.11 (d): Compliance Demonstration
- 75 6 NYCRR 617.11 (d): Compliance Demonstration
- 76 6 NYCRR 617.11 (d): Compliance Demonstration
- 77 6 NYCRR 617.11 (d): Compliance Demonstration
- 78 6 NYCRR 617.11 (d): Compliance Demonstration
- 79 6 NYCRR 617.11 (d): Compliance Demonstration

Emission Unit Level

- 80 6 NYCRR 219-7.2: Compliance Demonstration
- 81 6 NYCRR 219-7.2: Compliance Demonstration

NOTE: * preceding the condition number indicates capping.



FEDERALLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and



reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR 201-6.4 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR 201-6.4 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V



facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. When additional applicable requirements under the act become applicable to a title V facility with a remaining permit term of three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the department pursuant to the provisions of section 201- 6.6 of this Subpart.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit



is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

**Condition 1: Acceptable Ambient Air Quality
Effective between the dates of 02/15/2018 and 02/14/2023**

Applicable Federal Requirement: 6 NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where



reports required by the permit.

Condition 5: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.
- (2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.
- (3) For all other deviations from permit requirements,



the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual



report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement: 6 NYCRR 201-6.4 (e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as



specified in any special permit terms or conditions;
and
- such additional requirements as may be specified
elsewhere in this permit related to compliance
certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Stationary Source Compliance Section
USEPA Region 2
Air Compliance Branch
290 Broadway
New York, NY 10007-1866

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer
NYSDEC- Region 1 Headquarters
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409

The address for the BQA is as follows:

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2019.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires - Prohibitions
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 215.2



Item 9.1:

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 9.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**



The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

Condition 10: Maintenance of Equipment
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-1.7

Item 11.1:

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 13.1:

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Condition 14: Trivial Sources - Proof of Eligibility



Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 14.1:

The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Condition 15: Requirement to Provide Information

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: Right to Inspect

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Off Permit Changes



Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)

Item 17.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 18.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Accidental release provisions.

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40 CFR Part 68

Item 19.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;

b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:



for each independent train includes dry scrubbers for acid gas control, fabric filter for particulate removal, selective non-catalytic reduction (SNCR) for control of nitrogen oxides, activated carbon injection for control of mercury and good combustion. Each unit is also equipped with a continuous emission monitoring system to provide feedback on the effectiveness of the air pollution control (APC) equipment. The HRRF may accept and process up to 60,000 gallons per day of landfill leachate as dilution water in the three spray dry absorbers.

The base operating scenario for the Huntington Resource Recovery Facility (HRRF) includes the combustion of solid waste in three 250 tpd units as allowed in the HRRF's solid waste permit contained in the facility's Certificate to Operate and as otherwise approved by NYSDEC. The facility is authorized to receive municipal solid waste which includes residential, commercial and governmental and/or institutional waste, the combustible portion of construction and demolition (C&D) debris, light industrial waste, shredded tires, and other non-hazardous industrial waste streams as approved by NYSDEC on a case by case basis. Propane gas is used during startup to warm the unit up before introducing refuse into the furnace and during the transition period before the fires are fully sustained by the refuse. Propane gas is used as an auxiliary fuel during shutdown until refuse is burned off the grates. Auxiliary fuel is also used during periods of upset and to maintain proper combustion.

HRRF is subject to 40 CFR 60 Subpart Cb and will follow the procedures for startup, shutdown and malfunction relief, outlined in section 40 CFR 60.58b(a) of Subpart Eb, as referenced through 40 CFR 60.38b of Subpart Cb. The 40 CFR 60.58b(a) states that "the standards under this subpart apply at all times except, during periods of startup, shutdown, or malfunction; provided, however, that the duration of startup, shutdown and malfunction shall not exceed three (3) hours per occurrence." effective January 15, 2002, 40 CFR 60.58b(a) has been amended to increase the duration of the malfunction exemption period to 15 hours, applicable to the compliance of carbon monoxide emission only, if the malfunction is determined to be due to the loss of boiler water control level (e.g., boiler water tube failure) or a loss of combustion air fan (e.g., loss of combustion air fan, induced draft fan, combustion grate bar failure).

The standards regulated under this subpart, and, therefore, for which the regulation provides startup, shutdown and malfunction relief, are particulate matter, opacity, sulfur dioxide, hydrogen chloride, nitrogen oxide, carbon monoxide and baghouse inlet temperature. Furthermore, additional permit limits for the constituents

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



listed above, is logically afforded the same relief. HRRF will follow the procedures for malfunction relief as outlined in the 40 CFR 60.58b(a) as discussed above and can seek relief for additional regulated parameters from NYSDEC on a case by case basis pursuant to 6 NYCRR Part 201-1.4. In addition, the emergency defense provision of 6 NYCRR Part 201-1.5 also applies to HRRF.

Building(s): 1

Condition 24: Progress Reports Due Semiannually
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 201-6.4 (d) (4)

Item 24.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 25: Facility Permissible Emissions
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 25.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0 PTE: 1,236,000 pounds per year
Name: OXIDES OF NITROGEN

CAS No: 0NY998-00-0 PTE: 168,000 pounds per year
Name: VOC

Condition 26: Capping Monitoring Condition
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR Subpart 201-7

Item 26.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 **Facility DEC ID: 1472600790**



| | |
|--|---|
| Process: ST1 | Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 0NY210-00-0 | OXIDES OF NITROGEN |

Item 26.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Annual NOx emissions from each furnace flue shall not exceed the limit shown in this condition. This annual limitation shall be derived from the hourly mass emissions rate computed by the facility continuous emission monitoring system (CEMs), accounting the actual on-line

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



applicable requirement.

Item 27.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 27.6:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: ST1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: ST2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 200BH |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: ST3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 27.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Annual hydrocarbon (non-methane) as ethane emissions from each furnace flue shall not exceed the limit shown in this condition. The annual limitation shall be calculated from the stack emission tests conducted during the calendar year using the EPA method shown, accounting for the actual on-line hours for each respective furnace.

Records for demonstration of compliance with the voc emission limit shall be maintained on site for five years.

Any exceedances of the allowable annual voc emission limitation must be reported in writing to the NYSDEC regional office within 10 working days of the exceedance

Upper Permit Limit: 28 tons per year

Reference Test Method: 40 CFR 60 App A RM25A

Monitoring Frequency: ANNUALLY

Averaging Method: ANNUAL TOTAL

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 28: Acceptable procedures

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 202-1.3

Item 28.1:

Emission testing, sampling, and analytical determinations to ascertain compliance with this Subpart shall be conducted in accordance with test methods acceptable to the commissioner.

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Condition 29: Air pollution prohibited
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 211.1

Item 29.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Condition 30: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:6 NYCRR 231-2.5

Item 30.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: 1-MBMWC

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 30.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Hydrocarbon (non-methane) as ethane emissions from each flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing at interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 25A or equivalent method acceptable to the Commissioner.

Parameter Monitored: VOC

Upper Permit Limit: 6.4 pounds per hour

Reference Test Method: 40 CFR 60 App A RM25A

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 31: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 52.21, Subpart A



Item 31.1:

The Compliance Certification activity will be performed for the Facility.

Item 31.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The facility shall not burn more than 350,400 tons per year of authorized wastes. The total throughput for each month and the calendar year-to-date total of waste combusted must be reported to the Department on a monthly basis. This federally enforceable throughput limit is based on the Permit Modification requests dated April 2000, indicating that no increases to any other permit conditions are being sought, including all emission limitations. Compliance shall be based as follows:

Charging Rate:

The facility shall not charge (process) more than 350,400 tons per 12-month rolling total and shall report to the Department, on a monthly basis, the facility's rolling annual throughput using the following formula:

$$\text{Tons Processed/Week} = \text{Tons Received/Week} \pm \text{Change in Existing Inventory/Week} - \text{Bulkies Removed from the Floor/Week}$$

where,

Tons Received/Week = Tons of incoming municipal waste received at the tipping floor for that week.

\pm Change in the Existing Inventory/Week = Change in the existing waste inventory determined from the prior week's calculation and either added to (if the inventory went down) or subtracted from (if the inventory went up) the total deliveries recorded by the scale system for the week.

Bulkies Removed from the Floor/Week = Any bulky or unacceptable waste that is removed from the incoming waste on the tipping floor during that week.

To demonstrate compliance with the 12-month rolling total, the facility shall calculate the existing inventory, the tons of bulkies removed and the number of tons processed at the end of each month.

Auxiliary burners shall be operated at the following times:



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

1. Furnace start up prior to introduction of municipal solid waste into the furnace;
2. Furnace shutdown when municipal solid waste feed has been discontinued until all refuse is cleared from combustion chamber;
3. During upset operations or to maintain proper combustion.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: 12-MONTH TOTAL, ROLLED MONTHLY

Reporting Requirements: MONTHLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 3/30/2018.

Subsequent reports are due every 1 calendar month(s).

Condition 32: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 52.21, Subpart A

Item 32.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 32.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Stack Testing Frequency:

A. Manual stack testing shall be conducted for the following contaminants:

1. Total Particulate Matter
2. PM-10
3. Sulfur Dioxide
4. Oxides of Nitrogen
5. Carbon Monoxide
6. Hydrogen Chloride
7. 2,3,7,8-Tetrachlorodibenzo-P-Dioxin
8. 2,3,7,8-Tetrachlorodibenzofuran
9. Lead
10. Cadmium
11. Mercury
12. Polychlorinated Biphenyl
13. Total Polycyclic Aromatic Hydrocarbons
14. Formaldehyde
15. Hydrogen Fluoride



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007647-01-0 HYDROGEN CHLORIDE

Item 33.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

HCl emissions from each flue shall not exceed the limit shown in this condition. Compliance shall be based on annual stack testing using 40 CFR 60, Appendix A, Method 26 or equivalent method acceptable to the Commissioner.

Parameter Monitored: HYDROGEN CHLORIDE

Upper Permit Limit: 10.3 pounds per hour

Reference Test Method: 40 CFR 60 App

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE



Condition 34: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement: 40CFR 52.21(j)(2), Subpart A

Item 34.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Process: MW3 Emission Source: 20MWC

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 20SDA

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2AXBR

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2SNCR

Regulated Contaminant(s):
CAS No: 007440-41-7 BERYLLIUM

Item 34.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Emissions from each flue shall not exceed the limit shown
in this condition. Compliance shall be based on stack
testing conducted once per term of the permit or at an
interval specified by NYSDEC, using 40 CFR 60, Appendix A,
Method 29.

Parameter Monitored: BERYLLIUM

Upper Permit Limit: 0.0002 pounds per hour

Reference Test Method: 40 CFR 60 App A RM29

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 35: Compliance Certification

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 52.21(j)(2), Subpart A

Item 35.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 000BH

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 00ACI

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 00MWC

Emission Unit: 1-MBMWC Emission Point: 00001

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW1 | Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 007664-93-9 | SULFURIC ACID |

Item 35.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW2 | Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 000630-08-0 | CARBON MONOXIDE |

Item 36.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Emissions from each flue shall not exceed the limit shown in this condition. Facility CEMS data is used for measuring compliance and is based on the average of three 1-hour runs. Compliance shall be based on stack testing at interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 10 or equivalent method acceptable to the Commissioner.

Manufacturer Name/Model Number: CEMS

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 15.9 pounds per hour

Reference Test Method: 40 CFR 60 App A RM10

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 37: Compliance Certification



Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 52.21(j)(2), Subpart A

Item 37.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 20SDA

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2AXBR

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2SNCR

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 37.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Emissions from each flue shall not exceed the limit shown
in this condition. Facility CEMS data is used for
measuring compliance and is based on the average of three
1- hour runs. Compliance shall be based on stack testing
at interval specified by NYSDEC, using 40 CFR 60, Appendix
A, Method 6C or equivalent method acceptable to the
Commissioner.

Manufacturer Name/Model Number: CEMS

Parameter Monitored: SULFUR DIOXIDE

Upper Permit Limit: 32.6 pounds per hour

Reference Test Method: 40 CFR 60 App A RM6C

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: AVERAGING METHOD - SEE MONITORING
DESCRIPTION

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 38: Compliance Certification

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 52.21(j)(2), Subpart A

Item 38.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 000BH

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 00ACI

Emission Unit: 1-MBMWC Emission Point: 00001

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW1 | Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Monitoring Description:

Operating requirement per PSD permit to maintain temperature of the flue gas at the exit of the acid gas control device at or below the temperature indicated in this condition, as determined by continuous monitoring based on the averaging method shown. Except for 12 periods per year per boiler for scrubber atomizer wheel maintenance, during which the averaging time will be on a running 24-hour basis.

Parameter Monitored: TEMPERATURE
Upper Permit Limit: 320 degrees Fahrenheit
Reference Test Method: NYSDEC Acceptable
Monitoring Frequency: CONTINUOUS
Averaging Method: 4-HOUR ROLLING AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 4/30/2018.
Subsequent reports are due every 3 calendar month(s).

Condition 39: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 52.21(j)(2), Subpart A

Item 39.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Table with 2 columns: Emission Unit/Process and Emission Point/Source. Rows include units like 1-MBMWC and processes like MW1, MW2 with various emission points and sources.

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 0NY075-00-5 PM-10

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Emissions of particulate less than 10 microns diameter (PM-10) from each furnace flue shall not exceed 0.010 gr/dscf corrected to 7% O2. Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 201 or Methods 201A and 202.

Parameter Monitored: PM-10

Upper Permit Limit: 0.010 grains per dry standard cubic foot (corrected to 7% O2)

Reference Test Method: EPA 201 or 201A & 202

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 40: Compliance Certification

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 52.21(j)(2), Subpart A

Item 40.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

| | |
|--|------------------------|
| Process: MW3 | Emission Source: 20ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 20MWC |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 20SDA |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 007664-39-3 | HYDROGEN FLUORIDE |

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Emissions from each flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 26A or equivalent method acceptable to the Commissioner.

Parameter Monitored: HYDROGEN FLUORIDE

Upper Permit Limit: 0.73 pounds per hour

Reference Test Method: 40 CFR 60 App A RM26A

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 41: Compliance Certification

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.33b(b)(3)(i), NSPS Subpart

Cb

Item 41.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

| | |
|--|------------------------|
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00MWC |
| Regulated Contaminant(s): CAS No: 007446-09-5 | SULFUR DIOXIDE |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Item 41.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Sulfur dioxide (SO₂) emissions from each flue shall not exceed 29 ppm dry volume corrected to 7% O₂, as determined by continuous monitoring, based on a 24-hour daily geometric mean. The permittee shall meet the less stringent of this limit or the 75 percent reduction (24-hour daily geometric mean) of SO₂. Compliance based on CEMs. CEMs shall be installed, maintained and operated in accordance with 40 CFR 60, Appendix B and Appendix F.

For CEMS block averages greater than 1-hour (such as 4-hour and 24-hour blocks), 75% of the 1-hour averages must be valid in order to have a valid block average. Block averages with less than 75% of valid 1-hour averages would be partial blocks that would not be used for compliance but would be reported in the quarterly excess emissions report along with the date, time period, and reason.

A partial block period could result during any block, other than the 1-hour period, that does not have solid waste continuously burning due to startup or shutdown or the unit being off line or the continuous emission monitoring being down (i.e., cylinder gas audit, etc.) for part of the block period. The exemption of data use under the Emission Guidelines (40 CFR 60.58b(a)(1)) may also create a partial block. Emission standards or permit limitations applicable to block periods are not applicable to the partial block periods. All partial block periods and the reason for the partial block period must be reported in the quarterly excess emissions report.

Manufacturer Name/Model Number: CEMS

Parameter Monitored: SULFUR DIOXIDE

Upper Permit Limit: 29 parts per million by volume (dry, corrected to 7% O₂)

Reference Test Method: 40 CFR 60 App B & F

Monitoring Frequency: CONTINUOUS

Averaging Method: 24 HOUR DAILY AVERAGE (GEOMETRIC MEAN)

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2018.

Subsequent reports are due every 3 calendar month(s).

Condition 42: Compliance Certification

Effective between the dates of 02/15/2018 and 02/14/2023



Applicable Federal Requirement: 40CFR 60.33b(b)(3)(i), NSPS Subpart

Cb

Item 42.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: 1-MBMW C Emission Point: 00001
Process: MW1 Emission Source: 00MWC

Regulated Contaminant(s):
CAS No: 007446-09-5 SULFUR DIOXIDE

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Sulfur dioxide (SO₂) emissions from each flue shall not exceed 25 percent by weight of the uncontrolled SO₂ emissions (75 percent reduction), as determined by continuous monitoring, based on a 24-hour daily geometric mean, corrected to 7% O₂. The permittee shall meet the less stringent of this limit or the SO₂ limit of 29 ppm_{dv} (24-hour daily geometric mean). Compliance based on CEMs. CEMs shall be installed, maintained and operated in accordance with 40 CFR 60, Appendix B and Appendix F.

For CEMS block averages greater than 1-hour (such as 4-hour and 24-hour blocks), 75% of the 1-hour averages must be valid in order to have a valid block average. Block averages with less than 75% of valid 1-hour averages would be partial blocks that would not be used for compliance but would be reported in the quarterly excess emissions report along with the date, time period, and reason.

A partial block period could result during any block, other than the 1-hour period, that does not have solid waste continuously burning due to startup or shutdown or the unit being off line or the continuous emission monitoring being down (i.e., cylinder gas audit, etc.) for part of the block period. The exemption of data use under the Emission Guidelines (40 CFR 60.58b(a)(1)) may also create a partial block. Emission standards or permit limitations applicable to block periods are not applicable to the partial block periods. All partial block periods and the reason for the partial block period must be reported in the quarterly excess emissions report.

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Manufacturer Name/Model Number: CEMS
Parameter Monitored: SULFUR DIOXIDE
Lower Permit Limit: 75 percent reduction by weight or
volume (corrected to 7% O₂, dry
basis)
Reference Test Method: 40 CFR 60 App B & F
Monitoring Frequency: CONTINUOUS
Averaging Method: 24 HOUR DAILY AVERAGE (GEOMETRIC MEAN)
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2018.
Subsequent reports are due every 6 calendar month(s).

Condition 43: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement: 40CFR 60.33b(d), NSPS Subpart Cb

Item 43.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 43.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Emissions from each flue shall not exceed the limit shown in this condition.

Compliance shall be based on CEMs. CEMs shall be installed, maintained and operated in accordance with 40 CFR 60, Appendices B and F.

For CEMS block averages greater than 1-hour (such as 4-hour and 24-hour blocks), 75% of the 1-hour averages must be valid in order to have a valid block average. Block averages with less than 75% of valid 1-hour averages would be partial blocks that would not be used for compliance but would be reported in the quarterly excess emissions report along with the date, time period, and reason.

A partial block period could result during any block, other than the 1-hour period, that does not have solid waste continuously burning due to startup or shutdown or the unit being off line or the continuous emission

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 000630-08-0 CARBON MONOXIDE

Item 44.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

Carbon monoxide emission limit for mass burn waterwall municipal waste combustor.

For CEMS block averages greater than 1-hour (such as 4-hour and 24-hour blocks), 75% of the 1-hour averages must be valid in order to have a valid block average. Block averages with less than 75% of valid 1-hour averages would be partial blocks that would not be used for compliance but would be reported in the quarterly excess emissions report along with the date, time period, and reason.

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW1 | Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 45.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Discharge to the atmosphere of visible emissions of combustion ash from the ash conveying system (including conveyor transfer points) may not exceed 5 percent of the observation period (i.e. 9 minutes per 3-hour period), as determined by EPA Reference Method 22 observations. This emission limit does not cover visible emissions discharged inside buildings or enclosures of ash conveying systems; however, it does cover visible emissions discharged to the



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 46.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The permittee shall comply with the reporting and recordkeeping requirements listed in 60.59b, as applicable, excluding the siting requirements under 60.59b(a), (b) and (d)(11).

For affected facilities that apply activated carbon for mercury or dioxin/furan control, the owner or operator shall comply with the records specified in 40CFR60.59b(d)(4)(i) through (d)(4)(v) of the same section. These include, but not limited to, estimate of an average feed rate based on carbon injection system operating parameters such as the screw feeder speed, hopper volume, hopper refill frequency, or other parameters appropriate to the feed system being employed, as specified in 40CFR60.58b(m)(1)(i) and (m)(1)(ii) of the same section.

The owner or operator shall estimate the total carbon usage of the plant (kilograms or pounds) for each calendar quarter by two independent methods, according to the procedures in paragraphs 40CFR60.58b(m)(3)(i) and (m)(3)(ii) of the same section.



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 47.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Contingency Plans dated July 30, 2001 to demonstrate the back up capability of the facility's carbon injection system.

The two contingency plans are i) Volumetric Carbon flow Mode for the failure of the scale or associated controls (Plan "A") and ii) Split Carbon Flow Mode for the total



feed/scale systems failure (Plan "B"). These Plans must be implemented to demonstrate continuous compliance/monitoring of activated carbon feed rate as a parametric monitoring of mercury and dioxin/furan emissions, provided the following conditions are met:

1. A 24-hour written notification is made to the Department upon execution of any one of these plans.
2. Under Contingency Plan "A", the manual set-point of the feeder speed shall be at least 15%.
3. Under Contingency Plan "B", the carbon feed rate must be set to a minimum of two and one half (2.5) times the normal (i.e., stack tested) injection set-point.
4. The operating and recordkeeping procedures (e.g., hourly feeder set-point, output to feeder and refilling of the feeder hopper etc.) for both plans as depicted in the Section 7.4 of the Facility's Environmental Compliance Operating Manual (Response to Low Carbon Flow Excursion) shall be strictly adhered to and made available for Department review upon request.
5. Department reserves the right to exercise its own discretion to nullify the contingency plans and seek a permanent fixes of the feeder scale assembly, in case of prolong or excessive use of the plans.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 48: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.39b(a), NSPS Subpart Cb

Item 48.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

| | |
|------------------------|------------------------|
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 000BH |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00MWC |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 48.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The Permittee shall comply with the reporting and recordkeeping requirements listed in §60.59b of Subpart

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Eb, as applicable, excluding the siting requirements under §60.59b(a), (b)(5), and (d)(11).

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 49: Compliance Certification Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40 CFR Part 64

Item 49.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Emission Source/Control: 00SDA - Control
Control Type: DRY SPRAY ABSORPTION

Emission Source/Control: 0SNCR - Control
Control Type: SELECTIVE NON-CATALYTIC REDUCTION
(SNCR)

Emission Source/Control: 100BH - Control
Control Type: FABRIC FILTER

Emission Source/Control: 10ACI - Control
Control Type: ACTIVATED CARBON INJECTION

Emission Source/Control: 10SDA - Control
Control Type: DRY SPRAY ABSORPTION

Emission Source/Control: 00MWC - Incinerator
Design Capacity: 250 tons per day
Waste Feed Method: CHUTE FED
Waste Type: MUNICIPAL SOLID WASTE AND/OR SOLID
WASTE

Emission Source/Control: 10MWC - Incinerator
Design Capacity: 250 tons per day
Waste Feed Method: CHUTE FED
Waste Type: MUNICIPAL SOLID WASTE AND/OR SOLID
WASTE

Item 51.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-MBMWC

Process: MW2

Source Classification Code: 5-01-001-04

Process Description:

The base operating scenario for the Huntington Resource Recovery Facility (HRRF) includes the combustion of solid waste in a nominally sized 250 tons per day (tpd) unit as allowed in HRRF's solid waste permit contained in the facility's Certificate to Operate and as otherwise approved by NYSDEC. The facility is authorized to receive municipal solid waste which includes residential, commercial and government and/or institutional waste and other non-hazardous industrial waste streams as approved by NYSDEC on a case by case basis. The authorized non-hazardous wastes are hereby termed as "MSW". For startup, shutdown and malfunction relief, HRRF will follow the procedures outlined in the 40 CFR 60.58b(a) and can seek relief for additional regulated parameters from NYSDEC on a case by case basis pursuant to 6 NYCRR Part 201-1.4. In addition, the emergency defense provision of 6 NYCRR Part 201-1.5 also applies to HRRF. Replaces process MSW.

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Emission Source/Control: 1AXBR - Combustion

Emission Source/Control: 100BH - Control
Control Type: FABRIC FILTER

Emission Source/Control: 10ACI - Control
Control Type: ACTIVATED CARBON INJECTION

Emission Source/Control: 10SDA - Control
Control Type: DRY SPRAY ABSORPTION

Emission Source/Control: 1SNCR - Control
Control Type: SELECTIVE NON-CATALYTIC REDUCTION
(SNCR)

Emission Source/Control: 10MWC - Incinerator
Design Capacity: 250 tons per day
Waste Feed Method: CHUTE FED
Waste Type: MUNICIPAL SOLID WASTE AND/OR SOLID
WASTE

Item 51.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-MBMWC

Process: MW3

Source Classification Code: 5-01-001-04

Process Description:

The base operating scenario for the Huntington Resource Recovery Facility (HRRF) includes the combustion of solid waste in a nominally sized 250 tons per day (tpd) unit as allowed in HRRF's solid waste permit contained in the facility's Certificate to Operate and as otherwise approved by NYSDEC. The facility is authorized to receive municipal solid waste which includes residential, commercial and government and/or institutional waste and other non-hazardous industrial waste streams as approved by NYSDEC on a case by case basis. The authorized non-hazardous wastes are hereby termed as "MSW". For startup, shutdown and malfunction relief, HRRF will follow the procedures outlined in the 40 CFR 60.58b(a) and can seek relief for additional regulated parameters from NYSDEC on a case by case basis pursuant to 6 NYCRR Part 201-1.4. In addition, the emergency defense provision of 6 NYCRR Part 201-1.5 also applies to HRRF. Replaces process MSW.

Emission Source/Control: 2AXBR - Combustion

Emission Source/Control: 200BH - Control
Control Type: FABRIC FILTER

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Emission Source/Control: 20ACI - Control
Control Type: ACTIVATED CARBON INJECTION

Emission Source/Control: 20SDA - Control
Control Type: DRY SPRAY ABSORPTION

Emission Source/Control: 2SNCR - Control
Control Type: SELECTIVE NON-CATALYTIC REDUCTION
(SNCR)

Emission Source/Control: 20MWC - Incinerator
Design Capacity: 250 tons per day
Waste Feed Method: CHUTE FED
Waste Type: MUNICIPAL SOLID WASTE AND/OR SOLID
WASTE

Item 51.4:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-MBMWC
Process: ST1 Source Classification Code: 5-01-900-06
Process Description:

Municipal waste combustor is capable of firing propane during startup/shutdown and malfunction conditions, in addition to transitioning to/from MSW firing or to maintain combustion temperature. Propane gas is used during startup to warm the unit up before introducing refuse into the furnace and during the transition period before the fires are fully sustained by the refuse. Propane gas is used as an auxiliary fuel during shutdown until refuse is burned off the grates. Auxiliary fuel is also used during periods of upset and to maintain proper combustion. For startup, shutdown and malfunction relief, HRRF will follow the procedures outlined in the 40 CFR 60.58b(a) and can seek relief for additional regulated parameters from NYSDEC on a case by case basis pursuant to 6 NYCRR Part 201-1.4. In addition, the emergency defense provision of 6 NYCRR Part 201-1.5 also applies to HRRF. The following descriptions/definitions will be utilized to identify the MWC operating modes. Replaces process STS.

Emission Source/Control: AXBRN - Combustion

Emission Source/Control: 000BH - Control
Control Type: FABRIC FILTER

Emission Source/Control: 00ACI - Control
Control Type: ACTIVATED CARBON INJECTION

Emission Source/Control: 00SDA - Control
Control Type: DRY SPRAY ABSORPTION

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Emission Source/Control: 0SNCR - Control
Control Type: SELECTIVE NON-CATALYTIC REDUCTION
(SNCR)

Emission Source/Control: 00MWC - Incinerator
Design Capacity: 250 tons per day
Waste Feed Method: CHUTE FED
Waste Type: MUNICIPAL SOLID WASTE AND/OR SOLID
WASTE

Item 51.5:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-MBMWC
Process: ST2 Source Classification Code: 5-01-900-06
Process Description:

Municipal waste combustor is capable of firing propane during startup/shutdown and malfunction conditions, in addition to transitioning to/from MSW firing or to maintain combustion temperature. Propane gas is used during startup to warm the unit up before introducing refuse into the furnace and during the transition period before the fires are fully sustained by the refuse. Propane gas is used as an auxiliary fuel during shutdown until refuse is burned off the grates. Auxiliary fuel is also used during periods of upset and to maintain proper combustion. For startup, shutdown and malfunction relief, HRRF will follow the procedures outlined in the 40 CFR 60.58b(a) and can seek relief for additional regulated parameters from NYSDEC on a case by case basis pursuant to 6 NYCRR Part 201-1.4. In addition, the emergency defense provision of 6 NYCRR Part 201-1.5 also applies to HRRF. The following descriptions/definitions will be utilized to identify the MWC operating modes. Replaces process STS.

Emission Source/Control: 1AXBR - Combustion

Emission Source/Control: 100BH - Control
Control Type: FABRIC FILTER

Emission Source/Control: 10ACI - Control
Control Type: ACTIVATED CARBON INJECTION

Emission Source/Control: 10SDA - Control
Control Type: DRY SPRAY ABSORPTION

Emission Source/Control: 1SNCR - Control
Control Type: SELECTIVE NON-CATALYTIC REDUCTION
(SNCR)

Emission Source/Control: 10MWC - Incinerator
Design Capacity: 250 tons per day

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Waste Feed Method: CHUTE FED
Waste Type: MUNICIPAL SOLID WASTE AND/OR SOLID
WASTE

Item 51.6:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: 1-MBMWC
Process: ST3 Source Classification Code: 5-01-900-06

Process Description:

Municipal waste combustor is capable of firing propane during startup/shutdown and malfunction conditions, in addition to transitioning to/from MSW firing or to maintain combustion temperature. Propane gas is used during startup to warm the unit up before introducing refuse into the furnace and during the transition period before the fires are fully sustained by the refuse. Propane gas is used as an auxiliary fuel during shutdown until refuse is burned off the grates. Auxiliary fuel is also used during periods of upset and to maintain proper combustion. For startup, shutdown and malfunction relief, HRRF will follow the procedures outlined in the 40 CFR 60.58b(a) and can seek relief for additional regulated parameters from NYSDEC on a case by case basis pursuant to 6 NYCRR Part 201-1.4. In addition, the emergency defense provision of 6 NYCRR Part 201-1.5 also applies to HRRF. The following descriptions/definitions will be utilized to identify the MWC operating modes. Replaces process STS.

Emission Source/Control: 2AXBR - Combustion

Emission Source/Control: 200BH - Control
Control Type: FABRIC FILTER

Emission Source/Control: 20ACI - Control
Control Type: ACTIVATED CARBON INJECTION

Emission Source/Control: 20SDA - Control
Control Type: DRY SPRAY ABSORPTION

Emission Source/Control: 2SNCR - Control
Control Type: SELECTIVE NON-CATALYTIC REDUCTION
(SNCR)

Emission Source/Control: 20MWC - Incinerator
Design Capacity: 250 tons per day
Waste Feed Method: CHUTE FED
Waste Type: MUNICIPAL SOLID WASTE AND/OR SOLID
WASTE

Condition 52: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023



Applicable Federal Requirement: 40CFR 60.33b(a)(1)(i), NSPS Subpart

Cb

Item 52.1:

The Compliance Certification activity will be performed for the facility:
 The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Emission Unit: 1-MBMWC
Process: MW3

Emission Point: 00003
Emission Source: 20SDA

Emission Unit: 1-MBMWC
Process: MW3

Emission Point: 00003
Emission Source: 2AXBR

Emission Unit: 1-MBMWC
Process: MW3

Emission Point: 00003
Emission Source: 2SNCR

Regulated Contaminant(s):
CAS No: 0NY075-00-0 PARTICULATES

Item 52.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Each affected MWC unit is required to meet an emission limit for particulate matter not to exceed 25 milligrams per dry standard cubic meter, corrected to 7 percent oxygen. Compliance will be determined by conducting a stack emission test according to a protocol and schedule approved by the Department. Reporting shall be done in accordance with 40 CFR 60.39b, as applicable. Stack emissions tests will be required on annual basis unless otherwise directed by the Department.

Upper Permit Limit: 25 milligrams per dry standard cubic meter (corrected to 7% oxygen)

Monitoring Frequency: ANNUALLY

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 53: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.33b(a)(1)(iii), NSPS Subpart

Cb

Item 53.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: 1-MBMWC
Process: MW1

Emission Point: 00001
Emission Source: 000BH

Emission Unit: 1-MBMWC
Process: MW1

Emission Point: 00001
Emission Source: 00ACI

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 53.2:
Compliance Certification shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



meter (corrected to 7% oxygen)
Reference Test Method: EPA Ref Test Method
Monitoring Frequency: ANNUALLY
Averaging Method: ARITHMETIC MEAN
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2018.
Subsequent reports are due every 6 calendar month(s).

Condition 55: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.33b(a)(4), NSPS Subpart Cb

Item 55.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC | Emission Point: 00002 |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|------------------------|------------------------|
| Process: MW2 | Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 200BH |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 20ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 20MWC |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 20SDA |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007439-92-1 LEAD

Item 55.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Each affected MWC unit is required to meet an emission limit for lead not to exceed 400 micrograms per dry standard cubic meter, corrected to 7 percent oxygen. Compliance will be determined by conducting a stack emission test according to a protocol and schedule approved by the Department. Reporting shall be done in accordance with 40 CFR 60.39b, as applicable. Stack emissions tests will be required on annual basis unless otherwise directed by the Department.

Upper Permit Limit: 400 micrograms per dry standard cubic meter (corrected to 7% oxygen)

Monitoring Frequency: ANNUALLY

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 56: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.33b(b)(3)(ii), NSPS Subpart

Cb

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Item 56.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2AXBR

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2SNCR

Regulated Contaminant(s):
CAS No: 007647-01-0 HYDROGEN CHLORIDE

Item 56.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Each affected MWC unit is required to meet the less stringent of either of the following: an emission limit for hydrogen chloride not to exceed 29 part per million by volume, corrected to 7 percent oxygen (dry basis) or, an 95 percent reduction by weight or volume of the potential hydrogen chloride emission concentration. Compliance with the emission concentration limit will be determined by conducting a stack emission test according to a protocol and schedule approved by the Department. Reporting shall be done in accordance with 40 CFR 60.39b, as applicable. Stack emissions tests will be required on annual basis unless otherwise directed by the Department.

Upper Permit Limit: 29 parts per million by volume (dry, corrected to 7% O2)

Monitoring Frequency: ANNUALLY

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 57: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.33b(b)(3)(ii), NSPS Subpart

Cb

Item 57.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 000BH

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 00ACI

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007647-01-0 HYDROGEN CHLORIDE



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Item 57.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Each affected MWC unit is required to meet the less stringent of either of the following: an emission limit for hydrogen chloride not to exceed 29 part per million by volume, corrected to 7 percent oxygen (dry basis) or, an 95 percent reduction by weight or volume of the potential hydrogen chloride emission concentration. Compliance with the latter (percent reduction) limit will be determined by conducting a stack emission test according to a protocol and schedule approved by the Department. Reporting shall be done in accordance with 40 CFR 60.39b, as applicable. Stack emissions tests will be required on annual basis unless otherwise directed by the Department.

Lower Permit Limit: 95 percent reduction by weight or volume (corrected to 7% O2, dry basis)

Monitoring Frequency: ANNUALLY

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 58: Compliance Certification

Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.33b(c)(1)(iii), NSPS Subpart

Cb

Item 58.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 001746-01-6 | 2,3,7,8-TETRACHLORODIBENZO-P-DIOXIN |

Item 58.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Each affected MWC unit which does not employ an electrostatic precipitator for emission controls is required to meet an emission concentration limit for dioxin/furan not to exceed 30 nanograms per dry standard



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

| | |
|--|---|
| Process: MW2 | Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 59.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

An affected municipal waste combustor unit may not be operated at a steam load level exceeding 110 percent of the maximum demonstrated municipal waste combustor unit load (highest 4-hour block arithmetic average unit steam load, measured in pounds per hour) reached during the most recent performance test where compliance with the dioxin/furan emission limit was demonstrated) except as follows:

(1) During the annual dioxin/furan or mercury performance test and the 2 weeks preceding the annual dioxin/furan or mercury performance test, no municipal waste combustor unit load limit is applicable.

(2) The municipal waste combustor unit load limit may be waived in writing by the Department for the purpose of evaluating system performance, testing new technology or

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



control technologies, diagnostic testing, or related activities for the purpose of improving municipal waste combustor performance or advancing the state-of-the-art for controlling municipal waste combustor emissions. The municipal waste combustor unit load limit continues to apply, and remains enforceable, until and unless the Department grants the waiver.

Parameter Monitored: STEAM OUTPUT
Upper Permit Limit: 110 percent
Monitoring Frequency: CONTINUOUS
Averaging Method: 4-HOUR BLOCK (ARITHMETIC AVERAGE)
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 7/30/2018.
Subsequent reports are due every 6 calendar month(s).

Condition 60: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.34b(b), NSPS Subpart Cb

Item 60.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 60.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Each affected MWC unit will be required to operate at a temperature not to exceed 17 degrees Centigrade above the maximum demonstrated particulate matter control device temperature, as measured at the particulate matter control device inlet, during four consecutive hours (4-hour block arithmetic average) determined at the most recent dioxin/furan performance test demonstrating compliance with the applicable dioxin/furan limit, except as follows:

(1) During the annual dioxin/furan or mercury performance test and the 2 weeks preceding the annual dioxin/furan or mercury performance test, no particulate matter control device temperature limitations are applicable.

(2) The particulate matter control device temperature limits may be waived in writing by the Department for the purpose of evaluating system performance, testing new

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



technology or control technologies, diagnostic testing, or related activities for the purpose of improving municipal waste combustor performance or advancing the state-of-the-art for controlling municipal waste combustor emissions. The temperature limits continue to apply, and remain enforceable, until and unless the Department grants the waiver.

Parameter Monitored: TEMPERATURE ABOVE CONTROL DEVICE TEMPERATURE

Upper Permit Limit: 17 degrees Centigrade (or Celsius)

Monitoring Frequency: CONTINUOUS

Averaging Method: 4-HOUR BLOCK (ARITHMETIC AVERAGE)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2018.

Subsequent reports are due every 6 calendar month(s).

Condition 61: Operating Manual
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement: 40CFR 60.35b, NSPS Subpart Cb

Item 61.1:

This Condition applies to Emission Unit: 1-MBMWC Emission Point: 00001

Process: MW1

Emission

Source: 00MWC

Item 61.2:

The Permittee must develop and update on a yearly basis a site-specific operating manual that must, at a minimum, address the elements of municipal waste combustor unit operation specified below. This manual must be found acceptable by the Department.

- (1) A summary of the applicable standards under 40 CFR 60, Subpart Cb;
- (2) A description of basic combustion theory applicable to a municipal waste combustor;
- (3) Procedures for receiving, handling, and feeding municipal solid waste;
- (4) Municipal waste combustor unit startup, shutdown, and malfunction procedures;
- (5) Procedures for maintaining proper combustion air supply levels;
- (6) Procedures for operating the municipal waste combustor unit within the standards established under 40 CFR 60, Subpart Cb;
- (7) Procedures for responding to periodic upset or off-specification conditions;
- (8) Procedures for minimizing particulate matter carryover;
- (9) Procedures for handling ash;
- (10) Procedures for monitoring municipal waste combustor unit emissions; and
- (11) Reporting and recording keeping procedures.

A training program shall be established to review the operating manual according to the

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



schedule below, with each person who has responsibilities affecting the operation of a municipal waste combustor including, but not limited to, chief facility operators, shift supervisors, control room operators, ash handlers, maintenance personnel, and crane/load handlers. Training shall be completed as follows:

(1) Initial training shall be completed by the date prior to the day when the person assumes responsibilities affecting municipal waste combustor unit operation, and

(2) Annually, following the initial training.

The operating manual must be kept in a readily accessible location for all persons required to undergo training. The operating manual and records of training must be available for inspection by the Department upon request.

Condition 62: Operator Training
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.35b, NSPS Subpart Cb

Item 62.1:

This Condition applies to Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission
Source: 00MWC

Item 62.2:

All chief facility operators, shift supervisors, and control room operators must complete a municipal waste combustor operator training course which is acceptable to the Department prior to the date they assume responsibilities that affect operation of the municipal waste combustor unit. This requirement does not apply to chief facility operators, shift supervisors, and control room operators who have obtained full certification from the American Society of Mechanical Engineers on or before October 5, 1998. The owner or operator may request that the Department waive the requirements of this condition for chief facility operators, shift supervisors, and control room operators who have obtained only provisional certification from the American Society of Mechanical Engineers on or before October 5, 1998.

Condition 63: Compliance Certification
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.35b, NSPS Subpart Cb

Item 63.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 000BH

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 63.2:



Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

If both the certified chief facility operator and certified shift supervisor are unavailable, a provisionally certified control room operator on site at the municipal waste combustion unit may fulfill the certified operator requirement. Depending on the length of time that a certified chief facility operator and certified shift supervisor are away, the owner or operator of the affected facility must meet one of three criteria:

(1) When the certified chief facility operator and certified shift supervisor are both off site for 12 hours or less, and no other certified operator is on site, the provisionally certified control room operator may perform the duties of the certified chief facility operator or certified shift supervisor.

(2) When the certified chief facility operator and certified shift supervisor are off site for more than 12 hours, but for two weeks or less, and no other certified operator is on site, the provisionally certified control room operator may perform the duties of the certified chief facility operator or certified shift supervisor without notice to, or approval by, the Department. However, the owner or operator of the affected facility must record the period when the certified chief facility operator and certified shift supervisor are off site and include that information in the annual report as specified under §60.59b(g)(5).

(3) When the certified chief facility operator and certified shift supervisor are off site for more than two weeks, and no other certified operator is on site, the provisionally certified control room operator may perform the duties of the certified chief facility operator or certified shift supervisor without approval by the Department. However, the owner or operator of the affected facility must take two actions:

(a) Notify the Department in writing. In the notice, state what caused the absence and what actions are being taken by the owner or operator of the facility to ensure that a certified chief facility operator or certified shift supervisor is on site as expeditiously as practicable.

(b) Submit a status report and corrective action summary to the Department every four weeks following the initial

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



notification. If the Department provides notice that the status report or corrective action summary is disapproved, the municipal waste combustion unit may continue operation for 90 days, but then must cease operation. If corrective actions are taken in the 90-day period such that the Department withdraws the disapproval, municipal waste combustion unit operation may continue.

promoted A provisionally certified operator who is newly

or recently transferred to a shift supervisor position or a chief facility operator position at the municipal waste combustion unit may perform the duties of the certified chief facility operator or certified shift supervisor without notice to, or approval by, the Department for up to six months before taking the ASME QRO certification exam.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 64: Compliance and performance testing. Effective between the dates of 02/15/2018 and 02/14/2023

Applicable Federal Requirement:40CFR 60.38b, NSPS Subpart Cb

Item 64.1:

This Condition applies to Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission
Source: 00MWC

Item 64.2:

The Permittee shall meet the compliance and performance testing requirements listed in 40 CFR 60.58b as amended on May 10, 2006, as applicable, to determine compliance with the limits specified in this permit.

Item 64.3:

If the MWC achieves a dioxin/furan emission level less than or equal to 15 nanograms per dry standard cubic meter total mass, corrected to 7 percent oxygen, the alternative performance testing schedule for dioxins/furans specified in 40 CFR 60.58b(g)(5)(iii) may be used.



STATE ONLY ENFORCEABLE CONDITIONS
****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS
This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;

(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and



standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 65: Contaminant List
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:ECL 19-0301

Item 65.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000050-00-0
Name: FORMALDEHYDE

CAS No: 000630-08-0
Name: CARBON MONOXIDE

CAS No: 001336-36-3
Name: POLYCHLORINATED BIPHENYL

CAS No: 001746-01-6
Name: 2,3,7,8-TETRACHLORODIBENZO-P-DIOXIN

CAS No: 007439-92-1
Name: LEAD

CAS No: 007439-96-5
Name: MANGANESE

CAS No: 007439-97-6
Name: MERCURY

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



CAS No: 007440-02-0
Name: NICKEL METAL AND INSOLUBLE COMPOUNDS

CAS No: 007440-38-2
Name: ARSENIC

CAS No: 007440-41-7
Name: BERYLLIUM

CAS No: 007440-43-9
Name: CADMIUM

CAS No: 007440-47-3
Name: CHROMIUM

CAS No: 007440-62-2
Name: VANADIUM

CAS No: 007440-66-6
Name: ZINC

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007647-01-0
Name: HYDROGEN CHLORIDE

CAS No: 007664-39-3
Name: HYDROGEN FLUORIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 007664-93-9
Name: SULFURIC ACID

CAS No: 0NY075-00-0
Name: PARTICULATES

CAS No: 0NY075-00-5
Name: PM-10

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

CAS No: 0NY998-00-0
Name: VOC

CAS No: 130498-29-2
Name: POLYCYCLIC AROMATIC HYDROCARBONS

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Condition 66: Malfunctions and start-up/shutdown activities
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 201-1.4

Item 66.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 67: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 67.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Process: MW3

Emission Source: 2SNCR

Regulated Contaminant(s):

CAS No: 007664-41-7 AMMONIA

Item 67.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using USEPA draft method for the subject pollutant or equivalent method acceptable to the Commissioner.

Parameter Monitored: AMMONIA

Upper Permit Limit: 50 parts per million by volume (dry, corrected to 7% O2)

Reference Test Method: EPA Ref Test Method

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 68: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 68.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

| | |
|------------------------|------------------------|
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 000BH |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00MWC |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00SDA |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: AXBRN |
| Emission Unit: 1-MBMWC | Emission Point: 00002 |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW2 | Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Item 68.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Record keeping / Reporting requirements

Emissions in excess of the limits or not in accordance with the requirements set forth in this permit shall be reported by telephone or electronic mail to the NYSDEC Regional Air Pollution Control Engineer or his designee as soon as possible during normal working hours, but in any event within two business days of becoming aware of such occurrence, followed by written confirmation, along with a program for immediate correction.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 69: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 69.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

Table with 2 columns: Emission Unit/Process and Emission Point/Source. Rows include units like 1-MBMWC and processes like MW1, MW2, MW3 with various emission points and sources.



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

| | |
|--|--------------------------|
| Process: MW3 | Emission Source: 20ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 20MWC |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 20SDA |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |
| Process: MW3 | Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 001336-36-3 | POLYCHLORINATED BIPHENYL |

Item 69.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emissions of polychlorinated biphenyl from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing at interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 23 or any equivalent acceptable to the Commissioner.

Parameter Monitored: POLYCHLORINATED BIPHENYL

Upper Permit Limit: 3.88E+03 nanograms per dry standard cubic meter (corrected to 7% O2)

Reference Test Method: 40 CFR 60 App A RM23

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 70: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 70.1:

The Compliance Demonstration activity will be performed for the facility:

The Compliance Demonstration applies to:

| | |
|------------------------|------------------------|
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 000BH |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00ACI |

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007440-38-2 ARSENIC

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007440-02-0 NICKEL METAL AND INSOLUBLE
COMPOUNDS

Item 71.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emissions of nickel from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 29.

Parameter Monitored: NICKEL METAL AND INSOLUBLE COMPOUNDS

Upper Permit Limit: 8.2E-04 pounds per hour

Reference Test Method: 40 CFR 60 App A RM29

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE



Condition 72: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 72.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 000050-00-0 FORMALDEHYDE

Item 73.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Monitoring Description:

The emissions of formaldehyde from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using 40 CFR 266, Appendix IX, Method 0011 or equivalent method acceptable to the Commissioner.

Parameter Monitored: FORMALDEHYDE

Upper Permit Limit: 1.03E+05 nanograms per dry standard cubic meter (corrected to 7% O2)

Reference Test Method: Method 0011

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 74: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 74.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 130498-29-2 POLYCYCLIC AROMATIC HYDROCARBONS

Item 74.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emissions of polycyclic aromatic hydrocarbons (PAH) including benzo [a] pyrene) from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing at interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 23 or any equivalent acceptable to the Commissioner.

Parameter Monitored: POLYCYCLIC AROMATIC HYDROCARBONS

Upper Permit Limit: 8.77E+03 nanograms per dry standard
cubic meter (corrected to 7% O2)

Reference Test Method: 40 CFR 60 App A RM23

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE



Condition 75: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement: 6 NYCRR 617.11 (d)

Item 75.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00003 |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Process: MW3 Emission Source: 20MWC

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 20SDA

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2AXBR

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2SNCR

Regulated Contaminant(s):
CAS No: 007440-66-6 ZINC

Item 75.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emissions of zinc from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 29.

Parameter Monitored: ZINC

Upper Permit Limit: 8.6E-02 pounds per hour

Reference Test Method: 40 CFR 60 App A RM29

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 76: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 76.1:

The Compliance Demonstration activity will be performed for the facility:

The Compliance Demonstration applies to:

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 000BH

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 00ACI

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 00MWC

Emission Unit: 1-MBMWC Emission Point: 00001

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW1 | Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 007440-47-3 | CHROMIUM |

Item 76.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



The emissions of chromium from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 29.

Parameter Monitored: CHROMIUM

Upper Permit Limit: 1.2E-03 pounds per hour

Reference Test Method: 40 Cfr 60 App A RM29

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 77: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 77.1:

The Compliance Demonstration activity will be performed for the facility:

The Compliance Demonstration applies to:

Table with 2 columns: Emission Unit/Process and Emission Point/Source. Rows include units like 1-MBMWC and processes like MW1, MW2 with various emission points and sources.

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007440-62-2 VANADIUM

Item 77.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emissions of vanadium from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing conducted once per term of the permit or at an interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 29.

Parameter Monitored: VANADIUM
Upper Permit Limit: 2.0E-04 pounds per hour
Reference Test Method: 40 CFR 60 App A RM29
Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION
Averaging Method: ARITHMETIC MEAN
Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 78: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Item 78.1:

The Compliance Demonstration activity will be performed for the facility:

The Compliance Demonstration applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |



New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2AXBR

Emission Unit: 1-MBMWC Emission Point: 00003
Process: MW3 Emission Source: 2SNCR

Regulated Contaminant(s):
CAS No: 001746-01-6 2,3,7,8-TETRACHLORODIBENZO-P-DIOXIN

Item 78.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emissions of total polychlorinated dibenzo-p-dioxins and polychlorinated dibenzo furans (tetra-octa homologue groups as well as associated 2,3,7,8 substituted congeners) expressed as 2,3,7,8 tetrachlorinated dibenzo-para-dioxin equivalent using "toxic equivalency factors" (TEQ) listed in 6 NYCRR Part 219-1.1(b)(2), from each furnace flue shall not exceed the limit shown in this condition. Compliance shall be based on stack testing at interval specified by NYSDEC, using method 0010 and 40 CFR 60, Appendix A, Method 23 or equivalent method acceptable to the Commissioner. The minimum sample time shall be 4 hours per test.

Parameter Monitored: 2,3,7,8-TETRACHLORODIBENZO-P-DIOXIN

Upper Permit Limit: 0.61 nanograms per dry standard cubic meter (corrected to 7% O2)

Reference Test Method: 40 CFR 60 App A RM23

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 79: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 617.11 (d)

Item 79.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 000BH

Emission Unit: 1-MBMWC Emission Point: 00001
Process: MW1 Emission Source: 00ACI

Emission Unit: 1-MBMWC Emission Point: 00001

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW1 | Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |
| Regulated Contaminant(s): CAS No: 007440-43-9 | CADMIUM |

Item 79.2:

Compliance Demonstration shall include the following monitoring:

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The emissions of cadmium from each furnace flue shall not exceed the limit shown in this condition. The permittee shall also comply with the requirements of 40 CFR 60, Subpart Cb.

Compliance shall be based on stack testing at interval specified by NYSDEC, using 40 CFR 60, Appendix A, Method 29.

Parameter Monitored: CADMIUM

Upper Permit Limit: 1.5E-03 pounds per hour

Reference Test Method: 40 CFR 60 App A RM29

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

DESCRIPTION

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

****** Emission Unit Level ******

Condition 80: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 219-7.2

Item 80.1:

The Compliance Demonstration activity will be performed for the facility:
The Compliance Demonstration applies to:

| | |
|------------------------|------------------------|
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 000BH |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00ACI |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00MWC |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 00SDA |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC | Emission Point: 00001 |
| Process: MW1 | Emission Source: AXBRN |
| Emission Unit: 1-MBMWC | Emission Point: 00002 |

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



| | |
|--|---|
| Process: MW2 | Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007439-97-6 MERCURY

Item 80.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Mercury emission limit. The Permittee shall meet the less stringent of this limit (concentration), or the 85 percent reduction by weight Mercury emission limit cited in this permit under 6 NYCRR 219-7.2. Annual stack testing for Mercury shall follow the procedures contained in 40 CFR 60.58b(d)(2). Emission control devices must be kept in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



specifications, required to operate such devices effectively.

Parameter Monitored: MERCURY

Upper Permit Limit: 28 micrograms per dry standard cubic meter (corrected to 7% oxygen)

Reference Test Method: EPA Ref. Method 29

Monitoring Frequency: ANNUALLY

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2019.

Subsequent reports are due every 12 calendar month(s).

Condition 81: Compliance Demonstration
Effective between the dates of 02/15/2018 and 02/14/2023

Applicable State Requirement:6 NYCRR 219-7.2

Item 81.1:

The Compliance Demonstration activity will be performed for the facility:

The Compliance Demonstration applies to:

| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 000BH |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00ACI |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00MWC |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 00SDA |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: 0SNCR |
| Emission Unit: 1-MBMWC Process: MW1 | Emission Point: 00001 Emission Source: AXBRN |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 100BH |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10ACI |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10MWC |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 10SDA |

New York State Department of Environmental Conservation

Permit ID: 1-4726-00790/00004

Facility DEC ID: 1472600790



| | |
|--|---|
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1AXBR |
| Emission Unit: 1-MBMWC Process: MW2 | Emission Point: 00002 Emission Source: 1SNCR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 200BH |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20ACI |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20MWC |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 20SDA |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2AXBR |
| Emission Unit: 1-MBMWC Process: MW3 | Emission Point: 00003 Emission Source: 2SNCR |

Regulated Contaminant(s):
CAS No: 007439-97-6 MERCURY

Item 81.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Mercury emission limit. The Permittee shall meet the less stringent of this limit (percent reduction), or the concentration Mercury emission limit cited in this permit under 6 NYCRR 219-7.2. Annual stack testing for Mercury shall follow the procedures contained in 40 CFR 60.58b(d)(2). Emission control devices must be kept in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such devices effectively.

Parameter Monitored: MERCURY

Lower Permit Limit: 85 percent reduction by weight
(corrected to 7% O₂, dry basis)

Reference Test Method: EPA Ref. Method 29

Monitoring Frequency: ANNUALLY

Averaging Method: ARITHMETIC MEAN

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

New York State Department of Environmental Conservation
Permit ID: 1-4726-00790/00004 Facility DEC ID: 1472600790



The initial report is due 1/30/2019.
Subsequent reports are due every 12 calendar month(s).