

Facility DEC ID: 1472803244

**PERMIT
Under the Environmental Conservation Law (ECL)**

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
 Permit ID: 1-4728-03244/00005
 Effective Date: 10/14/2020 Expiration Date: 10/13/2025

Permit Type: Title IV (Phase II Acid Rain)
 Permit ID: 1-4728-03244/00007
 Effective Date: 10/14/2020 Expiration Date: 10/13/2025

Permit Issued To:EDGEWOOD ENERGY LLC
 1900 E GOLF RD STE 1030
 SCHAUMBURG, IL 60173

Contact: JASON WHITE
 J POWER USA
 1900 E GOLF RD STE 100
 SCHAUMBURG, IL 60173
 (847) 908-2876

Facility: EDGEWOOD ENERGY LLC
 21 SAGTIKOS PKWY|SCTM 500-71-1-1.11
 BRENTWOOD, NY 11717

Contact: KENNETH FORD
 EDGEWOOD ENERGY LLC
 380 PATTON AVE
 WEST BABYLON, NY 11704
 (631) 643-1560

Description:
 This is a renewal of a Title V and Title IV permit for the continued operation of two (2) simple cycle combustion turbines in Edgewood, NY. The facility has an optimum electrical output of 95 megawatts (MW) firing only natural gas. The facility is limited in operation; its annual NOx emissions are capped below the major source threshold. The cap was originally put in place prior to construction of the facility to prevent emissions from exceeding the threshold of non-attainment New Source Review (NSR) requirements. It also prevents the facility from being subject to NOx Reasonably Available Control Technology (RACT). The facility is subject to the provisions of 40 CFR 72, the Acid Rain Program (Title IV). Therefore, it is subject to Title V permit requirements.

The permit renewal removes the Prevention of Significant Deterioration (PSD) conditions under 6 NYCRR Subpart 231-8. The facility is not, and never was, a major source of any NSR contaminants that are not Greenhouse gases (GHGs). These conditions were put in the last permit when the facility increased its operating capacity. However, the U.S. Supreme Court ruled in 2014 that the EPA may not treat GHGs as an air pollutant for purposes of determining whether a source is a major source required to obtain a PSD permit. The permit renewal also incorporates the requirements of 6 NYCRR Part 242, CO2 Budget Trading Program and 6 NYCRR Part 251, CO2 Performance Standards for Major Electric Generating Facilities. Also,

Facility DEC ID: 1472803244

references to the Clean Air Interstate Rule (CAIR) were removed and Cross-State Air Pollution Rule (CSAPR) citations were added.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: KEVIN A KISPERT
 SUNY @ STONY BROOK
 50 CIRCLE RD
 STONY BROOK, NY 11790

Authorized Signature: _____ Date: ____ / ____ / ____

Facility DEC ID: 1472803244

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 1472803244

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

- 4 1 Facility Inspection by the Department
- 4 2 Relationship of this Permit to Other Department Orders and Determinations
- 4 3 Applications for permit renewals, modifications and transfers
- 5 4 Permit modifications, suspensions or revocations by the Department

Facility Level

- 5 5 Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS

Facility DEC ID: 1472803244

DEC GENERAL CONDITIONS

**** General Provisions ****

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department**Applicable State Requirement: ECL 19-0305****Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations**Applicable State Requirement: ECL 3-0301 (2) (m)****Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers**Applicable State Requirement: 6 NYCRR 621.11****Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be

Facility DEC ID: 1472803244

submitted prior to actual transfer of ownership.

Condition 4: Permit modifications, suspensions or revocations by the Department

Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal - REGION 1

HEADQUARTERS

Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
Region 1 Headquarters
Division of Environmental Permits
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409
(631) 444-0365

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To:EDGEWOOD ENERGY LLC
1900 E GOLF RD STE 1030
SCHAUMBURG, IL 60173

Facility: EDGEWOOD ENERGY LLC
21 SAGTIKOS PKWY|SCTM 500-71-1-1.11
BRENTWOOD, NY 11717

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Permit Effective Date: 10/14/2020

Permit Expiration Date: 10/13/2025

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 7 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 8 2 6 NYCRR 201-6.4 (a) (7): Fees
- 8 3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
- 8 4 6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
- 9 5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
- 11 6 6 NYCRR 201-6.4 (e): Compliance Certification
- 13 7 6 NYCRR 202-2.1: Compliance Certification
- 13 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 13 9 6 NYCRR 215.2: Open Fires - Prohibitions
- 15 10 6 NYCRR 200.7: Maintenance of Equipment
- 15 11 6 NYCRR 201-1.7: Recycling and Salvage
- 15 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 15 13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 16 14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 16 15 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
- 16 16 6 NYCRR 201-6.4 (a) (8): Right to Inspect
- 17 17 6 NYCRR 201-6.4 (f) (6): Off Permit Changes
- 17 18 6 NYCRR 202-1.1: Required Emissions Tests
- 17 19 40 CFR Part 68: Accidental release provisions.
- 18 20 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 18 21 6 NYCRR Subpart 201-6: Emission Unit Definition
- 19 22 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
- 19 23 6 NYCRR 201-7.1: Facility Permissible Emissions
- 19 *24 6 NYCRR 201-7.1: Capping Monitoring Condition
- 21 25 6 NYCRR 211.2: Visible Emissions Limited
- 21 26 6 NYCRR 227-1.3 (a): Compliance Certification
- 21 27 40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
- 22 28 40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
- 22 29 40CFR 60.7(c), NSPS Subpart A: Compliance Certification
- 23 30 40CFR 60.7(f), NSPS Subpart A: Facility files for subject sources.
- 23 31 40CFR 60.12, NSPS Subpart A: Circumvention.
- 24 32 40CFR 60.13, NSPS Subpart A: Monitoring requirements.
- 24 33 40CFR 60.14, NSPS Subpart A: Modifications.
- 24 34 40CFR 60.15, NSPS Subpart A: Reconstruction
- 24 35 40CFR 60.334(b), NSPS Subpart GG: CEMS
- 25 36 40 CFR Part 72: Facility Subject to Title IV Acid Rain Regulations and Permitting
- 25 37 40CFR 97.406, Subpart AAAAA: Compliance Certification
- 26 38 40CFR 97.606, Subpart CCCCC: Compliance Certification
- 27 39 40CFR 97, Subpart EEEEE: Compliance Certification
- 29 **Emission Unit Level**
- 29 40 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 29 41 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

EU=U-00001

- 30 42 6 NYCRR Subpart 201-6: Compliance Certification
- 30 43 6 NYCRR Subpart 201-6: Compliance Certification
- 31 44 6 NYCRR Subpart 201-6: Compliance Certification
- 32 45 6 NYCRR Subpart 201-6: Compliance Certification
- 33 46 6 NYCRR Subpart 201-6: Compliance Certification
- 34 47 6 NYCRR Subpart 201-6: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 36 48 ECL 19-0301: Contaminant List
- 36 49 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 37 50 6 NYCRR 201-1.4: Compliance Demonstration
- 38 51 6 NYCRR 201-6.5 (a): CLCPA Applicability
- 38 52 6 NYCRR 211.1: Air pollution prohibited
- 39 53 6 NYCRR 242-1.5: CO2 Budget Trading Program - Excess
emission requirements
- 39 54 6 NYCRR 242-1.5: Compliance Demonstration
- 40 55 6 NYCRR 242-1.5: Compliance Demonstration
- 41 56 6 NYCRR Subpart 242-4: Compliance Demonstration
- 43 57 6 NYCRR 242-8.5: Compliance Demonstration
- 45 58 6 NYCRR 251.3 (b): Compliance Demonstration
- 46 59 6 NYCRR 251.6 (f): Compliance Demonstration

NOTE: * preceding the condition number indicates capping.

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

FEDERALLY ENFORCEABLE CONDITIONS

Renewal 2/FINAL

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR 201-6.4 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR 201-6.4 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. When additional applicable requirements under the act become applicable to a title V facility with a remaining permit term of three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the department pursuant to the provisions of section 201- 6.6 of this Subpart.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

**Condition 1: Acceptable Ambient Air Quality
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable Federal Requirement: 6 NYCRR 200.6**Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 3: Recordkeeping and Reporting of Compliance Monitoring
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

Condition 4: Records of Monitoring, Sampling, and Measurement
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

reports required by the permit.

Condition 5: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.
- (2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.
- (3) For all other deviations from permit requirements,

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2021.
Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR 201-6.4 (e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related recordkeeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

specified in any special permit terms or conditions;
and
- such additional requirements as may be specified elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Air Compliance Branch
USEPA Region 2 DECA/ACB
290 Broadway, 21st Floor
New York, NY 10007

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer
NYSDEC- Region 1 Headquarters
Stony Brook University
50 Circle Road
Stony Brook, NY 11790-3409

The address for the BQA is as follows:

NYSDEC

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2021.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:

The Compliance Certification activity will be performed for the Facility.

Item 7.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires - Prohibitions
Effective between the dates of 10/14/2020 and 10/13/2025

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Applicable Federal Requirement: 6 NYCRR 215.2**Item 9.1:**

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 9.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 10: Maintenance of Equipment
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable Federal Requirement:6 NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Condition 11: Recycling and Salvage
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable Federal Requirement:6 NYCRR 201-1.7

Item 11.1:

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

**Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 13: Exempt Sources - Proof of Eligibility
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 13.1:

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Condition 14: Trivial Sources - Proof of Eligibility
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 14.1:

The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Condition 15: Requirement to Provide Information
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: Right to Inspect
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Off Permit Changes**Effective between the dates of 10/14/2020 and 10/13/2025****Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)****Item 17.1:**

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests**Effective between the dates of 10/14/2020 and 10/13/2025****Applicable Federal Requirement:6 NYCRR 202-1.1****Item 18.1:**

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Accidental release provisions.**Effective between the dates of 10/14/2020 and 10/13/2025****Applicable Federal Requirement:40 CFR Part 68****Item 19.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
 - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
 - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
 C/O CSC
 8400 Corporate Dr
 Carrollton, Md. 20785

Condition 20: Recycling and Emissions Reduction
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 40CFR 82, Subpart F

Item 20.1:
 The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 21: Emission Unit Definition
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 21.1:
 The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

Emission Unit U00001 represents two (2) identical GE LM6000 combustion turbines rated at 416 mmBtu/hr (LHV). The turbines will fire only natural gas. The turbines will be equipped with Selective Catalytic Reduction (SCR) and water injection to control NOx emissions and an oxidation catalyst to control emissions of CO and VOC. Each turbine will vent to an individual 105 foot stack.

Condition 22: Progress Reports Due Semiannually

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR 201-6.4 (d) (4)

Item 22.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 23: Facility Permissible Emissions
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR 201-7.1

Item 23.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0	PTE: 45,000 pounds per year
Name: OXIDES OF NITROGEN	

Condition 24: Capping Monitoring Condition
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR 201-7.1

Item 24.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 227-2
6 NYCRR Subpart 231-2

Item 24.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 24.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart,

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 24.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 24.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 24.6:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 24.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator of the facility shall install, calibrate, maintain, and operate a continuous emissions monitor for oxides of nitrogen. The limits for emissions of oxides of nitrogen shall be based upon the higher heating value of the fuel and shall apply at all loads of operation and during start-up and shutdown. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

Manufacturer Name/Model Number: NO_x CEM

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 22.5 tons per year

Reference Test Method: 40 CFR 75

Monitoring Frequency: CONTINUOUS

Averaging Method: ANNUAL MAXIMUM ROLLED DAILY

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 3 calendar month(s).

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Condition 25: Visible Emissions Limited
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 211.2

Item 25.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 26: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR 227-1.3 (a)

Item 26.1:

The Compliance Certification activity will be performed for the facility:
 The Compliance Certification applies to:

- Emission Unit: U-00001 Emission Point: 00001
- Emission Unit: U-00001 Emission Point: 00002

Item 26.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
 DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (based on a six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The applicant will conduct a Method 9 test annually. A report of the results of the test will be submitted to the Department within 30 days of the completion of the Method 9 test. All records generated by the permittee will be maintained at the facility for a minimum of five years.

Parameter Monitored: OPACITY
 Upper Permit Limit: 20 percent
 Reference Test Method: Method 9
 Monitoring Frequency: ANNUALLY
 Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
 Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 27: EPA Region 2 address.
Effective between the dates of 10/14/2020 and 10/13/2025

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A

Item 27.1:

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2
290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Condition 28: Recordkeeping requirements.
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:40CFR 60.7(b), NSPS Subpart A

Item 28.1:

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

Condition 29: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:40CFR 60.7(c), NSPS Subpart A

Item 29.1:

The Compliance Certification activity will be performed for the Facility.

Item 29.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Affected owners or operators shall submit an excess emissions report and/or a summary report form (as defined in 40 CFR 60.7(d)) semi-annually (or more frequently as required by the applicable Subpart or the Administrator), to the Administrator. These reports shall be post marked no later than 30 days after each six (6) month period (or

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

as appropriate), and shall contain the following information:

- 1) the magnitude of excess emissions computed, any conversion factors used, the date and time of each occurrence, and the process operating time during the reporting period;
- 2) specific identification of each period of excess emissions that occur during startup, shutdown, or malfunction, where the nature, cause, and corrective action are provided for a malfunction;
- 3) the date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments; and
- 4) when no excess emissions have occurred or when the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be provided in the report.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 6 calendar month(s).

**Condition 30: Facility files for subject sources.
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable Federal Requirement:40CFR 60.7(f), NSPS Subpart A

Item 30.1:

The following files shall be maintained at the facility for all affected sources: all measurements, including continuous monitoring systems, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part, recorded in permanent form suitable for inspections. The file shall be maintained for at least two years following the date of such measurements, reports, and records.

**Condition 31: Circumvention.
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable Federal Requirement:40CFR 60.12, NSPS Subpart A

Item 31.1:

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

Condition 32: Monitoring requirements.
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:40CFR 60.13, NSPS Subpart A

Item 32.1:
 All continuous monitoring systems and devices shall be installed, calibrated, maintained, and operated in accordance with the requirements of section 60.13.

Condition 33: Modifications.
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:40CFR 60.14, NSPS Subpart A

Item 33.1:
 Within 180 days of the completion of any physical or operational change (as defined in section 60.14), compliance with the applicable standards must be achieved.

Condition 34: Reconstruction
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:40CFR 60.15, NSPS Subpart A

Item 34.1:
 The following shall be submitted to the Administrator prior to reconstruction (as defined in section 60.15):

- 1) a notice of intent to reconstruct 60 days prior to the action;
- 2) name and address of the owner or operator;
- 3) the location of the existing facility;
- 4) a brief description of the existing facility and the components to be replaced;
- 5) a description of the existing air pollution control equipment and the proposed air pollution control equipment;
- 6) an estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility;
- 7) the estimated life of the facility after the replacements; and
- 8) a discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.

Condition 35: CEMS
Effective between the dates of 10/14/2020 and 10/13/2025

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Applicable Federal Requirement:40CFR 60.334(b), NSPS Subpart GG**Item 35.1:**

The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NOX emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NOX and O2 monitors. As an alternative, a CO2 monitor may be used to adjust the measured NOX concentrations to 15 percent O2 by either converting the CO2 hourly averages to equivalent O2 concentrations using Equation F-14a or F-14b in appendix F to 40 CFR Part 75 and making the adjustments to 15 percent O2, or by using the CO2 readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as specified in 40 CFR 60.334(b)(1), (2) and (3).

Condition 36: Facility Subject to Title IV Acid Rain Regulations and Permitting
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:40 CFR Part 72

Item 36.1: This facility is subject to the Title IV Acid Rain Regulations found in 40 CFR Parts 72, 73, 75, 76, 77 and 78. The Acid Rain Permit is an attachment to this permit.

Condition 37: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:40CFR 97.406, Subpart AAAAA**Item 37.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 37.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.413 through 97.418 of Subpart AAAAA. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.613 through 97.618 of Subpart CCCCC. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.

(2) The facility, and the designated representative, of each TR SO₂ Group 1 source (facility) and each TR SO₂ Group 1 Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.630 through 97.635 of Subpart CCCCC and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR SO₂ Group 1 allowances and to determine compliance with the TR SO₂ Group 1 emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO₂ Group 1 facility and each TR SO₂ Group 1 Unit at the facility shall hold, in the facilities compliance account, TR SO₂ Group 1 allowances available for deduction for such control period under §97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all TR SO₂ Group 1 Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 39: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 40CFR 97, Subpart EEEEE

Item 39.1:

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.813 through 97.818 of Subpart EEEEE. The facility shall notify the Department of this representative (and alternate) with contact information upon issuance of this permit and when any changes are made to the representative (or alternate) or their contact information.

(2) The facility, and the designated representative, of each CSAPR NO_x Ozone Season source (facility) and each CSAPR NO_x Ozone Season Unit at the facility must comply with the monitoring, reporting, and recordkeeping requirements of §§97.830 through 97.835 of Subpart EEEEE and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are to be submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are to be submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of CSAPR NO_x Ozone Season allowances and to determine compliance with the CSAPR NO_x Ozone Season emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO_x Ozone Season facility and each CSAPR NO_x Ozone Season Unit at the facility shall hold, in the facilities compliance account, CSAPR NO_x Ozone Season allowances available for deduction for such control period under §97.824(a) in an amount not less than the tons of total NO_x emissions for such control period from all CSAPR NO_x Ozone Season Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

DESCRIPTION
 Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

****** Emission Unit Level ******

Condition 40: Emission Point Definition By Emission Unit
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 40.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001

Height (ft.): 105 Diameter (in.): 126
 NYTMN (km.): 4516.441 NYTME (km.): 644.064

Emission Point: 00002

Height (ft.): 105 Diameter (in.): 126
 NYTMN (km.): 4516.44 NYTME (km.): 644.047

Condition 41: Process Definition By Emission Unit
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 41.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: GAS Source Classification Code: 2-01-002-01

Process Description:
 Gas Turbine firing natural gas for electricity generation.

Emission Source/Control: WI001 - Combustion
 Design Capacity: 416 million Btu per hour

Emission Source/Control: WI002 - Combustion
 Design Capacity: 416 million Btu per hour

Emission Source/Control: CO001 - Control
 Control Type: CATALYTIC OXIDATION

Emission Source/Control: CO002 - Control
 Control Type: CATALYTIC OXIDATION

Emission Source/Control: SCR01 - Control

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Emission Source/Control: SCR02 - Control

Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Condition 42: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 42.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitors for oxides of nitrogen. This limit shall apply only during periods of start-up of a turbine (30 minutes per occurrence). Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

Manufacturer Name/Model Number: NOx CEM

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 15.0 pounds

Reference Test Method: 40 CFR 75

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 3 calendar month(s).

Condition 43: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 43.1:

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Item 43.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A Shutdown shall be defined as the period of time when the stop signal is initiated to when fuel is no longer being combusted in the engine or a subsequent start is initiated, not to exceed 20 minutes per occurrence. The owner or operator shall record each period of shutdown and its duration. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

Parameter Monitored: DURATION OF SHUTDOWN

Upper Permit Limit: 20 minutes

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER
OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 3 calendar month(s).

Condition 44: Compliance Certification

Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 44.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 44.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator of the facility shall install, calibrate, maintain, and operate continuous emissions

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

monitors for oxides of nitrogen and either oxygen or carbon dioxide. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

The 2.5 ppmvd limit shall be applicable during periods of steady state operation where the facility operates a gas turbine 16 or more minutes consecutively in one clock hour. When a facility operates a gas turbine in steady state less than 16 minutes (consecutively in one clock hour, and excluding startup or shutdown) the 2.5 ppmvd limit does not apply, but a mass emission limit of 2.5 pounds applies. Emissions in excess of either the 2.5 ppmvd limit or the 2.5 pound limit shall be reported quarterly through the facility's excess emissions report.

Manufacturer Name/Model Number: NOX CEM
Parameter Monitored: OXIDES OF NITROGEN
Upper Permit Limit: 2.5 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 75
Monitoring Frequency: CONTINUOUS
Averaging Method: 1-HOUR AVERAGE
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2021.
Subsequent reports are due every 3 calendar month(s).

Condition 45: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 45.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):
CAS No: 007664-41-7 AMMONIA

Item 45.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator of the facility shall install, calibrate, maintain, and operate continuous emissions monitors for ammonia. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

of five years.

Manufacturer Name/Model Number: Ammonia CEM
 Parameter Monitored: AMMONIA
 Upper Permit Limit: 10 parts per million by volume (dry, corrected to 15% O2)
 Reference Test Method: 40 CFR 60, Appendix B and F
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2021.
 Subsequent reports are due every 3 calendar month(s).

Condition 46: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 46.1:
 The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 46.2:
 Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
 Monitoring Description:

The facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall apply only during periods of shutdown of a gas turbine, not to exceed 20 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

Manufacturer Name/Model Number: NOX CEM
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 5.00 pounds
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

The initial report is due 1/30/2021.
Subsequent reports are due every 3 calendar month(s).

Condition 47: Compliance Certification
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 47.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Item 47.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Start-up shall be defined as the 30 minute period of time from the point that the gas turbine begins firing fuel. The owner or operator shall record the date and time of each period of start-up. A report consisting of the recorded information shall be submitted to the Department quarterly with the facility's required excess emissions report. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

Parameter Monitored: DURATION OF START UP

Upper Permit Limit: 30 minutes

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER
OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 3 calendar month(s).

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;

(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 48: Contaminant List

Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: ECL 19-0301

Item 48.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit (emission limits, control requirements or compliance monitoring conditions).

CAS No: 000124-38-9
Name: CARBON DIOXIDE

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

Condition 49: Malfunctions and start-up/shutdown activities

Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 201-1.4

Item 49.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 50: Compliance Demonstration
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 201-1.4

Item 50.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 50.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

In the event that the permittee claims that an excess emission is the result of an unavoidable malfunction or upset, the permittee shall submit a quarterly Report of Malfunction and Abatement to the Department's Regional Air

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Pollution Control Engineer. The Report of Malfunction and Abatement shall contain the following information:

- 1) a description of the possible malfunction or upset;
- 2) The cause of the excess emission;
- 3) The reason(s) why it is claimed that the excess emission was the result of an unavoidable malfunction or upset;
- 4) The date and the time of the excess emission;
- 5) The air contaminant(s) emitted, including the parameters of the permit exceedance;
- 6) The estimated emission rates of the air contaminant(s) emitted;
- 7) The corrective action taken to address the excess emission; and
- 8) Any action taken to prevent such an excess emission from reoccurring.

Monitoring Frequency: CONTINUOUS
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2021.
 Subsequent reports are due every 3 calendar month(s).

Condition 51: CLCPA Applicability
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 201-6.5 (a)

Item 51.1:
 Pursuant to The New York State Climate Leadership and Community Protection Act (CLCPA) and Article 75 of the Environmental Conservation Law, emission sources shall comply with regulations to be promulgated by the Department to ensure that by 2030 statewide greenhouse gas emissions are reduced by 40% of 1990 levels, and by 2050 statewide greenhouse gas emissions are reduced by 85% of 1990 levels.

Condition 52: Air pollution prohibited
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 211.1

Item 52.1:
 No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

**Condition 53: CO2 Budget Trading Program - Excess emission requirements
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable State Requirement: 6 NYCRR 242-1.5

Item 53.1:

The owners and operators of a CO2 budget source that has excess emissions in any control period shall:

- (1) forfeit the CO2 allowances required for deduction under 6 NYCRR Part 242-6.5(d)(1), provided CO2 offset allowances may not be used to cover any part of such excess emissions; and
- (2) pay any fine, penalty, or assessment or comply with any other remedy imposed under 6 NYCRR Part 242-6.5(d)(2).

**Condition 54: Compliance Demonstration
Effective between the dates of 10/14/2020 and 10/13/2025**

Applicable State Requirement: 6 NYCRR 242-1.5

Item 54.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 54.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

The owners and operators and, to the extent applicable, the CO2 authorized account representative of each CO2 budget source and each CO2 budget unit at the source shall comply with the monitoring requirements of Subpart 242-8. The emissions measurements recorded and reported in accordance with Subpart 242-8 of this Part shall be used to determine compliance by the unit with the following CO2 requirements:

- (1) The owners and operators of each CO2 budget source and each CO2 budget unit at the source shall hold CO2 allowances available for compliance deductions under Section 242-6.5, as of the CO2 allowance transfer deadline, in the source's compliance account in an amount not less than the total CO2 emissions for the control period from all CO2 budget units at the source, as determined in accordance with Subparts 242-6 and 242-8.
- (2) Each ton of CO2 emitted in excess of the CO2 budget emissions limitation shall constitute a separate violation of this Part and applicable state law.
- (3) A CO2 budget unit shall be subject to the requirements specified in item 1 starting on the later, of January 1,

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

2009 or the date on which the unit commences operation.

(4) CO2 allowances shall be held in, deducted from, or transferred among CO2 Allowance Tracking System accounts in accordance with Subparts 242-5, 242-6, and 242-7, and Section 242-10.7.

(5) A CO2 allowance shall not be deducted, in order to comply with the requirements specified in item 1, for a control period that ends prior to the allocation year for which the CO2 allowance was allocated. A CO2 offset allowance shall not be deducted, in order to comply with the requirements under item 1, beyond the applicable percent limitations set out in 6NYCRR Part 242-6.5(a)(3).

(6) A CO2 allowance under the CO2 Budget Trading Program is a limited authorization by the Department or a participating state to emit one ton of CO2 in accordance with the CO2 Budget Trading Program. No provision of the CO2 Budget Trading Program, the CO2 budget permit application, or the CO2 budget permit or any provision of law shall be construed to limit the authority of the Department or a participating state to terminate or limit such authorization.

(7) A CO2 allowance under the CO2 Budget Trading Program does not constitute a property right.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 6 calendar month(s).

Condition 55: Compliance Demonstration
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 242-1.5

Item 55.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 55.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators of the CO2 budget source and each CO2 budget unit at the source shall keep on site at

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

the source each of the following documents for a period of 10 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 10 years, in writing by the department.

(i) The account certificate of representation for the CO₂ authorized account representative for the source and each CO₂ budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 6 NYCRR Part 242-2.4, provided that the certificate and documents shall be retained on site at the source beyond such 10-year period until such documents are superseded because of the submission of a new account certificate of representation.

(ii) All emissions monitoring information, in accordance with Subpart 242-8 and 40 CFR 75.57.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CO₂ Budget Trading Program.

(iv) Copies of all documents used to complete a CO₂ budget permit application and any other submission under the CO₂ Budget Trading Program or to demonstrate compliance with the requirements of the CO₂ Budget Trading Program.

The CO₂ authorized account representative of a CO₂ budget source and each CO₂ budget unit at the source shall submit the reports and compliance certifications required under the CO₂ Budget Trading Program, including those under Subpart 242-4.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 6 calendar month(s).

Condition 56: Compliance Demonstration
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR Subpart 242-4

Item 56.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000124-38-9 CARBON DIOXIDE

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Item 56.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Annual Compliance Certification Report:

(a) For each control period in which a CO₂ budget source is subject to the CO₂ requirements of subdivision 242-1.5(c) of this Part, CO₂ authorized account representative of the source shall submit to the department by March 1st following the relevant control period, a compliance certification report. The control period is a three-calendar-year time period.

(b) The compliance certification report shall include the following elements:

(1) identification of the source and each CO₂ budget unit at the source;

(2) as an option, the serial numbers of the CO₂ allowances that are to be deducted from the source's compliance account under section 242-6.5 of this Part for the control period, including the serial numbers of any CO₂ offset allowances that are to be deducted subject to the limitations of section 242-6.5(a)(3) of this Part; and

(3) the compliance certification under subdivision (c) of this section (below).

(c) In the compliance certification report the CO₂ authorized account representative shall certify, based on reasonable inquiry of those persons with primary responsibility for operating the source and the CO₂ budget units at the source in compliance with the CO₂ Budget Trading Program, whether the source and each CO₂ budget unit at the source for which the compliance certification is submitted was operated during the calendar years covered by the report in compliance with the requirements of the CO₂ Budget Trading Program, including:

(1) whether the source was operated in compliance with the CO₂ requirements of section 242-1.5(c) of this Part;

(2) whether the monitoring plan applicable to each unit at the source has been maintained to reflect the actual operation and monitoring of the unit, and contains all information necessary to attribute CO₂ emissions to the unit, in accordance with Subpart 242-8 of this

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Part;

(3) whether all the CO2 emissions from the units at the source were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including whether conditional data were reported in the quarterly reports in accordance with Subpart 242-8 of this Part. If conditional data were reported, the owner or operator shall indicate whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;

(4) whether the facts that form the basis for certification under Subpart 242-8 of each monitor at each unit at the source, or for using an excepted monitoring method or alternative monitoring method approved under Subpart 242-8 of this Part, if any, have changed; and

(5) if a change is required to be reported under paragraph (c)(4) above, specify the nature of the change, the reason for the change, when the change occurred, and how the unit's compliance status was determined subsequent to the change, including what method was used to determine emissions when a change mandated the need for monitor recertification.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 57: Compliance Demonstration
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 242-8.5

Item 57.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):
 CAS No: 000124-38-9 CARBON DIOXIDE

Item 57.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Recordkeeping and Reporting (6NYCRR Part 242-8.5)

(a) General provisions. The CO2 authorized account representative shall comply with all recordkeeping and reporting requirements in this section, the applicable

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

record keeping and reporting requirements under 40 CFR 75.73 and with the requirements of section 242-2.1(e) of this Part.

(b) Monitoring plans. The owner or operator of a CO₂ budget unit shall submit a monitoring plan in the manner prescribed in 40 CFR 75.62.

(c) Certification applications. The CO₂ authorized account representative shall submit an application to the department within 45 days after completing all CO₂ monitoring system initial certification or recertification tests required under section 242-8.2 of this Subpart including the information required under 40 CFR 75.63 and 40 CFR 75.53(e) and (f).

(d) Quarterly reports. The CO₂ authorized account representative shall submit quarterly reports, as follows:

(1) The CO₂ authorized account representative shall report the CO₂ mass emissions data and heat input data for the CO₂ budget unit, in an electronic format prescribed by the administrator unless otherwise prescribed by the department for each calendar quarter.

(2) The CO₂ authorized account representative shall submit each quarterly report to the department or its agent within 30 days following the end of the calendar quarter covered by the report. Quarterly reports shall be submitted in the manner specified in subpart H of 40 CFR part 75 and 40 CFR 75.64. Quarterly reports shall be submitted for each CO₂ budget unit (or group of units using a common stack), and shall include all of the data and information required in subpart G of 40 CFR part 75, except for opacity, NO_x, and SO₂ provisions.

(3) The CO₂ authorized account representative shall submit to the department or its agent a compliance certification in support of each quarterly report based on reasonable inquiry of those persons with primary responsibility for ensuring that all of the unit's emissions are correctly and fully monitored. The certification shall state that:

(i) the monitoring data submitted were recorded in accordance with the applicable requirements of this Subpart and 40 CFR part 75, including the quality assurance procedures and specifications;

(ii) for a unit with add-on CO₂ emissions controls and for all hours where data are substituted in accordance with 40 CFR 75.34(a)(1), the add-on emissions controls were operating within the range of parameters listed in the quality assurance/quality control program under appendix B of 40 CFR part 75 and the substitute values do not systematically underestimate CO₂ emissions; and

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

(iii) the CO2 concentration values substituted for missing data under Subpart D of 40 CFR part 75 do not systematically underestimate CO2 emissions.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 3 calendar month(s).

Condition 58: Compliance Demonstration
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 251.3 (b)

Item 58.1:

The Compliance Demonstration activity will be performed for the facility:
 The Compliance Demonstration applies to:

Emission Unit: U-00001

Regulated Contaminant(s):
 CAS No: 000124-38-9 CARBON DIOXIDE

Item 58.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

On or after December 31, 2020, owners or operators of non-modified existing sources shall not fire any single fossil fuel, alone or in combination with any other fuel, where each fossil fuel is required to meet an emission rate of 180 pounds of CO2 per million Btu of input (input-based limit). These emission limits are measured on an annual basis, calculated by dividing the annual total of CO2 emissions for the calendar year by the annual total Btus (input-based limit) fired for each separate fossil fuel fired. For monitoring its CO2 emissions, the facility will use the Part 75 system (i.e., fuel flowmeters and F-factor) that it uses for 40 CFR 98 annual reporting to the EPA. The facility will calculate its CO2 emissions on a quarterly or more frequent basis. The owner or operator must maintain all records associated with these requirements on site or at a location acceptable to the Department for a minimum of five years.

Parameter Monitored: CARBON DIOXIDE
 Upper Permit Limit: 180 pounds per million Btus

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Reference Test Method: 40 CFR 75

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: CALENDAR YEAR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 3 calendar month(s).

Condition 59: Compliance Demonstration
Effective between the dates of 10/14/2020 and 10/13/2025

Applicable State Requirement: 6 NYCRR 251.6 (f)

Item 59.1:

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000124-38-9 CARBON DIOXIDE

Item 59.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners or operators that choose not to demonstrate compliance with the provisions in subdivision 251.3(b) of this Part through the use of a CEM may utilize an alternative monitoring plan as approved by the Department.

The owners or operators may submit their annual reports under one of the following provisions:

- (1) Sources subject to the reporting requirements of 6 NYCRR Subpart 202-2 of this Title may use their annual emission statement to satisfy the requirements of this subdivision, or
- (2) Sources subject to the reporting requirements of 40 CFR Part 98 (see Table 1, section 200.9 of this Title) may use their annual submission to EPA to satisfy the requirements of this subdivision, or
- (3) Sources that are not subject to the reporting requirements of 6 NYCRR Subpart 202-2 of this Title or 40 CFR Part 98 (see Table 1, section 200.9 of this Title) must submit an annual report, in a format prescribed by the Department, by the April 15th immediately following the end of the calendar year for which the annual report is required. At a minimum, the annual report should include:
 - (i) Fuel type combusted in each unit subject to this

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244

Part;

(ii) Quantity of fuel combusted in each unit subject to this Part; and

(iii) Heat content of each fuel combusted.

The approved alternative monitoring shall be cited in a facility specific condition under subdivision 251.3(b) of this Part. and shall at a minimum include the prescribed CO2 emission limit and type of monitoring used to show compliance with said emission limit.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 12 calendar month(s).

Permit ID: 1-4728-03244/00005

Facility DEC ID: 1472803244