

Facility DEC ID: 2610200086

**PERMIT**  
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air Title V Facility  
Permit ID: 2-6102-00086/00011  
Effective Date: 03/24/2020 Expiration Date: 03/23/2025

Permit Issued To: ASTORIA GENERATING COMPANY LP  
18-01 20TH AVE  
LONG ISLAND CITY, NY 11105-4271

Contact: ANDREW W OLIVER  
ASTORIA GENERATING COMPANY, LP C/O EASTERN GENERATION  
LLC  
3650 JAMES ST STE 206  
SYRACUSE, NY 13206  
(315) 433-1371

Facility: NARROWS GENERATING STATION  
53RD ST & FIRST AVE|4 WHALE SQUARE  
BROOKLYN, NY 11232

Contact: NATALIA HERNANDEZ  
ASTORIA GENERATING STATION  
18-01 20TH AVE GATE 1  
ASTORIA, NY 11105  
(718) 204-3918

Description:

The Facility operates an existing power station that produces electricity. The facility operates sixteen (16) combustion turbines and thirty-two (32) starting engines located on two floating barges and emission units N-A0005 and N-A0006. Each combustion turbine is rated at 297 MMBtu/hr and each starting engine is rated at 600 horsepower. The turbines combust distillate oil (ULSD) and natural gas. The starting engines combust ULSD.

The Oxides of Nitrogen emissions are equal to or greater than 25 tons per year on a 12-month rolling period and the facility is subject to the 6NYCRR Subpart 201-6, Title V Facility Permits, requirements.

The oxides of nitrogen emissions from the starting engines are capped to less than 25 tons per year on a 12-month rolling basis to avoid Part 231 New Source Review requirements.

Under 40 CFR 75 the Oxides of nitrogen for the ozone season is limited to 50 tons per month from May 1 to September 30, for each emission unit, N-A0005 and N-A0006.

Facility DEC ID: 2610200086

The formaldehyde emissions are capped to less than 10 tons per year on a 12-month rolling basis to avoid 40CFR 63 Subpart DDDDD, National Emission Standards for hazardous Air pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator:           STEPHEN A WATTS  
  47-40 21ST ST  
  LONG ISLAND CITY, NY 11101-5401

Authorized Signature: \_\_\_\_\_ Date: \_\_\_ / \_\_\_ / \_\_\_

Facility DEC ID: 2610200086

**Notification of Other State Permittee Obligations**

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 2610200086

**PAGE LOCATION OF CONDITIONS**

**PAGE**

**DEC GENERAL CONDITIONS**

**General Provisions**

- 4 1 Facility Inspection by the Department
- 4 2 Relationship of this Permit to Other Department Orders and Determinations
- 4 3 Applications for permit renewals, modifications and transfers
- 5 4 Permit modifications, suspensions or revocations by the Department

**Facility Level**

- 5 5 Submission of application for permit modification or renewal -  
REGION 2 HEADQUARTERS

Facility DEC ID: 2610200086

**DEC GENERAL CONDITIONS**

\*\*\*\* General Provisions \*\*\*\*

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

**GENERAL CONDITIONS - Apply to ALL Authorized Permits.**

**Condition 1: Facility Inspection by the Department**

**Applicable State Requirement: ECL 19-0305**

**Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations**

**Applicable State Requirement: ECL 3-0301 (2) (m)**

**Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 3: Applications for permit renewals, modifications and transfers**

**Applicable State Requirement: 6 NYCRR 621.11**

**Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

**Item 3.3**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Facility DEC ID: 2610200086

**Condition 4: Permit modifications, suspensions or revocations by the Department**  
**Applicable State Requirement: 6 NYCRR 621.13**

**Item 4.1:**

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 5: Submission of application for permit modification or renewal - REGION 2 HEADQUARTERS**  
**Applicable State Requirement: 6 NYCRR 621.6 (a)**

**Item 5.1:**

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator  
Region 2 Headquarters  
Division of Environmental Permits  
1 Hunters Point Plaza, 4740 21st Street  
Long Island City, NY 11101-5407  
(718) 482-4997

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Permit Under the Environmental Conservation Law (ECL)**

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: ASTORIA GENERATING COMPANY LP  
18-01 20TH AVE  
LONG ISLAND CITY, NY 11105-4271

Facility: NARROWS GENERATING STATION  
53RD ST & FIRST AVE|4 WHALE SQUARE  
BROOKLYN, NY 11232

Authorized Activity By Standard Industrial Classification Code:  
4911 - ELECTRIC SERVICES  
4931 - ELEC & OTHER SERVICES COMBINED  
5171 - PETROLEUM BULK STATIONS & TERMINALS

Permit Effective Date: 03/24/2020

Permit Expiration Date: 03/23/2025

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**PAGE LOCATION OF CONDITIONS**

**PAGE**

**FEDERALLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 7 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 8 2 6 NYCRR 201-6.4 (a) (7): Fees
- 8 3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
- 8 4 6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
- 8 5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
- 11 6 6 NYCRR 201-6.4 (e): Compliance Certification
- 13 7 6 NYCRR 202-2.1: Compliance Certification
- 13 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 13 9 6 NYCRR 215.2: Open Fires - Prohibitions
- 15 10 6 NYCRR 200.7: Maintenance of Equipment
- 15 11 6 NYCRR 201-1.7: Recycling and Salvage
- 15 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 15 13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 15 14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 16 15 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
- 16 16 6 NYCRR 201-6.4 (a) (8): Right to Inspect
- 16 17 6 NYCRR 201-6.4 (f) (6): Off Permit Changes
- 17 18 6 NYCRR 202-1.1: Required Emissions Tests
- 17 19 40 CFR Part 68: Accidental release provisions.
- 18 20 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 18 21 6 NYCRR 200.6: Compliance Certification
- 19 22 6 NYCRR Subpart 201-6: Emission Unit Definition
- 19 23 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
- 19 24 6 NYCRR Subpart 201-7: Facility Permissible Emissions
- 20 \*25 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- 21 \*26 6 NYCRR Subpart 201-7: Capping Monitoring Condition
- 24 27 6 NYCRR Part 207: Submittal of Episode Action Plans
- 24 28 6 NYCRR 211.2: Visible Emissions Limited
- 24 29 6 NYCRR 225-1.2 (g): Compliance Certification
- 25 30 6 NYCRR 225-1.2 (h): Compliance Certification
- 26 31 6 NYCRR 225-1.5 (c): Compliance Certification
- 26 32 6 NYCRR 225.7 (a): Compliance Certification
- 27 33 6 NYCRR 227-1.3 (a): Compliance Certification
- 28 34 6 NYCRR 227-1.3 (a): Compliance Certification
- 30 35 6 NYCRR 227-2.5: Compliance Certification
- 31 36 6 NYCRR 227-2.6: Compliance Certification
- 31 37 6 NYCRR 227-2.6: Compliance Certification
- 32 38 6 NYCRR 227.2 (b) (1): Compliance Certification
- 33 39 40CFR 63, Subpart ZZZZ: Applicability
- 33 **Emission Unit Level**
- 33 40 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 36 41 6 NYCRR Subpart 201-6: Process Definition By Emission Unit
- 40 42 6 NYCRR Subpart 201-7: Emission Unit Permissible Emissions



Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**EU=N-A0005**

- 41 43 6 NYCRR Subpart 201-6: Compliance Certification
- 42 \*44 6 NYCRR Subpart 201-7: Capping Monitoring Condition

**EU=N-A0006**

- 43 45 6 NYCRR Subpart 201-6: Compliance Certification
- 44 \*46 6 NYCRR Subpart 201-7: Capping Monitoring Condition

**STATE ONLY ENFORCEABLE CONDITIONS**

**Facility Level**

- 48 47 ECL 19-0301: Contaminant List
- 48 48 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 49 49 6 NYCRR 211.1: Air pollution prohibited

NOTE: \* preceding the condition number indicates capping.

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**FEDERALLY ENFORCEABLE CONDITIONS**

Renewal 3/FINAL

\*\*\*\* Facility Level \*\*\*\*

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

- Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)**  
The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.
- Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)**  
Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.
- Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)**  
Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)**  
The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)**  
This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

planned changes or anticipated noncompliance does not stay any permit condition.

**Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)**

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

**Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)**

This permit does not convey any property rights of any sort or any exclusive privilege.

**Item H: Severability - 6 NYCRR 201-6.4 (a) (9)**

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

**Item I: Permit Shield - 6 NYCRR 201-6.4 (g)**

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

**Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)**

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. When additional applicable requirements under the act become applicable to a title V facility with a remaining permit term of three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the department pursuant to the provisions of section 201- 6.6 of this Subpart.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Item K: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS  
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

**The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.**

**Condition 1: Acceptable Ambient Air Quality**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR 200.6**

**Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Condition 2: Fees**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (7)**

**Item 2.1:**

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

**Condition 3: Recordkeeping and Reporting of Compliance Monitoring**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (c)**

**Item 3.1:**

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

**Condition 4: Records of Monitoring, Sampling, and Measurement**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (2)**

**Item 4.1:**

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

**Condition 5: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (3) (ii)****Item 5.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 5.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.
- (2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.
- (3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.
- (4) This permit may contain a more stringent reporting

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.



Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 6 calendar month(s).

**Condition 6: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR 201-6.4 (e)**

**Item 6.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 6.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
  - the identification of each term or condition of the permit that is the basis of the certification;
  - the compliance status;
  - whether compliance was continuous or intermittent;
  - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related record keeping and reporting requirements of this permit;
  - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions; and
  - such additional requirements as may be specified elsewhere in this permit related to compliance certification.

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department’s Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Air Compliance Branch  
 USEPA Region 2 DECA/ACB  
 290 Broadway, 21st Floor  
 New York, NY 10007

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer  
 Hunters Point Plaza  
 47-40 21st Street  
 Long Island City, NY 11101-5407

The address for the BQA is as follows:

NYSDEC  
 Bureau of Quality Assurance  
 625 Broadway  
 Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY  
 Reporting Requirements: ANNUALLY (CALENDAR)

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Reports due 30 days after the reporting period.  
 The initial report is due 4/30/2020.  
 Subsequent reports are due on the same day each year

**Condition 7: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 202-2.1**

**Item 7.1:**  
 The Compliance Certification activity will be performed for the Facility.

**Item 7.2:**  
 Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES  
 Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY  
 Reporting Requirements: ANNUALLY (CALENDAR)  
 Reports due by April 15th for previous calendar year

**Condition 8: Recordkeeping requirements**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 202-2.5**

**Item 8.1:**  
 (a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department; and
  - (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.
- (b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

**Condition 9: Open Fires - Prohibitions**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 215.2**

**Item 9.1:**  
 Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Item 9.2**

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS  
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

**The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.**

**[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall**

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

be specified as "not applicable".]

**Condition 10: Maintenance of Equipment**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR 200.7**

**Item 10.1:**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

**Condition 11: Recycling and Salvage**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR 201-1.7**

**Item 11.1:**

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

**Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR 201-1.8**

**Item 12.1:**

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 13: Exempt Sources - Proof of Eligibility**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR 201-3.2 (a)**

**Item 13.1:**

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

**Condition 14: Trivial Sources - Proof of Eligibility**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR 201-3.3 (a)**

**Item 14.1:**

The owner or operator of an emission source or activity that is listed as being trivial in this

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

**Condition 15: Requirement to Provide Information**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (4)**

**Item 15.1:**

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

**Condition 16: Right to Inspect**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (8)**

**Item 16.1:**

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

**Condition 17: Off Permit Changes**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)**

**Item 17.1:**

No permit revision will be required for operating changes that contravene an express permit

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

**Condition 18: Required Emissions Tests**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 202-1.1**

**Item 18.1:**

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

**Condition 19: Accidental release provisions.**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:40 CFR Part 68**

**Item 19.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
  - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
  - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Risk Management Plan Reporting Center  
C/O CSC  
8400 Corporate Dr  
Carrollton, Md. 20785

**Condition 20: Recycling and Emissions Reduction**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:40CFR 82, Subpart F**

**Item 20.1:**

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**The following conditions are subject to annual compliance certification requirements for Title V permits only.**

**Condition 21: Compliance Certification**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR 200.6**

**Item 21.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 21.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC  
OPERATIONS

Monitoring Description:

The unit OGT17 may not operate when firing ULSD for more than 7 calendar days per year. There are no restrictions on any other combinations of units when firing ULSD. This enforceable permit condition would ensure that the facility will not cause or contribute to a modeled exceedance of the 1-hour NO<sub>2</sub> NAAQS.

The facility operators to maintain for five years an operating log each time unit OGT17 is operating and make it available upon request to NYSDEC Division of Air Resources.

Work Practice Type: DAYS PER YEAR OPERATION

Upper Permit Limit: 7 days

Monitoring Frequency: WHEN THE SOURCE IS OPERATING

Averaging Method: ANNUAL TOTAL



Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Reporting Requirements: ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 4/30/2020.  
Subsequent reports are due every 12 calendar month(s).

**Condition 22: Emission Unit Definition**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 22.1:**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: N-A0005

Emission Unit Description:

Combustion turbines 1 through 8 on barge 1 are rated at 297 mmbtu/hr each. Each combustion turbine has the capability to burn both distillate oil and natural gas. Each combustion turbine has its own diesel starter engine, rated at 600 hp.

Building(s): PIER 1

**Item 22.2:**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: N-A0006

Emission Unit Description:

Combustion turbines 1 through 8 on barge 2 are rated at 297 mmbtu/hr each. Each combustion turbine has the capability to burn both distillate oil and natural gas. Each combustion turbine has its own diesel starter engine, rated at 600 hp.

Building(s): PIER 1

**Condition 23: Progress Reports Due Semiannually**  
Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement:6 NYCRR 201-6.4 (d) (4)**

**Item 23.1:**

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

(i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and

(ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

**Condition 24: Facility Permissible Emissions**  
Effective between the dates of 03/24/2020 and 03/23/2025

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Applicable Federal Requirement:6 NYCRR Subpart 201-7**

**Item 24.1:**

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 000050-00-0	PTE: 19,395 pounds per year
Name: FORMALDEHYDE	

CAS No: 0NY210-00-0	PTE: 14,632,131 pounds per year
Name: OXIDES OF NITROGEN	

**Condition 25: Capping Monitoring Condition  
Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR Subpart 201-7**

**Item 25.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40 CFR Part 63, Subpart DDDDD

**Item 25.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 25.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 25.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 25.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 25.6:**

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000050-00-0      FORMALDEHYDE

**Item 25.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40 CFR Part 63, Subpart DDDDD

The facility wide emissions of formaldehyde are limited to less than 10 tons per year.

The owner shall keep records of these emissions at the facility for 5 years and make available to DEC inspector(s) upon request and submit annually (calendar) the emissions to:

Regional Air Pollution Control Engineer  
NYSDEC, R2  
47-40 21st Street  
LIC, NY 11101

Parameter Monitored: FORMALDEHYDE

Upper Permit Limit: 10 tons per year

Monitoring Frequency: WHEN THE SOURCE IS OPERATING

Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 12 calendar month(s).

**Condition 26: Capping Monitoring Condition**

**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR Subpart 201-7**

**Item 26.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

6 NYCRR Subpart 231-2  
40 CFR Part 52, Subpart A

**Item 26.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 26.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 26.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 26.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 26.6:**

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: N-A0005 Process: SD1	Emission Source: OSD11
Emission Unit: N-A0005 Process: SD1	Emission Source: OSD12
Emission Unit: N-A0005 Process: SD1	Emission Source: OSD13
Emission Unit: N-A0005 Process: SD1	Emission Source: OSD14
Emission Unit: N-A0005 Process: SD1	Emission Source: OSD15
Emission Unit: N-A0005 Process: SD1	Emission Source: OSD16
Emission Unit: N-A0005 Process: SD1	Emission Source: OSD17

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Emission Unit: N-A0005 Process: SD1	Emission Source: OSD18
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD21
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD22
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD23
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD24
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD25
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD26
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD27
Emission Unit: N-A0006 Process: SD2	Emission Source: OSD28
Regulated Contaminant(s): CAS No: 0NY210-00-0	OXIDES OF NITROGEN

**Item 26.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The total annual operation of 16 starter engines (OSD11-OSD18, OS21-OSD28) in this process is limited to 2560 hours(Engine NOx emission factor 0.031 lbs/hp-hr, AP-42 Fifth Edition, October 1996, Table 3.3-1). Thus the total annual emissions of NOx from these units will be less than 25 tpy threshold for PSD or New source review applicability. Monthly total operating hours shall be maintained at the facility, and all the records shall be kept at the facility for a minimum of five years.

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 24.9 tons per year

Monitoring Frequency: WHEN THE SOURCE IS OPERATING

Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Reporting Requirements: ANNUALLY (CALENDAR)  
 Reports due 30 days after the reporting period.  
 The initial report is due 4/30/2020.  
 Subsequent reports are due every 12 calendar month(s).

**Condition 27: Submittal of Episode Action Plans**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR Part 207**

**Item 27.1:**

An episode action plan must be submitted for approval by the Department in accordance with the requirements of 6NYCRR Part 207. The plan shall contain detailed steps which will be taken by the facility to reduce air contaminant emissions during each stage of an air pollution episode. Once approved, the facility shall take whatever actions are prescribed by the episode action plan when an air pollution episode is in effect.

**Condition 28: Visible Emissions Limited**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 211.2**

**Item 28.1:**

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Condition 29: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 225-1.2 (g)**

**Item 29.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 29.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
 Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL  
 Parameter Monitored: SULFUR CONTENT  
 Upper Permit Limit: 0.0015 percent by weight  
 Monitoring Frequency: PER DELIVERY  
 Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)  
 Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 30: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 225-1.2 (h)**

**Item 30.1:**  
 The Compliance Certification activity will be performed for the Facility.

**Item 30.2:**  
 Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:  
 Owners and/or operators of a stationary combustion installations that fire distillate oil are limited to the firing of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016. Compliance with this limit will be based on vendor certifications.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
 Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL  
 Parameter Monitored: SULFUR CONTENT  
 Upper Permit Limit: 0.0015 percent by weight  
 Monitoring Frequency: PER DELIVERY  
 Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)  
 Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Condition 31: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 225-1.5 (c)**

**Item 31.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 31.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Measurements must be made daily of the rate of each fuel fired. The gross heat content and ash content of each fuel fired must be determined at least once each week. In the case of stationary combustion installations producing electricity for sale, the average electrical output and the hourly generation rate must also be measured.

Data collected pursuant to this Subpart must be tabulated and summarized in a form acceptable to the Department, and must be retained for at least five years. The owner of a Title V facility must furnish to the Department such records and summaries, on a semiannual calendar basis, within 30 days after the end of the semiannual period. All other facility owners or distributors must submit these records and summaries upon request of the Department.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 32: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 225.7 (a)**

**Item 32.1:**

The Compliance Certification activity will be performed for the Facility.

**Item 32.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The permittee shall retain fuel oil supplier certifications for each shipment of oil received. Such certifications shall contain, as a minimum, supplier name, date of shipment, quantity shipped, heating value of the oil, oil sulfur content, and the method used to determine



Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

the sulfur content. Such certifications shall be available for inspection by, or submitted to, the NYSDEC as per the stated reporting requirement.

Monitoring Frequency: PER DELIVERY  
 Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
 Reports due 30 days after the reporting period.  
 The initial report is due 4/30/2020.  
 Subsequent reports are due every 6 calendar month(s).

**Condition 33: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)**

**Item 33.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
 CAS No: 0NY075-00-0 PARTICULATES

**Item 33.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
 DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No owner or operator of a combustion installation shall emit greater than 20 percent opacity (on a six minute block period) except for one six minute block period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Operators of air contamination sources that are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

- 1) Observe the stack(s) or vent(s) once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).
- 2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:
  - weather condition
  - was a plume observed?

This logbook must be retained at the facility for five (5)

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days, then the Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence. The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**\*\* NOTE \*\*** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Parameter Monitored: OPACITY  
 Upper Permit Limit: 27 percent  
 Reference Test Method: METHOD 9  
 Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION  
 Averaging Method: 6 MINUTE AVERAGE  
 Reporting Requirements: QUARTERLY (CALENDAR)  
 Reports due 30 days after the reporting period.  
 The initial report is due 4/30/2020.  
 Subsequent reports are due every 3 calendar month(s).

**Condition 34: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)**

**Item 34.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
 CAS No: 0NY075-00-0 PARTICULATES

**Item 34.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES  
 Monitoring Description:

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**A. Opacity Incident Reporting**

Respondents shall prepare opacity incident reports consistent with the requirements of this paragraph. The term "opacity incident" as used in this appendix means smoke emissions which exhibit greater than 20% opacity (6-minute average). Opacity incident reports shall be maintained by the facility for a period of three years and shall be made available for inspection by the Department on demand. The reports consist of documenting incident events by way of Incident Reports in facility's information database system. Incident Reports identify personnel on duty, a brief summary of the incident and as necessary a sequence of events, a preliminary cause analysis and associated corrective action requirements. All opacity Incident Reports are available to cognizant facility departments and personnel for their information, review and use. Incident Reports form the basis for more detailed root cause analysis, corrective actions, design modifications and project/program development and implementation.

**B. Opacity Reporting Compliance Audits**

Respondents shall conduct monthly opacity reporting compliance audits consistent with the requirements of this paragraph. Audits include a detailed review of all opacity incidents for the prior month, confirmation that all indicated events were properly reported and documented, opacity incidents properly marked, survey sheets completed and all documentation retained. Comprehensive audits reports shall continue to be prepared to identify all relevant observations. Items tabulated include missing survey sheets, events greater than 20% opacity, events greater than 40% opacity, total incidents, incidents reported and events covered by Incident Reports.

**C. Awareness, Communications & Training**

Respondents shall comply with the opacity awareness, communications and training provisions of this paragraph. Opacity audit results and initiatives shall be formal agenda items at regular meetings conducted by the plant manager. Opacity reduction program activities shall also be discussed at the same meetings. Opacity understanding and awareness shall be communicated on an on-going basis from station management to supervisory and operating and maintenance personnel. Respondents shall provide training in opacity regulatory requirements and fundamentals of combustion.

**D. Preventative Maintenance**

Respondents shall conduct, on an ongoing basis, a preventive maintenance program as described in this

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

paragraph. The program shall encompass fuel regulators, fuel filters, fuel nozzles, combustion liners, control system components, ignitors, and inlet guide vanes. The Department shall be notified of all significant additions and deletions to the preventative maintenance programs.

**E. Root Cause Analysis and Corrective Action**

Respondents shall conduct root cause analyses as described in this paragraph and shall take all corrective actions that are deemed necessary to maintain the facilities in full compliance with the State's opacity requirements. Analysis, categorization and corrective action development shall be performed monthly by Respondents' station personnel. Corrections due to equipment failure, malfunction and marginal design shall be accomplished by corrective maintenance and simple design basis enhancement activities. Correction of operational deviations include focused training. Significant design basis deficiencies shall be corrected by the development and implementation of design basis enhancement projects, including, but not limited to, fuel switching and ignition and control system retrofits.

**F. Quarterly Reports**

The facility shall submit to the Department quarterly reports which describe the activities and progress that the owners have made during the preceding quarter in carrying out the requirements of paragraphs A. through E. above.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 3 calendar month(s).

**Condition 35: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR 227-2.5**

**Item 35.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 35.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Monitoring Description:

Astoria Generating Company's system-wide averaging of NOx emissions from its Astoria, Gowanus, and Narrows Generating Stations must be performed in accordance with the most current version of the NOx RACT Averaging Plan (October 2017) approved by the Department. Narrows Generating Station's sixteen turbines and starter engines are also included in the averaging plan.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 3 calendar month(s).

**Condition 36: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 227-2.6**

**Item 36.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 36.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Stack testing shall be performed to verify compliance of NOx emissions from the Combustion Turbines with the most current version of the system-wide averaging plan (NOx RACT Compliance and Operating Plan), submitted by Astoria Generating Company. All stack testing shall be done in accordance with 6NYCRR 227-2.6(c).

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

**Condition 37: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 227-2.6**

**Item 37.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**Item 37.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

In lieu of performing a stack test on the Starter Engines associated with the Combustion Turbines, a log must be kept which lists the dates of operation of the Starter Engines and the duration of each occurrence. The log must be maintained at the facility and submitted, semiannually to the Department, at the following address:

Hunters Point Plaza  
 47-40 21st Street  
 Long Island City, NY, 11101-5407  
 Att: Regional Air Pollution Control

Engineer

The information on the Starter Engines, provided to the applicant by the engine manufacturer, is attached to this permit and constitutes an enforceable part of the permit.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 6 calendar month(s).

**Condition 38: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR 227.2 (b) (1)**

**Item 38.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):  
 CAS No: 0NY075-00-0 PARTICULATES

**Item 38.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

Particulate emission limit for a stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

1) submit, to the Department, an acceptable protocol for the testing of particulate emission limit cited in this condition,

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

2) perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition, and

3) all records shall be maintained at the facility for a minimum of five years.

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 6 calendar month(s).

**Condition 39: Applicability**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:40CFR 63, Subpart ZZZZ**

**Item 39.1:**

Facilities that have reciprocating internal combustion engines must comply with applicable portions of 40 CFR 63 subpart ZZZZ.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 40: Emission Point Definition By Emission Unit**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 40.1:**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: N-A0005

Emission Point: OGT11

Height (ft.): 57	Length (in.): 240	Width (in.): 154
NYTMN (km.): 4500.487	NYTME (km.): 582.359	Building: PIER 1

Emission Point: OGT12

Height (ft.): 57	Length (in.): 240	Width (in.): 154
NYTMN (km.): 4500.482	NYTME (km.): 582.364	Building: PIER 1

Emission Point: OGT13

Height (ft.): 57	Length (in.): 240	Width (in.): 154
------------------	-------------------	------------------

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

NYTMN (km.): 4500.423	NYTME (km.): 582.433	Building: PIER 1
Emission Point: OGT14		
Height (ft.): 57	Length (in.): 240	Width (in.): 154
NYTMN (km.): 4500.423	NYTME (km.): 582.433	Building: PIER 1
Emission Point: OGT15		
Height (ft.): 62	Length (in.): 240	Width (in.): 154
NYTMN (km.): 4500.423	NYTME (km.): 582.433	Building: PIER 1
Emission Point: OGT16		
Height (ft.): 62	Length (in.): 240	Width (in.): 154
NYTMN (km.): 4500.423	NYTME (km.): 582.433	Building: PIER 1
Emission Point: OGT17		
Height (ft.): 62	Length (in.): 240	Width (in.): 154
NYTMN (km.): 4500.423	NYTME (km.): 582.433	Building: PIER 1
Emission Point: OGT18		
Height (ft.): 62	Length (in.): 240	Width (in.): 154
NYTMN (km.): 4500.423	NYTME (km.): 582.433	Building: PIER 1
Emission Point: OSD12		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD13		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD14		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD15		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD16		
Height (ft.): 36	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD17		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD18		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1

**Item 40.2:**

The following emission points are included in this permit for the cited Emission Unit:



Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Emission Unit: N-A0006

Emission Point: OGT21  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OGT22  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OGT23  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OGT24  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OGT25  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OGT26  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OGT27  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OGT28  
 Height (ft.): 57 Length (in.): 240 Width (in.): 154  
 NYTMN (km.): 4500.423 NYTME (km.): 582.433 Building: PIER 1

Emission Point: OSD21  
 Height (ft.): 37 Diameter (in.): 8  
 NYTMN (km.): 4500.472 NYTME (km.): 582.395 Building: PIER1

Emission Point: OSD22  
 Height (ft.): 37 Diameter (in.): 8  
 NYTMN (km.): 4500.472 NYTME (km.): 582.395 Building: PIER 1

Emission Point: OSD23  
 Height (ft.): 37 Diameter (in.): 8  
 NYTMN (km.): 4500.472 NYTME (km.): 582.395 Building: PIER1

Emission Point: OSD24  
 Height (ft.): 37 Diameter (in.): 8  
 NYTMN (km.): 4500.472 NYTME (km.): 582.395 Building: PIER 1

Emission Point: OSD25

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD26		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD27		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1
Emission Point: OSD28		
Height (ft.): 37	Diameter (in.): 8	
NYTMN (km.): 4500.472	NYTME (km.): 582.395	Building: PIER 1

**Condition 41: Process Definition By Emission Unit**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 41.1:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: N-A0005  
 Process: D01 Source Classification Code: 2-01-001-01  
 Process Description:  
 This process includes 8 combustion turbines on barge 1 rated at 297 mmbtu/hr each. This process covers the combustion of distillate oil in these turbines.

Emission Source/Control: 0GT11 - Combustion  
 Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT12 - Combustion  
 Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT13 - Combustion  
 Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT14 - Combustion  
 Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT15 - Combustion  
 Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT16 - Combustion  
 Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT17 - Combustion  
 Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT18 - Combustion

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Design Capacity: 297 million Btu per hour

**Item 41.2:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: N-A0005

Process: NG1

Source Classification Code: 2-01-001-01

Process Description:

This process includes 8 combustion turbines on barge 1 rated at 297 mmbtu/hr each. This process covers the combustion of natural gas in these turbines.

Emission Source/Control: 0GT11 - Combustion

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT12 - Combustion

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT13 - Combustion

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT14 - Combustion

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT15 - Combustion

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT16 - Combustion

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT17 - Combustion

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT18 - Combustion

Design Capacity: 297 million Btu per hour

**Item 41.3:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: N-A0005

Process: SD1

Source Classification Code: 2-01-001-01

Process Description:

This process includes 8 diesel starter engines on barge 1 rated at 600 hp each and combusting #2 fuel oil..

Emission Source/Control: OSD11 - Combustion

Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD12 - Combustion

Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD13 - Combustion

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD15 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD16 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD17 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD18 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD14 - Process  
Design Capacity: 600 horsepower (mechanical)

**Item 41.4:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: N-A0006

Process: D02

Source Classification Code: 2-01-001-01

Process Description:

This process includes 8 combustion turbines on barge 2 rated at 297 mmbtu/hr each. This process covers the combustion of distillate oil in these turbines.

Emission Source/Control: 0GT21 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT22 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT23 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT24 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT25 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT26 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT27 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT28 - Combustion  
Design Capacity: 297 million Btu per hour

**Item 41.5:**

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: N-A0006  
Process: NG2 Source Classification Code: 2-01-001-01  
Process Description:  
This process includes 8 combustion turbines on barge 2 rated at 297 mmbtu/hr each. This process covers the combustion of natural gas in these turbines.

Emission Source/Control: 0GT21 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT22 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT23 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT24 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT25 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT26 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT27 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT28 - Combustion  
Design Capacity: 297 million Btu per hour

**Item 41.6:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: N-A0006  
Process: SD2 Source Classification Code: 2-01-001-01  
Process Description:  
This process includes 8 diesel starter engines on barge 2 rated at 600 hp each and combusting #2 fuel oil.

Emission Source/Control: 0GT21 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT22 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT23 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT24 - Combustion

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT25 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT26 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT27 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: 0GT28 - Combustion  
Design Capacity: 297 million Btu per hour

Emission Source/Control: OSD21 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD22 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD23 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD24 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD25 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD26 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD27 - Combustion  
Design Capacity: 600 horsepower (mechanical)

Emission Source/Control: OSD28 - Combustion  
Design Capacity: 600 horsepower (mechanical)

**Condition 42: Emission Unit Permissible Emissions**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR Subpart 201-7**

**Item 42.1:**

The sum of emissions from all regulated processes specified in this permit for the emission unit cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: N-A0005

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

PTE(s): 1,424 pounds per hour  
7,314,269 pounds per year

Emission Unit: N-A0006

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 1,424 pounds per hour  
7,314,269 pounds per year

**Condition 43: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR Subpart 201-6**

**Item 43.1:**

The Compliance Certification activity will be performed for:

Emission Unit: N-A0005

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 43.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Beginning with the effective date of this permit, the permittee must comply with the following during the term of the permit:

1. The sulfur content of all deliveries of fuel oil to the facility shall be limited to 0.15 ppm (referred to as ultra low sulfur diesel (ULSD)).
2. A log of the sulfur content in oil per tank will be submitted to the Department on a quarterly basis.

Process Material: ULTRA LOW SULFUR DIESEL FUEL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 15 parts per million by weight

Reference Test Method: EPA Approved method

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 3 calendar month(s).

**Condition 44: Capping Monitoring Condition**

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Effective between the dates of 03/24/2020 and 03/23/2025

**Applicable Federal Requirement: 6 NYCRR Subpart 201-7****Item 44.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40 CFR Part 75

**Item 44.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 44.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 44.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 44.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 44.6:**

The Compliance Certification activity will be performed for:

Emission Unit: N-A0005

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 44.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

To maintain its status as a "Low Mass Emission Unit", the Applicant requests a federally enforceable cap of 50 tons



Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

nox per ozone season per combustion turbine. This corresponds to 400 tons of NO<sub>x</sub> from this emission unit for the period may 1 through sept 30 each year. Following equation will be used to verify emissions with the cap.

$D + G < 50$  tons/unit/ozone season of NO<sub>x</sub>, where:

D= monthly tons of NO<sub>x</sub> from distillate oil combustion as determined by the following equation  
(Monthly unit heat input, oil) x (epa accepted part 75.19 nox emission factor, oil)  
Mmbtu, oil x lbs of NO<sub>x</sub>/mmbtu, oil

G= monthly tons of nox from natural gas combustion as determined by the following equation  
(Monthly unit heat input, natural gas) x (EPA accepted Part 75.19 NO<sub>x</sub> emission factor, gas)  
Mmbtu, natural gas x lbs of nox/mmbtu, natural gas

Emission factor will be determined in accordance with 40 CFR 75.19

Work Practice Type: PARAMETER OF PROCESS MATERIAL  
Process Material: FUEL  
Parameter Monitored: OXIDES OF NITROGEN  
Upper Permit Limit: 50 tons  
Reference Test Method: CFR Part75.19  
Monitoring Frequency: MONTHLY  
Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -  
SEE MONITORING DESCRIPTION  
Reporting Requirements: QUARTERLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 4/30/2020.  
Subsequent reports are due every 3 calendar month(s).

**Condition 45: Compliance Certification**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 45.1:**

The Compliance Certification activity will be performed for:

Emission Unit: N-A0006

Regulated Contaminant(s):  
CAS No: 007446-09-5 SULFUR DIOXIDE

**Item 45.2:**

Compliance Certification shall include the following monitoring:

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Monitoring Type: MONITORING OF PROCESS OR CONTROL  
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Beginning with the effective date of this permit, the permittee must comply with the following during the term of the permit:

1. The sulfur content of all deliveries of fuel oil to the facility shall be limited to 0.15 ppm (referred to as ultra low sulfur diesel (ULSD)).
2. A log of the sulfur content in oil per tank will be submitted to the Department on a quarterly basis.

Process Material: ULTRA LOW SULFUR DIESEL FUEL

Parameter Monitored: SULFUR CONTENT

Upper Permit Limit: 15 parts per million by weight

Reference Test Method: EPA Approved Method

Monitoring Frequency: PER DELIVERY

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY  
TIME (INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 12 calendar month(s).

**Condition 46: Capping Monitoring Condition**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable Federal Requirement: 6 NYCRR Subpart 201-7**

**Item 46.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40 CFR Part 75

**Item 46.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 46.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 46.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 46.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 46.6:**

The Compliance Certification activity will be performed for:

Emission Unit: N-A0006

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 46.7:**

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

To maintain its status as a "low mass emission unit", the Applicant requests a federally enforceable cap of 50 tons NOx per ozone season per combustion turbine. This corresponds to 400 tons of NOx from this emission unit for the period may 1 through sept 30 each year. Following equation will be used to verify emissions with the cap.

$D + G < 50$  tons/unit/ozone season of NOx. Where,

D= monthly tons of NOx from distillate oil combustion as determined by the following equation  
 (Monthly unit heat input, oil) x (EPA accepted part 75.19 NOx emission factor, oil)  
 Mmbtu, oil x lbs of NOx/mmbtu, oil

G= monthly tons of nox from natural gas combustion as determined by the following equation  
 (Monthly unit heat input, natural gas) x (EPA accepted part 75.19 NOx emission factor, gas)  
 Mmbtu, natural gas x lbs of nox/mmbtu, natural gas

Emission factor will be determined in accordance with 40 CFR 75.19

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

Process Material: FUEL

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 50 tons

Reference Test Method: CFR Part 75.19

Monitoring Frequency: MONTHLY

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -  
SEE MONITORING DESCRIPTION

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 4/30/2020.

Subsequent reports are due every 3 calendar month(s).

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

**STATE ONLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

**NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Emergency Defense - 6 NYCRR 201-1.5**

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;

(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

#### STATE ONLY APPLICABLE REQUIREMENTS

**The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.**

**Condition 47: Contaminant List**

**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable State Requirement:ECL 19-0301**

**Item 47.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000050-00-0  
Name: FORMALDEHYDE

CAS No: 007446-09-5  
Name: SULFUR DIOXIDE

CAS No: 0NY075-00-0  
Name: PARTICULATES

CAS No: 0NY210-00-0  
Name: OXIDES OF NITROGEN

**Condition 48: Malfunctions and start-up/shutdown activities**

**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable State Requirement:6 NYCRR 201-1.4**

**Item 48.1:**

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

**Condition 49: Air pollution prohibited**  
**Effective between the dates of 03/24/2020 and 03/23/2025**

**Applicable State Requirement:6 NYCRR 211.1**

**Item 49.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Permit ID: 2-6102-00086/00011

Facility DEC ID: 2610200086