

Facility DEC ID: 2630800513

PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 2-6308-00513/00012
Effective Date: 09/09/2019 Expiration Date: 09/08/2024

Permit Issued To: JAMAICA BAY PEAKING FACILITY LLC
14-25 BAY 24TH ST
FAR ROCKAWAY, NY 11691

BA YSWATER PEAKING FACILITY LLC
14-25 BAY 24TH ST
FAR ROCKAWAY, NY 11691

Contact: GLENROY LESLIE
BA YSWATER/JAMAICA BAY PEAKING FACILITY
14-25 24TH ST
FAR ROCKAWAY, NY 11691
(718) 471-5541

Facility: BA YSWATER / JAMAICA BAY PEAKING FACILITY
14-25 BAY 24TH ST
FAR ROCKAWAY, NY 11691

Contact: GLENROY LESLIE
BA YSWATER/JAMAICA BAY PEAKING FACILITY
14-25 24TH ST
FAR ROCKAWAY, NY 11691
(718) 471-5541

Description:
NATURE OF BUSINESS AT THE FACILITY:

Electric Power Generation.

4911 (primary SIC) - Electrical Services.

TYPE OF EQUIPMENT AND OPERATION AT THE FACILITY:

This existing facility consists of a Pratt & Whitney FT8 Twin Pack (natural gas firing only) and a Pratt & Whitney FT-8 Swift Pack (natural gas & distillate oil), and an emergency 105 brake horsepower fire pump burning diesel fuel. The turbines shall operate as simple cycle units, and both units are equipped with SCR, a CO catalyst, and will continuously monitor emissions in accordance with 40 CFR 75.

Facility DEC ID: 2630800513

AIR PERMIT APPLICABILITY:

Title V permit for an existing facility (operating permit).

CAPPING/NON-APPLICABILITY RULES:

This facility shall accept permit limitations which shall keep the emission units below the applicability threshold for 6 NYCRR 231-2 and 40 CFR 52.21.

CONSENT ORDERS OR COMPLIANCE PLANS:

None.

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: STEPHEN A WATTS
 47-40 21ST ST
 LONG ISLAND CITY, NY 11101-5401

Authorized Signature: _____ Date: ___ / ___ / ___

Facility DEC ID: 2630800513

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit.

This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the

Facility DEC ID: 2630800513

lands

or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 2630800513

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

- 5 1 Facility Inspection by the Department
- 5 2 Relationship of this Permit to Other Department Orders and Determinations
- 5 3 Applications for permit renewals, modifications and transfers
- 6 4 Permit modifications, suspensions or revocations by the Department

Facility Level

- 6 5 Submission of application for permit modification or renewal -
REGION 2 HEADQUARTERS

Facility DEC ID: 2630800513

DEC GENERAL CONDITIONS

****** General Provisions ******

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department

Applicable State Requirement: ECL 19-0305

Item 1.1:

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations

Applicable State Requirement: ECL 3-0301 (2) (m)

Item 2.1:

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers

Applicable State Requirement: 6 NYCRR 621.11

Item 3.1:

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Facility DEC ID: 2630800513

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Condition 4: Permit modifications, suspensions or revocations by the Department

Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal - REGION 2

HEADQUARTERS

Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:

NYSDEC Regional Permit Administrator
 Region 2 Headquarters
 Division of Environmental Permits
 1 Hunters Point Plaza, 4740 21st Street
 Long Island City, NY 11101-5407
 (718) 482-4997

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: JAMAICA BAY PEAKING FACILITY LLC
14-25 BAY 24TH ST
FAR ROCKAWAY, NY 11691

BAYSWATER PEAKING FACILITY LLC
14-25 BAY 24TH ST
FAR ROCKAWAY, NY 11691

Facility: BAYSWATER / JAMAICA BAY PEAKING FACILITY
14-25 BAY 24TH ST
FAR ROCKAWAY, NY 11691

Authorized Activity By Standard Industrial Classification Code:
4911 - ELECTRIC SERVICES

Permit Effective Date: 09/09/2019

Permit Expiration Date: 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

PAGELOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

9	1	6 NYCRR 200.6: Acceptable Ambient Air Quality
9	2	6 NYCRR 201-6.4 (a) (7): Fees
9	3	6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
10	4	6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
10	5	6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
12	6	6 NYCRR 201-6.4 (e): Compliance Certification
14	7	6 NYCRR 202-2.1: Compliance Certification
15	8	6 NYCRR 202-2.5: Recordkeeping requirements
15	9	6 NYCRR 215.2: Open Fires - Prohibitions
16	10	6 NYCRR 200.7: Maintenance of Equipment
17	11	6 NYCRR 201-1.7: Recycling and Salvage
17	12	6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
17	13	6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
17	14	6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
18	15	6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
18	16	6 NYCRR 201-6.4 (a) (8): Right to Inspect
18	17	6 NYCRR 201-6.4 (f) (6): Off Permit Changes
19	18	6 NYCRR 202-1.1: Required Emissions Tests
19	19	40 CFR Part 68: Accidental release provisions.
20	20	40CFR 82, Subpart F: Recycling and Emissions Reduction
20	21	6 NYCRR Subpart 201-6: Emission Unit Definition
21	22	6 NYCRR Subpart 201-6: Compliance Certification
22	23	6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
22	24	6 NYCRR 201-7.1: Facility Permissible Emissions
22	25	6 NYCRR 207.2 (a): Episode Action Plan
23	26	6 NYCRR 211.2: Visible Emissions Limited
23	27	6 NYCRR 225-1.2: Compliance Certification
24	28	6 NYCRR 227-1.3 (a): Compliance Certification
24	29	40CFR 52.21, Subpart A: Compliance Certification
25	30	40CFR 52.21, Subpart A: Compliance Certification
26	31	40CFR 60.4, NSPS Subpart A: EPA Region 2 address.
27	32	40CFR 60.7(a), NSPS Subpart A: Modification Notification
27	33	40CFR 60.7(b), NSPS Subpart A: Recordkeeping requirements.
27	34	40CFR 60.14, NSPS Subpart A: Modifications.
28	35	40CFR 63, Subpart ZZZZ: Applicability
28	36	40 CFR Part 72: Facility Subject to Title IV Acid Rain Regulations and Permitting
28	37	40 CFR Part 97: Federal Cross-State Air Pollution Regulation (CSAPR)
28	38	40CFR 97.406, Subpart AAAAA: Compliance Certification
29	39	40CFR 97.606, Subpart CCCCC: Compliance Certification

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

- 31 40 40CFR 97, Subpart EEEEE: Compliance Certification
- Emission Unit Level**
- 32 41 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 33 42 6 NYCRR Subpart 201-6: Process Definition By Emission Unit
- 34 43 6 NYCRR 201-7.1: Emission Unit Permissible Emissions
- 35 44 6 NYCRR 201-7.1: Process Permissible Emissions

EU=U-00001

- 35 45 6 NYCRR Subpart 201-6: Compliance Certification
- 36 46 6 NYCRR Subpart 201-6: Compliance Certification
- 37 47 6 NYCRR Subpart 201-6: Compliance Certification
- 37 48 6 NYCRR Subpart 201-6: Compliance Certification
- 38 49 6 NYCRR Subpart 201-6: Compliance Certification
- 39 *50 6 NYCRR 201-7.1: Capping Monitoring Condition
- 41 51 40CFR 60.332(a)(1), NSPS Subpart GG: Compliance Certification
- 42 52 40CFR 60.334(a), NSPS Subpart GG: Compliance Certification
- 42 53 40CFR 60.334(b), NSPS Subpart GG: CEMS

EU=U-00002

- 43 54 6 NYCRR Subpart 201-6: Compliance Certification
- 44 *55 6 NYCRR 201-7.1: Capping Monitoring Condition
- 45 56 40CFR 60.332(a)(1), NSPS Subpart GG: Compliance Certification
- 46 57 40CFR 60.334(a), NSPS Subpart GG: Compliance Certification
- 47 58 40CFR 60.334(b), NSPS Subpart GG: CEMS

EU=U-00002,Proc=002

- 47 59 6 NYCRR Subpart 201-6: Compliance Certification
- 48 60 6 NYCRR Subpart 201-6: Compliance Certification
- 49 61 6 NYCRR Subpart 201-6: Compliance Certification
- 50 62 6 NYCRR Subpart 201-6: Compliance Certification

EU=U-00002,Proc=003

- 51 63 6 NYCRR Subpart 201-6: Compliance Certification
- 52 64 6 NYCRR Subpart 201-6: Compliance Certification
- 53 65 6 NYCRR Subpart 201-6: Compliance Certification
- 54 66 6 NYCRR Subpart 201-6: Compliance Certification
- 55 67 6 NYCRR 227.2 (b) (1): Compliance Certification

EU=U-00002,EP=00002,Proc=003

- 56 68 6 NYCRR 227-1.3: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 59 69 ECL 19-0301: Contaminant List
- 60 70 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 60 71 6 NYCRR 211.1: Air pollution prohibited
- 61 72 6 NYCRR 242-1.5: CO2 Budget Trading Program - Excess emission requirements
- 61 73 6 NYCRR 242-1.5: Compliance Demonstration

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

63 74 6 NYCRR 242-1.5: Compliance Demonstration

NOTE: * preceding the condition number indicates capping.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

FEDERALLY ENFORCEABLE CONDITIONS

Renewal 2/FINAL

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

- Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)**
The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.
- Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)**
Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.
- Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)**
Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)**
The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)**

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR 201-6.4 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR 201-6.4 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;

ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. When additional applicable requirements under the act become applicable to a title V facility with a remaining permit term of three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the department pursuant to the provisions of section 201- 6.6 of this Subpart.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Condition 1: Acceptable Ambient Air Quality
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 200.6

Item 1.1:

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 3: Recordkeeping and Reporting of Compliance Monitoring
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 201-6.4 (c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

Condition 4: Records of Monitoring, Sampling, and Measurement
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Condition 5: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 30 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.
- (2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.
- (3) For all other deviations from permit requirements, the report shall be contained in the 6 month monitoring report required above.
- (4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Monitoring Frequency: SEMI-ANNUALLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement: 6 NYCRR 201-6.4 (e)**Item 6.1:**

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related record keeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as specified in any special permit terms or conditions;and
 - such additional requirements as may be specified elsewhere in this permit related to compliance certification.
- ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.
- iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department’s Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Air Compliance Branch
 USEPA Region 2 DECA/ACB
 290 Broadway, 21st Floor
 New York, NY 10007

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer
 Hunters Point Plaza
 47-40 21st Street
 Long Island City, NY 11101-5407

The address for the BQA is as follows:

NYSDEC
 Bureau of Quality Assurance
 625 Broadway
 Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
 Reporting Requirements: ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:
 The Compliance Certification activity will be performed for the Facility.

Item 7.2:
 Compliance Certification shall include the following monitoring:

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 8.1:

(a) The following records shall be maintained for at least five years:

- (1) a copy of each emission statement submitted to the department;
- and
- (2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires - Prohibitions
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 215.2

Item 9.1:

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 9.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

**Condition 10: Maintenance of Equipment
Effective between the dates of 09/09/2019 and 09/08/2024**

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement:6 NYCRR 200.7**Item 10.1:**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage**Effective between the dates of 09/09/2019 and 09/08/2024****Applicable Federal Requirement:6 NYCRR 201-1.7****Item 11.1:**

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air**Effective between the dates of 09/09/2019 and 09/08/2024****Applicable Federal Requirement:6 NYCRR 201-1.8****Item 12.1:**

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility**Effective between the dates of 09/09/2019 and 09/08/2024****Applicable Federal Requirement:6 NYCRR 201-3.2 (a)****Item 13.1:**

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Condition 14: Trivial Sources - Proof of Eligibility**Effective between the dates of 09/09/2019 and 09/08/2024****Applicable Federal Requirement:6 NYCRR 201-3.3 (a)****Item 14.1:**

The owner or operator of an emission source or activity that is listed as being trivial in this

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Condition 15: Requirement to Provide Information
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 201-6.4 (a) (4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: Right to Inspect
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 201-6.4 (a) (8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

- (i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;
- (ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
- (iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and
- (iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Condition 17: Off Permit Changes
Effective between the dates of 09/09/2019 and 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)**Item 17.1:**

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 202-1.1**Item 18.1:**

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Accidental release provisions.
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:40 CFR Part 68**Item 19.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:

- 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
- 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
 C/O CSC
 8400 Corporate Dr
 Carrollton, Md. 20785

Condition 20: Recycling and Emissions Reduction
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40 CFR 82, Subpart F

Item 20.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 21: Emission Unit Definition
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 21.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00001

Emission Unit Description:

This emission unit for "BA YSWATER" consists of two simple cycle Pratt and Whitney FT-8 turbines (Twin Pak) combusting natural gas only. Emissions of oxide of nitrogen are controlled, via water injection and Selective Catalytic Reduction (SCR), to 2.5 ppmvd (corrected to 15% O₂). Emissions of CO are controlled by an oxidation catalyst. Concentrations of NO_x, CO and a diluent (O₂) are measured in the stack by a certified CEMs. Heat input is continuously monitored via the measurement of natural gas flow with a certified meter. In addition, water

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

injection rates are continuously monitored.

Building(s): B1
B2

Item 21.2:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00002

Emission Unit Description:

This emission unit for "JAMAICA BAY" consists of two simple cycle Pratt and Whitney FT-8 turbines combusting natural gas and fuel oil. Each turbine is equipped with water injection for control of oxides of nitrogen. Additional NO_x control by a selective catalytic reduction (SCR) system achieves 2.5 ppmvd (corrected to 15% O₂) for natural gas combustion and 6.0 ppmvd (corrected to 15% O₂) for fuel oil combustion. Emission of CO are controlled by an oxidation catalyst. Concentrations of NO_x, CO, ammonia and a diluent (O₂) are measured in the stack by a certified CEMS. Heat input is continuously monitored via the measurement of natural gas and fuel oil with certified meters. In addition, water and ammonia injection rates are continuously monitored.

Building(s): B2
B3

Condition 22: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 22.1:

The Compliance Certification activity will be performed for the Facility.

Item 22.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner and/or operator of this facility shall operate the gas turbines at base load (maximum load), either individually or simultaneously, at all times except during periods of start-up, shutdown and malfunction. The permittee shall maintain a log, at the facility, which records all periods of non-base load operation and the reason for such operation. These records shall be maintained, at the facility, for a period of no less than five years.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Monitoring Frequency: SEMI-ANNUALLY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2019.
Subsequent reports are due every 3 calendar month(s).

Condition 23: Progress Reports Due Semiannually
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 201-6.4 (d) (4)

Item 23.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 24: Facility Permissible Emissions
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 24.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following
Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0	PTE: 90,000 pounds per year
Name: OXIDES OF NITROGEN	

Condition 25: Episode Action Plan
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 207.2 (a)

Item 25.1: Any person who owns a significant air contamination source shall submit a proposed episode action plan to the commissioner within 90 days of his request therefor. The plan shall contain detailed steps which will be taken by the air contamination source owner to reduce air contaminant emissions during each stage of an air pollution episode. The commissioner shall make available and furnish with his request therefor, guidelines for preparation of episode action plans.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Condition 26: Visible Emissions Limited
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 211.2

Item 26.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 27: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 225-1.2

Item 27.1:

The Compliance Certification activity will be performed for the Facility.

Item 27.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

Owners and/or operators of a stationary combustion installation that fires distillate oil other than number two heating oil are limited to the purchase of distillate oil with 0.0015 percent sulfur by weight or less on or after July 1, 2014 and are limited to the firing of distillate oil including number two heating oil with 0.0015 percent sulfur by weight or less on or after July 1, 2016.

The department will require fuel analyses, information on the quantity of fuel received, fired or sold, and results of stack sampling, stack monitoring, and other procedures to ensure compliance with the provisions of this Subpart. All records must be maintained at the facility for a minimum of five years.

Facility owners subject to this Subpart must submit a written report of the fuel sulfur content exceeding the applicable sulfur-in-fuel limitation, measured emissions exceeding the applicable sulfur-in-fuel limitation, measured emissions exceeding the applicable equivalent emission rate, and the nature and cause of such

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

exceedances if known, for each calendar quarter, within 30 days after the end of any quarterly period in which an exceedance takes place.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
 Process Material: DISTILLATES - NUMBER 1 AND NUMBER 2 OIL
 Parameter Monitored: SULFUR CONTENT
 Upper Permit Limit: 0.0015 percent by weight
 Monitoring Frequency: PER DELIVERY
 Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME (INSTANTANEOUS/DISCRETE OR GRAB)
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 28: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)

Item 28.1:
 The Compliance Certification activity will be performed for the Facility.

Item 28.2:
 Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE

Monitoring Description:
 No owner or operator of a combustion installation shall emit greater than 20 percent opacity except for one six minute period per hour, not to exceed 27 percent, based upon the six minute average in reference test method 9 in Appendix A of 40 CFR 60.

Parameter Monitored: OPACITY
 Upper Permit Limit: 20 percent
 Averaging Method: 6-MINUTE AVERAGE (METHOD 9)
 Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 6 calendar month(s).

Condition 29: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement: 40CFR 52.21, Subpart A

Item 29.1:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: U-00001

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 007664-41-7 AMMONIA

Item 29.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain and operate a continuous emissions monitor for ammonia slip, in accordance with the manufacturer's specifications. The limit requirements have been determined from the manufacturer's specifications, control device guarantees, and fuel characteristics, as per the facility's application. The facility must submit a compliance test protocol, for an initial ammonia slip compliance test using USEPA conditional test method 27, for Department approval. Within 180 days of the initial operation of the SCR, the facility must perform a compliance test and submit the results for Department approval. The permittee shall maintain records of ammonia measurements, at the facility, for a period of not less than five years.

Manufacturer Name/Model Number: Ammonia Analyzer

Parameter Monitored: AMMONIA

Upper Permit Limit: 10 parts per million by volume (dry, corrected to 15% O₂)

Reference Test Method: CTM027

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 3 calendar month(s).

Condition 30: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement:40CFR 52.21, Subpart A**Item 30.1:**

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: U-00001

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 30.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The permittee shall install, calibrate, maintain and operate a continuous emissions monitor for the measurement of carbon monoxide. The limit requirements have been determined from the manufacturer's specifications, control device guarantees, and fuel characteristics, as per the facility's application. The permittee shall maintain records of carbon monoxide measurements, at the facility, for a period of no less than five years. A CO stack concentration limit is reported as 8.0 ppmvd @ 15% O₂.

Manufacturer Name/Model Number: CO Monitor

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 8.0 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: Method 10

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 3 calendar month(s).

Condition 31: EPA Region 2 address.**Effective between the dates of 09/09/2019 and 09/08/2024****Applicable Federal Requirement:40CFR 60.4, NSPS Subpart A****Item 31.1:**

All requests, reports, applications, submittals, and other communications to the Administrator pursuant to this part shall be submitted in duplicate to the following address:

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Director, Division of Enforcement and Compliance Assistance
USEPA Region 2
290 Broadway, 21st Floor
New York, NY 10007-1886

Copies of all correspondence to the administrator pursuant to this part shall also be submitted to the NYSDEC Regional Office issuing this permit (see address at the beginning of this permit) and to the following address:

NYSDEC
Bureau of Quality Assurance
625 Broadway
Albany, NY 12233-3258

Condition 32: Modification Notification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40 CFR 60.7(a), NSPS Subpart A

Item 32.1:

Any owner or operator subject to 40 CFR Part 60 shall furnish the Administrator and this office with the following information:

- a notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless the change is specifically exempted under 40 CFR Part 60. The notice shall be post marked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productivity capability of the facility before and after the change, and the expected completion date of the change. The Administrator and/or this Department may request additional information regarding the change.

Condition 33: Recordkeeping requirements.
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40 CFR 60.7(b), NSPS Subpart A

Item 33.1:

Affected owners or operators shall maintain records of occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.

Condition 34: Modifications.
Effective between the dates of 09/09/2019 and 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement:40CFR 60.14, NSPS Subpart A

Item 34.1:

Within 180 days of the completion of any physical or operational change (as defined in section 60.14), compliance with the applicable standards must be achieved.

Condition 35: Applicability

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:40CFR 63, Subpart ZZZZ

Item 35.1:

Facilities that have reciprocating internal combustion engines must comply with applicable portions of 40 CFR 63 subpart ZZZZ.

Condition 36: Facility Subject to Title IV Acid Rain Regulations and Permitting

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:40 CFR Part 72

Item 36.1: This facility is subject to the Title IV Acid Rain Regulations found in 40 CFR Parts 72, 73, 75, 76, 77 and 78. The Acid Rain Permit is an attachment to this permit.

Condition 37: Federal Cross-State Air Pollution Regulation (CSAPR)

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:40 CFR Part 97

Item 37.1: This facility is subject to the CSAPR requirements found in 40 CFR Part 97.

Condition 38: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:40CFR 97.406, Subpart AAAAA

Item 38.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 38.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.413 through 97.418 of Subpart AAAAA. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.

(2) The facility, and the designated representative, of each TR NO_x Annual source (facility) and each TR NO_x Annual Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.430 through 97.435 of Subpart AAAAA and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of TR NO_x Annual allowances and to determine compliance with the TR NO_x Annual emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Annual facility and each TR NO_x Annual Unit at the facility shall hold, in the facilities compliance account, TR NO_x Annual allowances available for deduction for such control period under §97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Annual Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 39: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement: 40CFR 97.606, Subpart CCCCC**Item 39.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5 SULFUR DIOXIDE

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

- (1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.613 through 97.618 of Subpart CCCCC. The facility shall notify the Department of this representative (and alternative) with contact information upon issuance of this permit and when any changes are made to the representative (or alternative) or their contact information.
- (2) The facility, and the designated representative, of each TR SO₂ Group 1 source (facility) and each TR SO₂ Group 1 Unit at the facility shall comply with the monitoring, reporting, and recordkeeping requirements of §§97.630 through 97.635 of Subpart CCCCC and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality-assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring data are submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.
- (3) The emissions data determined shall be used to calculate allocations of TR SO₂ Group 1 allowances and to determine compliance with the TR SO₂ Group 1 emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO₂ Group 1 facility and each TR SO₂ Group 1 Unit at the facility shall hold,

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

in the facilities compliance account, TR SO2 Group 1 allowances available for deduction for such control period under §97.624(a) in an amount not less than the tons of total SO2 emissions for such control period from all TR SO2 Group 1 Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 40: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40 CFR 97, Subpart EEEEE

Item 40.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

(1) The facility shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with §§97.813 through 97.818 of Subpart EEEEE. The facility shall notify the Department of this representative (and alternate) with contact information upon issuance of this permit and when any changes are made to the representative (or alternate) or their contact information.

(2) The facility, and the designated representative, of each CSAPR NOx Ozone Season source (facility) and each CSAPR NOx Ozone Season Unit at the facility must comply with the monitoring, reporting, and recordkeeping requirements of §§97.830 through 97.835 of Subpart EEEEE and subpart H of part 75 of this chapter. This includes but is not limited to: requirements for installation, certification, and data accounting for all required monitoring systems; requirements for recording, reporting, and quality assurance of the data; and certification of compliance of such data. Data from continuous emission monitoring equipment are to be submitted quarterly (calendar year). These reports are generally due 30 days after the end of a calendar quarter. All other monitoring

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

data are to be submitted to the DEC semiannually (calendar year). These reports are due on January 30th and July 30th of each year.

(3) The emissions data determined shall be used to calculate allocations of CSAPR NOx Ozone Season allowances and to determine compliance with the CSAPR NOx Ozone Season emissions limitation and assurance provisions. As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NOx Ozone Season facility and each CSAPR NOx Ozone Season Unit at the facility shall hold, in the facilities compliance account, CSAPR NOx Ozone Season allowances available for deduction for such control period under §97.824(a) in an amount not less than the tons of total NOx emissions for such control period from all CSAPR NOx Ozone Season Units at the facility.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

****** Emission Unit Level ******

Condition 41: Emission Point Definition By Emission Unit
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 41.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00001

Emission Point: 00001

Height (ft.): 110 Diameter (in.): 175
 NYTMN (km.): 4496.188 NYTME (km.): 604.695 Building: B1

Item 41.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-00002

Emission Point: 00002

Height (ft.): 110 Diameter (in.): 180
 NYTMN (km.): 4496.352 NYTME (km.): 604.723 Building: B3

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Condition 42: Process Definition By Emission Unit
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 42.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00001

Process: 001

Source Classification Code: 2-01-002-01

Process Description:

Two simple cycle Pratt and Whitney FT8 Combustion Turbines fired solely by natural gas. The two turbines serve one generator (Twin Pac configuration) and exhaust to a common stack.

Emission Source/Control: 00001 - Combustion

Design Capacity: 282.5 million Btu per hour

Emission Source/Control: 00002 - Combustion

Design Capacity: 282.5 million Btu per hour

Emission Source/Control: 100CO - Control

Control Type: CATALYTIC OXIDATION

Emission Source/Control: 10SCR - Control

Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Item 42.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002

Process: 002

Source Classification Code: 2-01-002-01

Process Description:

Two simple cycle Pratt and Whitney FT 8 Combustion turbines fired by natural gas. The two turbines serve one generator (Swift Pac configuration) and exhaust to a common stack.

Emission Source/Control: 00003 - Combustion

Design Capacity: 290.2 million Btu per hour

Emission Source/Control: 00004 - Combustion

Design Capacity: 290.2 million Btu per hour

Emission Source/Control: 200CO - Control

Control Type: CATALYTIC OXIDATION

Emission Source/Control: 20SCR - Control

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Item 42.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-00002

Process: 003

Source Classification Code: 2-01-001-01

Process Description:

Two simple cycle Pratt and Whitney FT8 Combustion turbines fired by fuel oil. The two turbines serve one generator (Swift Pac configuration) and exhaust to a common stack.

Emission Source/Control: 00003 - Combustion

Design Capacity: 290.2 million Btu per hour

Emission Source/Control: 00004 - Combustion

Design Capacity: 290.2 million Btu per hour

Emission Source/Control: 200CO - Control

Control Type: CATALYTIC OXIDATION

Emission Source/Control: 20SCR - Control

Control Type: SELECTIVE CATALYTIC REDUCTION (SCR)

Condition 43: Emission Unit Permissible Emissions

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 43.1:

The sum of emissions from all regulated processes specified in this permit for the emission unit cited

shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit: U-00001

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 5.2 pounds per hour

45,600 pounds per year

Emission Unit: U-00002

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

PTE(s): 13.5 pounds per hour

45,000 pounds per year

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Condition 44: Process Permissible Emissions

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 44.1:

The sum of emissions from the regulated process cited shall not exceed the following Potential to Emit (PTE) rates for each regulated contaminant:

Emission Unit:	U-00001	Process:	001
	CAS No: 0NY210-00-0		
	Name: OXIDES OF NITROGEN		
	PTE(s): 5.2 pounds per hour		45,600 pounds per year
Emission Unit:	U-00002	Process:	002
	CAS No: 0NY210-00-0		
	Name: OXIDES OF NITROGEN		
	PTE(s): 5.5 pounds per hour		45,000 pounds per year

Condition 45: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 45.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 45.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The permittee shall install, calibrate, maintain, and operate a continuous emissions monitor for the measurement of carbon monoxide. The permittee shall maintain records of carbon monoxide measurements, at the facility for a period of no less than five years.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Manufacturer Name/Model Number: CARBON MONOXIDE MONITOR
 Parameter Monitored: CARBON MONOXIDE
 Upper Permit Limit: 44 tons
 Reference Test Method: EPA METHOD 10
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 46: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 46.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 46.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
 Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall only during periods of start-up, not to exceed 30 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their facility for minimum of five years.

Manufacturer Name/Model Number: NOx Analyser
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 20 pounds
 Reference Test Method: none
 Monitoring Frequency: CONTINUOUS
 Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
 SEE MONITORING DESCRIPTION
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Condition 47: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 47.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 47.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain and operate a continuous emission monitor for oxides of nitrogen. This limit shall apply only during periods of shutdown, not to exceed 20 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their facility for a minimum of five years.

Manufacturer Name/Model Number: NO_x ANALYZER

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 4 pounds

Reference Test Method: EPA METHOD

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 3 calendar month(s).

Condition 48: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 48.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 48.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous emission monitor for oxides of nitrogen. The 5.7 pounds per hour limit shall apply during steady state operations where the turbine operates for the full 60 minutes of the hour. The following shall apply during steady state partial hours (less than the full 60 minutes) of operation. NOTE: Natural Gas operation does not include any period in which oil is fired):

Time Period (minutes)	NOx Mass Limit (pounds)
1-15	2.85
16-30	3.5
31-45	4.35
46-59	
5.7	

Emissions in excess of the steady state limits for full 60 minute hours and steady state partial hours shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their facility for a minimum of five years.

Manufacturer Name/Model Number: NOX ANALYZER
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 5.7 pounds per hour
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1 HOUR ROLLING AVERAGE ROLLED EVERY 1 MINUTE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 49: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Item 49.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 49.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain and operate a continuous 40 CFR Part 75 emissions monitor for measuring and recording oxides of nitrogen. The facility shall also install either a continuous monitor for oxygen or carbon dioxide. All records shall be maintained by the applicant at their facility for a minimum of five years.

The 2.5 ppmvd limit shall be applicable during periods of steady state operation where the facility operates 16 or more minutes consecutively in one clock hour. Emissions in excess of 2.5 ppmvd limit shall be reported quarterly through the facility's excess emission report.

Manufacturer Name/Model Number: NOx Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 2.5 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: 40 CFR 75

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 3 calendar month(s).

Condition 50: Capping Monitoring Condition

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 201-7.1

Item 50.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

would otherwise be subject to:

6 NYCRR Subpart 231-2

Item 50.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 50.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 50.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 50.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 50.6:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 50.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator shall install, calibrate, maintain, and operate a continuous emissions monitor to determine compliance with the limitation for oxides of nitrogen.

The facility shall determine compliance based on a one hour average. All records shall be maintained at the facility for a minimum of five years.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Manufacturer Name/Model Number: NO_x CEM
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 22.8 tons per year
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 51: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40CFR 60.332(a)(1), NSPS Subpart GG

Item 51.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 51.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0075 (14.4/Y) + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NO_x emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility.

The value of Y shall not exceed 14.4 kilojoules per watt

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

hour, and

F = NOX emission allowance for fuel-bound nitrogen as defined in paragraph 40 CFR 60.332(a)(4).

Manufacturer Name/Model Number: NOx ANALYZER

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 101.4 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: EPA METHOD

Monitoring Frequency: CONTINUOUS

Averaging Method: 4-HOUR ROLLING AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Condition 52: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40CFR 60.334(a), NSPS Subpart GG

Item 52.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00001

Item 52.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of any stationary gas turbine subject to the provisions of 40 CFR 60 Subpart GG that is using water injection to control NOx emissions shall install and operate a continuous monitoring system to monitor and record fuel consumption and the ratio of water to fuel fired in the turbine. This system shall be accurate to within +/- 5.0 percent and shall be approved by the Administrator.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Condition 53: CEMS

Effective between the dates of 09/09/2019 and 09/08/2024

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Applicable Federal Requirement:40CFR 60.334(b), NSPS Subpart GG

Item 53.1:

This Condition applies to Emission Unit: U-00001

Item 53.2:

The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NOX emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NOX and O2 monitors. As an alternative, a CO2 monitor may be used to adjust the measured NOX concentrations to 15 percent O2 by either converting the CO2 hourly averages to equivalent O2 concentrations using Equation F-14a or F-14b in appendix F to 40 CFR Part 75 and making the adjustments to 15 percent O2, or by using the CO2 readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as specified in 40 CFR 60.334(b)(1), (2) and (3).

Condition 54: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 54.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):

CAS No: 000630-08-0 CARBON MONOXIDE

Item 54.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The permittee shall install, calibrate, maintain, and operate a continuous emissions monitor for the measurement of carbon monoxide. The permittee shall maintain records of carbon monoxide measurements, at the facility for a period of no less than five years.

Manufacturer Name/Model Number: CO MONITOR

Parameter Monitored: CARBON MONOXIDE

Upper Permit Limit: 44 tons

Reference Test Method: EPA METHOD 10

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Monitoring Frequency: CONTINUOUS
Averaging Method: 12 MONTH AVERAGE - ROLLED MONTHLY
Reporting Requirements: QUARTERLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 10/30/2019.
Subsequent reports are due every 3 calendar month(s).

Condition 55: Capping Monitoring Condition
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 201-7.1

Item 55.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

6 NYCRR Subpart 231-2

Item 55.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 55.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 55.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 55.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 55.6:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 55.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The owner or operator shall install, calibrate, maintain, and operate a continuous emissions monitor to determine compliance with the limitation for oxides of nitrogen. The facility shall determine compliance based on a one hour average. All records shall be maintained at the facility for a minimum of five years.

Manufacturer Name/Model Number: NOx CEM
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 22.5 tons per year
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 56: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40CFR 60.332(a)(1), NSPS Subpart GG

Item 56.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 56.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

which contain nitrogen oxides in excess of:

$$\text{STD} = 0.0075 (14.4/Y) + F$$

where:

STD = allowable ISO corrected (if required as given in §60.335(b)(1)) NOX emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NOX emission allowance for fuel-bound nitrogen as defined in paragraph 40 CFR 60.332(a)(4).

Manufacturer Name/Model Number: NOx ANALYZER

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 101.4 parts per million by volume
(dry, corrected to 15% O₂)

Reference Test Method: EPA METHOD

Monitoring Frequency: CONTINUOUS

Averaging Method: 4-HOUR ROLLING AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Condition 57: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 40CFR 60.334(a), NSPS Subpart GG

Item 57.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Item 57.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of any stationary gas turbine

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

subject to the provisions of 40 CFR 60 Subpart GG that is using water injection to control NOx emissions shall install and operate a continuous monitoring system to monitor and record fuel consumption and the ratio of water to fuel fired in the turbine. This system shall be accurate to within +/- 5.0 percent and shall be approved by the Administrator.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Condition 58: CEMS**Effective between the dates of 09/09/2019 and 09/08/2024****Applicable Federal Requirement: 40 CFR 60.334(b), NSPS Subpart GG****Item 58.1:**

This Condition applies to Emission Unit: U-00002

Item 58.2:

The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NOX emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NOX and O2 monitors. As an alternative, a CO2 monitor may be used to adjust the measured NOX concentrations to 15 percent O2 by either converting the CO2 hourly averages to equivalent O2 concentrations using Equation F-14a or F-14b in appendix F to 40 CFR Part 75 and making the adjustments to 15 percent O2, or by using the CO2 readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as specified in 40 CFR 60.334(b)(1), (2) and (3).

Condition 59: Compliance Certification**Effective between the dates of 09/09/2019 and 09/08/2024****Applicable Federal Requirement: 6 NYCRR Subpart 201-6****Item 59.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Process: 002

Regulated Contaminant(s):

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 59.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain and operate a continuous emission monitor for oxides of nitrogen. This limit shall apply only during periods of shutdown, not to exceed 20 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 4 pounds

Reference Test Method: 40 CFTR 75

Monitoring Frequency: CONTINUOUS

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE

Reporting Requirements: QUARTERLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 3 calendar month(s).

Condition 60: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 60.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Process: 002

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 60.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

The facility shall install, calibrate, maintain and operate a continuous 40 CFR Part 75 emissions

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

monitor for measuring and recording oxides of nitrogen.
 The facility shall also install either a continuous oxygen or carbon dioxide monitor. All records shall be maintained by the applicant at their facility for a minimum of five years

The 2.5 ppmvd limit shall be applicable during periods of steady state operation where the facility operates 16 or more minutes consecutively in one clock hour. Emissions in excess of 2.5 ppmvd limit shall be reported quarterly through the facility's excess emission report.

Manufacturer Name/Model Number: NOx Analyzer
 Upper Permit Limit: 2.5 parts per million by volume (dry, corrected to 15% O2)
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 61: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 61.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002
 Process: 002

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 61.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. This limit shall only during periods of start-up, not to exceed 30 minutes per occurrence. Emissions in excess of this limit shall be reported

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

quarterly through the facility's excess emissions report.
 All records shall be maintained by the applicant at their facility for minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 20 pounds
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
 SEE MONITORING DESCRIPTION
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 62: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 62.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002
 Process: 002

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 62.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
 Monitoring Description:

The facility shall install, calibrate, maintain, and operate a continuous emission monitor for oxides of nitrogen. The 5.7 pounds per hour limit shall apply during steady state operations where the turbine operates for the full 60 minutes of the hour. The following shall apply during steady state partial hours (less than the full 60 minutes) of operation. NOTE: Natural Gas operation does not include any period in which oil is fired):

Time Period (minutes)	NOx Mass Limit (pounds)
1-15	2.85
16-30	3.5

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

years.

Manufacturer Name/Model Number: NOx Analyzer
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 2 pounds
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 64: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 64.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002
 Process: 003

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 64.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)
 Monitoring Description:

This facility shall install, calibrate, maintain, and operate a continuous 40 CFR 75 emissions monitor for measuring and recording oxides of nitrogen. The facility shall also install either a continuous monitor for oxygen or carbon dioxide. All records shall be maintained by the applicant at their facility for a minimum of five years.

The 6.0 ppmvd limit shall be applicable during periods of steady state operation where the facility operates 16 or more minutes consecutively in one clock hour. When a facility operates in steady state less than 16 minutes (consecutively in one clock hour, and excluding start-up or shutdown) the 6.0 ppmvd limit does not apply.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Emissions in excess of either the 6.0 ppmvd limit shall be reported quarterly through the facility's excess emissions report.

Manufacturer Name/Model Number: NOx Analyzer
 Upper Permit Limit: 6 parts per million by volume (dry, corrected to 15% O₂)
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: 1-HOUR AVERAGE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 65: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 65.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002
 Process: 003

Regulated Contaminant(s):
 CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 65.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. The 13.9 pounds per hour limit shall apply during steady state operations where the turbine operates for the full 60 minutes of the hour. The following limits shall apply during steady state partial hours (less than the full 60 minutes) of operation:

Time Period (minutes) (pounds)	NOx Mass Limit
1 - 15 6.95	
16 - 30	

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

8.5

31 - 45

11.0

46 - 59

13.9

Emissions in excess of the steady state limits for full 60 minute hours and steady state partial hours shall be reported quarterly through the facility's excess emissions report. All records shall be maintained by the applicant at their facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 13.9 pounds per hour

Reference Test Method: 40 CFR 75

Monitoring Frequency: CONTINUOUS

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Condition 66: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR Subpart 201-6

Item 66.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Process: 003

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Item 66.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This facility shall install, calibrate, maintain and operate a continuous emissions monitor for oxides of nitrogen. this limit shall apply only during periods of start-up, 30 minutes per occurrence. Emissions in excess of this limit shall be reported quarterly through the

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

facility's excess emissions report. All reports shall be maintained by the applicant at their facility for a minimum of five years.

Manufacturer Name/Model Number: NOx Analyzer
 Parameter Monitored: OXIDES OF NITROGEN
 Upper Permit Limit: 40 pounds
 Reference Test Method: 40 CFR 75
 Monitoring Frequency: CONTINUOUS
 Averaging Method: MAXIMUM - NOT TO BE EXCEEDED PER OCCURRENCE
 Reporting Requirements: QUARTERLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 10/30/2019.
 Subsequent reports are due every 3 calendar month(s).

Condition 67: Compliance Certification
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 227.2 (b) (1)

Item 67.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002
 Process: 003

Regulated Contaminant(s):
 CAS No: 0NY075-00-0 PARTICULATES

Item 67.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: INTERMITTENT EMISSION TESTING
 Monitoring Description:

Particulate emission limit for stationary combustion installation firing oil. The owner or operator shall complete the following once per term of this permit:

- 1) Submit to the Department an acceptable protocol for the testing of particulate emission limit cited in this condition.
- 2) Perform a stack test, based upon the approved test protocol, to determine compliance with the particulate emission limit cited in this condition.
- 3) All records shall be maintained at the facility for a minimum of five years.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Parameter Monitored: PARTICULATES

Upper Permit Limit: 0.10 pounds per million Btus

Reference Test Method: Method 5

Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT

Averaging Method: AVERAGING METHOD AS PER REFERENCE TEST
METHOD INDICATED

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Condition 68: Compliance Certification

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable Federal Requirement: 6 NYCRR 227-1.3

Item 68.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-00002

Emission Point: 00002

Process: 003

Item 68.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Operators of oil-fired internal combustion engines which are not exempt from permitting and where a continuous opacity monitor is not utilized for measuring smoke emissions, shall be required to perform the following:

1) Observe the stack for each internal combustion engine which is operating on oil once per day for visible emissions. This observation(s) must be conducted during daylight hours except during adverse weather conditions (fog, rain, or snow).

2) The results of each observation must be recorded in a bound logbook or other format acceptable to the Department. The following data must be recorded for each stack:

- weather condition
- was a plume observed?

This logbook must be retained at the facility for five (5)

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

years after the date of the last entry.

3) If the operator observes any visible emissions (other than steam - see below) two consecutive days firing oil (the firing of other fuels in between days of firing oil does not count as an interruption in the consecutive days of firing oil), then a Method 9 analysis (based upon a 6-minute mean) of the affected emission point(s) must be conducted within two (2) business days of such occurrence.

The results of the Method 9 analysis must be recorded in the logbook. The operator must contact the Regional Air Pollution Control Engineer within one (1) business day of performing the Method 9 analysis if the opacity standard is contravened. Upon notification, any corrective actions or future compliance schedules shall be presented to the Department for acceptance.

**** NOTE **** Steam plumes generally form after leaving the top of the stack (this is known as a detached plume). The distance between the stack and the beginning of the detached plume may vary, however, there is (normally) a distinctive distance between the plume and stack. Steam plumes are white in color and have a billowy consistency. Steam plumes dissipate within a short distance of the stack (the colder the air the longer the steam plume will last) and leave no dispersion trail downwind of the stack.

Monitoring Frequency: DAILY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

STATE ONLY ENFORCEABLE CONDITIONS

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;

(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 69: Contaminant List

Effective between the dates of 09/09/2019 and 09/08/2024

Applicable State Requirement:ECL 19-0301

Item 69.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000630-08-0
Name: CARBON MONOXIDE

CAS No: 007446-09-5
Name: SULFUR DIOXIDE

CAS No: 007664-41-7
Name: AMMONIA

CAS No: 0NY075-00-0
Name: PARTICULATES

CAS No: 0NY210-00-0
Name: OXIDES OF NITROGEN

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Condition 70: Malfunctions and start-up/shutdown activities
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable State Requirement:6 NYCRR 201-1.4

Item 70.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 71: Air pollution prohibited
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable State Requirement:6 NYCRR 211.1

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Item 71.1:

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**Condition 72: CO2 Budget Trading Program - Excess emission requirements
Effective between the dates of 09/09/2019 and 09/08/2024**

Applicable State Requirement:6 NYCRR 242-1.5

Item 72.1:

The owners and operators of a CO2 budget source that has excess emissions in any control period shall:

- (1) forfeit the CO2 allowances required for deduction under 6 NYCRR Part 242-6.5(d)(1), provided CO2 offset allowances may not be used to cover any part of such excess emissions; and
- (2) pay any fine, penalty, or assessment or comply with any other remedy imposed under 6 NYCRR Part 242-6.5(d)(2).

**Condition 73: Compliance Demonstration
Effective between the dates of 09/09/2019 and 09/08/2024**

Applicable State Requirement:6 NYCRR 242-1.5

Item 73.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 73.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators and, to the extent applicable, the CO2 authorized account representative of each CO2 budget source and each CO2 budget unit at the source shall comply with the monitoring requirements of Subpart 242-8. The emissions measurements recorded and reported in accordance with Subpart 242-8 of this Part shall be used to determine compliance by the unit with the following CO2 requirements:

- (1) The owners and operators of each CO2 budget source and each CO2 budget unit at the source shall hold CO2

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

allowances available for compliance deductions under Section 242-6.5, as of the CO₂ allowance transfer deadline, in the source's compliance account in an amount not less than the total CO₂ emissions for the control period from all CO₂ budget units at the source, as determined in accordance with Subparts 242-6 and 242-8.

(2) Each ton of CO₂ emitted in excess of the CO₂ budget emissions limitation shall constitute a separate violation of this Part and applicable state law.

(3) A CO₂ budget unit shall be subject to the requirements specified in item 1 starting on the later, of January 1, 2009 or the date on which the unit commences operation.

(4) CO₂ allowances shall be held in, deducted from, or transferred among CO₂ Allowance Tracking System accounts in accordance with Subparts 242-5, 242-6, and 242-7, and Section 242-10.7.

(5) A CO₂ allowance shall not be deducted, in order to comply with the requirements specified in item 1, for a control period that ends prior to the allocation year for which the CO₂ allowance was allocated. A CO₂ offset allowance shall not be deducted, in order to comply with the requirements under item 1, beyond the applicable percent limitations set out in 6NYCRR Part 242-6.5(a)(3).

(6) A CO₂ allowance under the CO₂ Budget Trading Program is a limited authorization by the Department or a participating state to emit one ton of CO₂ in accordance with the CO₂ Budget Trading Program. No provision of the CO₂ Budget Trading Program, the CO₂ budget permit application, or the CO₂ budget permit or any provision of law shall be construed to limit the authority of the Department or a participating state to terminate or limit such authorization.

(7) A CO₂ allowance under the CO₂ Budget Trading Program does not constitute a property right.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Subsequent reports are due every 6 calendar month(s).

Condition 74: Compliance Demonstration
Effective between the dates of 09/09/2019 and 09/08/2024

Applicable State Requirement: 6 NYCRR 242-1.5

Item 74.1:

The Compliance Demonstration activity will be performed for the Facility.

Item 74.2:

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owners and operators of the CO₂ budget source and each CO₂ budget unit at the source shall keep on site at the source each of the following documents for a period of 10 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 10 years, in writing by the department.

(i) The account certificate of representation for the CO₂ authorized account representative for the source and each CO₂ budget unit at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 6 NYCRR Part 242-2.4, provided that the certificate and documents shall be retained on site at the source beyond such 10-year period until such documents are superseded because of the submission of a new account certificate of representation.

(ii) All emissions monitoring information, in accordance with Subpart 242-8 and 40 CFR 75.57.

(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CO₂ Budget Trading Program.

(iv) Copies of all documents used to complete a CO₂ budget permit application and any other submission under the CO₂ Budget Trading Program or to demonstrate compliance with the requirements of the CO₂ Budget Trading Program.

The CO₂ authorized account representative of a CO₂ budget source and each CO₂ budget unit at the source shall submit the reports and compliance certifications required under the CO₂ Budget Trading Program, including those under

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513

Subpart 242-4.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 10/30/2019.

Subsequent reports are due every 6 calendar month(s).

Permit ID: 2-6308-00513/00012

Facility DEC ID: 2630800513