

Facility DEC ID: 3335200039

PERMIT
Under the Environmental Conservation Law (ECL)

IDENTIFICATION INFORMATION

Permit Type: Air Title V Facility
Permit ID: 3-3352-00039/00029
Effective Date: 07/09/2020 Expiration Date: 07/08/2025

Permit Issued To: BALL CORPORATION
9300 WEST 108TH CIRCLE
BROOMFIELD, CO 80021-3682

Contact: JOETTE BAILEY-KEOWN
BALL CORPORATION
9300 WEST 108TH CIRCLE
BROOMFIELD, CO 80021
(303) 460-5433

Facility: BALL METAL BEVERAGE CONTAINER CORP
95 BALLARD RD
MIDDLETOWN, NY 10940

Description:

The facility manufactures two piece aluminum beverage cans. Air emissions are from the cutting and forming of the can bodies, and also from coating and decorating operations. Emissions from these operations include volatile organic compounds (VOC), hazardous air pollutants (HAP), and particulates. A regenerative thermal oxidizer is used at the facility to reduce VOC and HAP emissions.

There are two emission units which comprise the facility. Emission Unit U-10100 consists of production lines which apply coatings to the aluminum cans. Emission Unit U-20200 consists of the processes for forming the can body.

Potential VOC emissions exceed the major source threshold, as defined in 6NYCRR Part 201-2. Therefore, the facility is subject to the provisions of Title V of the Clean Air Act. Applicable regulations include 6NYCRR Parts 200, 201, 202, 211, 212, and 228, 40 CFR 60 Subpart WW, and 40 CFR 63 Subpart ZZZZ.

Facility DEC ID: 3335200039

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: REBECCA S CRIST
21 S PUTT CORNERS RD
NEW PALTZ, NY 12561

Authorized Signature: _____ Date: ___ / ___ / ___

Facility DEC ID: 3335200039

Notification of Other State Permittee Obligations

Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

Item B: Permittee's Contractors to Comply with Permit

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

Item C: Permittee Responsible for Obtaining Other Required Permits

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

Item D: No Right to Trespass or Interfere with Riparian Rights

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 3335200039

PAGE LOCATION OF CONDITIONS

PAGE

DEC GENERAL CONDITIONS

General Provisions

- 4 1 Facility Inspection by the Department
- 4 2 Relationship of this Permit to Other Department Orders and Determinations
- 4 3 Applications for permit renewals, modifications and transfers
- 5 4 Permit modifications, suspensions or revocations by the Department

Facility Level

- 5 5 Submission of application for permit modification or renewal-REGION 3 HEADQUARTERS

Facility DEC ID: 3335200039

DEC GENERAL CONDITIONS

**** General Provisions ****

For the purpose of your Title V permit, the following section contains state-only enforceable terms and conditions.

GENERAL CONDITIONS - Apply to ALL Authorized Permits.

Condition 1: Facility Inspection by the Department**Applicable State Requirement: ECL 19-0305****Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

Item 1.2:

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

Item 1.3:

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

Condition 2: Relationship of this Permit to Other Department Orders and Determinations**Applicable State Requirement: ECL 3-0301 (2) (m)****Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

Condition 3: Applications for permit renewals, modifications and transfers**Applicable State Requirement: 6 NYCRR 621.11****Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

Item 3.2:

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

Item 3.3

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be

Facility DEC ID: 3335200039

submitted prior to actual transfer of ownership.

Condition 4: Permit modifications, suspensions or revocations by the Department
Applicable State Requirement: 6 NYCRR 621.13

Item 4.1:

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

****** Facility Level ******

Condition 5: Submission of application for permit modification or renewal-REGION 3
HEADQUARTERS
Applicable State Requirement: 6 NYCRR 621.6 (a)

Item 5.1:

Submission of applications for permit modification or renewal are to be submitted to:
NYSDEC Regional Permit Administrator
Region 3 Headquarters
Division of Environmental Permits
21 South Putt Corners Road
New Paltz, NY 12561-1696
(845) 256-3054

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Permit Under the Environmental Conservation Law (ECL)

ARTICLE 19: AIR POLLUTION CONTROL - TITLE V PERMIT

IDENTIFICATION INFORMATION

Permit Issued To: BALL CORPORATION
9300 WEST 108TH CIRCLE
BROOMFIELD, CO 80021-3682

Facility: BALL METAL BEVERAGE CONTAINER CORP
95 BALLARD RD
MIDDLETOWN, NY 10940

Authorized Activity By Standard Industrial Classification Code:
3411 - METAL CANS

Permit Effective Date: 07/09/2020

Permit Expiration Date: 07/08/2025

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

- 7 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 8 2 6 NYCRR 201-6.4 (a) (7): Fees
- 8 3 6 NYCRR 201-6.4 (c): Recordkeeping and Reporting of Compliance Monitoring
- 8 4 6 NYCRR 201-6.4 (c) (2): Records of Monitoring, Sampling, and Measurement
- 9 5 6 NYCRR 201-6.4 (c) (3) (ii): Compliance Certification
- 11 6 6 NYCRR 201-6.4 (e): Compliance Certification
- 13 7 6 NYCRR 202-2.1: Compliance Certification
- 13 8 6 NYCRR 202-2.5: Recordkeeping requirements
- 13 9 6 NYCRR 215.2: Open Fires - Prohibitions
- 15 10 6 NYCRR 200.7: Maintenance of Equipment
- 15 11 6 NYCRR 201-1.7: Recycling and Salvage
- 15 12 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air
- 15 13 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 16 14 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 16 15 6 NYCRR 201-6.4 (a) (4): Requirement to Provide Information
- 16 16 6 NYCRR 201-6.4 (a) (8): Right to Inspect
- 17 17 6 NYCRR 201-6.4 (f) (6): Off Permit Changes
- 17 18 6 NYCRR 202-1.1: Required Emissions Tests
- 17 19 40 CFR Part 68: Accidental release provisions.
- 18 20 40CFR 82, Subpart F: Recycling and Emissions Reduction
- 18 21 6 NYCRR Subpart 201-6: Emission Unit Definition
- 19 22 6 NYCRR 201-6.4 (b) (1): Compliance Certification
- 19 23 6 NYCRR 201-6.4 (d) (4): Progress Reports Due Semiannually
- 19 24 6 NYCRR 201-7.1: Facility Permissible Emissions
- 20 *25 6 NYCRR 201-7.1: Capping Monitoring Condition
- 21 *26 6 NYCRR 201-7.1: Capping Monitoring Condition
- 22 *27 6 NYCRR 201-7.1: Capping Monitoring Condition
- 24 *28 6 NYCRR 201-7.1: Capping Monitoring Condition
- 25 29 6 NYCRR 211.2: Visible Emissions Limited
- 25 30 6 NYCRR 212-1.6 (a): Compliance Certification
- 26 31 6 NYCRR 212-2.4 (b): Compliance Certification
- 27 32 6 NYCRR 231-11.2 (b): Compliance Certification
- 27 33 40CFR 63.6603(a), Subpart ZZZZ: Compliance Certification
- 28 34 40CFR 63.6655, Subpart ZZZZ: Compliance Certification
- 28 **Emission Unit Level**
- 28 35 6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit
- 31 36 6 NYCRR Subpart 201-6: Process Definition By Emission Unit

EU=U-10100

- 33 37 6 NYCRR 212-1.4 (l) (1): Part 228-1 process emission sources with respect to A-rated VOC contaminants
- 33 38 6 NYCRR 212-1.5 (d): Compliance Certification
- 34 39 6 NYCRR 212-1.5 (d): Compliance Certification

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

- 34 40 6 NYCRR 212-1.5 (g): Compliance Certification
- 35 41 6 NYCRR 212-1.7 (a): Emission Testing Using Approved Procedures
- 36 42 6 NYCRR 212-1.7 (b): Compliance Certification
- 36 43 6 NYCRR 228-1.3 (b) (1): Compliance Certification
- 37 44 6 NYCRR 228-1.3 (d): Surface Coating - Handling, storage and disposal
- 38 45 6 NYCRR 228-1.4 (d) (2): Compliance Certification
- 38 46 6 NYCRR 228-1.4 (d) (2): Compliance Certification
- 39 47 6 NYCRR 228-1.6 (a): Compliance Certification
- 40 48 6 NYCRR 228-1.6 (h): Compliance Certification

EU=U-10100,Proc=100

- 40 49 40CFR 60.492(c), NSPS Subpart WW: Compliance Certification

EU=U-10100,Proc=200

- 41 50 40CFR 60.492(b), NSPS Subpart WW: Compliance Certification

EU=U-10100,Proc=300

- 42 51 40CFR 60.492(a), NSPS Subpart WW: Compliance Certification

STATE ONLY ENFORCEABLE CONDITIONS

Facility Level

- 44 52 ECL 19-0301: Contaminant List
- 44 53 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 45 54 6 NYCRR 211.1: Air pollution prohibited

NOTE: * preceding the condition number indicates capping.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

FEDERALLY ENFORCEABLE CONDITIONS

Renewal 3/FINAL

**** Facility Level ****

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

The items listed below are not subject to the annual compliance certification requirements under Title V. Permittees may also have other obligations under regulations of general applicability.

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10 (b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.

Item B: Timely Application for the Renewal of Title V Permits - 6 NYCRR 201-6.2 (a) (4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR 201-6.2 (d) (12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR 201-6.4 (a) (2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR 201-6.4 (a) (3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4 (a) (5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4 (a) (6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR 201-6.4 (a) (9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR 201-6.4 (g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

facility for any violation of applicable requirements prior to or at the time of permit issuance;

iii. The applicable requirements of Title IV of the Act;

iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR 201-6.4 (i)

This Title V permit shall be reopened and revised under any of the following circumstances:

i. When additional applicable requirements under the act become applicable to a title V facility with a remaining permit term of three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the department pursuant to the provisions of section 201- 6.6 of this Subpart.

ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.

iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS
SUBJECT TO ANNUAL CERTIFICATIONS AT ALL TIMES**

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements at all times.

**Condition 1: Acceptable Ambient Air Quality
Effective between the dates of 07/09/2020 and 07/08/2025**

Applicable Federal Requirement: 6 NYCRR 200.6**Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

Condition 2: Fees
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (7)

Item 2.1:

The owner and/or operator of a stationary source shall pay fees to the Department consistent with the fee schedule authorized by ECL 72-0303.

Condition 3: Recordkeeping and Reporting of Compliance Monitoring
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (c)

Item 3.1:

The following information must be included in any required compliance monitoring records and reports:

- (i) The date, place, and time of sampling or measurements;
- (ii) The date(s) analyses were performed;
- (iii)The company or entity that performed the analyses;
- (iv) The analytical techniques or methods used including quality assurance and quality control procedures if required;
- (v) The results of such analyses including quality assurance data where required; and
- (vi) The operating conditions as existing at the time of sampling or measurement.

Any deviation from permit requirements must be clearly identified in all records and reports. Reports must be certified by a responsible official, consistent with Section 201-6.2 of Part 201.

Condition 4: Records of Monitoring, Sampling, and Measurement
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (c) (2)

Item 4.1:

Compliance monitoring and recordkeeping shall be conducted according to the terms and conditions contained in this permit and shall follow all quality assurance requirements found in applicable regulations. Records of all monitoring data and support information must be retained for a period of at least 5 years from the date of the monitoring, sampling, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

reports required by the permit.

Condition 5: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 6 NYCRR 201-6.4 (c) (3) (ii)

Item 5.1:

The Compliance Certification activity will be performed for the Facility.

Item 5.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

To meet the requirements of this facility permit with respect to reporting, the permittee must:

Submit reports of any required monitoring at a minimum frequency of every 6 months, based on a calendar year reporting schedule. These reports shall be submitted to the Department within 60 days after the end of a reporting period. All instances of deviations from permit requirements must be clearly identified in such reports. All required reports must be certified by the responsible official for this facility.

Notify the Department and report permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken. Where the underlying applicable requirement contains a definition of prompt or otherwise specifies a time frame for reporting deviations, that definition or time frame shall govern. Where the underlying applicable requirement fails to address the time frame for reporting deviations, reports of deviations shall be submitted to the permitting authority based on the following schedule:

- (1) For emissions of a hazardous air pollutant (as identified in an applicable regulation) that continue for more than an hour in excess of permit requirements, the report must be made within 24 hours of the occurrence.
- (2) For emissions of any regulated air pollutant, excluding those listed in paragraph (1) of this section, that continue for more than two hours in excess of permit requirements, the report must be made within 48 hours.
- (3) For all other deviations from permit requirements,

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

the report shall be contained in the 6 month monitoring report required above.

(4) This permit may contain a more stringent reporting requirement than required by paragraphs (1), (2) or (3) above. If more stringent reporting requirements have been placed in this permit or exist in applicable requirements that apply to this facility, the more stringent reporting requirement shall apply.

If above paragraphs (1) or (2) are met, the source must notify the permitting authority by telephone during normal business hours at the Regional Office of jurisdiction for this permit, attention Regional Air Pollution Control Engineer (RAPCE) according to the timetable listed in paragraphs (1) and (2) of this section. For deviations and incidences that must be reported outside of normal business hours, on weekends, or holidays, the DEC Spill Hotline phone number at 1-800-457-7362 shall be used. A written notice, certified by a responsible official consistent with 6 NYCRR Part 201-6.2(d)(12), must be submitted within 10 working days of an occurrence for deviations reported under (1) and (2). All deviations reported under paragraphs (1) and (2) of this section must also be identified in the 6 month monitoring report required above.

The provisions of 6 NYCRR 201-1.4 shall apply if the permittee seeks to have a violation excused unless otherwise limited by regulation. In order to have a violation of a federal regulation (such as a new source performance standard or national emissions standard for hazardous air pollutants) excused, the specific federal regulation must provide for an affirmative defense during start-up, shutdowns, malfunctions or upsets. Notwithstanding any recordkeeping and reporting requirements in 6 NYCRR 201-1.4, reports of any deviations shall not be on a less frequent basis than the reporting periods described in paragraphs (1) and (4) above.

In the case of any condition contained in this permit with a reporting requirement of "Upon request by regulatory agency" the permittee shall include in the semiannual report, a statement for each such condition that the monitoring or recordkeeping was performed as required or requested and a listing of all instances of deviations from these requirements.

In the case of any emission testing performed during the previous six month reporting period, either due to a request by the Department, EPA, or a regulatory requirement, the permittee shall include in the semiannual

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

report a summary of the testing results and shall indicate whether or not the Department or EPA has approved the results.

All semiannual reports may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). Mailing addresses for the above referenced persons are contained in the monitoring condition for 6 NYCRR Part 201-6.4(e), contained elsewhere in this permit.

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
Reports due 60 days after the reporting period.
The initial report is due 3/1/2021.
Subsequent reports are due every 6 calendar month(s).

Condition 6: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 6 NYCRR 201-6.4 (e)

Item 6.1:

The Compliance Certification activity will be performed for the Facility.

Item 6.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

Requirements for compliance certifications with terms and conditions contained in this facility permit include the following:

- i. Compliance certifications shall contain:
 - the identification of each term or condition of the permit that is the basis of the certification;
 - the compliance status;
 - whether compliance was continuous or intermittent;
 - the method(s) used for determining the compliance status of the facility, currently and over the reporting period consistent with the monitoring and related record keeping and reporting requirements of this permit;
 - such other facts as the Department may require to determine the compliance status of the facility as

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

specified in any special permit terms or conditions;
and

- such additional requirements as may be specified elsewhere in this permit related to compliance certification.

ii. The responsible official must include in the annual certification report all terms and conditions contained in this permit which are identified as being subject to certification, including emission limitations, standards, or work practices. That is, the provisions labeled herein as "Compliance Certification" are not the only provisions of this permit for which an annual certification is required.

iii. Compliance certifications shall be submitted annually. Certification reports are due 30 days after the anniversary date of four consecutive calendar quarters. The first report is due 30 days after the calendar quarter that occurs just prior to the permit anniversary date, unless another quarter has been acceptable by the Department.

iv. All annual compliance certifications may be submitted electronically or physically. Electronic reports shall be submitted using the Department's Air Compliance and Emissions Electronic-Reporting system (ACE). If the facility owner or operator elects to send physical copies instead, two copies shall be sent to the Department (one copy to the regional air pollution control engineer (RAPCE) in the regional office and one copy to the Bureau of Quality Assurance (BQA) in the DEC central office) and one copy shall be sent to the Administrator (or his or her representative). The mailing addresses for the above referenced persons are:

Chief – Air Compliance Branch
USEPA Region 2 DECA/ACB
290 Broadway, 21st Floor
New York, NY 10007

The address for the RAPCE is as follows:

Regional Air Pollution Control Engineer
NYSDEC
21 South Putt Corners Road
New Paltz, NY 12561-1696

The address for the BQA is as follows:

NYSDEC
Bureau of Quality Assurance

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

625 Broadway
Albany, NY 12233-3258

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2021.
Subsequent reports are due on the same day each year

Condition 7: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 202-2.1

Item 7.1:
The Compliance Certification activity will be performed for the Facility.

Item 7.2:
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES
Monitoring Description:

Emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year. Statements are to be mailed to: New York State Department of Environmental Conservation, Division of Air Resources, Bureau of Air Quality Planning, 625 Broadway, Albany NY 12233-3251

Monitoring Frequency: ANNUALLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due by April 15th for previous calendar year

Condition 8: Recordkeeping requirements
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 202-2.5

Item 8.1:
(a) The following records shall be maintained for at least five years:

(1) a copy of each emission statement submitted to the department; and

(2) records indicating how the information submitted in the emission statement was determined, including any calculations, data, measurements, and estimates used.

(b) These records shall be made available at the facility to the representatives of the department upon request during normal business hours.

Condition 9: Open Fires - Prohibitions
Effective between the dates of 07/09/2020 and 07/08/2025

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Applicable Federal Requirement: 6 NYCRR 215.2**Item 9.1:**

Except as allowed by Title 6 NYCRR Section 215.3, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

Item 9.2

Per Section 215.3, burning in an open fire, provided it is not contrary to other law or regulation, will be allowed as follows:

- (a) On-site burning in any town with a total population less than 20,000 of downed limbs and branches (including branches with attached leaves or needles) less than six inches in diameter and eight feet in length between May 15th and the following March 15th. For the purposes of this subdivision, the total population of a town shall include the population of any village or portion thereof located within the town. However, this subdivision shall not be construed to allow burning within any village.
- (b) Barbecue grills, maple sugar arches and similar outdoor cooking devices when actually used for cooking or processing food.
- (c) Small fires used for cooking and camp fires provided that only charcoal or untreated wood is used as fuel and the fire is not left unattended until extinguished.
- (d) On-site burning of agricultural wastes as part of a valid agricultural operation on contiguous agricultural lands larger than five acres actively devoted to agricultural or horticultural use, provided such waste is actually grown or generated on those lands and such waste is capable of being fully burned within a 24-hour period.
- (e) The use of liquid petroleum fueled smudge pots to prevent frost damage to crops.
- (f) Ceremonial or celebratory bonfires where not otherwise prohibited by law, provided that only untreated wood or other agricultural products are used as fuel and the fire is not left unattended until extinguished.
- (g) Small fires that are used to dispose of a flag or religious item, and small fires or other smoke producing process where not otherwise prohibited by law that are used in connection with a religious ceremony.
- (h) Burning on an emergency basis of explosive or other dangerous or contraband materials by police or other public safety organization.
- (i) Prescribed burns performed according to Part 194 of this Title.
- (j) Fire training, including firefighting, fire rescue, and fire/arson investigation training, performed under applicable rules and guidelines of the New York State Department of State's Office of Fire Prevention and Control. For fire training performed on acquired structures, the structures must be emptied and stripped of any material that is toxic, hazardous or likely to emit toxic smoke (such as asbestos, asphalt shingles and vinyl siding or other vinyl products) prior to burning and must be at least 300 feet from other occupied structures. No more than one structure per lot or within a 300 foot radius (whichever is bigger) may be burned in a training exercise.
- (k) Individual open fires as approved by the Director of the Division of Air Resources as may be required in response to an outbreak of a plant or animal disease upon request by the commissioner of the Department of Agriculture and Markets, or for the destruction of invasive plant and insect species.
- (l) Individual open fires that are otherwise authorized under the environmental conservation law, or by rule or regulation of the Department.

MANDATORY FEDERALLY ENFORCEABLE PERMIT CONDITIONS

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

SUBJECT TO ANNUAL CERTIFICATIONS ONLY IF APPLICABLE

The following federally enforceable permit conditions are mandatory for all Title V permits and are subject to annual compliance certification requirements only if effectuated during the reporting period.

[NOTE: The corresponding annual compliance certification for those conditions not effectuated during the reporting period shall be specified as "not applicable".]

Condition 10: Maintenance of Equipment
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 200.7

Item 10.1:

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

Condition 11: Recycling and Salvage
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-1.7

Item 11.1:

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

Condition 12: Prohibition of Reintroduction of Collected Contaminants to the air
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-1.8

Item 12.1:

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

Condition 13: Exempt Sources - Proof of Eligibility
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-3.2 (a)

Item 13.1:

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Condition 14: Trivial Sources - Proof of Eligibility

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-3.3 (a)

Item 14.1:

The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Condition 15: Requirement to Provide Information

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (4)

Item 15.1:

The owner and/or operator shall furnish to the department, within a reasonable time, any information that the department may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the department copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to the administrator along with a claim of confidentiality, if the administrator initiated the request for information or otherwise has need of it.

Condition 16: Right to Inspect

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (a) (8)

Item 16.1:

The department or an authorized representative shall be allowed upon presentation of credentials and other documents as may be required by law to:

(i) enter upon the permittee's premises where a facility subject to the permitting requirements of this Subpart is located or emissions-related activity is conducted, or where records must be kept under the conditions of the permit;

(ii) have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;

(iii) inspect at reasonable times any emission sources, equipment (including monitoring and air pollution control equipment), practices, and operations regulated or required under the permit; and

(iv) sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit or applicable requirements.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Condition 17: Off Permit Changes

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (f) (6)

Item 17.1:

No permit revision will be required for operating changes that contravene an express permit term, provided that such changes would not violate applicable requirements as defined under this Part or contravene federally enforceable monitoring (including test methods), recordkeeping, reporting, or compliance certification permit terms and conditions. Such changes may be made without requiring a permit revision, if the changes are not modifications under any provision of title I of the act and the changes do not exceed the emissions allowable under the permit (whether expressed therein as a rate of emissions or in terms of total emissions) provided that the facility provides the administrator and the department with written notification as required below in advance of the proposed changes within a minimum of seven days. The facility owner or operator, and the department shall attach each such notice to their copy of the relevant permit.

(i) For each such change, the written notification required above shall include a brief description of the change within the permitted facility, the date on which the change will occur, any change in emissions, and any permit term or condition that is no longer applicable as a result of the change.

(ii) The permit shield described in section 6 NYCRR 201-6.4 shall not apply to any change made pursuant to this paragraph.

Condition 18: Required Emissions Tests

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 202-1.1

Item 18.1:

For the purpose of ascertaining compliance or non-compliance with any air pollution control code, rule or regulation, the commissioner may require the person who owns such air contamination source to submit an acceptable report of measured emissions within a stated time.

Condition 19: Accidental release provisions.

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:40 CFR Part 68

Item 19.1:

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:

1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,

2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center
 C/O CSC
 8400 Corporate Dr
 Carrollton, Md. 20785

Condition 20: Recycling and Emissions Reduction
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:40CFR 82, Subpart F

Item 20.1:

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

The following conditions are subject to annual compliance certification requirements for Title V permits only.

Condition 21: Emission Unit Definition
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 21.1:

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-10100

Emission Unit Description:

This emission unit consists of basecoat/clearcoat, inside coating, respray, ink printing, and overvarnish application onto beverage cans. The emission unit also includes curing operations and a regenerative thermal oxidizer (RTO) for reducing VOC emissions from all process ovens. A heat exchanger on the RTO outlet will lower the RTO exit gas temperature.

Building(s): BLDG1

Item 21.2:

The facility is authorized to perform regulated processes under this permit for:

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Emission Unit: U-20200

Emission Unit Description:

This emission unit consists of body makers, trimmers, and associated mist collectors and cyclones.

Building(s): BLDG1

Condition 22: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (b) (1)

Item 22.1:

The Compliance Certification activity will be performed for the Facility.

Item 22.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The facility must notify the Department of any change in the coatings and inks used, which results in the potential of any HAP emission of more than 10 tons per year. Such HAP emission will then be limited to 9.5 tons in any consecutive 12 month period.

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL CHANGE

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 23: Progress Reports Due Semiannually
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-6.4 (d) (4)

Item 23.1:

Progress reports consistent with an applicable schedule of compliance are to be submitted at least semiannually, or at a more frequent period if specified in the applicable requirement or by the department. Such progress reports shall contain the following:

- (i) dates for achieving the activities, milestones, or compliance required in the schedule of compliance, and dates when such activities, milestones or compliance were achieved; and
- (ii) an explanation of why any dates in the schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

Condition 24: Facility Permissible Emissions
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-7.1

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Item 24.1:

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 000050-00-0 Name: FORMALDEHYDE	PTE: 19,000 pounds per year
CAS No: 000112-25-4 Name: ETHANOL,2-(HEXYLOXY)	PTE: 19,000 pounds per year
CAS No: 0NY100-00-0 Name: TOTAL HAP	PTE: 48,000 pounds per year

**Condition 25: Capping Monitoring Condition
Effective between the dates of 07/09/2020 and 07/08/2025**

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 25.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40 CFR Part 63, Subpart KKKK

Item 25.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 25.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 25.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 25.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Item 26.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 26.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 26.6:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 000112-25-4 ETHANOL,2-(HEXYLOXY)

Item 26.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Hexyl cellosolve (also called 2-(Hexyloxy)ethanol) emissions shall not exceed 9.5 tons in any consecutive 12 month period. The content of this compound in the coatings and inks shall be monitored and used to determine emissions.

Parameter Monitored: ETHANOL,2-(HEXYLOXY)

Upper Permit Limit: 9.5 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL TOTAL ROLLED MONTHLY

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 12 calendar month(s).

Condition 27: Capping Monitoring Condition
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 201-7.1

Item 27.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

40 CFR Part 63, Subpart KKKK

Item 27.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 27.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 27.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 27.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 27.6:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):
CAS No: 0NY100-00-0 TOTAL HAP

Item 27.7:

Compliance Certification shall include the following monitoring:

Capping: Yes
Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

Emissions of total hazardous air pollutants (HAP) shall not exceed 24.0 tons in any consecutive 12 month period. The HAP content in the coatings and inks shall be monitored and used to determine HAP emissions. A capture efficiency of 80.8 percent and an oxidizer destruction efficiency of 97 percent will be used in calculating HAP emissions. Coating usage, an emission factor of 0.014 pounds of formaldehyde per pounds of coating solids, and an oxidizer formaldehyde destruction efficiency of 92.2 percent will be used in calculating formaldehyde emissions.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Parameter Monitored: TOTAL HAP
Upper Permit Limit: 24.0 tons per year
Monitoring Frequency: MONTHLY
Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY
Reporting Requirements: ANNUALLY (CALENDAR)
Reports due 30 days after the reporting period.
The initial report is due 1/30/2021.
Subsequent reports are due every 12 calendar month(s).

Condition 28: Capping Monitoring Condition
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 6 NYCRR 201-7.1

Item 28.1:

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

40 CFR Part 63, Subpart KKKK

Item 28.2:

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

Item 28.3:

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Item 28.4:

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

Item 28.5:

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

Item 28.6:

The Compliance Certification activity will be performed for the facility:
The Compliance Certification applies to:

Emission Unit: U-10100

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Regulated Contaminant(s):

CAS No: 000112-25-4 ETHANOL,2-(HEXYLOXY)

CAS No: 0NY100-00-0 TOTAL HAP

Item 28.7:

Compliance Certification shall include the following monitoring:

Capping: Yes

Monitoring Type: INTERMITTENT EMISSION TESTING

Monitoring Description:

The facility shall operate the thermal oxidizer to meet the emission limits on hazardous air pollutants (HAP). A destruction efficiency of 97 percent shall be used, when the oxidizer is in operation, to calculate any HAP emissions, except for formaldehyde emissions. Pursuant to 6NYCRR Part 202-1.1, the Department may require emission testing, in order to confirm this efficiency.

Parameter Monitored: DESTRUCTION EFFICIENCY

Lower Permit Limit: 97 percent by weight

Reference Test Method: Method 25A

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Averaging Method: 1-HOUR AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 29: Visible Emissions Limited

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 211.2

Item 29.1:

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

Condition 30: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 212-1.6 (a)

Item 30.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: U-20200 Emission Point: 40EP1

Emission Unit: U-20200 Emission Point: 40EP2

Emission Unit: U-20200 Emission Point: 40EP3

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Emission Unit: U-20200

Emission Point: 41EP1

Emission Unit: U-20200

Emission Point: 41EP2

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 30.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

No person shall cause or allow emissions having an average opacity during any six consecutive minutes of 20 percent or greater from any process emission source, except only the emission of uncombined water. The Department may perform or require the facility to perform a Method 9 opacity evaluation.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: 6 MINUTE AVERAGE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 31: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 6 NYCRR 212-2.4 (b)

Item 31.1:

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: U-20200

Emission Point: 40EP1

Emission Unit: U-20200

Emission Point: 40EP2

Emission Unit: U-20200

Emission Point: 40EP3

Emission Unit: U-20200

Emission Point: 41EP1

Emission Unit: U-20200

Emission Point: 41EP2

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

Item 31.2:

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Emissions of solid particulates are limited to less than 0.050 grains of particulates per cubic foot of exhaust gas, expressed at standard conditions on a dry basis. Particulate emissions from each of the applicable emission points were calculated and were shown to be within the limit. A record of the calculations must be kept by the facility.

Monitoring Frequency: SINGLE OCCURRENCE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 32: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 231-11.2 (b)

Item 32.1:

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 32.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

For a modification with a project VOC emission potential which is less than 50 percent of the applicable significant project threshold, the facility owner or operator must maintain the following information:
 (1) A description of the project;
 (2) An identification of the affected emission sources and processes;
 (3) The calculation of the project emission potential (projected VOC emissions after the modification minus a two year average of VOC actual emissions); and
 (4) The date the modification commences operation.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 33: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:40CFR 63.6603(a), Subpart ZZZZ

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Item 33.1:

The Compliance Certification activity will be performed for the Facility.

Item 33.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Owners or operators of existing emergency generators must:

(1) Change oil and filter every 500 hours of operation or annually, whichever comes first:

(2) Inspect air cleaner every 1000 hours or annually, which ever comes first, and replace as necessary; and

(3) Inspect hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 34: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:40CFR 63.6655, Subpart ZZZZ

Item 34.1:

The Compliance Certification activity will be performed for the Facility.

Item 34.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The facility must keep records of emergency engine maintenance and hours of operation.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

****** Emission Unit Level ******

Condition 35: Emission Point Definition By Emission Unit

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Item 35.1:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-10100			
Emission Point:	11EP1		
Height (ft.):	47	Diameter (in.):	12
NYTMN (km.):	4590.241	NYTME (km.):	553.133
		Building:	BLDG1
Emission Point:	11EP2		
Height (ft.):	47	Diameter (in.):	16
NYTMN (km.):	4590.055	NYTME (km.):	553.212
		Building:	BLDG1
Emission Point:	11EP3		
Height (ft.):	47	Diameter (in.):	21
NYTMN (km.):	4590.06	NYTME (km.):	553.212
		Building:	BLDG1
Emission Point:	12EP1		
Height (ft.):	47	Diameter (in.):	12
NYTMN (km.):	4590.234	NYTME (km.):	553.188
		Building:	BLDG1
Emission Point:	12EP2		
Height (ft.):	47	Diameter (in.):	16
NYTMN (km.):	4590.056	NYTME (km.):	553.2
		Building:	BLDG1
Emission Point:	12EP3		
Height (ft.):	47	Diameter (in.):	21
NYTMN (km.):	4590.061	NYTME (km.):	553.202
		Building:	BLDG1
Emission Point:	13EP1		
Height (ft.):	47	Diameter (in.):	12
NYTMN (km.):	4590.223	NYTME (km.):	553.135
		Building:	BLDG1
Emission Point:	13EP2		
Height (ft.):	47	Diameter (in.):	16
NYTMN (km.):	4590.056	NYTME (km.):	553.196
		Building:	BLDG1
Emission Point:	13EP3		
Height (ft.):	47	Diameter (in.):	21
NYTMN (km.):	4590.061	NYTME (km.):	553.197
		Building:	BLDG1
Emission Point:	14EP1		
Height (ft.):	47	Diameter (in.):	12
NYTMN (km.):	4590.221	NYTME (km.):	553.193
		Building:	BLDG1
Emission Point:	14EP2		
Height (ft.):	47	Diameter (in.):	16
NYTMN (km.):	4590.058	NYTME (km.):	553.192
		Building:	BLDG1
Emission Point:	14EP3		
Height (ft.):	47	Diameter (in.):	26
NYTMN (km.):	4590.068	NYTME (km.):	553.19
		Building:	BLDG1

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Emission Point: 15RTO
 Height (ft.): 50 Diameter (in.): 56
 NYTMN (km.): 4590.001 NYTME (km.): 553.178

Emission Point: 21EP2
 Height (ft.): 47 Diameter (in.): 14
 NYTMN (km.): 4590.008 NYTME (km.): 553.201 Building: BLDG1

Emission Point: 22EP2
 Height (ft.): 47 Diameter (in.): 14
 NYTMN (km.): 4590.023 NYTME (km.): 553.199 Building: BLDG1

Emission Point: 23EP2
 Height (ft.): 47 Diameter (in.): 16
 NYTMN (km.): 4590.03 NYTME (km.): 553.2 Building: BLDG1

Emission Point: 3AEP1
 Height (ft.): 47 Diameter (in.): 17
 NYTMN (km.): 4590.018 NYTME (km.): 553.201 Building: BLDG1

Emission Point: AAEP1
 Height (ft.): 47 Diameter (in.): 20
 NYTMN (km.): 4590.011 NYTME (km.): 553.192 Building: BLDG1

Emission Point: AAEP2
 Height (ft.): 47 Diameter (in.): 20
 NYTMN (km.): 4590.026 NYTME (km.): 553.193 Building: BLDG1

Item 35.2:

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U-20200

Emission Point: 40EP1
 Height (ft.): 47 Length (in.): 43 Width (in.): 12
 NYTMN (km.): 4590.045 NYTME (km.): 553.146 Building: BLDG1

Emission Point: 40EP2
 Height (ft.): 47 Length (in.): 43 Width (in.): 12
 NYTMN (km.): 4590.045 NYTME (km.): 553.144 Building: BLDG1

Emission Point: 40EP3
 Height (ft.): 42 Diameter (in.): 44
 NYTMN (km.): 4590.017 NYTME (km.): 553.142 Building: BLDG1

Emission Point: 41EP1
 Height (ft.): 47 Diameter (in.): 27
 NYTMN (km.): 4590.001 NYTME (km.): 553.142 Building: BLDG1

Emission Point: 41EP2
 Height (ft.): 47 Diameter (in.): 27

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

NYTMN (km.): 4590.002 NYTME (km.): 553.132 Building: BLDG1

Condition 36: Process Definition By Emission Unit
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR Subpart 201-6

Item 36.1:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-10100

Process: 100

Source Classification Code: 4-02-008-43

Process Description:

The inside spray consists of one spray bank per manufacturing line. The respray line has one spray bank used to repair cans which did not receive the required amount of inside coating. The respray line is used intermittently.

Emission Source/Control: 15RTO - Control
Control Type: THERMAL OXIDATION

Emission Source/Control: 11ES1 - Process

Emission Source/Control: 11ES2 - Process

Emission Source/Control: 12ES1 - Process

Emission Source/Control: 12ES2 - Process

Emission Source/Control: 13ES1 - Process

Emission Source/Control: 13ES2 - Process

Emission Source/Control: 14ES1 - Process

Emission Source/Control: 14ES2 - Process

Item 36.2:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-10100

Process: 200

Source Classification Code: 4-02-008-42

Process Description:

Three (3) printer lines with associated drying ovens. The printers apply ink and overvarnish to the exterior of each can.

Emission Source/Control: 15RTO - Control
Control Type: THERMAL OXIDATION

Emission Source/Control: 21ES1 - Process

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Emission Source/Control: 21ES2 - Process

Emission Source/Control: 22ES1 - Process

Emission Source/Control: 22ES2 - Process

Emission Source/Control: 23ES1 - Process

Emission Source/Control: 23ES2 - Process

Item 36.3:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-10100

Process: 300

Source Classification Code: 4-02-017-21

Process Description:

Basecoat operation which includes one coater with a natural gas fired drying oven.

Emission Source/Control: 15RTO - Control

Control Type: THERMAL OXIDATION

Emission Source/Control: 3AES1 - Process

Emission Source/Control: 3AES2 - Process

Item 36.4:

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U-20200

Process: 400

Source Classification Code: 3-09-001-99

Process Description:

The scrap aluminum from the cutting and trimming operation is collected by duct work and transferred to cyclones. The scrap aluminum with water and oil lubricant from this operation goes through the cyclones where the aluminum drops out and is transferred to a compactor to be recycled. There is a potential for particulate emissions from this process. In addition, emissions of water and oil droplets are collected and sent to three Kirk and Blum mist eliminators, which remove the oil droplets with a 95 percent efficiency.

Emission Source/Control: 40ES1 - Control

Control Type: CENTRIFUGAL

Emission Source/Control: 40ES2 - Control

Control Type: CENTRIFUGAL

Emission Source/Control: 41ES1 - Control

Control Type: MIST ELIMINATOR

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Emission Source/Control: 41ES2 - Control
Control Type: MIST ELIMINATOR

Emission Source/Control: 41ES3 - Control
Control Type: MIST ELIMINATOR

Emission Source/Control: 4XESX - Process

Emission Source/Control: 4YESY - Process

**Condition 37: Part 228-1 process emission sources with respect to
A-rated VOC contaminants
Effective between the dates of 07/09/2020 and 07/08/2025**

Applicable Federal Requirement:6 NYCRR 212-1.4 (l) (1)

Item 37.1:

This Condition applies to Emission Unit: U-10100

Item 37.2:

The following process emission sources are not subject to the provisions of Part 212:

(l)(1) process emission sources subject to Table 1 of Subpart 228-1 of this Title or process emission sources exempt from Subpart 228-1 of this Title pursuant to paragraph 228-1.1(b), only with respect to emissions of VOCs that are not given an A rating.

**Condition 38: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025**

Applicable Federal Requirement:6 NYCRR 212-1.5 (d)

Item 38.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Regulated Contaminant(s):

CAS No: 000050-00-0 FORMALDEHYDE

Item 38.2:

Compliance Certification shall include the following monitoring:

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

A reduction in formaldehyde emissions of at least 92.2 percent must be achieved by the regenerative thermal oxidizer. This constitutes best available control technology, as justified by the facility. Compliance with this reduction limit shall be demonstrated by maintaining the average combustion temperature of the oxidizer at least 1500 degrees Fahrenheit.

Parameter Monitored: TEMPERATURE

Lower Permit Limit: 1500 degrees Fahrenheit

Monitoring Frequency: CONTINUOUS

Averaging Method: 15 Minute Average

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 39: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 212-1.5 (d)

Item 39.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Item 39.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

In instances where a facility owner or operator can demonstrate to the satisfaction of the department that the facility owner or operator will apply BACT for criteria air contaminants or T-BACT for non-criteria air contaminants, the department may specify a less restrictive permissible emission rate or degree of air cleaning for the process emission source or emission point than required under Subpart 212-2 of this Part.

Monitoring Frequency: SINGLE OCCURRENCE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

Condition 40: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 212-1.5 (g)

Item 40.1:

The Compliance Certification activity will be performed for:

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Emission Unit: U-10100

Item 40.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL
DEVICE PARAMETERS AS SURROGATE

Monitoring Description:

The facility shall operate a regenerative thermal oxidizer (RTO) during coating and drying operations, in support of limiting HAP emissions, reducing formaldehyde and VOC emissions, and reducing potential odors. The RTO must be operated and maintained in a manner consistent with safety, good engineering and air pollution control practices, and manufacturer's recommendations for minimizing emissions.

Coating and drying operations are allowed up to 200 hours over a 12-month period, whenever the RTO is shut down for malfunctions or maintenance. A new RTO bypass stack of at least 85 feet high shall be constructed and used to exhaust emissions from the drying ovens when the RTO is shut down. The facility must report when construction of the new stack is completed, and the 200 hour limit will then apply.

A record shall be kept of the date, time, and duration of when the RTO is shut down. The facility must report RTO shutdowns on a semi-annual basis.

If RTO equipment malfunctions and repair issues will result in a prolonged shutdown of the RTO and the 200 hour limit can not be met, the facility owner or operator must provide written notification to the department within five days after becoming aware of these issues. The notification must include why the limit can not be met and the corrective actions to be taken to restore RTO operation.

Parameter Monitored: HOURS OF OPERATION

Upper Permit Limit: 200 hours per year

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING
DESCRIPTION

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 41: Emission Testing Using Approved Procedures
Effective between the dates of 07/09/2020 and 07/08/2025**

Applicable Federal Requirement:6 NYCRR 212-1.7 (a)

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Item 41.1:

This Condition applies to Emission Unit: U-10100

Item 41.2:

Facility owners and/or operators of a process emission source required by the department to demonstrate compliance with this Part may be required to conduct capture efficiency and/or stack emissions testing using acceptable and approved procedures pursuant to Part 202 of this Title.

Condition 42: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 212-1.7 (b)

Item 42.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Item 42.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The combustion temperature of the regenerative thermal oxidizer must be monitored and recorded. The monitoring device must be operated at all times when the oxidizer is operating, except during any quality assurance or routine maintenance activities.

Monitoring Frequency: CONTINUOUS

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 43: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 228-1.3 (b) (1)

Item 43.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Item 43.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator must maintain and, upon request, provide the Department with a certification from the coating supplier or manufacturer which lists the

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

parameters used to determine the actual VOC content of each coating used at the facility. In addition, purchase, usage, or production records of the coating material must be maintained.

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 44: Surface Coating - Handling, storage and disposal
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 6 NYCRR 228-1.3 (d)

Item 44.1:

This Condition applies to Emission Unit: U-10100

Item 44.2:

Within the work area(s) associated with a coating line, the owner or operator of a facility must:

- (1) use closed, non-leaking containers to store or dispose of cloth or other absorbent applicators impregnated with VOC solvents that are used for surface preparation, cleanup or coating removal;
- (2) store in closed, non-leaking containers spent or fresh VOC solvents to be used for surface preparation, cleanup or coating removal;
- (3) not use VOC solvents to cleanup spray equipment unless equipment is used to collect the cleaning compounds and to minimize VOC evaporation;
- (4) not use open containers to store or dispense surface coatings and/or inks unless production, sampling, maintenance or inspection procedures require operational access. This provision does not apply to the actual device or equipment designed for the purpose of applying a coating material to a substrate. These devices may include, but are not limited to: spray guns, flow coaters, dip tanks, rollers, knife coaters, and extrusion coaters;
- (5) not use open containers to store or dispose of spent surface coatings, or spent VOC solvents;
- (6) minimize spills during the handling and transfer of coatings and VOC solvents; and
- (7) clean hand held spray guns by one of the following:
 - (i) an enclosed spray gun cleaning system that is kept closed when not in use;
 - (ii) non-atomized discharge of VOC solvent into a paint waste container that is kept closed when not in use;
 - (iii) disassembling and cleaning of the spray gun in a vat that is kept closed when not in use; or
 - (iv) atomized spray into a paint waste container that is fitted with a device designed to capture atomized VOC solvent emissions.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Condition 45: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 228-1.4 (d) (2)

Item 45.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 45.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC
OPERATIONS

Monitoring Description:

The VOC content in two-piece can interior body spray coatings is limited to 4.2 pounds of VOC per gallon of coating (minus water and excluded compounds).

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: COATING

Parameter Monitored: VOC CONTENT

Upper Permit Limit: 4.2 pounds per gallon

Reference Test Method: Method 24

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL
CHANGE

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE -
SEE MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 46: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement:6 NYCRR 228-1.4 (d) (2)

Item 46.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Regulated Contaminant(s):
CAS No: 0NY998-00-0 VOC

Item 46.2:

Compliance Certification shall include the following monitoring:

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

The VOC content in two-piece can exterior basecoats and in exterior overvarnish coatings is limited to 2.8 pounds of VOC per gallons of coating (minus water and excluded compounds).

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: COATING

Parameter Monitored: VOC CONTENT

Upper Permit Limit: 2.8 pounds per gallon

Reference Test Method: Method 24

Monitoring Frequency: PER BATCH OF PRODUCT/RAW MATERIAL CHANGE

Averaging Method: MAXIMUM - NOT TO EXCEED STATED VALUE - SEE MONITORING DESCRIPTION

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 47: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 6 NYCRR 228-1.6 (a)

Item 47.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Item 47.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Upon request by the Department, the owner or operator of an emission source subject to 6 NYCRR Part 228-1 must determine the actual VOC content of an as applied coating by measuring the volatile content, water content, density, volume of solids, and weight of solids in accordance with EPA Reference Test Method 311 or Method 24, included in Appendix A of 40 CFR parts 63 and 60 respectively, to demonstrate compliance with the requirements of Part 228-1.

An alternate sampling method that has been approved by both the Department and the Administrator may be used when Method 311 and/or Method 24 are not appropriate.

Reference Test Method: EPA Reference Test Method 311 or 24

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Reporting Requirements: UPON REQUEST BY REGULATORY AGENCY

Condition 48: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 6 NYCRR 228-1.6 (h)

Item 48.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Item 48.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Any information or record showing noncompliance with the requirements of 228-1 'Surface Coating Processes' must be reported to the department within 30 days following notice or generation of the information or record. All records required by this condition must be maintained at the facility for a period of five years.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

Condition 49: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 40CFR 60.492(c), NSPS Subpart WW

Item 49.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Process: 100

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 49.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

The VOC content in each two-piece can inside spray coating shall not exceed 0.89 kilograms of VOC per liter of coating solids. The VOC content of the coatings shall be determined from formulation data supplied by the coating manufacturer or by analysis of each coating using Method 24.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Work Practice Type: PARAMETER OF PROCESS MATERIAL
 Process Material: COATING
 Parameter Monitored: VOC CONTENT
 Upper Permit Limit: 0.89 kilograms VOC per liter of coating solids
 Reference Test Method: Method 24
 Monitoring Frequency: MONTHLY
 Averaging Method: CALENDAR MONTH AVERAGE
 Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2021.
 Subsequent reports are due every 6 calendar month(s).

Condition 50: Compliance Certification
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 40CFR 60.492(b), NSPS Subpart WW

Item 50.1:
 The Compliance Certification activity will be performed for:

Emission Unit: U-10100
 Process: 200

Regulated Contaminant(s):
 CAS No: 0NY998-00-0 VOC

Item 50.2:
 Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

The VOC content in each two-piece can clear base coating and in each overvarnish coating shall not exceed 0.46 kilograms of VOC per liter of coating solids. The VOC content of the coatings shall be determined from formulation data supplied by the coating manufacturer or by analysis of each coating using Method 24.

Work Practice Type: PARAMETER OF PROCESS MATERIAL
 Process Material: COATING
 Parameter Monitored: VOC CONTENT
 Upper Permit Limit: 0.46 kilograms VOC per liter of coating solids
 Reference Test Method: Method 24
 Monitoring Frequency: MONTHLY
 Averaging Method: CALENDAR MONTH AVERAGE
 Reporting Requirements: SEMI-ANNUALLY (CALENDAR)
 Reports due 30 days after the reporting period.
 The initial report is due 1/30/2021.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Subsequent reports are due every 6 calendar month(s).

Condition 51: Compliance Certification

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable Federal Requirement: 40CFR 60.492(a), NSPS Subpart WW

Item 51.1:

The Compliance Certification activity will be performed for:

Emission Unit: U-10100

Process: 300

Regulated Contaminant(s):

CAS No: 0NY998-00-0 VOC

Item 51.2:

Compliance Certification shall include the following monitoring:

Monitoring Type: WORK PRACTICE INVOLVING SPECIFIC OPERATIONS

Monitoring Description:

The VOC content in each two-piece can exterior basecoat shall not exceed 0.29 kilograms of VOC per liter of coating solids. The VOC content shall be determined from formulation data supplied by the coating manufacturer or by analysis of each coating using Method 24.

Work Practice Type: PARAMETER OF PROCESS MATERIAL

Process Material: COATING

Parameter Monitored: VOC CONTENT

Upper Permit Limit: 0.29 kilograms VOC per liter of coating solids

Reference Test Method: Method 24

Monitoring Frequency: MONTHLY

Averaging Method: CALENDAR MONTH AVERAGE

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 1/30/2021.

Subsequent reports are due every 6 calendar month(s).

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

STATE ONLY ENFORCEABLE CONDITIONS

****** Facility Level ******

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;

(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

Item B: General Provisions for State Enforceable Permit Terms and Condition - 6 NYCRR Part 201-5

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

STATE ONLY APPLICABLE REQUIREMENTS

The following conditions are state applicable requirements and are not subject to compliance certification requirements unless otherwise noted or required under 6 NYCRR Part 201.

Condition 52: Contaminant List

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable State Requirement:ECL 19-0301

Item 52.1:

Emissions of the following contaminants are subject to contaminant specific requirements in this permit(emission limits, control requirements or compliance monitoring conditions).

CAS No: 000050-00-0
Name: FORMALDEHYDE

CAS No: 000112-25-4
Name: ETHANOL,2-(HEXYLOXY)

CAS No: 0NY075-00-0
Name: PARTICULATES

CAS No: 0NY100-00-0
Name: TOTAL HAP

CAS No: 0NY998-00-0
Name: VOC

Condition 53: Malfunctions and start-up/shutdown activities

Effective between the dates of 07/09/2020 and 07/08/2025

Applicable State Requirement:6 NYCRR 201-1.4

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Item 53.1:

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

Condition 54: Air pollution prohibited
Effective between the dates of 07/09/2020 and 07/08/2025

Applicable State Requirement:6 NYCRR 211.1**Item 54.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039

Permit ID: 3-3352-00039/00029

Facility DEC ID: 3335200039