



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

Facility Identification Data

Name: SELKIRK COGENERATION PROJECT
Address: 24 POWER PARK DR ON GE PROPERTY
SELKIRK, NY 12158-2299

Owner/Firm

Name: SELKIRK COGEN PARTNERS LP
Address: 24 POWER PARK DR
SELKIRK, NY 12158-2299, USA
Owner Classification: Corporation/Partnership

Permit Contacts

Division of Environmental Permits:
Name: ANGELIKA R STEWART
Address: NYSDEC - REGION 4
1130 N WESTCOTT RD
SCHENECTADY, NY 12306
Phone:

Division of Air Resources:
Name: JAMES E HOGAN, III
Address: NYSDEC - HEADQUARTERS
625 BROADWAY
ALBANY, NY 12233-3258
Phone:5184028401

Air Permitting Facility Owner Contact:
Name: JAMES E RYAN
Address: 24 POWER PARK DR
SELKIRK, NY 12158
Phone:5184755773

Permit Description

Introduction

The Title V operating air permit is intended to be a document containing only enforceable terms and conditions as well as any additional information, such as the identification of emission units, emission points, emission sources and processes, that makes the terms meaningful. 40 CFR Part 70.7(a)(5) requires that each Title V permit have an accompanying "...statement that sets forth the legal and factual basis for the draft permit conditions". The purpose for this permit review report is to satisfy the above requirement by providing pertinent details regarding the permit/application data and permit conditions in a more easily understandable format. This report will also include background narrative and explanations of regulatory decisions made by the reviewer. It should be emphasized that this permit review report, while based on information contained in the permit, is a separate document and is not itself an enforceable term and condition of the permit.

Summary Description of Proposed Project

This DIM was created to address updating of start-up and shut-down parameters and streamline the permit.

Attainment Status

SELKIRK COGENERATION PROJECT is located in the town of BETHLEHEM in the county of



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

ALBANY.

The attainment status for this location is provided below. (Areas classified as attainment are those that meet all ambient air quality standards for a designated criteria air pollutant.)

| Criteria Pollutant | Attainment Status |
|---|--------------------------|
| Particulate Matter (PM) | ATTAINMENT |
| Particulate Matter < 10µ in diameter (PM10) | ATTAINMENT |
| Sulfur Dioxide (SO2) | ATTAINMENT |
| Ozone* | MARGINAL NON-ATTAINMENT |
| Oxides of Nitrogen (NOx)** | ATTAINMENT |
| Carbon Monoxide (CO) | ATTAINMENT |

* Ozone is regulated in terms of the emissions of volatile organic compounds (VOC) and/or oxides of nitrogen (NOx) which are ozone precursors.

** NOx has a separate ambient air quality standard in addition to being an ozone precursor.

Facility Description:

Selkirk Cogeneration Project (SCP) is a 345 MW combined cycle cogeneration facility that generates electricity under contract to utility customers and provides steam to an industrial steam customer. The facility consists of two phases. Phase I consists of a gas turbine and associated heat recovery steam generator with supplemental firing and one steam turbine generator. Phase II consists of two combustion turbines, two heat recovery steam generators with supplemental firing and one steam turbine generator. Each gas turbine is equipped with a GE Frame 7 Quiet Combustor low NOx burner and steam injection for NOx control. Units 2 and 3 are also equipped with selective catalytic reduction (SCR) to control the emissions of NOx. SCP operates four utility boilers as secondary steam generator units to assure an uninterrupted supply of steam to the industrial steam customer. The facility was approved a BACT facility for PSD purposes.

Permit Structure and Description of Operations

The Title V permit for SELKIRK COGENERATION PROJECT

is structured in terms of the following hierarchy: facility, emission unit, emission point, emission source and process. A facility is defined as all emission sources located at one or more adjacent or contiguous properties owned or operated by the same person or persons under common control. The facility is subdivided into one or more emission units (EU). Emission units are defined as any part or activity of a stationary facility that emits or has the potential to emit any federal or state regulated air pollutant. An emission unit is represented as a grouping of processes (defined as any activity involving one or more emission sources (ES) that emits or has the potential to emit any federal or state regulated air pollutant). An emission source is defined as any apparatus, contrivance or machine capable of causing emissions of any air contaminant to the outdoor atmosphere, including any appurtenant exhaust system or air cleaning device. [NOTE: Indirect sources of air contamination as defined in 6 NYCRR Part 203 (i.e. parking lots) are excluded from this definition]. The applicant is required to identify the principal piece of equipment (i.e., emission source) that directly results in or controls the emission of federal or state regulated air pollutants from an activity (i.e., process). Emission sources are categorized by the following types:

- combustion - devices which burn fuel to generate heat, steam or power
- incinerator - devices which burn waste material for disposal
- control - emission control devices
- process - any device or contrivance which may emit air contaminants



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

that is not included in the above categories.

SELKIRK COGENERATION PROJECT is defined by the following emission unit(s):

Emission unit U00001 - Emission unit U-00001 consists of a General Electric Frame 7 Quiet Combustor turbine and associated heat recovery steam generator (HRSG) equipped with a duct burner. The turbine may operate on gas, oil, or gas/oil. The duct burner may operate only on gas. The rated heat input for this emission unit is 1161.9 MMBtu/hr. There is one emission point associated with this emission unit. The combustion turbine and HRSG are located outside, therefore no buildings are associated with this emission unit that contain emission points or processes as defined by the application instructions.

Emission unit U00001 is associated with the following emission points (EP):

00001

Process: 1AG Phase 1 GE Frame 7 combustion Turbine firing natural gas with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine unit operating at any load. NOx emissions are controlled with steam injection.

Process: 1AO Phase 1 GE Frame 7 combustion turbine firing oil with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine operating at any load. NOx emissions are controlled with steam injection.

Note: This process is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire it's combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Process: 1BG Phase 1 GE Frame 7 combustion turbine firing natural gas with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine unit operating at baseload.

Process: 1BO Phase 1 GE Frame 7 combustion turbine firing oil with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine operating at baseload.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire it's combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Process: 1DB Phase1, unit 1, duct burner firing natural gas.

Process: 1GL Phase 1 GE Frame 7 combustion turbine firing natural gas with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine operating at base low flow.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

Process: 1HG GE Frame 7 combustion turbine firing natural gas with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine unit operating at or above base low flow. NOx emissions are controlled with steam injection.

Process: 1HO GE Frame 7 combustion turbine firing distillate oil or oil/gas with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine operating at or above base low flow. NOx emissions are controlled with steam injection.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire its combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Process: 1LF Phase 1 GE Frame 7 combustion turbine firing oil with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine operating at base low flow.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire its combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Process: 1LG GE Frame 7 combustion turbine firing natural gas with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine operating below the less of 784 MMBtu/hr and base low flow. NOx emissions are controlled with steam injection.

Process: 1LO GE Frame 7 combustion turbine firing distillate oil or oil/gas with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine operating below the lesser of 784 MMBtu/hr and base low flow. NOx emissions from the gas turbine are controlled with steam injection.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire its combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Process: 1MG GE Frame 7 combustion turbine firing natural gas with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine operating between 784 mmBTU/hr and base low flow. NOx emissions from the gas turbine are controlled with steam injection.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

Process: 1MO GE Frame 7 combustion turbine firing distillate oil/gas with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine operating between 784 mmBTU/hr and base low flow. NOx emissions are controlled with steam injection.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire its combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Emission unit U00002 - Emission unit U-00002 consists of 2 General Electric Frame 7 Standard Combustor combustion turbines and associated heat recovery steam generators (HRSGs) each equipped with a duct burner. The turbines may operate on gas, oil or gas/oil. The duct burner may operate only on gas. The rated heat input for each turbine/HRSG combustion unit is 1192.3 MMBtu/hr making the total heat input for the emission unit 2384.6 MMBtu/hr. NOx emissions from the gas turbines/HRSGs are controlled with selective catalytic reduction. There are two emission points associated with this emission unit. The combustion turbines are located in the gas turbine building and HRSGs are located outside.

Emission unit U00002 is associated with the following emission points (EP):
00002, 00003

Process: 23G One or two GE Frame 7 combustion turbines firing natural gas with or without the supplemental firing of one or two duct burners firing gas with the gas turbines operating at any load. NOx emissions are controlled with steam injection and selective catalytic reduction.

The Design Capacities in this Process Description are for a single combustion turbine and duct burner.

Process: 23O One or two GE Frame 7 combustion turbines firing distillate oil or oil/gas with or without the supplemental firing of one or two duct burners firing natural gas with the gas turbine operating at any load. NOx emissions are controlled with steam injection and selective catalytic reduction.

The Design Capacities in this Process Description are for a single combustion turbine and duct burner.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire its combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Process: 2DB Phase 2, units 2 or 3, duct burner firing natural gas.

Process: 2GB Phase 2 GE Frame 7 combustion turbine firing natural gas with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine unit operating at baseload.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

Process: 2GL Phase 2 GE Frame combustion turbine firing natural gas with or without the supplemental firing of the duct burner also firing natural gas and with the gas turbine unit operating at base low flow.

Process: 2OB Phase 2 GE Frame combustion turbine firing oil with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine unit operating at baseload.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire its combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Process: 2OL Phase 2 GE Frame combustion turbine firing oil with or without the supplemental firing of the duct burner firing natural gas and with the gas turbine unit operating at base low flow.

Note: This condition is included to provide for operational flexibility as defined by NYCRR Part 201-6.5(f). Operational flexibility in this instance, ensures that the SCP can provide reliable power during times when natural gas is commercially unavailable by utilizing the facility's alternate ability to fire its combustion turbines on fuel oil. Also, under the provisions of operational flexibility, SCP is allowed to suspend the otherwise required fuel oil compliance testing and reporting provisions until SCP actually fires fuel oil for the first time in the permit term. At such time that the combustion turbines are fired on oil, then that date shall be the date of first fire, and the testing and reporting provisions of this condition and all other applicable state and federal requirements are activated.

Emission unit U00004 - This emission unit consists of four auxiliary boilers. Boiler No. 2 is a Murray Iron Works 77/75 (gas/oil) MMBtu/hr boiler. Boiler No. 3 is a Combustion Engineering A-Type boiler rated at 180 MMBtu/hr. Boilers No 4 & 5 are identical Babcock & Wilcox D-Type boilers rated at 180 MMBtu/hr each. All boilers may fire natural gas, oil or a gas/oil mixture. There are four emissions points for this emission unit. All boilers are operated on an intermittent basis to supplement steam produced by the facility turbine/HRSG combustion units and to assure an uninterrupted steam supply to the industrial steam customer.

Emission unit U00004 is associated with the following emission points (EP):

00601, 00602, 00605, 00607

Process: B2G is located at Building UTILITYBLG - Boiler No. 2 Murray Iron Works boiler firing natural gas.

Process: B2O is located at Building UTILITYBLG - Boiler No. 2 Murray Iron Works boiler firing distillate oil or oil/gas.

Process: B3G Boiler No. 3 Combustion Engineering A-Type package boiler firing natural gas.

Process: B4G Boiler No. 4 Babcock and Wilcox D-Type package boiler firing natural gas.



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

Process: B4O Boiler No. 4 Babcock and Wilcox D-Type package boiler firing distillate oil or oil/gas.

Process: B5G Boiler No. 5 Babcock and Wilcox D-Type package boiler firing natural gas.

Process: B5O Boiler No. 5 Babcock and Wilcox D-Type package boiler firing distillate oil or oil/gas.

Emission unit U00005 - This emission unit consists of a 42,000 gallon ammonium hydroxide storage tank. Ammonium hydroxide is used to reduce NOx emissions and is injected into the exhaust gas prior to the selective catalytic reduction (SCR) unit. The tank has a vent that is maintained at 1-2 psi pressure to reduce or prevent the release of NH3 vapors.

Emission unit U00005 is associated with the following emission points (EP):

00005

Process: TNK This unit is a 42,000 gallon tank used to store ammonium hydroxide solution. The maximum amount of ammonium hydroxide stored is 37,800 gallons. Ammonium hydroxide is used to control nitrogen oxides in the gas turbine selective catalytic reduction control systems. The tank relief vent is maintained at 1-2 psi to reduce or prevent the release of ammonia vapors.

Emission unit U00006 -

Emission unit U00006 is associated with the following emission points (EP):

00006

Process: AUX Auxiliary generator rated at 3.39 MMBTU/hr firing # 2 fuel oil.

Title V/Major Source Status

SELKIRK COGENERATION PROJECT is subject to Title V requirements. This determination is based on the following information:

The Selkirk Cogeneration Project (SCP) is subject to Title V or major status permitting requirements. SCP is major facility due to it's potential to emit (PTE) exceeding the major source thresholds for the following air contaminates; NOx, SO2, CO, PM, VOC and HAP.

Program Applicability

The following chart summarizes the applicability of SELKIRK COGENERATION PROJECT with regards to the principal air pollution regulatory programs:

| Regulatory Program | Applicability |
|----------------------|---------------|
| PSD | YES |
| NSR (non-attainment) | NO |



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | |
|--------------------------------|-----|
| NESHAP (40 CFR Part 61) | NO |
| NESHAP (MACT - 40 CFR Part 63) | YES |
| NSPS | YES |
| TITLE IV | YES |
| TITLE V | YES |
| TITLE VI | NO |
| RACT | YES |
| SIP | YES |

NOTES:

PSD Prevention of Significant Deterioration (40 CFR 52, 6 NYCRR 231-7, 231-8) - requirements which pertain to major stationary sources located in areas which are in attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NSR New Source Review (6 NYCRR 231-5, 231-6) - requirements which pertain to major stationary sources located in areas which are in non-attainment of National Ambient Air Quality Standards (NAAQS) for specified pollutants.

NESHAP National Emission Standards for Hazardous Air Pollutants (40 CFR 61, 6 NYCRR 200.10) - contaminant and source specific emission standards established prior to the Clean Air Act Amendments of 1990 (CAAA) which were developed for 9 air contaminants (inorganic arsenic, radon, benzene, vinyl chloride, asbestos, mercury, beryllium, radionuclides, and volatile HAP's).

MACT Maximum Achievable Control Technology (40 CFR 63, 6 NYCRR 200.10) - contaminant and source specific emission standards established by the 1990 CAAA. Under Section 112 of the CAAA, the US EPA is required to develop and promulgate emissions standards for new and existing sources. The standards are to be based on the best demonstrated control technology and practices in the regulated industry, otherwise known as MACT. The corresponding regulations apply to specific source types and contaminants.

NSPS New Source Performance Standards (40 CFR 60, 6 NYCRR 200.10) - standards of performance for specific stationary source categories developed by the US EPA under Section 111 of the CAAA. The standards apply only to those stationary sources which have been constructed or modified after the regulations have been proposed by publication in the Federal Register and only to the specific contaminant(s) listed in the regulation.

Title IV Acid Rain Control Program (40 CFR 72 thru 78, 6 NYCRR 201-6) - regulations which mandate the implementation of the acid rain control program for large stationary combustion facilities.

Title VI Stratospheric Ozone Protection (40 CFR 82, Subpart A thru G, 6 NYCRR 200.10) - federal requirements that apply to sources which use a minimum quantity of CFC's (chlorofluorocarbons), HCFC's (hydrofluorocarbons) or other ozone depleting substances or regulated substitute substances in equipment such as air conditioners, refrigeration equipment or motor vehicle air conditioners or appliances.

RACT Reasonably Available Control Technology (6 NYCRR Parts 212-3, 226, 227-2, 228, 229, 230, 232, 233, 234, 235, 236) - the lowest emission limit that a specific source is capable of meeting by application of control technology that is reasonably available, considering technological and economic



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

feasibility. RACT is a control strategy used to limit emissions of VOC's and NOx for the purpose of attaining the air quality standard for ozone. The term as it is used in the above table refers to those state air pollution control regulations which specifically regulate VOC and NOx emissions.

SIP State Implementation Plan (40 CFR 52, Subpart HH, 6 NYCRR 200.10) - as per the CAAA, all states are empowered and required to devise the specific combination of controls that, when implemented, will bring about attainment of ambient air quality standards established by the federal government and the individual state. This specific combination of measures is referred to as the SIP. The term here refers to those state regulations that are approved to be included in the SIP and thus are considered federally enforceable.

Compliance Status

Facility is in compliance with all requirements.

SIC Codes

SIC or Standard Industrial Classification code is an industrial code developed by the federal Office of Management and Budget for use, among other things, in the classification of establishments by the type of activity in which they are engaged. Each operating establishment is assigned an industry code on the basis of its primary activity, which is determined by its principal product or group of products produced or distributed, or services rendered. Larger facilities typically have more than one SIC code.

SIC Code

Description

| | |
|------|--------------------------------|
| 4911 | ELECTRIC SERVICES |
| 4931 | ELEC & OTHER SERVICES COMBINED |

SCC Codes

SCC or Source Classification Code is a code developed and used" by the USEPA to categorize processes which result in air emissions for the purpose of assessing emission factor information.Each SCC represents a unique process or function within a source category logically associated with a point of air pollution emissions. Any operation that causes air pollution can be represented by one or more SCC's.

SCC Code

Description

| | |
|-------------|---|
| 1-01-006-01 | EXTERNAL COMBUSTION BOILERS - ELECTRIC GENERATION ELECTRIC UTILITY BOILER - NATURAL GAS Boilers > 100 MBtu/Hr except Tangential |
| 1-03-005-01 | EXTERNAL COMBUSTION BOILERS - COMMERCIAL/ INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - DISTILLATE OIL Grades 1 and 2 Oil |
| 1-03-006-01 | EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS Over 100 MMBtu/Hr |
| 1-03-006-02 | EXTERNAL COMBUSTION BOILERS - COMMERCIAL/INDUSTRIAL COMMERCIAL/INSTITUTIONAL BOILER - NATURAL GAS 10-100 MMBtu/Hr |
| 2-01-001-01 | INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION |



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | |
|-------------|--|
| 2-01-001-02 | ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - DISTILLATE OIL (DIESEL) Turbine |
| 2-01-002-01 | INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - DISTILLATE OIL (DIESEL) Reciprocating INTERNAL COMBUSTION ENGINES - ELECTRIC GENERATION ELECTRIC UTILITY INTERNAL COMBUSTION ENGINE - NATURAL GAS Turbine |

Facility Emissions Summary

In the following table, the CAS No. or Chemical Abstract Service code is an identifier assigned to every chemical compound. [NOTE: Certain CAS No.'s contain a 'NY' designation within them. These are not true CAS No.'s but rather an identification which has been developed by the department to identify groups of contaminants which ordinary CAS No.'s do not do. As an example, volatile organic compounds or VOC's are identified collectively by the NY CAS No. 0NY998-00-0.] The PTE refers to the Potential to Emit. This is defined as the maximum capacity of a facility or air contaminant source to emit any air contaminant under its physical and operational design. Any physical or operational limitation on the capacity of the facility or air contamination source to emit any air contaminant, including air pollution control equipment and/or restrictions on the hours of operation, or on the type or amount or material combusted, stored, or processed, shall be treated as part of the design only if the limitation is contained in federally enforceable permit conditions. The PTE for each contaminant that is displayed represents the facility-wide PTE in tons per year (tpy) or pounds per year (lbs/yr). In some instances the PTE represents a federally enforceable emissions cap or limitation for that contaminant. The term 'HAP' refers to any of the hazardous air pollutants listed in section 112(b) of the Clean Air Act Amendments of 1990. Total emissions of all hazardous air pollutants are listed under the special NY CAS No. 0NY100-00-0. In addition, each individual hazardous air pollutant is also listed under its own specific CAS No. and is identified in the list below by the (HAP) designation.

| Cas No. | Contaminant | PTE lbs/yr | PTE tons/yr | Actual lbs/yr | Actual tons/yr |
|----------------|-----------------------|-------------------|--------------------|----------------------|-----------------------|
| 000630-08-0 | CARBON MONOXIDE | | 75000 | | |
| 0NY210-00-0 | OXIDES OF NITROGEN | | 75000 | | |
| 007446-09-5 | SULFUR DIOXIDE | | 75000 | | |

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Public Access to Recordkeeping for Title V Facilities - 6 NYCRR 201-1.10(b)

The Department will make available to the public any permit application, compliance plan, permit, and monitoring and compliance certification report pursuant to Section 503(e) of the Act, except for information entitled to confidential treatment pursuant to 6 NYCRR Part 616 - Public Access to records and Section 114(c) of the Act.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

Item B: Timely Application for the Renewal of Title V Permits -6 NYCRR Part 201-6.2(a)(4)

Owners and/or operators of facilities having an issued Title V permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

Item C: Certification by a Responsible Official - 6 NYCRR Part 201-6.2(d)(12)

Any application, form, report or compliance certification required to be submitted pursuant to the federally enforceable portions of this permit shall contain a certification of truth, accuracy and completeness by a responsible official. This certification shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Item D: Requirement to Comply With All Conditions - 6 NYCRR Part 201-6.4(a)(2)

The permittee must comply with all conditions of the Title V facility permit. Any permit non-compliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

Item E: Permit Revocation, Modification, Reopening, Reissuance or Termination, and Associated Information Submission Requirements - 6 NYCRR Part 201-6.4(a)(3)

This permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.

Item F: Cessation or Reduction of Permitted Activity Not a Defense - 6 NYCRR 201-6.4(a)(5)

It shall not be a defense for a permittee in an enforcement action to claim that a cessation or reduction in the permitted activity would have been necessary in order to maintain compliance with the conditions of this permit.

Item G: Property Rights - 6 NYCRR 201-6.4(a)(6)

This permit does not convey any property rights of any sort or any exclusive privilege.

Item H: Severability - 6 NYCRR Part 201-6.4(a)(9)

If any provisions, parts or conditions of this permit are found to be invalid or are the subject of a challenge, the remainder of this permit shall continue to be valid.

Item I: Permit Shield - 6 NYCRR Part 201-6.4(g)

All permittees granted a Title V facility permit shall be covered under the protection of a permit shield, except as provided under 6 NYCRR Subpart 201-6. Compliance with the conditions of the permit shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that such applicable requirements are included and are specifically identified in the permit, or the Department, in acting on the permit application or revision, determines in writing that other requirements specifically identified



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

are not applicable to the major stationary source, and the permit includes the determination or a concise summary thereof. Nothing herein shall preclude the Department from revising or revoking the permit pursuant to 6 NYCRR Part 621 or from exercising its summary abatement authority. Nothing in this permit shall alter or affect the following:

- i. The ability of the Department to seek to bring suit on behalf of the State of New York, or the Administrator to seek to bring suit on behalf of the United States, to immediately restrain any person causing or contributing to pollution presenting an imminent and substantial endangerment to public health, welfare or the environment to stop the emission of air pollutants causing or contributing to such pollution;
- ii. The liability of a permittee of the Title V facility for any violation of applicable requirements prior to or at the time of permit issuance;
- iii. The applicable requirements of Title IV of the Act;
- iv. The ability of the Department or the Administrator to obtain information from the permittee concerning the ability to enter, inspect and monitor the facility.

Item J: Reopening for Cause - 6 NYCRR Part 201-6.4(i)

This Title V permit shall be reopened and revised under any of the following circumstances:

- i. If additional applicable requirements under the Act become applicable where this permit's remaining term is three or more years, a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which this permit is due to expire, unless the original permit or any of its terms and conditions has been extended by the Department pursuant to the provisions of Part 201-6.7 and Part 621.
- ii. The Department or the Administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.
- iii. The Department or the Administrator determines that the Title V permit must be revised or reopened to assure compliance with applicable requirements.
- iv. If the permitted facility is an "affected source" subject to the requirements of Title IV of the Act, and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

Proceedings to reopen and issue Title V facility permits shall follow the same procedures as apply to initial permit issuance but shall affect only those parts of the permit for which cause to reopen exists.

Reopenings shall not be initiated before a notice of such intent is provided to the facility by the Department at least thirty days in advance of the date that the permit is to be reopened, except that the Department may provide a shorter time period in the case of an emergency.

Item K: Permit Exclusion - ECL 19-0305



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

Item L: Federally Enforceable Requirements - 40 CFR 70.6(b)

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS

Item A: Emergency Defense - 6 NYCRR 201-1.5

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

- (a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:
- (1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;
 - (2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;
 - (3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and
 - (4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.
- (b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement. item_02

**Item B: General Provisions for State Enforceable Permit Terms and Condition - 6
 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

Regulatory Analysis

| Location Facility/EU/EP/Process/ES | Regulation | Condition | Short Description |
|---|-------------------|--|---|
| FACILITY | ECL 19-0301 | 234 | Powers and Duties of the Department with respect to air pollution control |
| FACILITY | 40CFR 52-A.21 | 47, 48, 49, 50, 51, 52, 53, 54, 55 | Prevention of Significant Deterioration |
| U-00001 | 40CFR 52-A.21 | 66, 67 | Prevention of Significant Deterioration |
| U-00001/00001 | 40CFR 52-A.21 | 93, 94, 95, 96, 97 | Prevention of Significant Deterioration |
| U-00001/00001/1AG | 40CFR 52-A.21 | 98, 99 | Prevention of Significant Deterioration |
| U-00001/00001/1AG/OOGT1 | 40CFR 52-A.21 | 100, 101, 102 | Prevention of Significant Deterioration |
| U-00001/00001/1AO | 40CFR 52-A.21 | 103, 104 | Prevention of Significant Deterioration |
| U-00001/00001/1AO/OOGT1 | 40CFR 52-A.21 | 105, 106, 107 | Prevention of Significant Deterioration |
| U-00001/00001/1BG/OOGT1 | 40CFR 52-A.21 | 108, 109, 110, 111 | Prevention of Significant Deterioration |
| U-00001/00001/1BO/OOGT1 | 40CFR 52-A.21 | 112, 113, 114, 115 | Prevention of Significant Deterioration |
| U-00001/00001/1DB/OODB1 | 40CFR 52-A.21 | 116, 117, 118, 119, 120, 121, 122, 123, 124, 125, 126, 127 | Prevention of Significant Deterioration |



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | | | |
|-------------------------|---------------|--|---|
| U-00001/00001/1GL/OOGT1 | 40CFR 52-A.21 | 128, 129, 130, 131 | Prevention of Significant Deterioration |
| U-00001/00001/1HG | 40CFR 52-A.21 | 132, 133 | Prevention of Significant Deterioration |
| U-00001/00001/1HG/OOGT1 | 40CFR 52-A.21 | 134 | Prevention of Significant Deterioration |
| U-00001/00001/1HO | 40CFR 52-A.21 | 135, 136 | Prevention of Significant Deterioration |
| U-00001/00001/1HO/OOGT1 | 40CFR 52-A.21 | 137 | Prevention of Significant Deterioration |
| U-00001/00001/1LF/OOGT1 | 40CFR 52-A.21 | 138, 139, 140, 141 | Prevention of Significant Deterioration |
| U-00001/00001/1LG | 40CFR 52-A.21 | 142, 143 | Prevention of Significant Deterioration |
| U-00001/00001/1LG/OOGT1 | 40CFR 52-A.21 | 144 | Prevention of Significant Deterioration |
| U-00001/00001/1LO | 40CFR 52-A.21 | 145, 146 | Prevention of Significant Deterioration |
| U-00001/00001/1LO/OOGT1 | 40CFR 52-A.21 | 147 | Prevention of Significant Deterioration |
| U-00001/00001/1MG | 40CFR 52-A.21 | 148, 149 | Prevention of Significant Deterioration |
| U-00001/00001/1MG/OOGT1 | 40CFR 52-A.21 | 150 | Prevention of Significant Deterioration |
| U-00001/00001/1MO | 40CFR 52-A.21 | 151, 152 | Prevention of Significant Deterioration |
| U-00001/00001/1MO/OOGT1 | 40CFR 52-A.21 | 153 | Prevention of Significant Deterioration |
| U-00002 | 40CFR 52-A.21 | 156, 157, 158, 159 | Prevention of Significant Deterioration |
| U-00002/-/23G | 40CFR 52-A.21 | 178, 179, 180, 181, 182, 183 | Prevention of Significant Deterioration |
| U-00002/-/23G/OGT23 | 40CFR 52-A.21 | 184, 185, 186, 187 | Prevention of Significant Deterioration |
| U-00002/-/23O | 40CFR 52-A.21 | 188, 189, 190, 191, 192, 193 | Prevention of Significant Deterioration |
| U-00002/-/23O/OGT23 | 40CFR 52-A.21 | 194, 195, 196, 197, 198, 199 | Prevention of Significant Deterioration |
| U-00002/-/2DB/ODB23 | 40CFR 52-A.21 | 202, 203, 204, 205, 206, 207, 208, 209, 210, 211, 212, 213 | Prevention of Significant Deterioration |
| U-00002/-/2GB/OGT23 | 40CFR 52-A.21 | 214, 215, 216, 217 | Prevention of Significant Deterioration |
| U-00002/-/2GL/OGT23 | 40CFR 52-A.21 | 218, 219, 220, 221 | Prevention of Significant Deterioration |



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | | | |
|---------------------|-----------------------|--------------------|--|
| U-00002/-/20B/OGT23 | 40CFR 52-A.21 | 222, 223, 224, 225 | Significant Deterioration Prevention of Significant Deterioration |
| U-00002/-/20L/OGT23 | 40CFR 52-A.21 | 226, 227, 228 | Prevention of Significant Deterioration |
| U-00002/00002 | 40CFR 52-A.21 | 229, 230 | Prevention of Significant Deterioration |
| U-00002/00003 | 40CFR 52-A.21 | 231, 232 | Prevention of Significant Deterioration |
| U-00004 | 40CFR 52-A.21 | 233 | Prevention of Significant Deterioration |
| FACILITY | 40CFR 60-A | 3 -2 | General provisions |
| FACILITY | 40CFR 60-A.12 | 3 -12 | General provisions - Circumvention |
| FACILITY | 40CFR 60-A.13 | 3 -13 | General provisions - Monitoring requirements |
| FACILITY | 40CFR 60-A.14 | 3 -14 | General provisions - Modification |
| FACILITY | 40CFR 60-A.15 | 3 -15 | General provisions - Reconstruction |
| FACILITY | 40CFR 60-A.4 | 56 | General provisions - Address |
| FACILITY | 40CFR 60-A.7(a) | 3 -3 | Notification and Recordkeeping |
| FACILITY | 40CFR 60-A.7(b) | 3 -4 | Notification and Recordkeeping |
| FACILITY | 40CFR 60-A.8(a) | 3 -5 | Performance Tests |
| FACILITY | 40CFR 60-A.8(b) | 3 -6 | Performance Tests |
| FACILITY | 40CFR 60-A.8(c) | 3 -7 | Performance Tests |
| FACILITY | 40CFR 60-A.8(d) | 3 -8 | Performance Tests |
| FACILITY | 40CFR 60-A.8(e) | 3 -9 | Performance Tests |
| FACILITY | 40CFR 60-A.8(f) | 3 -10 | Performance Tests |
| FACILITY | 40CFR 60-A.9 | 3 -11 | General provisions - Availability of information |
| U-00001/-/1DB | 40CFR 60-Db.44b(a)(4) | 89 | Standard for Nitrogen Oxides for Duct Burners Used in Combined Cycle Projects. |
| U-00002/-/2DB | 40CFR 60-Db.44b(a)(4) | 200 | Standard for Nitrogen Oxides for Duct Burners Used in Combined Cycle Projects. |
| U-00001/-/1DB | 40CFR 60-Db.49b | 90 | Reporting and Recordkeeping Requirements. |
| U-00002/-/2DB | 40CFR 60-Db.49b | 201 | Reporting and Recordkeeping Requirements. |
| FACILITY | 40CFR 60-GG.334(b) | 3 -16 | Monitoring of Operations: CEMS |
| FACILITY | 40CFR 60-GG.334(h) | 3 -17 | Fuel Content |
| FACILITY | 40CFR 60-GG.334(h)(3) | 58 | Allowance not to monitor sulfur or nitrogen for natural |



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | | | | |
|----------|----------------------|------------|------------|---|
| FACILITY | 40CFR 60-GG.334(j) | 3 | -18 | gas Reporting Requirements |
| FACILITY | 40CFR 63-JJJJJJ | 59 | | National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources |
| FACILITY | 40CFR 63-ZZZZ | 60 | | Reciprocating Internal Combustion Engine (RICE) NESHAP |
| FACILITY | 40CFR 68 | 19 | | Chemical accident prevention provisions |
| U-00001 | 40CFR 75-B.10(a) | 87 | | Continuous emission monitoring - general operating requirements |
| U-00001 | 40CFR 75-B.10(d) | 88 | | Continuous emission monitoring - general operating requirements |
| FACILITY | 40CFR 82-F | 20 | | Protection of Stratospheric Ozone - recycling and emissions reduction |
| FACILITY | 40CFR 97 | 61 | | Federal Cross-State Air Pollution Regulation (CSAPR) |
| FACILITY | 6NYCRR 200.6 | 1 | | Acceptable ambient air quality. |
| FACILITY | 6NYCRR 200.7 | 10 | | Maintenance of equipment. |
| FACILITY | 6NYCRR 201-1.4 | 235 | | Unavoidable noncompliance and violations |
| FACILITY | 6NYCRR 201-1.7 | 11 | | Recycling and Salvage |
| FACILITY | 6NYCRR 201-1.8 | 12 | | Prohibition of reintroduction of collected contaminants to the air |
| FACILITY | 6NYCRR 201-3.2(a) | 13 | | Exempt Activities - Proof of eligibility |
| FACILITY | 6NYCRR 201-3.3(a) | 14 | | Trivial Activities - proof of eligibility |
| FACILITY | 6NYCRR 201-6 | 21, 62, 63 | | Title V Permits and the Associated Permit Conditions |
| U-00001 | 6NYCRR 201-6 | 3 | -19, 3 -20 | Title V Permits and the Associated Permit Conditions |
| U-00002 | 6NYCRR 201-6 | 154, 3 | -22, 3 -23 | Title V Permits and the Associated Permit Conditions |
| FACILITY | 6NYCRR 201-6.4(a)(4) | 15 | | General Conditions - Requirement to Provide Information |
| FACILITY | 6NYCRR 201-6.4(a)(7) | 2 | | General Conditions - Fees |
| FACILITY | 6NYCRR 201-6.4(a)(8) | 16, 3 | -1 | General Conditions - Right to Inspect |



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | | | |
|----------|--------------------------|-------|--|
| FACILITY | 6NYCRR 201-6.4(c) | 3 | Recordkeeping and Reporting of Compliance Monitoring |
| FACILITY | 6NYCRR 201-6.4(c)(2) | 4 | Records of Monitoring, Sampling and Measurement |
| FACILITY | 6NYCRR 201-6.4(c)(3)(ii) | 5 | Reporting Requirements - Deviations and Noncompliance |
| FACILITY | 6NYCRR 201-6.4(d)(4) | 22 | Compliance Schedules - Progress Reports |
| FACILITY | 6NYCRR 201-6.4(e) | 6 | Compliance Certification |
| FACILITY | 6NYCRR 201-6.4(f)(6) | 17 | Off Permit Changes |
| FACILITY | 6NYCRR 202-1.1 | 18 | Required emissions tests. |
| FACILITY | 6NYCRR 202-2.1 | 7 | Emission Statements - Applicability |
| FACILITY | 6NYCRR 202-2.5 | 8 | Emission Statements - record keeping requirements. |
| FACILITY | 6NYCRR 211.1 | 23 | General Prohibitions - air pollution prohibited |
| FACILITY | 6NYCRR 211.2 | 236 | General Prohibitions - visible emissions limited. |
| FACILITY | 6NYCRR 215.2 | 9 | Open Fires - Prohibitions |
| FACILITY | 6NYCRR 225-1.2(g) | 24 | Sulfur-in-Fuel Limitations |
| FACILITY | 6NYCRR 225-1.5(c) | 25 | Monitoring Requirements |
| FACILITY | 6NYCRR 227-1.3(a) | 26 | Smoke Emission Limitations. |
| U-00001 | 6NYCRR 227-2 | 3 -21 | Reasonably available control technology for NOx |
| FACILITY | 6NYCRR 227-2.4(b)(1)(ii) | 27 | 2010 NOx RACT presumptive limits. |
| FACILITY | 6NYCRR 227-2.4(c)(1)(ii) | 28 | 2010 NOx RACT presumptive limit. |
| FACILITY | 6NYCRR 242-1.5 | 237 | CO2 Budget Trading Program - Standard requirements |
| FACILITY | 6NYCRR 242-8 | 238 | CO2 Budget Trading Program - Monitoring and reporting |
| FACILITY | 6NYCRR 243-1.6(a) | 29 | Permit Requirements - CAIR NOx Ozone Season Trading Program |
| FACILITY | 6NYCRR 243-1.6(b) | 30 | Monitoring Requirements - CAIR NOx Ozone Season Trading Program |
| FACILITY | 6NYCRR 243-1.6(c) | 31 | NOx Ozone Season Emission Requirements - CAIR NOx Ozone Season Trading Program |
| FACILITY | 6NYCRR 243-1.6(d) | 32 | Excess Emission Requirements - CAIR NOx Ozone Season |



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | | | |
|----------|-------------------|--------|---|
| FACILITY | 6NYCRR 243-1.6(e) | 33 | Trading Program Recordkeeping and reporting requirements - CAIR NOx Ozone Season Trading Program |
| FACILITY | 6NYCRR 243-2.1 | 34 | Authorization and responsibilities - CAIR Designated Representative Certificate of representation - CAIR Designated Representative General Requirements |
| FACILITY | 6NYCRR 243-2.4 | 35 | - Monitoring and Reporting |
| FACILITY | 6NYCRR 243-8.1 | 36, 37 | Quarterly reports re: recordkeeping and reporting - Monitoring and Reporting |
| FACILITY | 6NYCRR 243-8.5(d) | 38 | Compliance certification re: recordkeeping and reporting - Monitoring and Reporting |
| FACILITY | 6NYCRR 243-8.5(e) | 39 | CAIR NOx Ozone Annual Trading Program General Provisions |
| FACILITY | 6NYCRR 244-1 | 40, 41 | CAIR Designated Representative for CAIR NOx Sources |
| FACILITY | 6NYCRR 244-2 | 42 | Monitoring and Reporting CAIR NOx Allowances |
| FACILITY | 6NYCRR 244-8 | 43 | CAIR SO2 Trading Program General Provisions |
| FACILITY | 6NYCRR 245-1 | 44 | CAIR Designated Representative for CAIR SO2 Sources |
| FACILITY | 6NYCRR 245-2 | 45 | Monitoring and Reporting for CAIR SO2 Trading Program |
| FACILITY | 6NYCRR 245-8 | 46 | |

Applicability Discussion:

Mandatory Requirements: The following facility-wide regulations are included in all Title V permits:

ECL 19-0301

This section of the Environmental Conservation Law establishes the powers and duties assigned to the Department with regard to administering the air pollution control program for New York State.

6 NYCRR 200.6

Acceptable ambient air quality - prohibits contravention of ambient air quality standards without mitigating measures

6 NYCRR 200.7

Anyone owning or operating an air contamination source which is equipped with an emission control device



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

must operate the control consistent with ordinary and necessary practices, standards and procedures, as per manufacturer's specifications and keep it in a satisfactory state of maintenance and repair so that it operates effectively

6 NYCRR 201-1.4

This regulation specifies the actions and recordkeeping and reporting requirements for any violation of an applicable state enforceable emission standard that results from a necessary scheduled equipment maintenance, start-up, shutdown, malfunction or upset in the event that these are unavoidable.

6 NYCRR 201-1.7

Requires the recycle and salvage of collected air contaminants where practical

6 NYCRR 201-1.8

Prohibits the reintroduction of collected air contaminants to the outside air

6 NYCRR 201-3.2 (a)

An owner and/or operator of an exempt emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains exempt emission sources or units, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR 201-3.3 (a)

The owner and/or operator of a trivial emission source or unit may be required to certify that it operates within the specific criteria described in this Subpart. All required records must be maintained on-site for a period of 5 years and made available to department representatives upon request. In addition, department representatives must be granted access to any facility which contains trivial emission sources or units subject to this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

6 NYCRR Subpart 201-6

This regulation applies to those terms and conditions which are subject to Title V permitting. It establishes the applicability criteria for Title V permits, the information to be included in all Title V permit applications as well as the permit content and terms of permit issuance. This rule also specifies the compliance, monitoring, recordkeeping, reporting, fee, and procedural requirements that need to be met to obtain a Title V permit, modify the permit and demonstrate conformity with applicable requirements as listed in the Title V permit. For permitting purposes, this rule specifies the need to identify and describe all emission units, processes and products in the permit application as well as providing the Department the authority to include this and any other information that it deems necessary to determine the compliance status of the facility.

6 NYCRR 201-6.4 (a) (4)

This mandatory requirement applies to all Title V facilities. It requires the permittee to provide information that the Department may request in writing, within a reasonable time, in order to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. The request may include copies of records required to be kept by the permit.

6 NYCRR 201-6.4 (a) (7)

This is a mandatory condition that requires the owner or operator of a facility subject to Title V requirements to pay all applicable fees associated with the emissions from their facility.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

6 NYCRR 201-6.4 (a) (8)

This is a mandatory condition for all facilities subject to Title V requirements. It allows the Department to inspect the facility to determine compliance with this permit, including copying records, sampling and monitoring, as necessary.

6 NYCRR 201-6.4 (c)

This requirement specifies, in general terms, what information must be contained in any required compliance monitoring records and reports. This includes the date, time and place of any sampling, measurements and analyses; who performed the analyses; analytical techniques and methods used as well as any required QA/QC procedures; results of the analyses; the operating conditions at the time of sampling or measurement and the identification of any permit deviations. All such reports must also be certified by the designated responsible official of the facility.

6 NYCRR 201-6.4 (c) (2)

This requirement specifies that all compliance monitoring and recordkeeping is to be conducted according to the terms and conditions of the permit and follow all QA requirements found in applicable regulations. It also requires monitoring records and supporting information to be retained for at least 5 years from the time of sampling, measurement, report or application. Support information is defined as including all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

6 NYCRR 201-6.4 (c) (3) (ii)

This regulation specifies any reporting requirements incorporated into the permit must include provisions regarding the notification and reporting of permit deviations and incidences of noncompliance stating the probable cause of such deviations, and any corrective actions or preventive measures taken.

6 NYCRR 201-6.4 (d) (5)

This condition applies to every Title V facility subject to a compliance schedule. It requires that reports, detailing the status of progress on achieving compliance with emission standards, be submitted semiannually.

6 NYCRR 201-6.4 (e)

Sets forth the general requirements for compliance certification content; specifies an annual submittal frequency; and identifies the EPA and appropriate regional office address where the reports are to be sent.

6 NYCRR 201-6.4 (f) (6)

This condition allows changes to be made at the facility, without modifying the permit, provided the changes do not cause an emission limit contained in this permit to be exceeded. The owner or operator of the facility must notify the Department of the change. It is applicable to all Title V permits which may be subject to an off permit change.

6 NYCRR 202-1.1

This regulation allows the department the discretion to require an emission test for the purpose of determining compliance. Furthermore, the cost of the test, including the preparation of the report are to be borne by the owner/operator of the source.

6 NYCRR 202-2.1

Requires that emission statements shall be submitted on or before April 15th each year for emissions of the previous calendar year.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

6 NYCRR 202-2.5

This rule specifies that each facility required to submit an emission statement must retain a copy of the statement and supporting documentation for at least 5 years and must make the information available to department representatives.

6 NYCRR 211.2

This regulation limits opacity from sources to less than or equal to 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

6 NYCRR 215.2

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

40 CFR Part 68

This Part lists the regulated substances and their applicability thresholds and sets the requirements for stationary sources concerning the prevention of accidental releases of these substances.

40 CFR Part 82, Subpart F

Subpart F requires the reduction of emissions of class I and class II refrigerants to the lowest achievable level during the service, maintenance, repair, and disposal of appliances in accordance with section 608 of the Clean Air Act Amendments of 1990. This subpart applies to any person servicing, maintaining, or repairing appliances except for motor vehicle air conditioners. It also applies to persons disposing of appliances, including motor vehicle air conditioners, refrigerant reclaimers, appliance owners, and manufacturers of appliances and recycling and recovery equipment. Those individuals, operations, or activities affected by this rule, may be required to comply with specified disposal, recycling, or recovery practices, leak repair practices, recordkeeping and/or technician certification requirements.

Facility Specific Requirements

In addition to Title V, SELKIRK COGENERATION PROJECT has been determined to be subject to the following regulations:

40 CFR 52.21

This citation applies to facilities that are subject to Prevention of Significant Deterioration provisions;

ie: facilities that are located in an attainment area and that emit pollutants which are listed in 40 CFR 52.21(b)(23)(i) .

40 CFR 60.12

This regulation prohibits an owner or operator from concealing emissions in violation of applicable standards by any means.

40 CFR 60.13

This regulation specifies how monitoring shall be performed and which methods and appendices are used to determine if the monitoring is adequate and in compliance with the regulated standards.

40 CFR 60.14

This regulation defines the term modification and what is and is not considered to be a modification, for



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

the purpose of rule applicability.

40 CFR 60.15

This regulation defines the term reconstruction and what is and is not considered to be a reconstruction project, for the purpose of rule applicability.

40 CFR 60.334 (b)

This regulation allows the owner/operator of a gas turbine to use a CEMS to monitor NOx emissions instead of monitoring fuel and water/steam usage.

40 CFR 60.334 (h)

This regulation requires the applicant to monitor the sulfur and nitrogen content of the fuel being burned in the turbine.

40 CFR 60.334 (h) (3)

This regulation allows the owner or operator of a gas turbine to not monitor the fuel for sulfur or nitrogen content if the fuel meets the 40 CFR 60.331(u) definition of natural gas.

40 CFR 60.334 (j)

This regulation sets forth the reporting requirements for affected units that continuously monitor parameters or emissions or those that periodically determine the sulfur and/or nitrogen content of the fuel burned in a gas turbine.

40 CFR 60.4

This condition lists the USEPA Region 2 address for the submittal of all communications to the "Administrator". In addition, all such communications must be copied to NYSDEC Bureau of Quality Assurance (BQA).

40 CFR 60.44b (a) (4)

These standards apply to boilers firing natural gas and/or distillate oil as provided in 40 CFR 60.44b(a)(4) Duct Burners Used in a Combined Cycle System.

40 CFR 60.49b

This rule specifies the reporting and recordkeeping requirements for affected steam generating units.

40 CFR 60.7 (a)

This regulation requires any owner or operator subject to a New Source Performance Standard (NSPS) to furnish the Administrator with notification of the dates of: construction or reconstruction, initial startup, any physical or operational changes, commencement of performance testing for continuous monitors and anticipated date for opacity observations as required.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

40 CFR 60.7 (b)

This regulation requires the owner or operator to maintain records of the occurrence and duration of any startup, shutdown, or malfunction of the source or control equipment or continuous monitoring system.

40 CFR 60.8 (a)

This regulation contains the requirements for the completion date and reporting of Performance Testing (stack testing), at the facility. Within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup, the owner or operator of the facility must conduct performance test(s) and furnish a written report of the test results.

40 CFR 60.8 (b)

This regulation contains the requirements for Performance test methods and procedures, to be used by the owner or operator, of the affected facility.

40 CFR 60.8 (c)

This condition contains the requirements for operating conditions, of the emission source, during performance testing.

40 CFR 60.8 (d)

This regulation contains the requirements for advance notification of Performance (stack) testing.

40 CFR 60.8 (e)

This regulation requires the facility to provide appropriate sampling ports, safe platforms and utilities as necessary for Performance (stack) testing.

40 CFR 60.8 (f)

This regulation requires that Performance (stack) tests consist of three runs unless otherwise specified. The rule also designates the allowable averaging methods for the analysis of the results.

40 CFR 60.9

This rule citation allows the public access to any information submitted to the EPA Administrator (or state contact), in conjunction with a project subject to this section of the regulation.

40 CFR 75.10 (a)

This section specifies the primary measurement requirements for opacity, and all SO₂, NO_x, and CO₂ emissions from the facility. It details how often measurements are to be made and the general type of systems to be used.

40 CFR 75.10 (d)

This section specifies the operating requirements of the monitoring systems. It requires the facility to



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

ensure that all monitoring systems in operation and functioning as specified, at all times fuel is being burned, except as provided in § 75.11(e) and during other specified periods.

40 CFR Part 60, Subpart A

This regulation contains the General Provisions of 40 CFR 60. The facility owner is responsible for reviewing these general provisions in detail and complying with all applicable technical, administrative and reporting requirements

40 CFR Part 63, Subpart JJJJJ

This regulation covers facilities that own or operate an industrial, commercial, or institutional boiler as defined in §63.11237 that is located at, or is part of, an area source of hazardous air pollutants (HAP), as defined in §63.2, except as specified in §63.11195.

40 CFR Part 63, Subpart ZZZZ

40 CFR Part 97

Cross-State Air Pollution Rule (CSAPR), requires states to significantly improve air quality by reducing power plant emissions that contribute to ozone and/or fine particle pollution in other states.

6 NYCRR 211.1

This regulation requires that no person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property.

6 NYCRR 225-1.2 (g)

Sulfur-in-fuel limitations for the purchase of distillate oil on or after July 1, 2014.

6 NYCRR 225-1.5 (c)

This citation sets the daily and weekly fuel monitoring requirements for subject emission sources.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

6 NYCRR 227-1.3 (a)

This regulation prohibits any person from operating a stationary combustion installation which emits smoke equal to or greater than 20% opacity except for one six-minute period per hour of not more than 27% opacity.

6 NYCRR 227-2.4 (b) (1) (ii)

Future NO_x RACT presumptive limits effective 7/1/14.

6 NYCRR 227-2.4 (c) (1) (ii)

Future NO_x RACT presumptive limit effective 7/1/14.

6 NYCRR 242-1.5

This regulation requires that the facility hold enough carbon dioxide allowances in their carbon dioxide budget at least equal to the amount of carbon dioxide emitted from the facility each year.

6 NYCRR 243-1.6 (a)

This condition requires the facility to acknowledge that they are subject to this CAIR regulation and provide owner and contact information. It also requires them to update this information as it changes or provide supplemental information at the Departments request.

6 NYCRR 243-1.6 (b)

This condition obligates the owners and operators of the facility to comply with the monitoring and reporting requirements of the CAIR regulations.

6 NYCRR 243-1.6 (c)

This citation explains the general provisions of the Clean Air Interstate Rule (CAIR) NO_x Ozone Season Trading Program. This ozone season NO_x cap and trade program runs from May 1 through September 30 each year, starting in 2009. Each source shall hold a tonnage equivalent in CAIR NO_x Ozone Season allowances that is not less than the total tons of NO_x emissions for the ozone season.

6 NYCRR 243-1.6 (d)

This citation for the Clean Air Interstate Rule (CAIR) NO_x Ozone Season Trading Program explains some of the penalties that can be imposed on a CAIR NO_x Ozone Season source that does not surrender enough CAIR NO_x Ozone Season allowances to cover their NO_x Ozone Season emissions.

6 NYCRR 243-1.6 (e)

This citation for the Clean Air Interstate Rule (CAIR) NO_x Ozone Season Trading Program requires that all reports be submitted as required by this program, and that copies of all records and submissions made for this program be kept on site for at least five years.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

6 NYCRR 243-2.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that a CAIR NOx Ozone Season designated representative must be selected to submit, sign and certify each submission on behalf of the source for this program.

6 NYCRR 243-2.4

This condition describes the required elements of the "Certificate of Representation" for the CAIR program and the certifying language required with submissions to the Department.

6 NYCRR 243-8.1

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains that CAIR NOx Ozone Season Trading Program sources must install, certify and operate monitoring systems that meet the monitoring, recordkeeping, and reporting requirements in Subpart 6 NYCRR 243-8 and in Subpart H of 40 CFR Part 75.

6 NYCRR 243-8.5 (d)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains what requirements the quarterly reports must meet.

6 NYCRR 243-8.5 (e)

This citation of the Clean Air Interstate Rule (CAIR) NOx Ozone Season Trading Program explains the compliance certification requirements the source must follow for each quarterly report.

6 NYCRR Subpart 227-2

This regulation limits the emission of oxides of nitrogen (NOx) from stationary combustion installations (boilers, combustion turbines and internal combustion engines).

6 NYCRR Subpart 242-8

Citation 6NYCRR Part 242-8.5 requires that the record keeping and reporting requirements of 40 CFR Part 75.73 and 6NYCRR Part 242-2.1(e) be followed, that a CO2 monitoring plan(s) be submitted, that the CO2 emission monitor(s) be certified, and that CO2 emissions be reported quarterly in an electronic format.

6 NYCRR Subpart 244-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) Nitrogen Oxide (NOx) Annual Trading Program. The control period for this annual NOx cap and trade program runs from January 1 to December 31 each year, starting in 2009. Each source shall hold a tonnage equivalent in



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

CAIR NOx allowances that is not less than the total tons of NOx emissions for the control period.

6 NYCRR Subpart 244-2

Each Clean Air Interstate Rule (CAIR) NOx source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR NOx Annual Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate representative.

6 NYCRR Subpart 244-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR NOx unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 244-8 and in 40 CFR Part 75, Subparts F and G. A certified NOx emission monitoring system must be used to measure NOx emissions. NOx emission reports must be certified and submitted quarterly.

6 NYCRR Subpart 245-1

This subpart explains the general provisions of the Clean Air Interstate Rule (CAIR) sulfur dioxide (SO2) Trading Program. The control period for this annual SO2 cap and trade program runs from January 1 to December 31, starting in the year 2010. Each source shall hold a tonnage equivalent in CAIR SO2 allowances that is not less than the total tons of SO2 emissions for the control period.

6 NYCRR Subpart 245-2

Each Clean Air Interstate Rule (CAIR) SO2 source shall have one CAIR designated representative and may have one alternate representative. Each submission for the CAIR SO2 Trading Program shall be submitted, signed, and certified by the CAIR designated representative or the alternate representative.

6 NYCRR Subpart 245-8

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR SO2 unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. A certified SO2 emission monitoring system must be used to measure SO2 emissions. SO2 emission reports must be certified and submitted quarterly.

The owners, operators, and Clean Air Interstate Rule (CAIR) designated representative of a CAIR SO2 unit shall comply with the monitoring, recordkeeping, and reporting requirements as provided in Subpart 6 NYCRR Part 245-8 and in 40 CFR Part 75, Subparts F and G. A certified SO2 emission monitoring system must be used to measure SO2 emissions. SO2 emission reports must be certified and submitted quarterly.

Non Applicability Analysis

List of non-applicable rules and regulations:

| Location Facility/EU/EP/Process/ES | Regulation | Short Description |
|---|-------------------|--------------------------|
|---|-------------------|--------------------------|



**New York State Department of Environmental Conservation
Permit Review Report**

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

Therefore, this rule does not apply.

NOTE: Non-applicability determinations are cited as a permit condition under 6 NYCRR Part 201-6.4(g). This information is optional and provided only if the applicant is seeking to obtain formal confirmation, within an issued Title V permit, that specified activities are not subject to the listed federal applicable or state only requirement. The applicant is seeking to obtain verification that a requirement does not apply for the stated reason(s) and the Department has agreed to include the non-applicability determination in the issued Title V permit which in turn provides a shield against any potential enforcement action.

Compliance Certification

Summary of monitoring activities at SELKIRK COGENERATION PROJECT:

| Location Facility/EU/EP/Process/ES | Cond No. | Type of Monitoring |
|---|-----------------|---|
| FACILITY | 48 | work practice involving specific operations |
| FACILITY | 49 | record keeping/maintenance procedures |
| FACILITY | 50 | record keeping/maintenance procedures |
| FACILITY | 51 | record keeping/maintenance procedures |
| FACILITY | 52 | record keeping/maintenance procedures |
| FACILITY | 53 | record keeping/maintenance procedures |
| FACILITY | 54 | record keeping/maintenance procedures |
| FACILITY | 55 | record keeping/maintenance procedures |
| U-00001 | 66 | work practice involving specific operations |
| U-00001 | 67 | record keeping/maintenance procedures |
| U-00001/00001 | 93 | work practice involving specific operations |
| U-00001/00001 | 94 | work practice involving specific operations |
| U-00001/00001 | 95 | work practice involving specific operations |
| U-00001/00001 | 96 | record keeping/maintenance procedures |
| U-00001/00001 | 97 | work practice involving specific operations |
| U-00001/00001/LAG | 98 | continuous emission monitoring (cem) |
| U-00001/00001/LAG | 99 | continuous emission monitoring (cem) |
| U-00001/00001/LAG/OOGT1 | 100 | intermittent emission testing |
| U-00001/00001/LAG/OOGT1 | 101 | intermittent emission testing |
| U-00001/00001/LAG/OOGT1 | 102 | intermittent emission testing |
| U-00001/00001/LAO | 103 | continuous emission monitoring (cem) |
| U-00001/00001/LAO | 104 | continuous emission monitoring (cem) |
| U-00001/00001/LAO/OOGT1 | 105 | intermittent emission testing |
| U-00001/00001/LAO/OOGT1 | 106 | intermittent emission testing |
| U-00001/00001/LAO/OOGT1 | 107 | intermittent emission testing |
| U-00001/00001/LBG/OOGT1 | 108 | intermittent emission testing |
| U-00001/00001/LBG/OOGT1 | 109 | intermittent emission testing |
| U-00001/00001/LBG/OOGT1 | 110 | intermittent emission testing |
| U-00001/00001/LBG/OOGT1 | 111 | intermittent emission testing |
| U-00001/00001/LBO/OOGT1 | 112 | intermittent emission testing |
| U-00001/00001/LBO/OOGT1 | 113 | intermittent emission testing |
| U-00001/00001/LBO/OOGT1 | 114 | intermittent emission testing |
| U-00001/00001/LBO/OOGT1 | 115 | intermittent emission testing |
| U-00001/00001/LDB/OODB1 | 116 | intermittent emission testing |
| U-00001/00001/LDB/OODB1 | 117 | intermittent emission testing |
| U-00001/00001/LDB/OODB1 | 118 | intermittent emission testing |
| U-00001/00001/LDB/OODB1 | 119 | intermittent emission testing |
| U-00001/00001/LDB/OODB1 | 120 | intermittent emission testing |
| U-00001/00001/LDB/OODB1 | 121 | intermittent emission testing |
| U-00001/00001/LDB/OODB1 | 122 | intermittent emission testing |



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | | |
|-------------------------|-----|---|
| U-00001/00001/1DB/OODB1 | 123 | intermittent emission testing |
| U-00001/00001/1DB/OODB1 | 124 | intermittent emission testing |
| U-00001/00001/1DB/OODB1 | 125 | intermittent emission testing |
| U-00001/00001/1DB/OODB1 | 126 | intermittent emission testing |
| U-00001/00001/1DB/OODB1 | 127 | intermittent emission testing |
| U-00001/00001/1GL/OOGT1 | 128 | intermittent emission testing |
| U-00001/00001/1GL/OOGT1 | 129 | intermittent emission testing |
| U-00001/00001/1GL/OOGT1 | 130 | intermittent emission testing |
| U-00001/00001/1GL/OOGT1 | 131 | intermittent emission testing |
| U-00001/00001/1HG | 132 | continuous emission monitoring (cem) |
| U-00001/00001/1HG | 133 | continuous emission monitoring (cem) |
| U-00001/00001/1HG/OOGT1 | 134 | intermittent emission testing |
| U-00001/00001/1HO | 135 | continuous emission monitoring (cem) |
| U-00001/00001/1HO | 136 | continuous emission monitoring (cem) |
| U-00001/00001/1HO/OOGT1 | 137 | intermittent emission testing |
| U-00001/00001/1LF/OOGT1 | 138 | intermittent emission testing |
| U-00001/00001/1LF/OOGT1 | 139 | intermittent emission testing |
| U-00001/00001/1LF/OOGT1 | 140 | intermittent emission testing |
| U-00001/00001/1LF/OOGT1 | 141 | intermittent emission testing |
| U-00001/00001/1LG | 142 | continuous emission monitoring (cem) |
| U-00001/00001/1LG | 143 | continuous emission monitoring (cem) |
| U-00001/00001/1LG/OOGT1 | 144 | intermittent emission testing |
| U-00001/00001/1LO | 145 | continuous emission monitoring (cem) |
| U-00001/00001/1LO | 146 | continuous emission monitoring (cem) |
| U-00001/00001/1LO/OOGT1 | 147 | intermittent emission testing |
| U-00001/00001/1MG | 148 | continuous emission monitoring (cem) |
| U-00001/00001/1MG | 149 | continuous emission monitoring (cem) |
| U-00001/00001/1MG/OOGT1 | 150 | intermittent emission testing |
| U-00001/00001/1MO | 151 | continuous emission monitoring (cem) |
| U-00001/00001/1MO | 152 | continuous emission monitoring (cem) |
| U-00001/00001/1MO/OOGT1 | 153 | intermittent emission testing |
| U-00002 | 156 | work practice involving specific operations |
| U-00002 | 157 | record keeping/maintenance procedures |
| U-00002 | 158 | record keeping/maintenance procedures |
| U-00002 | 159 | work practice involving specific operations |
| U-00002/-/23G | 178 | continuous emission monitoring (cem) |
| U-00002/-/23G | 179 | continuous emission monitoring (cem) |
| U-00002/-/23G | 180 | continuous emission monitoring (cem) |
| U-00002/-/23G | 181 | continuous emission monitoring (cem) |
| U-00002/-/23G | 182 | continuous emission monitoring (cem) |
| U-00002/-/23G | 183 | continuous emission monitoring (cem) |
| U-00002/-/23G/OGT23 | 184 | intermittent emission testing |
| U-00002/-/23G/OGT23 | 185 | intermittent emission testing |
| U-00002/-/23G/OGT23 | 186 | intermittent emission testing |
| U-00002/-/23G/OGT23 | 187 | intermittent emission testing |
| U-00002/-/230 | 188 | continuous emission monitoring (cem) |
| U-00002/-/230 | 189 | continuous emission monitoring (cem) |
| U-00002/-/230 | 190 | continuous emission monitoring (cem) |
| U-00002/-/230 | 191 | continuous emission monitoring (cem) |
| U-00002/-/230 | 192 | continuous emission monitoring (cem) |
| U-00002/-/230 | 193 | continuous emission monitoring (cem) |
| U-00002/-/230/OGT23 | 194 | intermittent emission testing |
| U-00002/-/230/OGT23 | 195 | intermittent emission testing |
| U-00002/-/230/OGT23 | 196 | intermittent emission testing |
| U-00002/-/230/OGT23 | 197 | intermittent emission testing |
| U-00002/-/230/OGT23 | 198 | intermittent emission testing |
| U-00002/-/230/OGT23 | 199 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 202 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 203 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 204 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 205 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 206 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 207 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 208 | intermittent emission testing |



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

| | | |
|---------------------|------|---|
| U-00002/-/2DB/ODB23 | 209 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 210 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 211 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 212 | intermittent emission testing |
| U-00002/-/2DB/ODB23 | 213 | intermittent emission testing |
| U-00002/-/2GB/OGT23 | 214 | intermittent emission testing |
| U-00002/-/2GB/OGT23 | 215 | intermittent emission testing |
| U-00002/-/2GB/OGT23 | 216 | intermittent emission testing |
| U-00002/-/2GB/OGT23 | 217 | intermittent emission testing |
| U-00002/-/2GL/OGT23 | 218 | intermittent emission testing |
| U-00002/-/2GL/OGT23 | 219 | intermittent emission testing |
| U-00002/-/2GL/OGT23 | 220 | intermittent emission testing |
| U-00002/-/2GL/OGT23 | 221 | intermittent emission testing |
| U-00002/-/2OB/OGT23 | 222 | intermittent emission testing |
| U-00002/-/2OB/OGT23 | 223 | intermittent emission testing |
| U-00002/-/2OB/OGT23 | 224 | intermittent emission testing |
| U-00002/-/2OB/OGT23 | 225 | intermittent emission testing |
| U-00002/-/2OL/OGT23 | 226 | intermittent emission testing |
| U-00002/-/2OL/OGT23 | 227 | intermittent emission testing |
| U-00002/-/2OL/OGT23 | 228 | intermittent emission testing |
| U-00002/00002 | 229 | work practice involving specific operations |
| U-00002/00002 | 230 | work practice involving specific operations |
| U-00002/00003 | 231 | work practice involving specific operations |
| U-00002/00003 | 232 | work practice involving specific operations |
| U-00004 | 233 | record keeping/maintenance procedures |
| FACILITY | 3-17 | record keeping/maintenance procedures |
| FACILITY | 58 | record keeping/maintenance procedures |
| FACILITY | 3-18 | record keeping/maintenance procedures |
| U-00001 | 87 | record keeping/maintenance procedures |
| U-00001 | 88 | record keeping/maintenance procedures |
| U-00001 | 3-19 | continuous emission monitoring (cem) |
| U-00001 | 3-20 | continuous emission monitoring (cem) |
| U-00002 | 3-22 | continuous emission monitoring (cem) |
| U-00002 | 3-23 | continuous emission monitoring (cem) |
| U-00002 | 154 | continuous emission monitoring (cem) |
| FACILITY | 5 | record keeping/maintenance procedures |
| FACILITY | 6 | record keeping/maintenance procedures |
| FACILITY | 7 | record keeping/maintenance procedures |
| FACILITY | 24 | work practice involving specific operations |
| FACILITY | 25 | record keeping/maintenance procedures |
| FACILITY | 26 | monitoring of process or control device parameters as surrogate |
| U-00001 | 3-21 | continuous emission monitoring (cem) |
| FACILITY | 27 | intermittent emission testing |
| FACILITY | 28 | intermittent emission testing |
| FACILITY | 237 | record keeping/maintenance procedures |
| FACILITY | 238 | record keeping/maintenance procedures |
| FACILITY | 41 | record keeping/maintenance procedures |
| FACILITY | 42 | record keeping/maintenance procedures |
| FACILITY | 43 | record keeping/maintenance procedures |
| FACILITY | 46 | record keeping/maintenance procedures |

Basis for Monitoring

This DIM for Selkirk Cogeneration Partners (SCP) facility included redefining start-up and shut-down parameters. The allowable emissions and time table for those emissions reflect more accurately the existing facility's operations.

It also contains edits and updates to citations which were either redundant or could be group together. Examples of redundant citations are General Requirements for the 40 CFR 60 Standards, every applicable requirement was stated for two emission units. Additionally, these were then cited at the facility level.



New York State Department of Environmental Conservation
Permit Review Report

Permit ID: 4-0122-00078/00013

Renewal Number: 1

Modification Number: 3 04/04/2018

A cap was incorrectly placed in the permit to remove requirements pertaining to fuel/NOx limitations. Since the facility has calculated emissions for a RACT analysis, the results satisfy only 6 NYCRR 227 Stationary Combustion Installations regulatory requirements and do not remove them from 227 applicability. This cap is now a limit under 227-2.