

Inactive Hazardous Waste Site Operations and Maintenance Review Report

Form Date 96.10.01

Site Name: OLD **BETHPAGE** LANDFILL Class: 4 Number: **130001**

O&M Funding Source: State Superfund Federal Superfund Municipal Responsible Party

O&M Information: O&M Start: 93109 End: Annual Cost: \$ Estimated

Interim Remedial **Measures/Operable** Units in **O&M** Phase:

- | | | |
|--|---|--|
| <input type="checkbox"/> Drum Removal | <input type="checkbox"/> Soil Removal | <input type="checkbox"/> Tank Removal |
| <input checked="" type="checkbox"/> Cap/Cover | <input type="checkbox"/> Containment Structure | <input type="checkbox"/> Fence/Security |
| <input checked="" type="checkbox"/> Groundwater Recovery/Treatment | <input checked="" type="checkbox"/> Leachate Collection/Treatment | <input type="checkbox"/> Vapor Extraction/Treatment |
| <input type="checkbox"/> Air Sparging/Stripper System | <input type="checkbox"/> Treatment/Filtration Plant/System | <input type="checkbox"/> Potable Water Supply/System |
| <input type="checkbox"/> Other: | | |

Institutional Controls: Deed Restriction Discharge Permit Department of Health Sampling
 Other:

O&M Review Information:

Reports: 1998 Second Quarter Report and 1997 Annual Report (Received 10198)

Inspection: _____

Sampling: _____

Other: _____

Conclusions:

Remedy Effective? Yes No: _____

ROD Compliance? Yes No: _____

Consent Order Compliance? Yes No: _____


Other: _____

Recommendations: The facility appears to be running well since the previous annual review of April 1997. The annual report for 1997, which was received in October 1998, indicated overall treatment efficiency to be over 99%, with an online performance of 88%, and average daily flow of 1.26 MGD for 1997. The average effluent total VOC discharge was 1.31ppb. As was indicated in the previous annual review, the monitoring reports are not submitted in a timely fashion, but in the Town's defense their reports are voluminous and contain an extensive amount of sampling results. Considering this is the only problem noted, and as long as the facility's performance continues, it is less of a concern. The Town is very responsive on reporting when wells are shut-down for longer than 48 hours, and subsequently returned to service. Town personnel telephone, and provide follow-up letters by both fax and mail on pump failures.

ROD/Consent Order Modifications? No Yes (per above) Reclassify the Site? No Yes → Class:

Comments: The most recent quarterly report submission indicates that the overall treatment efficiency was 99.2%, the online performance over the 91 day period was 90.5%, at an average daily flow of 1.26MGD. A telephone call to the Town of Oyster Bay's Engineering Department indicated they will be sending out the third quarter report for 1998 shortly. It is a 3 volume report that contains a great deal of information and apparently requires a substantial time to compile.

NEXT ANNUAL REVIEW DUE 412000

Project Manager:  Signature _____ Date May 14, 1999			Reviewer: Signature _____ Date _____		
Carl Hoffman	WIS / BHSC / DER	(518) 457-9538	Name	Region or Bureau	Telephone