

10 October 2022

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

SEPTEMBER 2022 REPORTING PERIOD

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 September to 30 September 2022 are presented in Attachment A. The plant was down for approximately 19.2 hours during the reporting period as the result of the backwashing of the GAC units and low flow alarms from the advanced oxidation process (AOP) hydrogen peroxide delivery system.

As indicated in Attachment A, all SPDES permitted constituents are in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0636 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Robert G. Gregory

Robert & Dryng

Project Manager

Attachment A: Groundwater and Air Sampling Results for September 2022

- cc: C. Haas, NYSDEC Region 1
 - C. Engelhardt, NYSDEC Region 1
 - J. Pilewski, NYSDEC Region 1 Water Engineer
 - K. Granzen, NYSDEC
 - M. Travis, NYSDEC
 - J. Sullivan, NYSDOH
 - G. Ennis, Nassau County Department of Public Works
 - T. Licata, Town of Oyster Bay
 - M. Russo, Town of Oyster Bay
 - S. Sokolowski, NAVFAC Mid-Atlantic
 - V. Varricchio, NWIRP Bethpage Facilities Management
 - P. Schauble, KGS
 - GM-38 Copy

ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS SEPTEMBER 2022

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report September 2022

SPDES Parameters			September 2022				
Process Stream	Daily Treated Effluent Maximum ⁽¹⁾	Units	RW-1	RW-3	RW-4	Combined Influent (RW-1 + RW-3 + RW- 4)	Treated Effluent
Well Depth	N/A	ft	445	530	675	N/A	N/A
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	570-670	N/A	N/A
Sampling Date	N/A		9/14/22				
Effective Flowrate	1100	GPM	470	0	459	929	985
Total Flow	N/A	gallons	19,770,300	0	19,293,000	39,063,300	41,404,800
рН	5.5 - 8.5	SU	5.59	NS	6.28	5.93	6.67
Chloroform	5	μg/L	0.276 J	NS	ND (1.0)	0.14 J	ND (1.0)
1,1-Dichloroethane	5	μg/L	1.07 J	NS	ND (1.0)	0.54 J	ND (1.0)
1,2-Dichloroethane	0.6	μg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)	ND (1.0)
1,1-Dichloroethene	5	μg/L	0.647 J	NS	1.60 J	1.12 J	ND (1.0)
cis 1,2-Dichloroethene	5	μg/L	3.35 J	NS	ND (1.0)	1.70 J	ND (1.0)
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)	ND (1.0)
Tetrachloroethene	5	μg/L	14.2	NS	6.06 J	10.2	ND (1.0)
1,1,1-Trichloroethane	5	μg/L	0.315 J	NS	ND (1.0)	0.16 J	ND (1.0)
Trichloroethene	5	μg/L	51.2	NS	677	360.3	ND (1.0)
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	NS	4.69 J	2.3 J	ND (1.0)
Vinyl Chloride	2	μg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)	ND (1.0)
1,4-Dioxane - 8270D	1	μg/L	1.9	NS	13	7.4	0.11 *
1,4-Dioxane - 8270D SIM IDMS	1	μg/L	2.1	NS	14	8.0	0.11 *
Mercury	0.00025	mg/L	ND (0.00010)	NS	ND (0.00010)	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)	ND (1.0)

Notes:

- J Estimated result between laboratory method detection limit and reporting limit
- ND Not detected above laboratory method detection limit. Limit of Detection (LOD) given in parentheses.
- N/A Not Applicable
- NS Not Sampled
- * Indicates the samples were reanalyzed outside of the holdtime.
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results September 2022

DAR Parameters	September 2022				
Process Stream	Units	Discharge Goal ⁽¹⁾	Influent	Effluent	
Sampling Date			9/14/22		
Average Flowrate	CFM	N/A	NR	7,999	
Total Flow	ft ³	N/A	NR	336,356,807	
Total Flow	m ³	N/A	NR	9,524,564	
,2-Dichloroethane μg/m		N/A	ND	1.6 J	
cis 1,2-Dichloroethene	μg/m³	≤ 100,000 ⁽²⁾	28	13	
trans 1,2-Dichloroethene	μg/m³	≤ 100,000	ND	ND	
1,2-Dichloroethene (total)	μg/m³	≤ 100,000	28	13	
Toluene	μg/m³	N/A	ND	ND	
Total Xylene	μg/m³	N/A	ND	ND	
1,1,2-Trichloroethane	μg/m³	N/A	ND	ND	
Trichloroethene	μg/m³	≤ 2600	7000	6.2	
Vinyl Chloride	μg/m³	≤ 560	ND	ND	
Tetrachloroethene	μg/m³	≤ 5100	180	ND	

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions September 2022

DAR Parameters	Units	Discharge Goal ⁽¹⁾	September 2022	
Sampling Date			9/14/22	
Average Flowrate	CFM	N/A	7,999	
Total Flow	ft ³	N/A	336,356,807	
Total Flow	m ³	N/A	9,524,564	
Trichloroethene	lb/hr	≤ 0.09	0.00018	
Vinyl Chloride	lb/hr	≤ 0.02	0.00000	
1,2 Dichloroethene	lb/hr	≤ 11	0.00038	
1,2-Dichloroethane	lb/hr	N/A	0.00005	
Toluene	lb/hr	N/A	0.00000	
Total Xylene	lb/hr	N/A	0.00000	
1,1,2-Trichloroethane	lb/hr	N/A	0.00000	
Tetrachloroethene	lb/hr	≤ 0.18	0.00000	

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.