

May 15, 2023

Robert G. Gregory
KOMAN Government Services, LLC
180 Gordon Dr.
Suite 110
Exton, PA 19341

RE: Project: NYAW-MERRICK OPS-POC/1,4DIO5/5
Pace Project No.: 70255417

Dear Robert Gregory:

Enclosed are the analytical results for sample(s) received by the laboratory on May 05, 2023. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Kimberley M. Mack
kimberley.mack@pacelabs.com
(631)694-3040
Project Manager

Enclosures

cc: Ericka Seiler, KOMAN Government Services, LLC



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70255417001	GAC-3S/4S(SEAMAN NECK GAC EFF.	Drinking Water	05/05/23 10:15	05/05/23 11:25
70255417002	GAC-3S/4S(SEAMAN NECK G. EFF-D	Drinking Water	05/05/23 10:20	05/05/23 11:25
70255417003	WELL 3A N-14347(INFLUENT)	Drinking Water	05/05/23 10:30	05/05/23 11:25
70255417004	WELL 4 N-09338(INFLUENT)	Drinking Water	05/05/23 10:45	05/05/23 11:25

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70255417001	GAC-3S/4S(SEAMAN NECK GAC EFF.	EPA 522	SPM	2
		EPA 524.2	KGG	62
70255417002	GAC-3S/4S(SEAMAN NECK G. EFF-D	EPA 524.2	KGG	62
70255417003	WELL 3A N-14347(INFLUENT)	EPA 522	SPM	2
		EPA 524.2	KGG	62
70255417004	WELL 4 N-09338(INFLUENT)	EPA 522	SPM	2
		EPA 524.2	KGG	62

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Sample: GAC-3S/4S(SEAMAN NECK GAC EFF. **Lab ID:** 70255417001 Collected: 05/05/23 10:15 Received: 05/05/23 11:25 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
522 MSS 1,4 Dioxane (SIM)									
Analytical Method: EPA 522 Preparation Method: EPA 522									
Pace Analytical Services - Melville									
1,4-Dioxane (p-Dioxane)	1.6	ug/L	0.020		1	05/10/23 10:13	05/11/23 15:43	123-91-1	
Surrogates									
1,4-Dioxane-d8 (S)	103	%	70-130		1	05/10/23 10:13	05/11/23 15:43		
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Melville									
Benzene	<0.50	ug/L	0.50	5	1		05/11/23 19:00	71-43-2	
Bromobenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	108-86-1	
Bromochloromethane	<0.50	ug/L	0.50		1		05/11/23 19:00	74-97-5	
Bromodichloromethane	<0.50	ug/L	0.50	80	1		05/11/23 19:00	75-27-4	
Bromoform	<0.50	ug/L	0.50	80	1		05/11/23 19:00	75-25-2	
Bromomethane	<0.50	ug/L	0.50		1		05/11/23 19:00	74-83-9	
n-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	104-51-8	
sec-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	135-98-8	
tert-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	98-06-6	
Carbon tetrachloride	<0.50	ug/L	0.50	5	1		05/11/23 19:00	56-23-5	
Chlorobenzene	<0.50	ug/L	0.50	100	1		05/11/23 19:00	108-90-7	
Chlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:00	75-45-6	N3
Chloroethane	<0.50	ug/L	0.50		1		05/11/23 19:00	75-00-3	
Chloroform	<0.50	ug/L	0.50	80	1		05/11/23 19:00	67-66-3	
Chloromethane	<0.50	ug/L	0.50		1		05/11/23 19:00	74-87-3	
2-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 19:00	95-49-8	
4-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 19:00	106-43-4	
Dibromochloromethane	<0.50	ug/L	0.50	80	1		05/11/23 19:00	124-48-1	
Dibromomethane	<0.50	ug/L	0.50		1		05/11/23 19:00	74-95-3	
1,2-Dichlorobenzene	<0.50	ug/L	0.50	600	1		05/11/23 19:00	95-50-1	
1,3-Dichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	541-73-1	
1,4-Dichlorobenzene	<0.50	ug/L	0.50	75	1		05/11/23 19:00	106-46-7	
Dichlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:00	75-71-8	
1,1-Dichloroethane	<0.50	ug/L	0.50		1		05/11/23 19:00	75-34-3	
1,2-Dichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 19:00	107-06-2	
1,1-Dichloroethene	<0.50	ug/L	0.50	7	1		05/11/23 19:00	75-35-4	
cis-1,2-Dichloroethene	<0.50	ug/L	0.50	70	1		05/11/23 19:00	156-59-2	
trans-1,2-Dichloroethene	<0.50	ug/L	0.50	100	1		05/11/23 19:00	156-60-5	
1,2-Dichloropropane	<0.50	ug/L	0.50	5	1		05/11/23 19:00	78-87-5	
1,3-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:00	142-28-9	
2,2-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:00	594-20-7	
1,1-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:00	563-58-6	
cis-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:00	10061-01-5	
trans-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:00	10061-02-6	
Ethylbenzene	<0.50	ug/L	0.50	700	1		05/11/23 19:00	100-41-4	
Hexachloro-1,3-butadiene	<0.50	ug/L	0.50		1		05/11/23 19:00	87-68-3	
Isopropylbenzene (Cumene)	<0.50	ug/L	0.50		1		05/11/23 19:00	98-82-8	
p-Isopropyltoluene	<0.50	ug/L	0.50		1		05/11/23 19:00	99-87-6	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5
Pace Project No.: 70255417

Sample: GAC-3S/4S(SEAMAN NECK GAC EFF. **Lab ID:** 70255417001 Collected: 05/05/23 10:15 Received: 05/05/23 11:25 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Melville									
Methylene Chloride	<0.50	ug/L	0.50	5	1		05/11/23 19:00	75-09-2	
Methyl-tert-butyl ether	<0.50	ug/L	0.50		1		05/11/23 19:00	1634-04-4	
n-Propylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	103-65-1	
Styrene	<0.50	ug/L	0.50	100	1		05/11/23 19:00	100-42-5	
1,1,1,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 19:00	630-20-6	
1,1,2,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 19:00	79-34-5	
Tetrachloroethene	<0.50	ug/L	0.50	5	1		05/11/23 19:00	127-18-4	
Toluene	<0.50	ug/L	0.50	1000	1		05/11/23 19:00	108-88-3	
Total Trihalomethanes (Calc.)	<0.50	ug/L	0.50	80	1		05/11/23 19:00		
1,2,3-Trichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	87-61-6	
1,2,4-Trichlorobenzene	<0.50	ug/L	0.50	70	1		05/11/23 19:00	120-82-1	
1,1,1-Trichloroethane	<0.50	ug/L	0.50	200	1		05/11/23 19:00	71-55-6	
1,1,2-Trichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 19:00	79-00-5	
Trichloroethene	<0.50	ug/L	0.50	5	1		05/11/23 19:00	79-01-6	
Trichlorofluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:00	75-69-4	
1,2,3-Trichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:00	96-18-4	
1,1,2-Trichlorotrifluoroethane	<0.50	ug/L	0.50		1		05/11/23 19:00	76-13-1	L1,N3
1,2,4-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	95-63-6	
1,3,5-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:00	108-67-8	
Vinyl chloride	<0.50	ug/L	0.50	2	1		05/11/23 19:00	75-01-4	
m&p-Xylene	<0.50	ug/L	0.50		1		05/11/23 19:00	179601-23-1	
o-Xylene	<0.50	ug/L	0.50		1		05/11/23 19:00	95-47-6	
Surrogates									
1,2-Dichlorobenzene-d4 (S)	95	%	70-130		1		05/11/23 19:00	2199-69-1	
4-Bromofluorobenzene (S)	102	%	70-130		1		05/11/23 19:00	460-00-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Sample: GAC-3S/4S(SEAMAN) **Lab ID:** 70255417002 **Collected:** 05/05/23 10:20 **Received:** 05/05/23 11:25 **Matrix:** Drinking Water
NECK G. EFF-D

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV		Analytical Method: EPA 524.2 Pace Analytical Services - Melville							
Benzene	<0.50	ug/L	0.50	5	1		05/11/23 19:27	71-43-2	
Bromobenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	108-86-1	
Bromochloromethane	<0.50	ug/L	0.50		1		05/11/23 19:27	74-97-5	
Bromodichloromethane	<0.50	ug/L	0.50	80	1		05/11/23 19:27	75-27-4	
Bromoform	<0.50	ug/L	0.50	80	1		05/11/23 19:27	75-25-2	
Bromomethane	<0.50	ug/L	0.50		1		05/11/23 19:27	74-83-9	
n-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	104-51-8	
sec-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	135-98-8	
tert-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	98-06-6	
Carbon tetrachloride	<0.50	ug/L	0.50	5	1		05/11/23 19:27	56-23-5	
Chlorobenzene	<0.50	ug/L	0.50	100	1		05/11/23 19:27	108-90-7	
Chlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:27	75-45-6	N3
Chloroethane	<0.50	ug/L	0.50		1		05/11/23 19:27	75-00-3	
Chloroform	<0.50	ug/L	0.50	80	1		05/11/23 19:27	67-66-3	
Chloromethane	<0.50	ug/L	0.50		1		05/11/23 19:27	74-87-3	
2-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 19:27	95-49-8	
4-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 19:27	106-43-4	
Dibromochloromethane	<0.50	ug/L	0.50	80	1		05/11/23 19:27	124-48-1	
Dibromomethane	<0.50	ug/L	0.50		1		05/11/23 19:27	74-95-3	
1,2-Dichlorobenzene	<0.50	ug/L	0.50	600	1		05/11/23 19:27	95-50-1	
1,3-Dichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	541-73-1	
1,4-Dichlorobenzene	<0.50	ug/L	0.50	75	1		05/11/23 19:27	106-46-7	
Dichlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:27	75-71-8	
1,1-Dichloroethane	<0.50	ug/L	0.50		1		05/11/23 19:27	75-34-3	
1,2-Dichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 19:27	107-06-2	
1,1-Dichloroethene	<0.50	ug/L	0.50	7	1		05/11/23 19:27	75-35-4	
cis-1,2-Dichloroethene	<0.50	ug/L	0.50	70	1		05/11/23 19:27	156-59-2	
trans-1,2-Dichloroethene	<0.50	ug/L	0.50	100	1		05/11/23 19:27	156-60-5	
1,2-Dichloropropane	<0.50	ug/L	0.50	5	1		05/11/23 19:27	78-87-5	
1,3-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:27	142-28-9	
2,2-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:27	594-20-7	
1,1-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:27	563-58-6	
cis-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:27	10061-01-5	
trans-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:27	10061-02-6	
Ethylbenzene	<0.50	ug/L	0.50	700	1		05/11/23 19:27	100-41-4	
Hexachloro-1,3-butadiene	<0.50	ug/L	0.50		1		05/11/23 19:27	87-68-3	
Isopropylbenzene (Cumene)	<0.50	ug/L	0.50		1		05/11/23 19:27	98-82-8	
p-Isopropyltoluene	<0.50	ug/L	0.50		1		05/11/23 19:27	99-87-6	
Methylene Chloride	<0.50	ug/L	0.50	5	1		05/11/23 19:27	75-09-2	
Methyl-tert-butyl ether	<0.50	ug/L	0.50		1		05/11/23 19:27	1634-04-4	
n-Propylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	103-65-1	
Styrene	<0.50	ug/L	0.50	100	1		05/11/23 19:27	100-42-5	
1,1,1,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 19:27	630-20-6	
1,1,1,2,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 19:27	79-34-5	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Sample: GAC-3S/4S(SEAMAN) **Lab ID:** 70255417002 **Collected:** 05/05/23 10:20 **Received:** 05/05/23 11:25 **Matrix:** Drinking Water
NECK G. EFF-D

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Melville									
Tetrachloroethene	<0.50	ug/L	0.50	5	1		05/11/23 19:27	127-18-4	
Toluene	<0.50	ug/L	0.50	1000	1		05/11/23 19:27	108-88-3	
Total Trihalomethanes (Calc.)	<0.50	ug/L	0.50	80	1		05/11/23 19:27		
1,2,3-Trichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	87-61-6	
1,2,4-Trichlorobenzene	<0.50	ug/L	0.50	70	1		05/11/23 19:27	120-82-1	
1,1,1-Trichloroethane	<0.50	ug/L	0.50	200	1		05/11/23 19:27	71-55-6	
1,1,2-Trichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 19:27	79-00-5	
Trichloroethene	<0.50	ug/L	0.50	5	1		05/11/23 19:27	79-01-6	
Trichlorofluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:27	75-69-4	
1,2,3-Trichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:27	96-18-4	
1,1,2-Trichlorotrifluoroethane	<0.50	ug/L	0.50		1		05/11/23 19:27	76-13-1	L1,N3
1,2,4-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	95-63-6	
1,3,5-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:27	108-67-8	
Vinyl chloride	<0.50	ug/L	0.50	2	1		05/11/23 19:27	75-01-4	
m&p-Xylene	<0.50	ug/L	0.50		1		05/11/23 19:27	179601-23-1	
o-Xylene	<0.50	ug/L	0.50		1		05/11/23 19:27	95-47-6	
Surrogates									
1,2-Dichlorobenzene-d4 (S)	89	%	70-130		1		05/11/23 19:27	2199-69-1	
4-Bromofluorobenzene (S)	97	%	70-130		1		05/11/23 19:27	460-00-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5
Pace Project No.: 70255417

Sample: WELL 3A N-14347(INFLUENT) **Lab ID: 70255417003** Collected: 05/05/23 10:30 Received: 05/05/23 11:25 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
522 MSS 1,4 Dioxane (SIM)									
Analytical Method: EPA 522 Preparation Method: EPA 522									
Pace Analytical Services - Melville									
1,4-Dioxane (p-Dioxane)	2.1	ug/L	0.020		1	05/10/23 10:13	05/11/23 16:00	123-91-1	
Surrogates									
1,4-Dioxane-d8 (S)	104	%	70-130		1	05/10/23 10:13	05/11/23 16:00		
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Melville									
Benzene	<0.50	ug/L	0.50		5		05/11/23 19:54	71-43-2	
Bromobenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	108-86-1	
Bromochloromethane	<0.50	ug/L	0.50		1		05/11/23 19:54	74-97-5	
Bromodichloromethane	<0.50	ug/L	0.50	80	1		05/11/23 19:54	75-27-4	
Bromoform	<0.50	ug/L	0.50	80	1		05/11/23 19:54	75-25-2	
Bromomethane	<0.50	ug/L	0.50		1		05/11/23 19:54	74-83-9	
n-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	104-51-8	
sec-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	135-98-8	
tert-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	98-06-6	
Carbon tetrachloride	<0.50	ug/L	0.50		5	1	05/11/23 19:54	56-23-5	
Chlorobenzene	<0.50	ug/L	0.50		100	1	05/11/23 19:54	108-90-7	
Chlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:54	75-45-6	N3
Chloroethane	<0.50	ug/L	0.50		1		05/11/23 19:54	75-00-3	
Chloroform	<0.50	ug/L	0.50	80	1		05/11/23 19:54	67-66-3	
Chloromethane	<0.50	ug/L	0.50		1		05/11/23 19:54	74-87-3	
2-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 19:54	95-49-8	
4-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 19:54	106-43-4	
Dibromochloromethane	<0.50	ug/L	0.50	80	1		05/11/23 19:54	124-48-1	
Dibromomethane	<0.50	ug/L	0.50		1		05/11/23 19:54	74-95-3	
1,2-Dichlorobenzene	<0.50	ug/L	0.50	600	1		05/11/23 19:54	95-50-1	
1,3-Dichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	541-73-1	
1,4-Dichlorobenzene	<0.50	ug/L	0.50	75	1		05/11/23 19:54	106-46-7	
Dichlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:54	75-71-8	
1,1-Dichloroethane	<0.50	ug/L	0.50		1		05/11/23 19:54	75-34-3	
1,2-Dichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 19:54	107-06-2	
1,1-Dichloroethene	<0.50	ug/L	0.50	7	1		05/11/23 19:54	75-35-4	
cis-1,2-Dichloroethene	<0.50	ug/L	0.50	70	1		05/11/23 19:54	156-59-2	
trans-1,2-Dichloroethene	<0.50	ug/L	0.50	100	1		05/11/23 19:54	156-60-5	
1,2-Dichloropropane	<0.50	ug/L	0.50	5	1		05/11/23 19:54	78-87-5	
1,3-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:54	142-28-9	
2,2-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:54	594-20-7	
1,1-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:54	563-58-6	
cis-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:54	10061-01-5	
trans-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 19:54	10061-02-6	
Ethylbenzene	<0.50	ug/L	0.50	700	1		05/11/23 19:54	100-41-4	
Hexachloro-1,3-butadiene	<0.50	ug/L	0.50		1		05/11/23 19:54	87-68-3	
Isopropylbenzene (Cumene)	<0.50	ug/L	0.50		1		05/11/23 19:54	98-82-8	
p-Isopropyltoluene	<0.50	ug/L	0.50		1		05/11/23 19:54	99-87-6	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5
Pace Project No.: 70255417

Sample: WELL 3A N-14347(INFLUENT) **Lab ID: 70255417003** Collected: 05/05/23 10:30 Received: 05/05/23 11:25 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Melville									
Methylene Chloride	<0.50	ug/L	0.50	5	1		05/11/23 19:54	75-09-2	
Methyl-tert-butyl ether	<0.50	ug/L	0.50		1		05/11/23 19:54	1634-04-4	
n-Propylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	103-65-1	
Styrene	<0.50	ug/L	0.50	100	1		05/11/23 19:54	100-42-5	
1,1,1,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 19:54	630-20-6	
1,1,2,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 19:54	79-34-5	
Tetrachloroethene	<0.50	ug/L	0.50	5	1		05/11/23 19:54	127-18-4	
Toluene	<0.50	ug/L	0.50	1000	1		05/11/23 19:54	108-88-3	
Total Trihalomethanes (Calc.)	<0.50	ug/L	0.50	80	1		05/11/23 19:54		
1,2,3-Trichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	87-61-6	
1,2,4-Trichlorobenzene	<0.50	ug/L	0.50	70	1		05/11/23 19:54	120-82-1	
1,1,1-Trichloroethane	<0.50	ug/L	0.50	200	1		05/11/23 19:54	71-55-6	
1,1,2-Trichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 19:54	79-00-5	
Trichloroethene	10.6	ug/L	0.50	5	1		05/11/23 19:54	79-01-6	
Trichlorofluoromethane	<0.50	ug/L	0.50		1		05/11/23 19:54	75-69-4	
1,2,3-Trichloropropane	<0.50	ug/L	0.50		1		05/11/23 19:54	96-18-4	
1,1,2-Trichlorotrifluoroethane	<0.50	ug/L	0.50		1		05/11/23 19:54	76-13-1	L1,N3
1,2,4-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	95-63-6	
1,3,5-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 19:54	108-67-8	
Vinyl chloride	<0.50	ug/L	0.50	2	1		05/11/23 19:54	75-01-4	
m&p-Xylene	<0.50	ug/L	0.50		1		05/11/23 19:54	179601-23-1	
o-Xylene	<0.50	ug/L	0.50		1		05/11/23 19:54	95-47-6	
Surrogates									
1,2-Dichlorobenzene-d4 (S)	83	%	70-130		1		05/11/23 19:54	2199-69-1	
4-Bromofluorobenzene (S)	93	%	70-130		1		05/11/23 19:54	460-00-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Sample: WELL 4 N-09338(INFLUENT) **Lab ID: 70255417004** Collected: 05/05/23 10:45 Received: 05/05/23 11:25 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
522 MSS 1,4 Dioxane (SIM)									
Analytical Method: EPA 522 Preparation Method: EPA 522									
Pace Analytical Services - Melville									
1,4-Dioxane (p-Dioxane)	1.7	ug/L	0.020		1	05/10/23 10:13	05/11/23 16:18	123-91-1	
Surrogates									
1,4-Dioxane-d8 (S)	106	%	70-130		1	05/10/23 10:13	05/11/23 16:18		
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Melville									
Benzene	<0.50	ug/L	0.50	5	1		05/11/23 20:21	71-43-2	
Bromobenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	108-86-1	
Bromochloromethane	<0.50	ug/L	0.50		1		05/11/23 20:21	74-97-5	
Bromodichloromethane	<0.50	ug/L	0.50	80	1		05/11/23 20:21	75-27-4	
Bromoform	<0.50	ug/L	0.50	80	1		05/11/23 20:21	75-25-2	
Bromomethane	<0.50	ug/L	0.50		1		05/11/23 20:21	74-83-9	
n-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	104-51-8	
sec-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	135-98-8	
tert-Butylbenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	98-06-6	
Carbon tetrachloride	<0.50	ug/L	0.50	5	1		05/11/23 20:21	56-23-5	
Chlorobenzene	<0.50	ug/L	0.50	100	1		05/11/23 20:21	108-90-7	
Chlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 20:21	75-45-6	N3
Chloroethane	<0.50	ug/L	0.50		1		05/11/23 20:21	75-00-3	
Chloroform	<0.50	ug/L	0.50	80	1		05/11/23 20:21	67-66-3	
Chloromethane	<0.50	ug/L	0.50		1		05/11/23 20:21	74-87-3	
2-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 20:21	95-49-8	
4-Chlorotoluene	<0.50	ug/L	0.50		1		05/11/23 20:21	106-43-4	
Dibromochloromethane	<0.50	ug/L	0.50	80	1		05/11/23 20:21	124-48-1	
Dibromomethane	<0.50	ug/L	0.50		1		05/11/23 20:21	74-95-3	
1,2-Dichlorobenzene	<0.50	ug/L	0.50	600	1		05/11/23 20:21	95-50-1	
1,3-Dichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	541-73-1	
1,4-Dichlorobenzene	<0.50	ug/L	0.50	75	1		05/11/23 20:21	106-46-7	
Dichlorodifluoromethane	<0.50	ug/L	0.50		1		05/11/23 20:21	75-71-8	
1,1-Dichloroethane	<0.50	ug/L	0.50		1		05/11/23 20:21	75-34-3	
1,2-Dichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 20:21	107-06-2	
1,1-Dichloroethene	<0.50	ug/L	0.50	7	1		05/11/23 20:21	75-35-4	
cis-1,2-Dichloroethene	<0.50	ug/L	0.50	70	1		05/11/23 20:21	156-59-2	
trans-1,2-Dichloroethene	<0.50	ug/L	0.50	100	1		05/11/23 20:21	156-60-5	
1,2-Dichloropropane	<0.50	ug/L	0.50	5	1		05/11/23 20:21	78-87-5	
1,3-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 20:21	142-28-9	
2,2-Dichloropropane	<0.50	ug/L	0.50		1		05/11/23 20:21	594-20-7	
1,1-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 20:21	563-58-6	
cis-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 20:21	10061-01-5	
trans-1,3-Dichloropropene	<0.50	ug/L	0.50		1		05/11/23 20:21	10061-02-6	
Ethylbenzene	<0.50	ug/L	0.50	700	1		05/11/23 20:21	100-41-4	
Hexachloro-1,3-butadiene	<0.50	ug/L	0.50		1		05/11/23 20:21	87-68-3	
Isopropylbenzene (Cumene)	<0.50	ug/L	0.50		1		05/11/23 20:21	98-82-8	
p-Isopropyltoluene	<0.50	ug/L	0.50		1		05/11/23 20:21	99-87-6	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

Sample: WELL 4 N-09338(INFLUENT) **Lab ID:** 70255417004 Collected: 05/05/23 10:45 Received: 05/05/23 11:25 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV									
Analytical Method: EPA 524.2									
Pace Analytical Services - Melville									
Methylene Chloride	<0.50	ug/L	0.50	5	1		05/11/23 20:21	75-09-2	
Methyl-tert-butyl ether	<0.50	ug/L	0.50		1		05/11/23 20:21	1634-04-4	
n-Propylbenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	103-65-1	
Styrene	<0.50	ug/L	0.50	100	1		05/11/23 20:21	100-42-5	
1,1,1,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 20:21	630-20-6	
1,1,2,2-Tetrachloroethane	<0.50	ug/L	0.50		1		05/11/23 20:21	79-34-5	
Tetrachloroethene	<0.50	ug/L	0.50	5	1		05/11/23 20:21	127-18-4	
Toluene	<0.50	ug/L	0.50	1000	1		05/11/23 20:21	108-88-3	
Total Trihalomethanes (Calc.)	<0.50	ug/L	0.50	80	1		05/11/23 20:21		
1,2,3-Trichlorobenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	87-61-6	
1,2,4-Trichlorobenzene	<0.50	ug/L	0.50	70	1		05/11/23 20:21	120-82-1	
1,1,1-Trichloroethane	<0.50	ug/L	0.50	200	1		05/11/23 20:21	71-55-6	
1,1,2-Trichloroethane	<0.50	ug/L	0.50	5	1		05/11/23 20:21	79-00-5	
Trichloroethene	1.1	ug/L	0.50	5	1		05/11/23 20:21	79-01-6	
Trichlorofluoromethane	<0.50	ug/L	0.50		1		05/11/23 20:21	75-69-4	
1,2,3-Trichloropropane	<0.50	ug/L	0.50		1		05/11/23 20:21	96-18-4	
1,1,2-Trichlorotrifluoroethane	0.51	ug/L	0.50		1		05/11/23 20:21	76-13-1	L1,N3
1,2,4-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	95-63-6	
1,3,5-Trimethylbenzene	<0.50	ug/L	0.50		1		05/11/23 20:21	108-67-8	
Vinyl chloride	<0.50	ug/L	0.50	2	1		05/11/23 20:21	75-01-4	
m&p-Xylene	<0.50	ug/L	0.50		1		05/11/23 20:21	179601-23-1	
o-Xylene	<0.50	ug/L	0.50		1		05/11/23 20:21	95-47-6	
Surrogates									
1,2-Dichlorobenzene-d4 (S)	98	%	70-130		1		05/11/23 20:21	2199-69-1	
4-Bromofluorobenzene (S)	104	%	70-130		1		05/11/23 20:21	460-00-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5
Pace Project No.: 70255417

QC Batch: 304707 Analysis Method: EPA 524.2
QC Batch Method: EPA 524.2 Analysis Description: 524.2 MSV
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70255417001, 70255417002, 70255417003, 70255417004

METHOD BLANK: 1543850 Matrix: Water
Associated Lab Samples: 70255417001, 70255417002, 70255417003, 70255417004

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
1,1,1,2-Tetrachloroethane	ug/L	<0.50	0.50	05/11/23 11:14	
1,1,1-Trichloroethane	ug/L	<0.50	0.50	05/11/23 11:14	
1,1,2,2-Tetrachloroethane	ug/L	<0.50	0.50	05/11/23 11:14	
1,1,2-Trichloroethane	ug/L	<0.50	0.50	05/11/23 11:14	
1,1,2-Trichlorotrifluoroethane	ug/L	<0.50	0.50	05/11/23 11:14	N3
1,1-Dichloroethane	ug/L	<0.50	0.50	05/11/23 11:14	
1,1-Dichloroethene	ug/L	<0.50	0.50	05/11/23 11:14	
1,1-Dichloropropene	ug/L	<0.50	0.50	05/11/23 11:14	
1,2,3-Trichlorobenzene	ug/L	<0.50	0.50	05/11/23 11:14	
1,2,3-Trichloropropane	ug/L	<0.50	0.50	05/11/23 11:14	
1,2,4-Trichlorobenzene	ug/L	<0.50	0.50	05/11/23 11:14	
1,2,4-Trimethylbenzene	ug/L	<0.50	0.50	05/11/23 11:14	
1,2-Dichlorobenzene	ug/L	<0.50	0.50	05/11/23 11:14	
1,2-Dichloroethane	ug/L	<0.50	0.50	05/11/23 11:14	
1,2-Dichloropropane	ug/L	<0.50	0.50	05/11/23 11:14	
1,3,5-Trimethylbenzene	ug/L	<0.50	0.50	05/11/23 11:14	
1,3-Dichlorobenzene	ug/L	<0.50	0.50	05/11/23 11:14	
1,3-Dichloropropane	ug/L	<0.50	0.50	05/11/23 11:14	
1,4-Dichlorobenzene	ug/L	<0.50	0.50	05/11/23 11:14	
2,2-Dichloropropane	ug/L	<0.50	0.50	05/11/23 11:14	
2-Chlorotoluene	ug/L	<0.50	0.50	05/11/23 11:14	
4-Chlorotoluene	ug/L	<0.50	0.50	05/11/23 11:14	
Benzene	ug/L	<0.50	0.50	05/11/23 11:14	
Bromobenzene	ug/L	<0.50	0.50	05/11/23 11:14	
Bromochloromethane	ug/L	<0.50	0.50	05/11/23 11:14	
Bromodichloromethane	ug/L	<0.50	0.50	05/11/23 11:14	
Bromoform	ug/L	<0.50	0.50	05/11/23 11:14	
Bromomethane	ug/L	<0.50	0.50	05/11/23 11:14	
Carbon tetrachloride	ug/L	<0.50	0.50	05/11/23 11:14	
Chlorobenzene	ug/L	<0.50	0.50	05/11/23 11:14	
Chlorodifluoromethane	ug/L	<0.50	0.50	05/11/23 11:14	N3
Chloroethane	ug/L	<0.50	0.50	05/11/23 11:14	
Chloroform	ug/L	<0.50	0.50	05/11/23 11:14	
Chloromethane	ug/L	<0.50	0.50	05/11/23 11:14	
cis-1,2-Dichloroethene	ug/L	<0.50	0.50	05/11/23 11:14	
cis-1,3-Dichloropropene	ug/L	<0.50	0.50	05/11/23 11:14	
Dibromochloromethane	ug/L	<0.50	0.50	05/11/23 11:14	
Dibromomethane	ug/L	<0.50	0.50	05/11/23 11:14	
Dichlorodifluoromethane	ug/L	<0.50	0.50	05/11/23 11:14	
Ethylbenzene	ug/L	<0.50	0.50	05/11/23 11:14	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

METHOD BLANK: 1543850

Matrix: Water

Associated Lab Samples: 70255417001, 70255417002, 70255417003, 70255417004

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Hexachloro-1,3-butadiene	ug/L	<0.50	0.50	05/11/23 11:14	
Isopropylbenzene (Cumene)	ug/L	<0.50	0.50	05/11/23 11:14	
m&p-Xylene	ug/L	<0.50	0.50	05/11/23 11:14	
Methyl-tert-butyl ether	ug/L	<0.50	0.50	05/11/23 11:14	
Methylene Chloride	ug/L	<0.50	0.50	05/11/23 11:14	
n-Butylbenzene	ug/L	<0.50	0.50	05/11/23 11:14	
n-Propylbenzene	ug/L	<0.50	0.50	05/11/23 11:14	
o-Xylene	ug/L	<0.50	0.50	05/11/23 11:14	
p-Isopropyltoluene	ug/L	<0.50	0.50	05/11/23 11:14	
sec-Butylbenzene	ug/L	<0.50	0.50	05/11/23 11:14	
Styrene	ug/L	<0.50	0.50	05/11/23 11:14	
tert-Butylbenzene	ug/L	<0.50	0.50	05/11/23 11:14	
Tetrachloroethene	ug/L	<0.50	0.50	05/11/23 11:14	
Toluene	ug/L	<0.50	0.50	05/11/23 11:14	
Total Trihalomethanes (Calc.)	ug/L	<0.50	0.50	05/11/23 11:14	
trans-1,2-Dichloroethene	ug/L	<0.50	0.50	05/11/23 11:14	
trans-1,3-Dichloropropene	ug/L	<0.50	0.50	05/11/23 11:14	
Trichloroethene	ug/L	<0.50	0.50	05/11/23 11:14	
Trichlorofluoromethane	ug/L	<0.50	0.50	05/11/23 11:14	
Vinyl chloride	ug/L	<0.50	0.50	05/11/23 11:14	
1,2-Dichlorobenzene-d4 (S)	%	94	70-130	05/11/23 11:14	
4-Bromofluorobenzene (S)	%	100	70-130	05/11/23 11:14	

LABORATORY CONTROL SAMPLE: 1543851

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
1,1,1,2-Tetrachloroethane	ug/L	10	9.9	99	70-130	
1,1,1-Trichloroethane	ug/L	10	10.2	102	70-130	
1,1,2,2-Tetrachloroethane	ug/L	10	10.9	109	70-130	
1,1,2-Trichloroethane	ug/L	10	10.4	104	70-130	
1,1,2-Trichlorotrifluoroethane	ug/L	10	13.1	131	70-130	L1,N3
1,1-Dichloroethane	ug/L	10	9.9	99	70-130	
1,1-Dichloroethene	ug/L	10	8.8	88	70-130	
1,1-Dichloropropene	ug/L	10	10.3	103	70-130	
1,2,3-Trichlorobenzene	ug/L	10	11.9	119	70-130	
1,2,3-Trichloropropane	ug/L	10	9.7	97	70-130	
1,2,4-Trichlorobenzene	ug/L	10	10.9	109	70-130	
1,2,4-Trimethylbenzene	ug/L	10	10.6	106	70-130	
1,2-Dichlorobenzene	ug/L	10	11.3	113	70-130	
1,2-Dichloroethane	ug/L	10	11.7	117	70-130	
1,2-Dichloropropane	ug/L	10	10.2	102	70-130	
1,3,5-Trimethylbenzene	ug/L	10	10.2	102	70-130	
1,3-Dichlorobenzene	ug/L	10	11.0	110	70-130	
1,3-Dichloropropane	ug/L	10	10.2	102	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

LABORATORY CONTROL SAMPLE: 1543851

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
1,4-Dichlorobenzene	ug/L	10	10.7	107	70-130	
2,2-Dichloropropane	ug/L	10	11.0	110	70-130	
2-Chlorotoluene	ug/L	10	10.4	104	70-130	
4-Chlorotoluene	ug/L	10	11.0	110	70-130	
Benzene	ug/L	10	9.9	99	70-130	
Bromobenzene	ug/L	10	10.6	106	70-130	
Bromochloromethane	ug/L	10	9.0	90	70-130	
Bromodichloromethane	ug/L	10	9.8	98	70-130	
Bromoform	ug/L	10	9.0	90	70-130	
Bromomethane	ug/L	10	11.7	117	70-130	
Carbon tetrachloride	ug/L	10	9.7	97	70-130	
Chlorobenzene	ug/L	10	9.6	96	70-130	
Chlorodifluoromethane	ug/L	10	10.0	100	70-130	N3
Chloroethane	ug/L	10	10.4	104	70-130	
Chloroform	ug/L	10	10.5	105	70-130	
Chloromethane	ug/L	10	11.2	112	70-130	
cis-1,2-Dichloroethene	ug/L	10	9.4	94	70-130	
cis-1,3-Dichloropropene	ug/L	10	10.2	102	70-130	
Dibromochloromethane	ug/L	10	9.2	92	70-130	
Dibromomethane	ug/L	10	9.8	98	70-130	
Dichlorodifluoromethane	ug/L	10	8.3	83	70-130	v1
Ethylbenzene	ug/L	10	10.1	101	70-130	
Hexachloro-1,3-butadiene	ug/L	10	10.8	108	70-130	v1
Isopropylbenzene (Cumene)	ug/L	10	9.9	99	70-130	
m&p-Xylene	ug/L	20	19.0	95	70-130	
Methyl-tert-butyl ether	ug/L	10	12.3	123	70-130	
Methylene Chloride	ug/L	10	9.5	95	70-130	
n-Butylbenzene	ug/L	10	11.4	114	70-130	v1
n-Propylbenzene	ug/L	10	10.5	105	70-130	
o-Xylene	ug/L	10	10.4	104	70-130	
p-Isopropyltoluene	ug/L	10	10.3	103	70-130	
sec-Butylbenzene	ug/L	10	10.2	102	70-130	
Styrene	ug/L	10	10.2	102	70-130	
tert-Butylbenzene	ug/L	10	10.1	101	70-130	
Tetrachloroethene	ug/L	10	10.3	103	70-130	
Toluene	ug/L	10	10.2	102	70-130	
Total Trihalomethanes (Calc.)	ug/L		38.4			
trans-1,2-Dichloroethene	ug/L	10	9.7	97	70-130	
trans-1,3-Dichloropropene	ug/L	10	10.1	101	70-130	
Trichloroethene	ug/L	10	9.9	99	70-130	
Trichlorofluoromethane	ug/L	10	11.3	113	70-130	
Vinyl chloride	ug/L	10	10.2	102	70-130	
1,2-Dichlorobenzene-d4 (S)	%			101	70-130	
4-Bromofluorobenzene (S)	%			113	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

SAMPLE DUPLICATE: 1544696

Parameter	Units	70255520001 Result	Dup Result	RPD	Max RPD	Qualifiers
1,1,1,2-Tetrachloroethane	ug/L	<0.50	<0.50		20	
1,1,1-Trichloroethane	ug/L	1.3	1.2	11	20	
1,1,2,2-Tetrachloroethane	ug/L	<0.50	<0.50		20	
1,1,2-Trichloroethane	ug/L	<0.50	<0.50		20	
1,1,2-Trichlorotrifluoroethane	ug/L	<0.50	<0.50		20	N3
1,1-Dichloroethane	ug/L	3.3	3.4	1	20	
1,1-Dichloroethene	ug/L	2.6	2.8	8	20	
1,1-Dichloropropene	ug/L	<0.50	<0.50		20	
1,2,3-Trichlorobenzene	ug/L	<0.50	<0.50		20	
1,2,3-Trichloropropane	ug/L	<0.50	<0.50		20	
1,2,4-Trichlorobenzene	ug/L	<0.50	<0.50		20	
1,2,4-Trimethylbenzene	ug/L	<0.50	<0.50		20	
1,2-Dichlorobenzene	ug/L	<0.50	<0.50		20	
1,2-Dichloroethane	ug/L	<0.50	<0.50		20	
1,2-Dichloropropane	ug/L	<0.50	<0.50		20	
1,3,5-Trimethylbenzene	ug/L	<0.50	<0.50		20	
1,3-Dichlorobenzene	ug/L	<0.50	<0.50		20	
1,3-Dichloropropane	ug/L	<0.50	<0.50		20	
1,4-Dichlorobenzene	ug/L	<0.50	<0.50		20	
2,2-Dichloropropane	ug/L	<0.50	<0.50		20	
2-Chlorotoluene	ug/L	<0.50	<0.50		20	
4-Chlorotoluene	ug/L	<0.50	<0.50		20	
Benzene	ug/L	<0.50	<0.50		20	
Bromobenzene	ug/L	<0.50	<0.50		20	
Bromochloromethane	ug/L	<0.50	<0.50		20	
Bromodichloromethane	ug/L	<0.50	<0.50		20	
Bromoform	ug/L	<0.50	<0.50		20	
Bromomethane	ug/L	<0.50	<0.50		20	
Carbon tetrachloride	ug/L	<0.50	<0.50		20	
Chlorobenzene	ug/L	<0.50	<0.50		20	
Chlorodifluoromethane	ug/L	<0.50	<0.50		20	N3
Chloroethane	ug/L	<0.50	<0.50		20	
Chloroform	ug/L	0.55	0.53	3	20	
Chloromethane	ug/L	<0.50	<0.50		20	
cis-1,2-Dichloroethene	ug/L	1.9	1.9	2	20	
cis-1,3-Dichloropropene	ug/L	<0.50	<0.50		20	
Dibromochloromethane	ug/L	<0.50	<0.50		20	
Dibromomethane	ug/L	<0.50	<0.50		20	
Dichlorodifluoromethane	ug/L	<0.50	<0.50		20	
Ethylbenzene	ug/L	<0.50	<0.50		20	
Hexachloro-1,3-butadiene	ug/L	<0.50	<0.50		20	
Isopropylbenzene (Cumene)	ug/L	<0.50	<0.50		20	
m&p-Xylene	ug/L	<0.50	<0.50		20	
Methyl-tert-butyl ether	ug/L	<0.50	<0.50		20	
Methylene Chloride	ug/L	<0.50	<0.50		20	
n-Butylbenzene	ug/L	<0.50	<0.50		20	
n-Propylbenzene	ug/L	<0.50	<0.50		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

SAMPLE DUPLICATE: 1544696

Parameter	Units	70255520001 Result	Dup Result	RPD	Max RPD	Qualifiers
o-Xylene	ug/L	<0.50	<0.50		20	
p-Isopropyltoluene	ug/L	<0.50	<0.50		20	
sec-Butylbenzene	ug/L	<0.50	<0.50		20	
Styrene	ug/L	<0.50	<0.50		20	
tert-Butylbenzene	ug/L	<0.50	<0.50		20	
Tetrachloroethene	ug/L	5.4	6.0	10	20	
Toluene	ug/L	<0.50	<0.50		20	
Total Trihalomethanes (Calc.)	ug/L	0.55	0.53	3	20	
trans-1,2-Dichloroethene	ug/L	<0.50	<0.50		20	
trans-1,3-Dichloropropene	ug/L	<0.50	<0.50		20	
Trichloroethene	ug/L	28.6	28.7	0	20	
Trichlorofluoromethane	ug/L	<0.50	<0.50		20	
Vinyl chloride	ug/L	<0.50	<0.50		20	
1,2-Dichlorobenzene-d4 (S)	%	96	94		20	
4-Bromofluorobenzene (S)	%	99	92		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5
Pace Project No.: 70255417

QC Batch: 304409 Analysis Method: EPA 522
QC Batch Method: EPA 522 Analysis Description: 522 MSS 1,4 Dioxane
Laboratory: Pace Analytical Services - Melville
Associated Lab Samples: 70255417001, 70255417003, 70255417004

METHOD BLANK: 1542356 Matrix: Drinking Water
Associated Lab Samples: 70255417001, 70255417003, 70255417004

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
1,4-Dioxane (p-Dioxane)	ug/L	<0.020	0.020	05/11/23 10:59	
1,4-Dioxane-d8 (S)	%	107	70-130	05/11/23 10:59	

LABORATORY CONTROL SAMPLE: 1542357

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
1,4-Dioxane (p-Dioxane)	ug/L	2	1.9	96	70-130	
1,4-Dioxane-d8 (S)	%			108	70-130	

MATRIX SPIKE SAMPLE: 1542358

Parameter	Units	70255304001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
1,4-Dioxane (p-Dioxane)	ug/L	5.9	2	7.9	102	70-130	
1,4-Dioxane-d8 (S)	%				112	70-130	

SAMPLE DUPLICATE: 1542359

Parameter	Units	70255304002 Result	Dup Result	RPD	Max RPD	Qualifiers
1,4-Dioxane (p-Dioxane)	ug/L	2.1	2.2	4	30	
1,4-Dioxane-d8 (S)	%	110	111		30	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5

Pace Project No.: 70255417

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

L1 Analyte recovery in the laboratory control sample (LCS) was above QC limits. Results for this analyte in associated samples may be biased high.

N3 Accreditation is not offered by the relevant laboratory accrediting body for this parameter.

v1 The continuing calibration verification was above the method acceptance limit. Any detection for the analyte in the associated samples may have a high bias.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: NYAW-MERRICK OPS-POC/1,4DIO5/5
Pace Project No.: 70255417

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70255417001	GAC-3S/4S(SEAMAN NECK GAC EFF.	EPA 522	304409	EPA 522	304621
70255417003	WELL 3A N-14347(INFLUENT)	EPA 522	304409	EPA 522	304621
70255417004	WELL 4 N-09338(INFLUENT)	EPA 522	304409	EPA 522	304621
70255417001	GAC-3S/4S(SEAMAN NECK GAC EFF.	EPA 524.2	304707		
70255417002	GAC-3S/4S(SEAMAN NECK G. EFF-D	EPA 524.2	304707		
70255417003	WELL 3A N-14347(INFLUENT)	EPA 524.2	304707		
70255417004	WELL 4 N-09338(INFLUENT)	EPA 524.2	304707		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Client Name:

KGS

WO#: 70255417

PM: KMM

Due Date: 05/16/23

CLIENT: KGS

Courier: Fed-Ex UPS USPS Client Commercial Race Other

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No N/A

Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other

Type of Ice: Wet Blue None

Thermometer Used: THD: TH148 Correction Factor: -0.3

Samples on ice, cooling process has begun

Cooler Temperature(°C): 7.5 Cooler Temperature Corrected(°C): 12

Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Date and Initials of person examining contents: SH 5/5/23

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC,

Did samples originate from a foreign source

NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for I) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
Includes date/time/ID, Matrix, SW, Oil	
All containers needing preservation have been checked? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot #	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH >9 Sulfide, NAOH >12 Cyanide) <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #	
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sulfide? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	
Pace Trip Blank Lot # (if applicable):	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: