




COUNTY OF NASSAU
DEPARTMENT OF PUBLIC WORKS
MINEOLA, NEW YORK 11501-4822

October 15, 2004

New York State Department of
Environmental Conservation
Division of Environmental Remediation
Bureau of Hazardous Site Control
625 Broadway
Albany, New York 12233

Attn: Cynthia Whitfield, P.E.
Environmental Engineer II



Re: Monthly Effluent Monitoring Report / June through July 2004
Nassau County Fireman's Training Center, Site #1-30-042

Gentlemen:

Attached are the June and July 2004 Monthly Effluent Monitoring Reports for the groundwater remediation at the Fireman's Training Center site in Old Bethpage, New York. No effluent discharge criterion was exceeded during this time period.

If you have any questions concerning the monthly monitoring report, please contact me at (516) 571-6970.

Very truly yours,

Peter J. Witkowski
Director of Hazardous Waste Services

PJW:JNW:cs
Attachments

c: William Spitz, Region 1, NYSDEC

**NASSAU COUNTY FIREMAN'S TRAINING CENTER
GROUNDWATER REMEDIATION FACILITY
MONTHLY EFFLUENT MONITORING REPORT
OUTFALL 001**

JUNE 2004

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1 06/01/04	WEEK 2 06/08/04	WEEK 3 06/15/04	WEEK 4 06/21/04	WEEK 5 06/29/04
FLOW, DAILY AVG	MONITOR	GPD	NA	780171	778586	774600	773283	768871
FLOW, DAILY MAX	MONITOR	GPD	NA	779500	780800	779200	777900	770900
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
TETRACHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
METHYL ETHYL KEYTONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL	BDL
ACETONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL	BDL
CHLOROFORM	7	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
NAPHTHALENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL	BDL
TOTAL VOCs		µ g/l	0.0	0.0	0.0	0.0	0.0	0.0
PHENANTHRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
FLUORENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
PYRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
BIS(2-ETHLHEXYL)PHTHALATE	4.3	µ g/l	1.0	BDL	BDL	BDL	BDL	1.6
DI-N-OCTYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
DIMETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
DIETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
IRON, TOTAL	600	µ g/l	2.0	24.0	32.0	28.0	40.0	36.0
MANGANESE, TOTAL	600	µ g/l	1.0	411.0	420.0	412.0	411.0	413.0
SUM IRON & MANGANESE	1000	µ g/l	NA	435.0	452.0	440.0	451.0	449.0
NICKEL, TOTAL	2000	µ g/l	5.0	6.0	6.0	5.0	5.0	5.0
ARSENIC, TOTAL	50	µ g/l	48.0	BDL	BDL	BDL	BDL	BDL
ALUMINUM, TOTAL	2000	µ g/l	40.0	BDL	BDL	BDL	BDL	BDL
CHROMIUM, TOTAL	50	µ g/l	2.0	BDL	BDL	BDL	BDL	BDL

**NASSAU COUNTY FIREMAN'S TRAINING CENTER
GROUNDWATER REMEDIATION FACILITY
MONTHLY EFFLUENT MONITORING REPORT
OUTFALL 001**

JULY 2004

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1 07/06/04	WEEK 2 07/13/04	WEEK 3 07/20/04	WEEK 4 07/27/04	WEEK 5
FLOW, DAILY AVG	MONITOR	GPD	NA	761733	762443	762814	760971	
FLOW, DAILY MAX	MONITOR	GPD	NA	793800	767100	76640	769200	
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	
1,2(TRANS)-DICHLOROETHENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	
1,2(CIS)-DICHLOROETHENE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL	
TRICHLOROETHENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL	
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	
TETRACHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	1.5	
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	
1,1-DICHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	
METHYL ETHYL KEYTONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL	
ACETONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL	
CHLOROFORM	7	µ g/l	1.1	BDL	BDL	BDL	BDL	
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	
NAPHTHALENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL	
TOTAL VOCs		µ g/l	0.0	0.0	0.0	0.0	1.5	0.0
PHENANTHRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	
FLUORENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	
PYRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	
BIS(2-ETHLHEXYL)PHTHALATE	4.3	µ g/l	1.0	BDL	BDL	BDL	BDL	
DI-N-OCTYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	
DIMETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	
DIETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	
IRON, TOTAL	600	µ g/l	2.0	35.0	33.0	74.0	37.0	
MANGANESE, TOTAL	600	µ g/l	1.0	425.0	428.0	415.0	436.0	
SUM IRON & MANGANESE	1000	µ g/l	NA	460.0	461.0	489.0	473.0	0.0
NICKEL, TOTAL	2000	µ g/l	5.0	4.0	4.0	4.0	4.0	
ARSENIC, TOTAL	50	µ g/l	48.0	BDL	BDL	BDL	BDL	
ALUMINUM, TOTAL	2000	µ g/l	40.0	BDL	BDL	BDL	BDL	
CHROMIUM, TOTAL	50	µ g/l	2.0	BDL	BDL	1.0	BDL	