


August 2, 2005

Heidi-Marie Dudek, P.E. NYSDEC Division of Environmental Remediation Remedial Bureau A 625 Broadway, 11th Floor Albany, New York 12233-7015



Re: Quarterly Interim Remedial Measure Operation

& Maintenance and Indoor Air Quality

Monitoring Report

March 24 through June 16, 2005

Jimmy's Dry Cleaner Site, Roosevelt, New York

NYSDEC Site No. 1-30-080

File:

10653/36951 #5

Dear Ms. Dudek:

O'Brien & Gere has developed this letter report to serve as a Quarterly Operation, Monitoring & Maintenance (O&M) and Indoor Air Quality (IAQ) Report for the Soil Vapor Extraction (SVE) System in operation at the former Jimmy's Dry Cleaner (JDC) located at 61 Nassau Road in Roosevelt, New York. The SVE system was installed as an Interim Remedial Measure (IRM) to abate volatile organic compounds (VOCs) observed at businesses and residences located in the vicinity of the Site.

Background

The IRM consists of seven (7) extraction wells, underground piping, a blower, and granular activated carbon (GAC) vessels to treat the effluent air from the system. Refer to Figure 1. After the start-up of the SVE system on August 7, 2002, Shaw Environmental & Infrastructure Engineering of New York, P.C. (Shaw) implemented an IAQ Monitoring program for select sampling locations. In June 2005, O'Brien & Gere replaced Shaw and assumed the implementation of the IAQ monitoring program. Throughout Shaw's subsequent monitoring events, an overall decrease in concentrations of tetrachloroethene (PCE) in ambient air at the Deli, KFC, 40 and 44 Dutchess Street sample locations has been observed. This report covers the period of March 24 through June 16, 2005.

Remedial System Operation and Maintenance

To evaluate and adjust the SVE system operating performance, three (3) site visits were completed during the reporting period. During the site visits, VOC concentrations, air flow rates and vacuum readings were observed at extraction wells SVE-1, SVE-2, SVE-3, SVE-4, SVE-5, SVE-6, SVE-7 and at the SVE blower. Air flow rates and VOC concentrations were also observed at the carbon influent, mid carbon and carbon effluent monitoring points. The monitoring data log sheets are presented in **Attachment 1** and a summary of the monitoring data collected during the monitoring events is presented in **Attachment 2**.



The vacuum, airflow, and VOC concentration data are summarized below in **Table 1**. During the current monitoring period, the air flow control valve at SVE-1 was adjusted from 25% to 10% to 25% for April, May, and June, respectively. The airflow control valve at SVE-5 was adjusted from 80% to 100% to 80% for April, May, and June, respectively.

Table 1 SVE System Monitoring Data Values Observed During Site Visits										
	Average Vacuum	Average Air Flow	VOC Con							
Location ID	("H2O)	(cfm)	Average	Maximum						
SVE-1	6.0	35.1	89.1	93.3						
SVE-2	5.5	10.1	0	0						
SVE-3	5.6	24.8	10.9	14						
SVE-4	5.6	50.2	0.07	0.2						
SVE-5	4.7	48	0	0						
SVE-6	4.2	30.3	0	0						
SVE-7	4.03	13.1	0	0						
Total Influent	NA	66.7	8.8	10.2						
Carbon Influent	NA	99.3	4.3	5.2						
Mid Carbon	NA	84.4	0	0						
Carbon Effluent	NA	134	0	0						
Blower	24	NA	NA	NA						

Notes: "H2O = inches of water column
cfm = cubic feet per minute
ppm = parts per million
NA = not applicable

The VOC concentrations for March 24 through June 16, 2005 are lower than the VOC concentrations for the previous quarter, December 22, 2004 through March 23, 2005.

A total of thirteen (13) carbon vessel change outs have occurred since system startup. During each carbon change out, the lag vessel was moved to the lead position and a new carbon vessel was placed in the lag position. Four (4) new carbon vessels were delivered to the site on March 22, 2005 and were staged on a pallet located next to the SVE system. Five (5) spent carbon vessels were removed from the site on March 23, 2005 by a waste transportation firm for reactivation at a permitted off-site facility in accordance with Federal, State and local regulations. The rate of carbon usage will be monitored during each site visit to determine the maximum VOC extraction rate that can be accomplished to minimize VOC migration while maximizing the life of the carbon vessels.

Indoor Air Quality Monitoring Results

O'Brien & Gere and Shaw conducted an indoor air quality monitoring event on June 15, 2005 for the Deli, KFC, 40, and 44 Dutchess Street. Passive diffusion dosimeters were used to collect air samples over a 24-hour period. Additional air samples were collected, including a background sample near the Deli and a duplicate sample from KFC for comparative purposes. The samples were analyzed for

the presence of PCE according to New York State Department of Health (NYSDOH) Method 311-9. The laboratory report of analyses is presented as Attachment 3 and the analytical results are summarized in Attachment 4. The analytical results indicated that concentrations of PCE were well below the NYSDOH Ambient Air Guidance Value of $100~\mu g/m^3$ in each of the samples that were collected. The highest PCE concentration observed during this monitoring event was $29~\mu g/m^3$ from the sample collected in the Deli front room. The SVE system will continue to be adjusted during each site visit to minimize the migration of PCE into the Deli. Quarterly monitoring will continue at KFC, the Deli and the residences to verify that PCE is not migrating into these areas at levels above the ambient air guideline.

Following the completion of the next quarter of monitoring events, a letter report summarizing the monitoring events will be prepared by O'Brien & Gere and submitted to the NYSDEC. If you have any questions or comments regarding this information, please contact me at (315) 437-6100, extension 2258.

Very truly yours,

O'BRIEN & GERE ENGINEERS, INC.

Marc J. Dent, P.E. Managing Engineer

Mare Sent

I:\DIV71\Projects\10653\36951\5_rpts\JDC_QtrlyRpt_Apr-Jun05.doc

cc: Joseph Yavonditte, P.E. - NYSDEC

Justin Deming, NYSDOH Joseph DeFranco, NCDOH

FIGURE 1

NYSDEC
JIMMY'S DRY CLEANER
ROOSEVELT, NEW YORK

IRM - SVE PLAN

AUGUST 2005



ATTACHMENT 1

Monitoring Data Log Sheets

SITE VISIT FORM

Shaw Environmental Inc., 13 British American Blvd, Latham, NY 12110

Project:

824324

Technician: R Hyde

Proj. Mgr. Helde Marle Dudek

Jimmy's Dry Cleaner, NYSDEC Site Mgr:

John Skaarup

PREPARTORY COMMENTS

Visit Date: 4/28/05 Weather:

Arrival Time:

1000

Departure Time: Temperature:

NO

NO

NO

YES

YES

YES

1130

100%

Are you in possession of a Health and Safety Plan? Is there a HASP on site permanently?

Map to Hospital in HASP current?

Have you signed the A&A sheet after reviewing the HASP? Air Monitoring Equipment Unit # (Photolonization Detector):

Date Calibrated:

YOU ARE THE MOST VISIBLE MEMBER OF SHAW ENVIRONMENTAL - PLEASE WORK AND

DRIVE SAFELY!!!

System Check - Task/Cost Code No. 05000000

(Monthly)

Is SVE running upon arrival? Is SVE running upon departure?

YES X NO YES X NÖ

If system is down use up to 1 hour and effect repairs to restart the system. List problems with system on attached sheet.

If additional time is required please contact project manager or site manager.

Hours Estimated:

Hours Used:

Soil Vapor Extraction System - Task/Cost Code No. 05000000 Perform routine maintenance tasks (filters, oil, etc.)

(Monthly)

0 Valve%Open-

Inspect SVE Intake filter. Clean if necessary. Replace if necessary.

Document actions in Notes section.

Bleed Valve % Open:

50%

Total vacuum @ Blower (inches of water (wc)): 23"

		3 "	of water (wc)): 23	aum @ Blower (Inches	i otai vaci			
	8.5	68 PID (ppm)-	e): Flow (cfm)-	Total Influent (Before Bleed Valve): Flow (cfm)-				
	4.7	98 PID (ppm)-	Flow (cfm)-	uent (Carbon Influent):	Total Influ			
	0	76 PID (ppm)-	Flow (cfm)-	Carbon Units:	Between			
	0	128 PID (ppm)-	Flow (cfm)-		Final Efflu			
Previous % 25%	93.3 Valve%Open-	48 PID (ppm)-	6 Flow (cfm)-	Vac (wc)-	SVE-1			
100%	0 Valve%Open-	11 PID (ppm)-	6 Flow (cfm)-	Vac (wc)-	SVE-2			
100%	12.8 Valve%Open-	25 PID (ppm)-	6 Flow (cfm)-	Vac (wc)-	SVE-3			
100%	0 Valve%Open-	50 PID (ppm)-	6 Flow (cfm)-	Vac (wc)-	SVE-4			
80%	0 Valve%Open-	45 PfD (ppm)-	4.6 Flow (cfm)-	Vac (wc)-	SVE-5			
100%	0 Valve%Open-	31.5 PID (ppm)-	3.8 Flow (cfm)-	Vac (wc)-	SVE-6			

10.8 PtD (ppm)-

Hours Estimated:

Vac (wc)-

Vac (wc)- X

SVE-7

VMP-1

Flow (cfm)- X Hours Used:

3.5 Flow (cfm)-

Move the lag to lead and place a new carbon in the lag position. Stage drums in proper locations.											
Number of "Spent Carbon" Units p	resent on Site:	FOUR									
Number of new vessels present:	NONE										
Take another round of parameters	from the influent, mi	d, and effluent ports.									
Total Influent (Before Bleed Valve): Flow (fpm)-	PID (ppm)-									
Total Influent (Carbon Influent):	Flow (fpm)-	PIO (ppm)-									
Between Carbon Units:	Flow (fpm)-	PID (ppm)-									
Final Effluent:	Flow (fpm)-	PID (ppm)-									
FINAL CHECKS Please ensure that all manhole or Complete an entry into the onsite Report any significant problems or	log, if present. r deficiencies to the P										
TECHNICIANS COMMENTS											
	 										
	·										
- 											

Total Hours Estimated - Travel Time Estimated - Total Hours Used -Travel Time Used -

Shaw Environmental Inc., 13 Britis	n Amencan Blvd, Latham	I, NY 12110				
Project: 824324 Site: Jimmy's Dry Cleaner, Proj. Mgr: Heide Marle Dudek	Technician: K.H., NYSDEC Site Mgr: John Ska	arup				
PREPARTORY COMMENTS	•					
Visit Date: 5/3/05 Weather: Are you in possession of a Health Is there a HASP on site permaner Map to Hospital in HASP current? Have you signed the A&A sheet a Air Monitoring Equipment Unit # (FDate Calibrated: 5/3/05) YOU ARE THE MOST VISIBLE MORIVE SAFELY!!!	ntly? fter reviewing the HASP? Photoionization Detector)	(ES)	ature: NO NO NO NO NO	5		
System Check - Task/Cost Code	No. 05000000	(Monthly)				
Is SVE running upon arrival? Is SVE running upon departure?	YES	NO NO				
If system is down use up to 1 hour system on attached sheet.	r and effect repairs to rest	art the system. List p	problems with			
if additional time is required pleas	e contact project manage	r or site manager.				
Hours Estimated:	Hours Used:				:	
Soll Vapor Extraction System - Perform routine maintenance task		00000	(Monthly)			•
Inspect SVE intake filter. Clean if Document actions in Notes section		cessary.				
Bleed Valve % Open: 75	E.					
Total vacuum @ Blower (inches o	f water (wc)): 22					
Total Influent (Before Bleed Valve): Flow (cfm)- 60.5	PID (ppm)- 7	7			
Total Influent (Carbon Influent):	Flow (cfm)- 98	PID (ppm)- 3,/	ĺ			
Between Carbon Units:	Flow (cfm)- 89	PID (ppm)-				
Final Effluent:	Flow (cfm)- 143	PID (ppm)-			Deniara W	
SVE-1 Vac (wc)-	Flow (cfm)- 7,25	PID (ppm)- 84	Valve%Open-	10	Previous % 10%	
	Flow (cfm)- 8,8	•		100	100%	
SVE-3 Vac (wc)- 4,8	Flow (cfm)- 19,5	PID (ppm)- 14	Valve%Open-	100	100%	
SVE-4 Vac (wc)- 4-8	Flow (cfm)- 456	PID (ppm)- O	Valve%Open-	100	100%	
SVE-5 Vac (wc)-	Flow (cfm)-	- PID (ppm)	- Valve%Open-		100%	- under wood Chipper
SVE-6 Vac (wc)- 4,3	Flow (cfm)- 23	PID (ppm)-	Valve%Open-	100	100%	chipper
SVE-7 Vac (wc)- 41	Flow (cfm)- 15	PID (ppm)-	Valve%Open-	100	100%	

SITE VISIT FORM

Shaw Environmental Inc., 13 British American Blvd, Latham, NY 12110

rub contractors - disposal etc

VMP-1 Vac (wc)-	Flow (cfm)-	
Hours Estimated:	Hours Used:	
Carbon Unit Change Out Task Move the lag to lead and place a		000 osition. Stage drums in proper locations.
Number of "Spent Carbon" Units	present on Site:	ZERO
lumber of new vessels present:	FOUR	
ake another round of parameter	s from the influent, mid,	, and effluent ports.
otal influent (Before Bleed Valve	e): Flow (fpm)-	PID (ppm)-
Fotal Influent (Carbon Influent):	Flow (fpm)-	PID (ppm)-
Between Carbon Units:	Flow (fpm)-	PID (ppm)-
Final Effluent:	Flow (fpm)-	PID (ppm)-
Mosture ca 55-gol da Laure on sa	er atorneed	s to be drained - neel none when water to 3 full by mosture separator was
Held 15+ of 2	to Mark	nectings of OBG
	Chrit	
	Qu.	(YEB)
		

Total Hours Used -Travel Time Used -

Total Hours Estimated - Travel Time Estimated - SITE VISIT FORM

Shaw Environmental Inc., 13 British American Blvd, Latham, NY 12110

Project:

824324

Technician: R Hyde

Proj. Mgr. Helde Marte Dudek

Jimmy's Dry Cleaner, NYSDEC Site Mgr.

John Skaarup

PREPARTORY COMMENTS

Visit Date: 6/15/05 Weather:

Arrival Time:

1000

Departure Time: **Temperature**

NO

NO

NO

NO

YES

il Ex

YES

YES

1630

Are you in possession of a Health and Safety Plan? Is there a HASP on site permanently?

Map to Hospital in HASP current?

Have you signed the A&A sheet after reviewing the HASP? Air Monitoring Equipment Unit # (Photoionization Detector):

Date Calibrated:

YOU ARE THE MOST VISIBLE MEMBER OF SHAW ENVIRONMENTAL - PLEASE WORK AND

DRIVE SAFELY!!!

System Check - Task/Cost Code No. 05000000

(Monthly)

Is SVE running upon arrival? Is SVE running upon departure?

NO YES X

If system is down use up to 1 hour and effect repairs to restart the system. List problems with system on attached sheet.

If additional time is required please contact project manager or site manager.

Hours Estimated:

Hours Used:

Soil Vapor Extraction System - Task/Cost Code No. 05000000 Perform routine maintenance tasks (filters, oil, etc.)

(Monthly)

Inspect SVE intake filter. Clean if necessary. Replace if necessary. Document actions in Notes section.

Bleed Valve % Open:

25%

Total vacuum @ Blower (in	nches of water (wc)):	28"		
Total Influent (Before Blee	d Valve): Flow (cfm)-	71.5 PID (ppm)-	10.2	
Total Influent (Carbon Influ	ent): Flow (cfm)-	102 PID (ppm)-	5.2	
Between Carbon Units:	Flow (cfm)-	88.2 PID (ppm)-	0	
Final Effluent:	Flow (cfm)-	131 PID (ppm)-	0	
SVE-1 Vac (wc)-	6 Flow (cfm)-	50 PID (ppm)-	89.4 Valve%Open-	Previous % 25%
SVE-2 Vac (wc)-	6 Flow (cfm)-	10.5 PID (ppm)-	0 Valve%Open-	100%
SVE-3 Vac (wc)-	6 Flow (cfm)-	30 PID (ppm)-	5.9 Valve%Open-	100%
SVE-4 Vac (wc)-	6 Flow (cfm)-	55 PID (ppm)-	0 Valve%Open-	100%
SVE-5 Vac (wc)-	4.8 Flow (cfm)-	51 PID (ppm)-	0 Valve%Open-	80%
SVE-6 Vac (wc)-	4.5 Flow (cfm)-	36.3 PID (ppm)-	0 Valve%Open-	100%
SVE-7 Vac (wc)-	4.5 Flow (cfm)-	13.6 PID (ppm)-	0 Valve%Open-	100%
VMP-1 Vac (wc)- X	Flow (cfm)-	x		

Hours Estimated:

Hours Used:

Carbon Unit Change Out Task/Cost Code No. 08000000 Move the lag to lead and place a new carbon in the lag position. Stage drums in proper locations.											
Number of "Spent Carbon" Units p	present on Site:	FOUR									
Number of new vessels present:	NONE										
Take another round of parameters	from the influent, mid, a	and effluent ports.									
Total Influent (Before Bleed Valve): Flow (fpm)-	PID (ppm)-									
Total Influent (Carbon Influent):	Flow (fpm)-	PID (ppm)-									
Between Carbon Units:	Flow (fpm)-	PID (ppm)-									
Final Effluent:	Flow (fpm)-	PID (ppm)-									
FINAL CHECKS Please ensure that all manhole or Complete an entry into the onsite Report any significant problems or TECHNICIANS COMMENTS Also deployed air monitors for 24t Returned on the 16th and collecte	log, if present. r deficiencies to the Proj	ect Manager without delay!!!									
		· · · · · · · · · · · · · · · · · · ·									
-											
	_										

Total Hours Estimated -Travel Time Estimated - Total Hours Used -Travel Time Used -

ATTACHMENT 2

IRM Parameters

		4/28/05				5/31/05			6/15/05			
Sample Location	Vac (inches of water)	Flow (cfm)	PID (ppm)	Valve % Open	Vac (inches of water)	Flow (cfm)	PID (ppm)	Valve % Open	Vac (inches of water)	Flow (cfm)	PID (ppm)	Valve % Open
SVE - 1	6.0	48	93.3	25%	>5	7.25	84.6	10%	6.0	50	89.4	25%
SVE - 2	6.0	11	0	100%	4.5	8.8	0	100%	6.0	10.5	0	100%
SVE - 3	6.0	25	12.8	100%	4.8	19.5	14	100%	6.0	30	5.9	100%
SVE - 4	6.0	50	0	100%	4.8	45.6	0.2	100%	6.0	55	0	100%
SVE - 5	4.6	45	0	80%	NS	NS	NS	100%	4.8	51	0	80%
SVE - 6	3.8	31.5	0	100%	4.3	23	0	100%	4.5	36.3	0	100%
SVE - 7	3.5	10.8	0	100%	4.1	15	0	100%	4.5	13.6	0	100%
VMP - 1	NS	NS	NS	NA	NS	NS	NS	NA	NS	NS	NS	NA
Before blower	NA	68	8.5	NA	NA_	60.5	7.7	NA	NA	71.5	10.2	NA
Influent	NA	98	4.7	NA	NA NA	98	3.1	NA	NA	102	5.2	NA
Mid	NA	76	0	NA	NA	89	0	NA	NA	88.2	0	NA
Effluent	NA	128	0	NA	NA NA	143	0	NA	NA	131	0	NA

Notes:

NS = Not sampled, well head not accessible.
NA = Not applicable.

Influent = Before carbon.

Mid = Between carbon.

Over = Greater than meter capacity.



		August 7, 200	2			August 12	, 2002		August 21, 2002			
	Vac (inches of	,	PID	Valve %	Vac (inches of	_		Valve %	Vac (inches of	ı	PID	Valve %
Sample Location	water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	(ppm)	Open
SVE - 1	7.0	30.0	326.0	100%	3.5	18.8	449.0	25%	7.0	31.7	925.0	25%
SVE - 2	6.0	10.0	64.4	100%	4.0	9.5	32.4	100%	7.0	17.9	68.9	100%
SVE - 3	5.5	25.0	695.0	100%	4.0	17.7	221.0	50%	7.0	23.0	521.0	50%
SVE - 4	6.0	39.0	36.4	100%	5.0	34.5	28.0	100%	8.0	25.2	37.1	100%
SVE - 5	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS_	NS	100%
SVE - 6	5.0	17.0	0.0	100%	4.0	20.5	0.0	100%	6.0	11.4	0.0	100%
SVE - 7	5.0	10.5	0.0	100%	4.0	22.0	0.0	100%	6.0	9.3	0.0	100%
VMP - 1	0.0	NA	283.0	NA	0.0	NA	50.6	NA	0.0	NA_	NS	NA
Before blower	NA NA	98.0	157.0	NA	NA	80.0	132.0	50%	NA	73.5	178.0	50%
Influent	NA NA	113.0	162.0	_NA	NA_	105.0	96.5	NA	NA_	115.0	145.0	NA
Mid	NA	97.5	0.0	NA	NA NA	99.0	0.0	NA	NA	102.0	163.0	NA_
Effluent	NA	110.0	0.0	NA	_ NA	110.0	0.0	NA	NA NA	108.0	0.0	NA

Open bleed air valve 10%

	Open bleed an valve 10%.											
Before blower	NA	95.0	156.0	NA								
Influent	NA NA	113.0	143.0	NA								
Mid	NA NA	95.0	0.0	NA								
Effluent	NA NA	104.0	0.0	NA								

Notes:

Mid = Between carbon.

NA = not applicable. NS = not sampled due to access issues. Influent = Before carbon.

		August 27, 2	002			September	5, 2002	***************************************	September 5, 2002			
	Vac (inches of	_	PID	Valve %	Vac (inches of			Valve %	Vac (inches of	•	PID	Valve %
Sample Location	water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	(ppm)	Open
SVE - 1	4.0	18.0	1098.0	25%	4.0	19.8	>2000	15%	NS	NS	NS	10%
SVE - 2	4.0	12.5	93.2	100%	5.0	10.5	576.0	100%	NS	NS	NS	100%
SVE - 3	4.0	16.5	425.0	50%	3.0	11.5	>2000	50%	NS	NS	NS	50%
SVE - 4	4.0	20.6	33.2	100%	5.0	26.5	385.0	100%	NS	NS	NS	100%
SVE - 5	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 6	4.0	23.4	0.0	100%	3.0	10.1	0.0	100%	NS	NS	NS	100%
SVE - 7	3.0	6.5	0.0	100%	3.0	7.5	0.0	100%	NS	NS	NS	100%
VMP - 1	0.0	NA	116.0	NA	0.0	NA	1220.0	NA	Oper	n bleed air valve	e to 75%.	
Before blower	NA	57.0	193.0	65%	NA	43.5	>2000	65%	NA	35.2	>2000	75%
Influent	NA	103.0	90.3	NΑ	NA	103.0	1150.0	NA	NA	104.0	615.0	NA
Mid	NA	83.0	69.6	NA	NA	76.0	915.0	NA	NA	78.0	850.0	NΑ
Effluent	NA	128.0	0.0	NA	NA N	99.5	0.0	NA	NA	101.0	0.0	NA

Carbon change out performed.

Notes:

Effluent = After carbon.

NA = not applicable.
NS = not sampled due to access issues.
Influent = Before carbon.

Mid = Between carbon.

		September 12	, 2002		Sept.	12, 2002 (Afte	r adjustments	s)		September 18	3, 2002	· · · · · · · · · · · · · · · · · · ·
	Vac (inches of	f	PID	Valve %	Vac (inches of			Valve %	Vac (inches of			Valve %
Sample Location	water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	1.0	9.7	>2000	10%	NA	NA	NA	0%	NA NA	NA	NA	0%
SVE - 2	3.0	20.4	682.0	100%_	2.0-3.0	12.3	668.0	50%	3.5	8.0	68.1	100%
SVE - 3	2.0-3.0	8.6	>2000	50%	2.0	6.8	>2000	30%	3.2	3.0	368.0	30%
SVE - 4	2.0-3.0	21.9	410.0	100%	3.0	17.2	276.0	50%	3.7	10.2	54.5	50%
SVE - 5	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 6	2.0-3.0	14.7	0.0	100%	NS_	NS	NS	100%	3.0	16.5	0.0	100%
SVE - 7	2.0-3.0	21.5	0.0	100%	NS	NS	NS	100%	3.0	8.5	0.0	100%
VMP - 1	0.0	NA	>2000	NA	NS	NA _	NS	NA	0.0	NA _	0.0	NA
Before blower	NA	32.8	>2000	75%	NA_	30.3	626.0	75%	NA NA	34.0	69.2	75%
Influent	NA	98.5	711.0	NA	NA NA	98.0	153.0	NA	NA NA	106.0	16.5	NA
Mid _	NA	84.5	763.0	NA	NA	78	494.0	NA	NA NA	94.5	48.6	NA
Effluent	NA	130.0	0.0	NA	NA	115.0	0.0	NA	NA	94.0	46.3	NA

Notes:

NA = not applicable.
NS = not sampled due to access issues.

Influent = Before carbon.

Mid = Between carbon.

Followin	ng carbon vesse	ei change out.	
Before blower	36.1	67.1	NA
influent	110.0	16.1	NA
Mid	94.5_	43.7	NA
Effluent	104.0	0.0	NA
		0.0	

		September 3	30, 2002			October 1	1, 2002			November	1, 2002	
	Vac (inches of			Valve %	Vac (inches of			Valve %	Vac (inches of			Valve %
Sample Location	water)	Flow_(cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	NA	NA	NA	0%	NA	NA	NA	0%
SVE - 2	NS	NS	NS	50%	NS	NS	NS	50%	NS	NS	NS	50%
SVE - 3	3-4	6.4	>2000	30%	3.5	10.8	513.0	30%	3.0	8.8	369.0	50%
SVE - 4	2-3	24.5	1245.0	50%	4.5	38.5	109.0	50%	3.5	17.0	105.0	100%
SVE - 5	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 6	2-3	21.1	0.0	100%	2.5	11.8	0.0	100%	<1.0	2.0	0.0	100%
SVE - 7	2.0	8.3	0.0	100%	3.0	3.07	0.0	100%	<1.0	9.40	0.0	100%
VMP - 1	0.0	NA	620.0	NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA
Before blower	NA	31.5	1350.0	NA	NA	40.4	95.4	NA	NA	53.0	140.0	NA
Influent	NA	106.0	240.0	NA -	NA	113.0	7.4	NA	NA	118.0	16.5	NA
Mid	NA	94.5	144.0	NA	NA	95.0	0.0	NA	NA	97.0	10.5	NA
Effluent	NA	114.0	0.0	NA	NA	113.0	0.0	NA	NA	102.0	0.0	NA

Notes:

NA = not applicable.

NS = not sampled due to access issues.

Influent = Before carbon.

Mid = Between carbon.

Effluent = After carbon.

Carbon change out performed.

		November 1	15, 2002			December	4, 2002			December 1	6, 2002	
	Vac (inches of	ı		Valve %	Vac (inches of			Valve %	Vac (inches of	•		Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	3.0	10.4	29.1	30%	NS	NS	NS	30%
SVE - 2	NS	NS	NS	50%	NS	NS	NS	50%	NS	NS	NS	50%
SVE - 3	~1.0	5.2	0.0	50%	2-3	17.0	225.0	50%	0.5	1.6	117.0	50%
SVE - 4	NS	NS	NS	100%	4.0	12.0	97.1	100%	1.5	1.3	126.0	100%
SVE - 5	NS	NS	NS	100%	3-4	3.2	0.0	100%	1.0	1.3	0.0	100%
SVE - 6	~2.0	11.8	0.0	100%	2.0	4.5	0.0	100%	1.0	0.5	0.0	100%
SVE - 7	~2.0	5.0	0.0	100%	2.0	4.7	0.0	100%	1.0	0.5	0.0	100%
VMP - 1	0.0	NA	0.0	NA	0.0	NA	8.7	NA	0.0	NA	0.0	NA
Before blower	NA	High	92.9	NA	NA	47.9	120.0	NA	NA	40.5	190.0	NA
Influent	NA	82.5	25.2	NA	NA	110.0	15.0	NA	NA	98.1	26.4	NA
Mid	NA	84.0	17.0	-NA	NA	86.5	4.5	NA	NA	911	39.0	NA
Effluent	NA	126.0	0.0.	NA	NA	107.5	0.0	NA	NA	132.9	0.0	NA

** = Well under water, could not bail out fast enough.

Notes:

NA = not applicable.

Effluent = After carbon.

NS = not sampled due to access issues.

Influent = Before carbon.

Mid = Between carbon.

		January 6	, 2003			January 13	3, 2003			January 3	1, 2003	
	Vac (inches o	f		Valve %	Vac (inches of			Valve %	Vac (inches of	f		Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	4.0	3.0	900.0	30%	3.0	13.0	823.0	30%	4.0	8.0	425.0	30%
SVE - 2	NS	NS	NS	50%	NS	NS	NS	50%	NS	NS	NS	50%
SVE - 3	~1.0	2.4	78.2	50%	1.25	1.10	72.0	50%	0-1	1.00	10.0	50%
SVE - 4	NS	NS	NS	100%	NS	NS	NS _	100%	NS NS	NS	NS	100%
SVE - 5	3.0	4.1	0.0	100%	NS	NS	NS	100%	NS	NS _	NS	100%
SVE - 6	~2.0	5.8	0.0	100%	3.0	8.15	0.0	100%	2-3	6.00	0.0	100%
SVE - 7	~2.0	4.6	0.0	100%	2.0	4.70	0.0	100%	2-3	5.10	0.0	100%
VMP - 1	0.0	NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA NA	0.0	NA
Before blower	NA	40.1	180.0	NA	NA	120.0	210.0	NA	NA	17.0	525.0	NA
Influent	NA	NS	NS	NA	NA	103.0	36.0	NA	NA	115.0	38.6	NA
Mid	NA	91.0	24.0	NA	NA	93.0	12.0	NA:	NA _	96.0	28.0	NA
Effluent	NA	111.0	0.0.	NA	NA	118.0	1.5	NA	NA _	112.0	0.0	NA

** = Well under water, could not bail out fast enough.

Carbon change out performed.

Notes:

Effluent = After carbon.

NA = not applicable. NS = not sampled due to access issues.

Influent = Before carbon.

Mid = Between carbon.

		February 1	0, 2003			March 5,	2003			March 18	, 2003	
	Vac (inches of		•	Valve %	Vac (inches of			Valve %	Vac (inches d	of		Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	8.0	28.7	350.0	30%	NA	_ NA	NA	0%	NA	NA NA	NA	0%
SVE - 2	NS	NS	NS	50%	<1	0.3	7.7	100%	2.0	3.6	0.0	100%
SVE - 3	0.0	0.0	0.0	50%	<1	0.0	0.0	50%	2.0	4.6	46.1	50%
SVE - 4	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 5	NS	NS	NS	100%	<1	0.2	2.7	100%	2.5	11.3	0.0	100%
SVE - 6	0.0	0.0	0.0	100%	0.0	0.0	0.0	100%	2.5	3.9	0.0	100%
SVE - 7	0.0	0.0	0.0	100%	0.0	0.0	0.0	100%	_3.0	10.9	0.0	100%
VMP - 1	0.0	NA NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA
Before blower	NA	30.0	165.0	NA NA	NA	44.0	0.0	NA	NA _	54.0	2.6	NA NA
Influent	NA	15.3	109.0	NA	NA	106.0	0.0	NA	NA	113.0	0.0	NA
Mid	NA NA	92.5	3.3	NA	NA	88.6	22.3	NA	NA	85.0	0.0	NA
Effluent	NA	126.0	0.0	NA	NA	115.0	0.0	NA	NA	121.0	0.0	NA

Open valve at SVE -2 to 100%

Carbon Change out performed Close valve at SVE -1 to 0%

Notes:

Mid = Between carbon. Effluent = After carbon.

NA = not applicable.
NS = not sampled due to access issues.

Influent = Before carbon.

		April 5, 2	2003			April 14,	2003			May 1, 2	2003	····
	Vac (inches of			Valve %	Vac (inches of			Valve %	Vac (inches o	f		Valve %
Sample Location	water)	Flow (cfm)	PiD (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	NA	NA	NA	0%	NA NA	NA	NA	0%
SVE - 2	7.5	7.2	0.5	100%	9.0	11.5	10.8	100%	NA	NA	NA	100%
SVE - 3	7.0**	9.8**	131.0**	100%	9.0	5.0	85.0	100%	8.0	22.1	89.2	100%
SVE - 4	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 5	7.0	21.3	0.0	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 6	6.5	13.1	0.0	100%	8.0	55.0	0.0	100%	7.0	40.5	0.0	100%
SVE - 7	6.0	9.5	0.0	100%	9.0	34.0	0.0	100%	7.0	43.4	0.0	100%
VMP - 1	0.0	NA NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA NA
Before blower	NA	46.0	36.6	NA	NA_	93.0	36.4	NA	NA	59.0	24.5	NA
Influent	NA _	120.0	9.7	NA	NA NA	118.0	15.6	NA	NA	109.5	15.1	NA
Mid	NA NA	96.1	0.6	NA	NA	94.0	5.5	NA	NĀ	101.0	20.5	NA
Effluent	NĀ	105.0	0.0	NA	NA _	106.0	0.0	NA	NA NA	111.0	0.0	NA

Changed the extraction rate at SVE-3 to 100%. SVE - 3 7.0 10.6 144

Notes:

Mid = Between carbon.

100%

NA = not applicable.
NS = not sampled due to access issues.

Effluent = After carbon.

Influent = Before carbon.

		May 14, 2	2003			May 27,	2003			June 11,	2003	
	Vac (inches of			Valve %	Vac (inches of			Valve %	Vac (inches of			Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	NA	NA	NA	0%	NA	NA	NA	0%
SVE - 2	NS	NS	NS	100%	8.5	83.0	14.5	100%	NS	NS	NS	100%
SVE - 3	>5_	5.35	101.0	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 4	>5	15.7	35.9	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 5	NS	NS	NS	100%	8.0	71.5	5.6	100%	NS	NS	NS	100%
SVE - 6	>5	21.7	0.0	100%	8.0	46.8	0.0	100%	<5	23.3	0.0	100%
SVE - 7	>5	16.0	0.0	100%	8.0	25.3	0.0	100%	<5	18.3	0.0	100%
VMP - 1	0.0	NA	0.0	NA _	0.0	NA	0.0	NA	0.0	NA	0.0	NA
Before blower	NA_	74.5	31.6	NA	NA	140.0	35.5	NA	NA	71.5	6.6	NA
Influent	NA	104.0	17.5	NA	NA _	105.0	16.2	NA	NA	81.5	0.0	NA
Mid	NA _	90.5	14.6	NA	NA	25.6	26.2	NA	NA	86.5	0.0	NA .
Effluent	NA	122.0	0.0	NA	NA	106.0	0.0	NA	NA NA	128.0	0.0	NA NA

Notes:

NA = not applicable.

NS = not sampled due to access issues.

influent = Before carbon.

Mid = Between carbon.

		June 30,	2003			July 16,	2003			July 29, 20	003	
	Vac (inches of	f		Valve %	Vac (inches of			Valve %	Vac (inches of	-		Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	NA	NA	NA	0%	NA	NA	NA	0%
SVE - 2	5.0	23.5	0.0	100%	NS	NS	NS	100%	5.0	15.6	0.0	100%
SVE - 3	6.0	25.0	76.8	100%	5.5	NS	3.0	100%	6.0	6.0	0.0	100%
SVE - 4	NS	NS	NS	100%	NS	NS	NS	100%	5	29.9	0	100%
SVE - 5	NS	NS	NS	100%	NS	NS	NS	100%	4.5	10.0	0.0	100%
SVE - 6	6.0	43.2	0.0	100%	4.0	NS	3.2	100%	4.0	7.6	0.0	100%
SVE - 7	5.5	19.2	0.0	100%	4.0	NS	1.6	100%	5.0	13.0	0.0	100%
VMP - 1	0.0	NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA
Before blower	NA	62.5	7.0	NA _	NA	NS	31.0	NA	NA	65.0	34.9	NA
Influent	NA	96.0	0.0	NA	NA	NS	21.6	NA	NA	108.0	18.3	NA
Mid	NA	89.5	7.0	NA	NA	NS	22.0	NA	NA_	91.5	11.5	NA
Effluent	NA	121.3	20.6	NA	NA	NS	16.4	NA	NA	121.0	7.6	NA

Notes:

NA = not applicable.

Unable to change out carbon units due to access issues.

Flow meter not working.

NS = not sampled due to access issues.

Influent = Before carbon.

Mid = Between carbon.

Followin	g carbon vesse	el change out.	
Before blower	71.5	31.2	NA
influent	100.0	14.0	NA
Mid	92.0	0.0	NA
Effluent	114.0	0.0	NΔ

		August 26,	2003			September 2	24, 2003	<u> </u>		October 21	, 2003	
ľ	Vac (inches of			Valve %	Vac (inches of			Valve %	Vac (inches of			Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	NA NA	NA	NA	0%	NA_	NA NA	NA	0%
SVE - 2	NS	NS	NS	100%	5.0	10.8	1026.0	100%	NS	NS	NS	100%
SVE - 3	5.0	36.5	157.0	100%	4.0	28.1	82.5	100%	3.0	13.7	101.0	100%
SVE - 4	5.0	26.3	50.2	100%	5.0	20.2	127.0	100%	3.0	25.2	53.8	100%
SVE - 5	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 6	4.0	19.0	0.0	100%	3.5	24.5	0.0	100%_	2.0	27.2	0.0	100%
SVE - 7	4.0	23.6	0.0	100%	4.0	16.9	0.0	100%	2.0	24.4	0.0	100%
VMP - 1	0.0	NA	0.0	NA	0.0	NA	0.0	NA	0.0	NA _	0.0	NA
Before blower	NA	120.0	43.0	NA	NA	52.0	478.0	_NA	NA	101.0	46.2	NA
Influent	NA	125.0	20.2	NA	NA_	119.0	139.0	NA	ŇĀ	114.0	17.0	NA
Mid	NA _	102.0	0.0	NA	NA	98.5	53.0	NA	NA	97.5	0.0	NA
Effluent	NA	110.0	0.0	NA	NA	99.5	67.0	NA	NA NA	87.0	0.0	NA

Notes:

NA = not applicable.

NS = not sampled due to access issues.

Influent = Before carbon.

Mid = Between carbon.

		November 2	4, 2003			December 17	, 2003			January 6	2004	
	Vac (inches of			Valve %	Vac (inches of			Valve %	Vac (inches of			Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	NA	NA	NA	0%	NS	NS	NS	0%
SVE - 2	4.5	4.7	67.9	100%	NS _	NS	NS	100%	NS	NS	NS	100%
SVE - 3	3.5	6.9	185.0	100%	0.0	0.0	19.9	100%	NS	NS	NS	100%
SVE - 4	5.0	16.4	46.7	100%	NS	NS	NS	100%	NS _	NS	NS	100%
SVE - 5	3.2	12.5	3.4	100%	NS	NS_	NS	100%	NS	NS	NS	100%
SVE - 6	3.0	8.4	0.0	100%	0.0	0.0	0.0	100%	NS	NS	NS	100%
SVE - 7	2.5	10.5	0.0	100%	0.0	0.0	0.0	100%	NS	NS	NS	100%
VMP - 1	0.0	0.0	NA	NA	0.0	0.0	NA	NA	NS	NS	NS	NA .
Before blower	NA	218.0	39.2	NA	NA	160.0	136.0	NA	NS	NS	NS	NA
Influent	NA	75.0	3.6	NA	NA	86.0	12.7	NA	NS	NS	NS	NA
Mid	NA	83.0	0.0	NA	NA	81.5	1.5	NA _	NS	NS	NS	NA
Effluent	NA	132.0	0.0	NA	NA _	126.0	0.0	NA	NS	NS	NS	NA

Notes:

NA = not applicable.

NS = not sampled due to access issues.

Influent = Before carbon.

Mid = Between carbon.

Effluent = After carbon.

NS = System not sampled due to maintence, standing water in lines, changed SVE filter.

		February 9	, 2004			March 30,	2004			April 28, 2	004	
1	Vac (inches of			Valve %	Vac (inches of			Valve %	Vac (inches of	•		Valve %
Sample Location	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open	water)	Flow (cfm)	PID (ppm)	Open
SVE - 1	NA	NA	NA	0%	2.0	10.0	0.0	10%	7.0	9.7	97.4	10%
SVE - 2	NS	NS	NS	100%	6.0	47.0	5.0	100%	NS	NS	NS	100%
SVE - 3	2.0	4.4	42.3	100%	5.0	30.0	60.0	100%	1.2	0.9	2.2	100%
SVE - 4	NS	NS	NS _	100%	5.0	24.0	15.0	100%	6.0	17.7	7.3	100%
SVE - 5	0.1	1.0	18.8	100%	5.0	22.0	10.0	100%	NS	NS	NS	100%
SVE - 6	0.0	0.9	0.0	100%	4.0	24.0	0.0	100%	0.08	0.88	0.0	100%
SVE - 7	0.0	0.1	0.0	100%	4.0	32.0	0.0	100%	0.05	2.97	0.01	100%
VMP - 1	0.0	0.0	NA	NA	NS	NS	NA NA	NA	NS	NS	NA	NA
Before blower	NA	6.3	19.5	NA	NA	45.0	33.0	NA NA	NA	18.8	42.5	NA
Influent	NA	101.0	0.0	NA	NA	128.0	14.0	NA	NA	82.0	7.1	NA
Mid	NA	88.0	0.0	NA	NA	103.0	5.0	NA	NA	96.5	4.1	NA
Effluent	NA	133.0	0.0	NA	NA	100.0	0.0	NA	NA NA	130.0	1.1	NA
Notes:			_	_	Notes:					ng carbon vess		
NA = not applicable).				Carbon change	out performed.			Before blower	36.0	35.7	NA
NS = Not sampled,		water.					-		Influent	128.0	6.3	NA
Influent = Before ca								j	Mid	106.0	1.1	NA
Mid = Between carl	oon.				•				Effluent	100.0	0.0	NĀ
Effluent = After carl	bon.					_	_					

		May 24, 200	04			June 22, 200	04			July 28, 200	04	
	Vac (inches of	•	PID	Valve %	Vac (inches of		PID	Valve %	Vac (inches of		PID	Valve %
Sample Location	water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	(ppm)	Open
SVE - 1	2.6	18.8	120.0	10%	2.0	27.0	212.0	20%	3.5	65.5	77.5	25%
SVE - 2	NS	NS	NS	100%	4.0	38.0	0.0	100%	NS	NS	NS	100%
SVE - 3	2.9	2.1	69.7	100%	3.0	19.0	83.0	100%	3.0	5.0	86.8	100%
SVE - 4	NS	NS	NS	100%	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 5	NS	NS	NS	100%_	NS	NS	NS	100%	NS	NS	NS	100%
SVE - 6	2.60	9.00	0.0	100%	3.00	15.00	0.0	100%	2.75	55.5	0.0	100%
SVE - 7	2.50	12.70	0.00	100%	3.00	22.00	0.00	100%	2.75	66.0	0.00	100%
VMP - 1	NS	NS	NS	NA	NS	NS	NS	NA	NS	NS	NS	NA
Before blower	NA	33.5	32.6	NA	NA	39.0	53.0	NA	NA	42.4	19.9	NA
Influent	NA	92.5	10.6	NA	NA NA	114.0	8.0	NA	NA	109.0	2.0	NA
Mid	NA NA	85.0	0.0	NA	NA	89.0	0.0	NA	NA	83.5	1.5	NA
Effluent	NA	126.0	0.0	NA	NA	91.0	0.0	NA NA	NA	136.0	0.0	NA

Changed SVE-1 to 25%

Changed SVE-1 to 20% open NS = Not sampled, well head not accessible.

Notes:

NA = not applicable. Influent = Before carbon.

Mid = Between carbon.

Attachment 2
IRM Parameters
NYSDEC - Jimmy's Dry Cleaner

		August 20, 2004	904		0	September 29, 2004	2004	
	Vac (inches of		品	Valve %	Vac (inches of		ᄗ	Valve %
Sample Location	water)	Flow (cfm)	(mdd)	Open	water)	Flow (cfm)	(mdd)	Open
SVE - 1	7.0	43.0	153.0	%57	6.0	7.1	145.0	25%
SVE - 2	SN	SN	SN	100%	SN	SN	NS	100%
SVE - 3	4.0	23.0	75.0	100%	2.0	6.5	31.9	100%
SVE - 4	SN	SN	NS	100%	SN	SN	NS	100%
SVE - 5	SN	NS	NS	100%	NS	SN	SN	100%
SVE - 6	4.00	35.00	0.0	100%	4.60	7.90	0.0	100%
SVE - 7	4.00	18.00	0.00	100%	4.80	5.75	0.00	100%
VMP - 1	SN	SN	SN	AN	SN	SN	SN	AN
Before blower	NA	48.0	49.0	NA	NA	145.0	23.7	Ą
Influent	NA	122.0	34.0	NA	NA	91.0	9.0	ΑN
Mid	NA	98.0	33.0	NA	NA	86.0	0.0	AN
Effluent	NA	107.0	31.0	Ν	NA	127.0	0.0	AN
Notes:	Following	Following carbon vessel change out	change ou					-
NS = Not sampled, well head not accessible.	Before blower	48.0	53.0	Ϋ́				_
NA = not applicable.	Influent	122.0	33.0	NA				
Influent = Before carbon.	Mid	98.0	0.0	NA				=
Mid = Between carbon.	Effluent	107.0	0.0	NA				•
Effluent = After carbon.								

	0	ctober 20, 20	004		No	vember 17,	2004		De	cember 21, 2	2004	
	Vac (inches of		PID	Valve %	Vac (inches of		PłD	Valve %	Vac (inches of	-	PID	Valve %
Sample Location	water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	(ppm)	Open
SVE - 1	5.0	13.4	133.0	25%	6.5	26.6	175.0	25%	3.5	1.89	232.0	25%
SVE - 2	NS	NS	NS	NA	NS	NS	NS	NA	2.0	17.50	1.4	100%
SVE - 3	3.0	13.9	33.2	100%	5.0	7.5	19.8	100%	2.5	3.53	19.0	100%
SVE - 4	NS	NS	NS	100%	6.0	18.7	25.5	100%	3.0	12.0	10.7	100%
SVE - 5	NS	NS	NS	100%	3.0	28.2	0.0	80%	2.3	10.30	0.0	80%
SVE - 6	4.00	8.90	0.0	100%	4.5	10.00	0.0	100%	3.00	9.38	0.0	100%
SVE - 7	4.00	8.85	0.0	100%	4.5	19.00	0.0	100%	3.00	16.20	0.0	100%
VMP - 1	NS	NS	NS	NA	NS	NS	NS	NA	NS	NS	NS	NA
Before blower	NA	218.0	23.5	NA	NA	214+	23.7	NA	NA	Over	36.2	NA
Influent	NA	89.0	7.3	NA	NA	110.0	9.0	NA	NA	97.0	11.5	NA
Mid	NA	84.5	0.10	NA	NA NA	97.0	0.0	NA	NA	78.0	4.1	NA
Effluent	NA	134.0	0.0	NA	NA NA	128.0	0.0	NA	NA _	106.0	2.6	NA
Notes:	_				Following c	arbon vessel	change	out.	Following c	arbon vessel	change	out.
NS = Not sampled, well head not accessible.					Before blower	204.0	25.6	NA	Before blower	85.5	33.9	NA
NA = Not applicable.					Influent	113.0	9.3	NA	Influent	115.0	16.7	NA
Influent = Before carbon.					Mid	102.0	0.0	NA	Mid	80.5	6.6	NA

Effluent

132.0

0.0

NA

Effluent

130.0

0.0

NA

Influent = Before carbon.

Mid = Between carbon.

Over = Greater than meter capacity.

		January 20,	, 2005			January 27	, 2005			February 2	, 2005	
Sample	Vac (inches		PID	Valve %	Vac (inches	-	PID	Valve %	Vac (inches	-	PID	Valve %
Location	of water)	Flow (cfm)	(ppm)	Open	of water)	Flow (cfm)	(ppm)	Open	of water)	Flow (cfm)	(ppm)	Open
SVE - 1					5.5	73.0	NA	10%	6.0	9.60	300.0	10%
SVE - 2					3.8	34.1	NA	100%	2.5	6.35	0.0	100%
SVE - 3					1.5	3.5	NA	100%	1.0	2.77	12.9	100%
SVE - 4					2.8	12.8	NA	100%	0.8	9.3	0.0	100%
SVE - 5					3.3	4.2	NA	100%	2.6	27.00	0.0	80%
SVE - 6					3.0	6.85	NA	100%	2.00	6.85	0.0	100%
SVE - 7					3.0	7.25	NA	100%	1.80	1.90	0.0	100%
VMP - 1					NS	NS	NS	NA	NS	NS	NS	NA
Before blo	wer				NA	40.0	NA	NA	NA	200.0	57.3	NA
Influent					NA	130.0	ÑΑ	NA	NA	112.0	14.8	NA
Mid					NA	NA	NA	NA	NA	94.0	0.0	NA
Effluent					NA	101.0	NA	NA	NA	140.0	0.0	NA
	•	nut down due to and ice obser			System resta service. Syst	rted, lag vess tem operating	•		Installed lag	vessel; two ve	ssels now	in service.
Notes:	-											

NS = Not sampled, well head not accessible.

NA = Not applicable. Influent = Before carbon.

Mid = Between carbon.

Over = Greater than meter capacity.

		February 1	0, 2005	W 1000 4 0000		February 1	7, 2005			February 2	2, 2005	
Sample	Vac (inches	_	PID	Valve %	Vac (inches	_	PID	Valve %	Vac (inches	•	PID	Valve %
Location	of water)	Flow (cfm)	(ppm)	Open	of water)	Flow (cfm)	(ppm)	Open	of water)	Flow (cfm)	(ppm)	Open
SVE - 1	6.0	17.5	29.9	10%	6.0	16.8	30.1	10%				
SVE - 2	1.8	3.1	0.0	100%	1.8	2.97	0.0	100%				
SVE - 3	2.0	2.6	11.0	100%	2.6	3.08	17.0	100%				
SVE - 4	NS	NS	NS	NS	2.0	1.7	0.8	100%				
SVE - 5	1.5	30.2	0.0	80%	1.8	35.0	0.0	80%				
SVE - 6	1.20	6.75	0.0	100%	1.5	7.05	0.0	100%				
SVE - 7	1.80	5.40	0.0	100%	2.0	5.50	0.0	100%				
VMP - 1	NS	NS	NS	NA	NS	NS	NS	NA				
Before blower	NA	30.0	2.7	NA	NA NA	28.5	3.7	NA				
Influent	NA	102.0	0.0	NA	NA	107.0	0.0	NA				
Mid	NA	86.5	0.00	NA_	NA	82.5	0.0	NA _				
Effluent	NA	104.0	0.0	NA	NA	112.0	0.0	NA				

Notes:

NS = Not sampled, well head not accessible.

NA = Not applicable.

influent = Before carbon.

Mid = Between carbon.

Over = Greater than meter capacity.

Brief visit to confirm system operation and check for water accumulation in moisture separator.

System OK.

		March 2,	2005			March 22, 2	2005			March 23,	2005	
Sample	Vac (inches		PID	Valve %	Vac (inches of		PID	Valve %	Vac (inches		PID	Valve %
Location	of water)	Flow (cfm)	(ppm)	Open	water)	Flow (cfm)	(ppm)	Open	of water)	Flow (cfm)	(ppm)	Open
SVE - 1	NS	NS	NS	NS	7.0	26.1	128.0	10%	5.0	7.15	NA	10%
SVE - 2	3.5	12.3	1.6	100%	0.0	0.5	2.6	100%	4.0	12.70	NA	100%
SVE - 3	NS	NS	NS	100%	3.0	19.5	11.5	100%	NA	NA	NA	100%
SVE - 4	4.0	25.5	16.4	100%	5.5	34.2	23.5	100%	4.5	39.2	NA	100%
SVE - 5	3.0	13.0	0.6	100%	0.0	0.2	0.0	100%	3.3	18.20	NA	100%
SVE - 6	2.00	10.80	0.0	100%	0.0	0.13	0.0	100%	3.00	7.60	NA	100%
SVE - 7	2.50	10.70	0.0	100%	0.0	0.13	0.0	100%	3.00	17.00	NA	100%
VMP - 1	NS	NS	NS	NA	NS	NS	NS	NA	NS	NS	NS	NA
Before blower	NA	214.0	124.2	NA	NA	210.0	25.5	NA	NA	NA	NA	NA
Influent	NA	114.0	10.4	NA	NA	113.0	8.4	NA	NA	NA	NA	NA
Mid	NA	88.0	0.80	NA	NA	88.0	1.8	NA	NA	NA	NA	NA
Effluent	NA	113.0	0.0	NA	NA	117.0	0.0	NA	NA	NA	NA	NA

Notes:

NS = Not sampled, well head not accessible.

NA = Not applicable. Influent = Before carbon.

Mid = Between carbon.

Over = Greater than meter capacity.

Following	carbon vess	sel change o	out.
Before blower	Over	17.2	NA
Influent	110.0	9.1	NA
Mid	91.5	0.0	NA
Effluent	121.0	0.0	NA

ATTACHMENT 3

Indoor Air Analytical



LABORATORY ANALYSIS REPORT

Client : Shaw Environmental & Infrastructure

: Jimmy's Dry Cleaner Site

: 824324 Project No.

Date Sampled : 15-JUN-05 Date Received : 17-JUN-05

Account No.: 14965 Login No. : L119713

Date Analyzed : 13-JUN-05

Perchloroethylene

<u>Sample ID</u>	Lab ID	Time minutes	Total 	Conc ug/m3
BACKGROUND	L119713-1	1440	0.48	11
DUPA	L119713-2	1440	0.71	17
DELI	L119713-3	1355	1.16	29
KFC	L119713-4	1440	0.28	6.7
J	L119713-5	1440	0.7	17
G	L119713-6	1440	0.52	12
TRIP BLANK	L119713-7	NA	0.51	NA

COMMENTS: Total ug corrected for a desorption efficiency of 103%. Sample results were corrected for the in-house media blank value. Sample results have not been corrected for the client blank value.

Level of quantitation: 0.03 ug
Analytical Method : mod. NYS DOH 311-9 Submitted by: RAF Approved by : dk Date : 24-JUN-05 OSHA PEL (TWA) : 100 ppm NYS DOH # : 11626 Collection Media : OVM QC by: Lyndi Mott -Less Than

-Greater Than

mg -Milligrams

m3 -Cubic Meters

kg -Kilograms

NA -Not Applicable

ug -Micrograms ND -Not Detected

-Liters 1 ppm -Parts per Million

NS -Not Specified

ATTACHMENT 4

Indoor Air Quality Data

Attachment 4

Indoor Air Quality Data

NYSDEC - Jimmy's Dry Cleaners

61 Nassau Road, Roosevelt, New York

		NYSDOH					
Sample Location	Units	Guidance Value	6/15/05				
KFC - Kitchen	μg/m³	100	6.7				
40 Dutchess (Bsmt. Living. Rm)	μg/m ³	100	NS				
40 Dutchess (Bsmt. Bdrm/baby rm)	μg/m ³	100	12				
40 Dutchess (Kitchen/First Floor)	μg/m ³	100	NS				
Deli - Front Room	μg/m ³	100	29				
Deli - Storage Room (Back)	μg/m³	100	NS				
DUPA (KFC)	μg/m³	100	17	_		_	
Dupe 1 (Deli - Front Room)	μg/m ³	100	NS				
Dupe 2 (40 Dutchess.Bsmt)	μg/m³	100	NS				
Dupe 3 (Deli - Front Room)	μg/m³	100	NS				
Dupe 4 (KFC)	μg/m³	100	NS		_		
44 Dutchess (Jackson Bsmt./Family Rm)	μg/m³	100	17_			-	
44 Dutchess (First Floor/Kitchen)	μg/m³	100	NS				
34 Dutchess (Bsmt. Rec Room)	μg/m³	100	NS				
34 Dutchess (Bsmt. Bdrm)	μg/m³	100	NS				
34 Dutchess (First Floor/Kitchen)	μg/m³	100	NS				
MSUP - Bld. 1 Basement, store room	μg/m³	100	NS			_	
MSUP - Bld. 1 First floor, southwest corner	μg/m ³	100	NS				
MSUP - Bld. First floor, northwest corner	μg/m³	100	NS				
MSUP - Bld. 2 First floor, front room	μg/m ³	100	NS _				
MSUP - Bld. 2 First floor, rear room	μg/m³	100	NS				
MSUP - Bld. 3 Basement, computer room	μg/m³	100	NS				
MSUP - Bld. 3 First floor, office	μg/m³	100	NS				
MSUP - Play area southwest of Bld. 1	μg/m³	100	NS				
Background	μg/m³	100	11				
Natas					-		

Notes:

Bold = Value exceeds NYSDOH guidance value.

MSUP = Miss Shelly's School - 66 Nassau Road.

KFC = 497 North Main Street.

All samples were sampled for Tetrachloroethene by NYSDOH Method 311-9.

NYSDOH Guidance Value references NYSDOH's "Tetrachloroethene

in Indoor and Outdoor Air", May, 2003.

NS = Not sampled.

NA = Data not available.

ND = Non - Detect.

(PL) = value detected less than the reported value.

5 (PL)/5 (PL) = Indicates that the NCDOH collected

a duplicate sample from this location.



Attachment 4 Indoor Air Quality Data NYSDEC - Jimmy's Dry Cleaner

61 Nassau Road, Roosevelt, New York

1	NYSDOH					
Units	Guidance Value	09/29/98	01/05/99	08/17/00	08/28/01	05/09/02
ug/m ³	10	NS	NS	NS	10	70
ug/m³	10	NS	NS	NS	5 (PL)	NS
ug/m ³	10	NS	NS	NS	5 (PL)	490
ug/m ³	10	NS	NS	NS	5 (PL)	280
ug/m ³	10	1250/1400	400/400	510/480	108	900/870
ug/m ³	10	930/970	400/400	490/480	NS	NS
ug/m ³	10	NS	NS	NS	NS	NS
ug/m ³	10	NS	NS	NS	NS	NS
ug/m ³	10	NS	NS	NS	NS	NS
ug/m ³	10	NS	NS_	NS	NS	NS
ug/m ³	10	NS	NS	NS	NS	NS
ug/m³	10	NS	NS	NS	NS	NS
	10	NS	NS NS	NS	NS	NS
ug/m³	10	NS	NS	NS	5 (PL)/5 (PL)	NS
ug/m³	10	NS	NS	NS	5 (PL)	NS
	10	NS	NS	NS	5 (PL)	NS
	10	NS	NS	NS	ND	ND
ug/m ³	10	NS	NS	NS _	ND/ND	5 (PL)
ug/m ³	10	NS	NS	NS	ND	5 (PL)
ug/m ³	10	NS	NS	NS	ND	5 (PL)
ug/m ³	10	NS	NS	NS	ND	ND
ug/m ³	10	NS	NS	NS	ND	5 (PL)/5 (PL)
ug/m ³	10	NS	NS	NS	ND	ND
ug/m ³	10	NS	NS	NS	ND/ND	5 (PL)
ug/m³	10	NS	NS	NS	NA	NA
	ug/m³	Units Guidance Value ug/m³ 10 ug/m³ 10	Units Guidance Value 09/29/98 ug/m³ 10 NS ug/m³ 10 NS ug/m³ 10 NS ug/m³ 10 NS ug/m³ 10 930/970 ug/m³ 10 NS ug/m³ 10	Units Guidance Value 09/29/98 01/05/99 ug/m³ 10 NS NS ug/m³ 10 NS NS ug/m³ 10 NS NS ug/m³ 10 NS NS ug/m³ 10 1250/1400 400/400 ug/m³ 10 NS NS ug/m³ 10 NS <td>Units Guidance Value 09/29/98 01/05/99 08/17/00 ug/m³ 10 NS NS NS ug/m³ 10 NS NS NS ug/m³ 10 NS NS NS ug/m³ 10 1250/1400 400/400 510/480 ug/m³ 10 930/970 400/400 490/480 ug/m³ 10 NS NS NS ug/m³<td>Units Guidance Value 09/29/98 01/05/99 08/17/00 08/28/01 ug/m³ 10 NS NS NS 10 ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 1250/1400 400/400 510/480 108 ug/m³ 10 930/970 400/400 510/480 NS ug/m³ 10 NS NS NS NS ug/m³ 10 NS NS NS</td></td>	Units Guidance Value 09/29/98 01/05/99 08/17/00 ug/m³ 10 NS NS NS ug/m³ 10 NS NS NS ug/m³ 10 NS NS NS ug/m³ 10 1250/1400 400/400 510/480 ug/m³ 10 930/970 400/400 490/480 ug/m³ 10 NS NS NS ug/m³ <td>Units Guidance Value 09/29/98 01/05/99 08/17/00 08/28/01 ug/m³ 10 NS NS NS 10 ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 1250/1400 400/400 510/480 108 ug/m³ 10 930/970 400/400 510/480 NS ug/m³ 10 NS NS NS NS ug/m³ 10 NS NS NS</td>	Units Guidance Value 09/29/98 01/05/99 08/17/00 08/28/01 ug/m³ 10 NS NS NS 10 ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 NS NS NS 5 (PL) ug/m³ 10 1250/1400 400/400 510/480 108 ug/m³ 10 930/970 400/400 510/480 NS ug/m³ 10 NS NS NS NS ug/m³ 10 NS NS NS

Notes:

Bold = Value exceeds NYSDOH guidance value.

MSUP = Miss Shelly's School - 66 Nassau Road.

KFC = 497 North Main Street.

All samples were sampled for Tetrachloroethene by NYSDOH Method 311-9.

NYSDOH Guidance Value references NYSDOH's "Tetrachloroethene in Indoor and

Outdoor Air", May, 2003.

NS = Not sampled.

NA = Data not available.

ND = Non - Detect.

(PL) = value detected less than the reported value.

5 (PL)/5 (PL) = Indicates that the NCDOH collected a

duplicate sample from this location.

Attachment 4 Indoor Air Quality Data NYSDEC - Jimmy's Dry Cleaner 61 Nassau Boad, Boosevelt, New York

		NYSDOH					
Sample Location	Units	Guidance Value	07/01/02	11/25/02	01/13/03	03/05/03	05/01/03
KFC - Kitchen	ug/m ³		NS	18	6.4	3.3	42
40 Dutchess (Bsmt. Living. Rm)	ug/m ³	10	5 (PL)	NS	NS	NS	NS
40 Dutchess (Bsmt. Bdrm/baby rm)	ug/m ³	10	5	1.0	5.2	24	NS
40 Dutchess (Kitchen/First Floor)	ug/m ³	10	NS	NS	NS	NS	NS
Deli - Front Room	ug/m ³	10_	230	67	48	119	69
Deli - Storage Room (Back)	ug/m³	10	NS	NS	NS	NS	NS
DUPA (KFC)	ug/m³	10	NS	NS	NS	NS	NS
Dupe 1 (Deli - Front Room)	ug/m ³	10	NS	NS	49	NS	NS
Dupe 2 (40 Dutchess.Bsmt)	ug/m ³	10	NS	NS	NS	20	NS
Dupe 3 (Deli - Front Room)	ug/m ³	10	NS	NS	NS	NS	69
Dupe 4 (KFC)	ug/m ³		NS	NS	NS	NS	NS
44 Dutchess (Jackson Bsmt./Family Rm)	ug/m ³	10	14	7.4	NS	2.6	NS
44 Dutchess (First Floor/Kitchen)	ug/m ³		5 (PL)	NS	NS	NS	NS
34 Dutchess (Bsmt. Rec Room)	ug/m ³	10	NS	NS	NS	NS	NS
34 Dutchess (Bsmt. Bdrm)	ug/m ³	10	NS	NS	NS	NS	NS
34 Dutchess (First Floor/Kitchen)	ug/m ³	10	NS	NS	NS	NS	NS
MSUP - Bld. 1 Basement, store room	ug/m ³	10	NS	NS	NS	NS	NS
MSUP - Bld. 1 First floor, southwest corner	ug/m³	10	NS	NS	NS	NS	NS
MSUP - Bld. First floor, northwest corner	ug/m ³	10	NS	NS	NS	NS	NS
MSUP - Bld. 2 First floor, front room	ug/m ³	10	NS	NS	NS	NS	NS
MSUP - Bld. 2 First floor, rear room	ug/m³	10	NS	NS	NS	NS	NS
MSUP - Bid. 3 Basement, computer room	ug/m³	10	NS	NS	NS	NS	NS
MSUP - Bld. 3 First floor, office	ug/m ³	10	NS	NS	NS	NS	NS
MSUP - Play area southwest of Bld. 1	ug/m³	10	NS	NS	NS	NS	NS
Background	ug/m ³	10	NS	1.7	2.4	4.0	15

Notes:

Bold = Value exceeds NYSDOH guidance value.

MSUP = Miss Shelly's School - 66 Nassau Road.

KFC = 497 North Main Street.

All samples were sampled for Tetrachloroethene by NYSDOH Method 311-9.

NYSDOH Guidance Value references NYSDOH's "Tetrachloroethene

in Indoor and Outdoor Air", May, 2003.

NS = Not sampled.

NA = Data not available.

ND = Non - Detect.

(PL) = value detected less than the reported value.

5 (PL)/5 (PL) = Indicates that the NCDOH collected

a duplicate sample from this location.

Attachment 4 Indoor Air Quality Data NYSDEC - Jimmy's Dry Cleaner 61 Nassau Road, Roosevelt, New York

				a duplicate sample	in Indoor and Outdoor Air", May, 2003.				
				ON edt that teetsol			achloroeth	NYSDOH Guidance Value references NYSDOH's "Tetr	
				ted less than the r				All samples were sampled for Tetrachloroethene by MY	
		_	, , , ,		VD = Non - Detect			KFC = 497 North Main Street.	
		•		ilable.	eve for sted = AV	1		MSUP = Miss Shelly's School - 66 Massau Road.	
				•	belqmss toM = 2V	1		Bold = Value exceeds NYSDOH guidance value.	
L								Notes:	
4.2	8.4	0.4	6.4	8.4	2.9	01	_E W/Bn		
SN	SN .	SN	SN	SN	SN	01	_E ui/6n		
SN	SN	SN	SN	SN	SN	01	_e ɯ/ɓn		
SN	SN	SN	SN	SN	SN	01	_e w/6n		
SN	SN	SN	SN	SN	SN	01	nd\m ₃		
SN	SN	SN	SN	SN	SN	01	_s w/6n		
SN	SN	SN	SN	SN	SN	01	_E w/6n	MSUP - Bld. First floor, northwest corner	
SN	SN	SN	SN	SN	SN	10	_E w/6n	MSUP - Bld. 1 First floor, southwest corner	
i SN	SN	SN	SN	SN	SN	01	_E w/6n	MSUP - Bld. 1 Basement, store room	
SN	SN	SN	SN	SN	SN	01	_E w/6n	34 Dutchess (First Floor/Kitchen)	
SN	SN	SN	SN	SN	SN	10	_E w/6n	34 Dutchess (Bsmt. Bdrm)	
SN	SN	SN	SN	9.£	SN	10	չш/6п	34 Dutchess (Bsmt. Rec Room)	
SN	SN	SN	SN	SN	SN	01	_ε ш/бп	44 Dutchess (First Floor/Kitchen)	
6.3	SN	5.2	SN	0.8	SN	01	_e ш/bn	44 Dutchess (Jackson Bsmt./Family Rm)	
SN	SN	SN	SN	SN	5.2	10	_E ш/bn	Dupe 4 (KFC)	
SN	SN	SN	SN	SN	SN	01	_E ш/bn		
SN	SN	SN	SN	SN	SN	01	_E ш/bn		
SN	SN	SN	SN	SN	SN	01	_E w/6n	Dupe 1 (Deli - Front Room)	
0.6	7.3	50	1.7	5.2	SN	01	_E ɯ/ɓn	DUPA (KFC)	
SN	SN	SN	SN	SN	SN	Of	չш/6п	Deli - Storage Room (Back)	
36	31	72	24	0.41	56	01	չш/ɓո	Deli - Front Room	
SN	SN	SN	SN	SN	SN	10	_є ш/бп	40 Dutchess (Kitchen/First Floor)	
4.8	0.4	2.8	5.9	0.01	2.8	10	քш/քո		
SN	SN	SN	SN	SN	SN	10	_E ɯ/ɓn	40 Dutchess (Bsmt. Living. Rm)	
8.8	5.8	6 l	£.4	3.8	6.3	10	_E w/bn	KFC - Kitchen	
3/22/2005	12/21/2004	9/30/2004	6/22/2004	3/30/2004	60/23/03	ulsV eansbiu	stinU	Sample Location	
				SAGIC IAGA LOI		ИХЗДОН			