


# LBG ENGINEERING SERVICES, P.C.

Professional Environmental & Civil Engineers



126 Monroe Turnpike  
Trumbull, CT 06611  
(203) 452-3110  
(203) 452-3119 (FAX)

June 6, 2005

Mr. Jeffery Trad  
Project Manager  
New York State Department of Environmental Conservation  
Division of Environmental Remediation, Construction Services  
625 Broadway, 12<sup>th</sup> floor  
Albany, NY 12233-7013

RE: April 2005 Status Report  
Ground-Water Remedial Action  
Rowe Industries Superfund Site  
Sag Harbor, New York

Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above referenced site. LBG has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 452-3100.

Very truly yours,


LEGGETTE, BRASHEARS & GRAHAM, INC.

*Mark M. Goldberg*  
Mark M. Goldberg, P.E.  
Senior Environmental Engineer

MG:ng

Enclosures

H:\NABIS\2005\Monthly Reports\April 2005\trad\_Apr2005\_report.doc



**PROJECT STATUS MEMORANDUM**

**NO. 04-05**

**TO:** Pamela Tames, USEPA

**FROM:** Mark M. Goldberg, P.E.  
Alfred N. Kovalik, P.E.

**DATE:** May 20, 2005

**PROJECT:** Rowe Industries Superfund Site  
Ground-Water Recovery and Treatment System  
April 2005 Status Report  
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from April 1, 2005 through April 30, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground-water, system effluent samples, and air quality results.

**SUMMARY OF SYSTEM PERFORMANCE AND OPERATION**  
*(April 1, 2005 through April 30, 2005)*

1. Hours of operation during the reporting period: 448 hours (62%)
2. Alarm conditions during the reporting period: See Table 1
3. Was the SPDES VOC discharge permit criteria achieved: yes, (Table 2)
4. Total volume of water pumped during the reporting period: 9,848,410 gal.
5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1)
6. Mass of VOCs recovered during the reporting period: 1.3 pounds
7. Cumulative mass of VOCs recovered since startup on 12/17/02:  
(calculations can be provided upon request) 163.7 pounds
8. Effluent VOC vapor concentration for the reporting period: 0.095 mg/m<sup>3</sup> (Table 3)
9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:  
(calculations can be provided upon request) yes (0.00086 lbs/hr.)

## GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration ( $\mu\text{g}/\text{L}$ )	VOC Recovery (lbs)
RW-1	370,035	14.3	26	1.5	0.005
RW-2	601,937	24.6	26	9.0	0.05
RW-3	323,997	13.1	23	2.0	0.01
RW-4*	256,880	40	13	171.4	0.37
RW-5	1,418,186	55.0	42	13.1	0.16
RW-6	719,856	27.6	28	81.0	0.49
RW-7	1,917,438	70.0	54	22.0	0.35
RW-8**	1,145,188	43.8	46	7.0	0.07
RW-9***	279,873	17.2	68	4.5	0.01

\* The RW-4 motor was not operating from April 1 to April 25, 2005. A replacement motor and power cable were installed in RW-4 on April 26, 2004. In addition, the RW-4 flow meter and piping were cleaned. An initial flow reading (signal) of 40 gpm was observed at the remediation building during start-up, however the meter stopped sending an accurate flow reading shortly thereafter. The flow meter will be inspected to determine if debris is blocking the flow disc from spinning. The most likely cause for debris in the flow meter may be attributed to vault flooding during rain events sending debris (i.e. twigs, sand, fine gravel) into the well. The pump subsequently lifts the debris up the riser pipe to the flow meter. The initial reading of 40 gpm was used to determine the volume of water pumped from RW-4.

\*\* From April 1 to April 19, 2005, the RW-8 flow meter was sending an erroneous (180 gpm flow rate) signal from the flow meter to the main computer causing a high flow alarm. The communication wiring for RW-8 was previously disconnected at the flow meter to allow it to operate at its current flow rate of 35 gpm during this period. On April 19, 2005 the RW-8 flow meter wiring was re-connected to record flow at the remediation building. From April 19 to April 30, 2005, RW-8 flow measurements were recorded in the normal manner. The total volume pumped from RW-8 was determined in two steps. The first step assumed an average flow rate of 35 gpm from April 1 to April 19, 2005 and multiplying by the operating time in that period. The second step used the computer totalizer readings for RW-8 from April 19 to April 30, 2005. These two values were combined to obtain the total volume pumped from RW-8. The average flow was calculated by dividing the total volume pumped by the hours of operation for RW-8 in April.

\*\*\* On April 19, 2005 a leak was observed at a union in the RW-9 vault. Initial attempts to fix the leak included an attempt to tighten the union, however, the union could not be tightened any further. A new union has been ordered and is scheduled for installation during the RW-9 well rehabilitation activities.

Recovery wells RW-1, RW-2, RW-3, RW-6, RW-8 and RW-9 had average flows below the minimum design flow to capture the plume. Despite periodic pipe cleanings RW-1, RW-2 and RW-3 have decreased in flow due to iron build-up in the below-grade pipes. The flow in RW-6 has slowly been decreasing over time. This is believed to be the result of bio-fouling in the pump, well screen, and the surrounding formation.

Prior to pipe/flow meter cleaning, well rehabilitation and the installation of a new motor, the maximum flow that could be achieved from RW-8 was 35 gpm. Following these activities, on April 19, 2005, the flow at RW-8 was restored to 65 gpm, however the lower flow rates from April 1

through April 18 brought the average flow reading below the minimum design flow for the month of April. The ability to increase the pumping rate at RW-8 from 35 gpm to 65 gpm suggests that the RW-8 rehabilitation and maintenance activities mentioned above were successful.

The low flow at RW-9 is believed to be caused by iron build-up in a section of the below-grade piping not accessible to high-pressure jet-washing techniques. In April, below-grade piping at the new clean-out port on Noyac Road allowed cleaning of 135 feet of additional piping not previously accessible with the jet-washing equipment. However, there is still additional below-grade piping that was not accessible. Two additional clean-out ports on Noyac Road are scheduled for construction in June to address iron build-up in the remaining inaccessible below-grade piping.

Well rehabilitation activities and pump servicing scheduled for May and June 2005 may help improve flow at RW-2, 3, 6 and 9.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. April pH readings of water samples from the recovery wells were observed to be in the range of approximately 5.2 to 6.1, which is the background pH for the ground water in this area. The FSP&T system does not use any chemical treatment processes to alter pH. In addition the effluent water discharge and the recovery well extraction points are located in the same aquifer. As discussed with the New York State Department of Environmental Conservation (NYSDEC), because the pH is naturally occurring, it is not considered an exceedance of the discharge requirements.

### BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
Apr. 1 to Apr. 30	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

### OTHER O&M MODIFICATIONS AND FUTURE O&M ACTIVITIES

- On April 7, 2005, the below-grade piping near RW-8 and at the new clean-out port on Noyac Road was completed. Cleaned 100 feet of previously inaccessible below-grade pipe on Noyac Road before encountering an obstacle. Updated static depth to water at recovery wells, monitor wells and piezometers.
- On April 13, 2005, the system was de-energized to allow Keyspan Energy to dig test holes adjacent to Brick Kiln Road to locate our below-grade conduit and piping. Replaced RW-9 well-head pressure sensor; there is still no reading on the local RW-9 well-head pressure display. Replaced RW-3 flow meter battery.

- On April 19, 2005, the RW-8 flow meter wiring was re-connected and flow was restored to 65 gpm. The leak in the union at RW-9 was observed and the well was turned off after sampling until the leak could be addressed.
- On April 20, 2005, the combined off-site, combined on-site and RW-9 flow meters were cleaned. In addition, check valves and piping were cleaned at the remediation building, RW-2 and RW-3. The well-head pressure display at RW-9 was fixed by replacing it with another unit. The local well-head pressure display at RW-9 was providing a good pressure reading. The discharge pipe was inspected and three locations on the discharge pipe were exposed.
- On April 21, 2005, the pipes were cleaned from both clean-out ports on Noyac Road. After making some modifications to the jet-washing equipment, 135 of pipe was jet-washed (an additional 35 feet of pipe was cleaned compared to April 7). Vault and below-grade pipes were cleaned at RW-6, and RW-9. The RW-6 flow meter was inspected and cleaned. The FSP&T system was de-energized for the anticipated gas main construction on Brick Kiln Road.
- On April 26, 2005 a new motor and power cable were installed in RW-4. Following installation, the RW-4 pump was operating at a flow of 40 gpm. Shortly after start-up a flow signal was not received at the building. The RW-4 flow meter will be inspected to determine if there are any obstructions.

Future O&M activities scheduled for spring/summer 2005 include:

- Sample the focused pump and treat wells and select monitor wells near the FDSA in May 2005;
- Cover exposed discharge piping with soil in May 2005;
- Inspect tower packing material for iron build-up;
- Construct two additional clean-out ports on Noyac Road;
- Conduct well rehabilitation for select recovery wells RW-2, 3, 4, 6, 7 and 9 using the same methodology as RW-8;
- Remove sediment from the air stripper tower sump and transfer tank;
- Troubleshoot the RW-4 flow meter; and,
- Repair the leak at RW-9.

MMG:ng

cc: Terry Gerrish, CH2M Hill  
 Mark Lucas, CH2M Hill  
 Phil McAndrew, Kraft Foods, N.A. – .pdf  
 Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf  
 Jeff Trad, NYSDEC  
 Chief-Operation Maintenance and Support Section  
 Robert Schneck, RWE, R-1, NYSDEC  
 David Gilmartin, Jr., Esq., Town of Southampton

#### Attachments

H:\NABIS\2005\Monthly Reports\April 2005\Status0405Apr.doc

**TABLES**

**TABLE 1**  
**GROUND-WATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**

**MAINTENANCE LOG**  
(April 1, 2005 through April 30, 2005)

Date	Time	System Changes/Modifications	Personnel
4/5/05	9:08 PM	Power failure alarm; RW-1, 2, 3, 5 and 8 pump fault alarms; control room temperature alarm.	
	9:29 PM	RW-6 pump fault alarm. Only RW-7 and 9 were operating.	
4/6/05	10:29 AM	Wells turned off for weekly O&M and in preparation for below-grade pipe cleaning on April 7.	ETL, SS
4/7/05		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS
		Continuation of below-grade pipe cleaning and flow meter cleaning	ETL, SS
		Updated static depth to water levels at recovery wells, monitor wells and piezometers.	SS, MG
		Marked-out below-grade piping on Brick Kiln Road for Keyspan gas main construction work.	MG
	1:14 PM	Reset RW 1, 2, 3, 5, 6 and 8 pump drives, reset alarms and restarted the system.	SS
4/9/05	10:56 AM	Communication Failure Alarm	
4/13/05		De-energized system for Keyspan gas test holes to be completed on Brick Kiln Road to locate our below-grade piping.	MG
		Replaced the malfunctioning RW-9 well-head pressure sensor, however, there is still no reading at the local well-head pressure display. A bad display may be the problem. A good reading is still being observed from the computer display in the remediation building for RW-9 well-head pressure.	MG
		RW-3 local flow display is not working. Replaced battery in flow meter, however local flow display still did not work. A good reading is still being observed from the computer display in the remediation building for the RW-3 flow.	MG
	2:01 PM	Re-booted the system, reset the alarms and restarted the system.	MG
	11:17 AM	Leak observed in the RW-9 vault at the union just before the check valve. The well was sampled then turned off until the leak could be addressed.	MG
4/19/05		Re-wired RW-8 flow meter so it would display in the building. Verified with PJ that wiring was properly hooked up so that it would display locally and at the computer, however, the local flow display would not provide a reading. Following pipe/flow meter cleaning, well rehabilitation and installation of a new motor, the flow in RW-8 was restored to 65 gpm. Prior to these activities, RW-8 was operating at 35 gpm.	MG
	9:14 AM	Shut down system for ETL pipe cleaning at RW-2, 3, and building flow meters/check valves/piping.	ETL/MG
4/20/05		Switched the operable RW-3 well-head pressure display with the inoperable RW-9 well-head pressure display to see if a pressure reading could be obtained at RW-9. RW-9 local well-head pressure meter now works.	MG
		Tried to tighten the RW-9 union to stop the leak, however the union would not tighten any further. The next step is to remove and inspect the union and replace the union if needed. A new union for RW-9 has been ordered.	ETL/MG
		Inspected the length of the below-grade discharge piping from the remediation building to the discharge basins. Below-grade discharge piping is exposed in three locations between the remediation building and the recharge basins. Exposed piping will be covered with soil in May.	MG
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG

**TABLE 1**  
**GROUND-WATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**

**MAINTENANCE LOG**  
(April 1, 2005 through April 30, 2005)

Date	Time	System Changes/Modifications	Personnel
4/21/05		System remains off. ETL pipe cleaning at RW-6, 9 and the two clean-out ports on Noyac Road were completed.	MG/ETL
		System de-energized and remained off for anticipated Keyspan gas main construction on Brick Kiln Road on 4/25/05.	MG
4/25/05		Keyspan changed gas main construction schedule. Keyspan will communicate with LBG regarding updated schedule.	
4/26/05	10:28 AM	Re-energized the system, reset several alarms that result in re-energizing the system, re-booted the computer and restarted the system.	TS
		Turned valve in RW-9 vault to the off position to prevent a backflow of process water from entering the well.	TS

TABLE 2

**GROUND-WATER REMEDIAL ACTION  
ROWE INDUSTRIES SUPERFUND SITE  
SAG HARBOR, NEW YORK**

**EFFLUENT WATER QUALITY RESULTS**

Date Sampled	pH <sup>1</sup>	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Naphthalene (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	6.5 to 8.5	—	1	5	5	5	5	5	—	—	5	—	10	7	—	—	—	
7-Apr-05	5.3	110	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	8.55	0.277
13-Apr-05	5.3	110	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.04	0.0799
19-Apr-05	5.3	92	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.07	0.0969
27-Apr-05	5.3	110	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.614	0.173

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

—: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethylene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

**Notes:**

1. pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.

2. "Effluent" samples were collected from sample port labeled NP2-10.



TABLE 4

**GROUND-WATER REMEDIAL ACTION  
ROWE INDUSTRIES SUPERFUND SITE  
SAG HARBOR, NEW YORK**

**RECOVERY WELL WATER QUALITY RESULTS**

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropyl-benzene (ug/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)	
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE	
RW-1	23-Apr-03	ND<1	ND<1	ND<1	ND<1	1.2	8.6	0.053	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	ND<1	ND<1	ND<1	ND<1	1.8	8.7	0.051	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1	
	11-Jun-03	ND<1	ND<1	ND<1	ND<1	ND<1	8.1	0.0290	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	ND<1	ND<1	ND<1	ND<1	2.9	6.6	0.0100	0.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	ND<1	ND<1	ND<1	ND<1	2.6	9.4	0.0930	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	ND<1	ND<1	ND<1	ND<1	3.2	14	0.0540	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0613	0.0074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	ND<1	ND<1	ND<1	ND<1	2.2	9.4	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	ND<1	ND<1	ND<1	ND<1	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.5	
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1	
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.1*	ND<1	ND<1	ND<1	
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	8.0	
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-2	23-Apr-03	14	1.3	ND<1	ND<1	ND<1	ND<1	6.31	0.212	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	21	2	ND<1	ND<1	ND<1	ND<1	3.8	5.51	0.052	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	
	11-Jun-03	15	0.6	ND<1	ND<1	ND<1	ND<1	3.01	0.885	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	5.34	0.438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	7.9	ND<1	ND<1	ND<1	ND<1	ND<1	5.99	0.758	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	9.2	0.5	ND<1	ND<1	ND<1	ND<1	6.0	4.49	0.899	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	8.1	0.7	ND<1	ND<1	ND<1	ND<1	6.79	0.101	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	5.5	ND<1	ND<1	ND<1	ND<1	ND<1	5.5	5.46	0.0213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	ND<1	1.1	5.57	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.9	3.77	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	ND<1	3.3	0.343	0.318	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	ND<1	2.8	5.59	0.224	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	4.7	4.5	0.691	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1	
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	

TABLE 4

**GROUND-WATER REMEDIAL ACTION  
ROWE INDUSTRIES SUPERFUND SITE  
SAG HARBOR, NEW YORK**

**RECOVERY WELL WATER QUALITY RESULTS**

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropyl-benzene (ug/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)	
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	5	NE	NE	
RW-3	23-Apr-03	1.1	1.2	ND<1	ND<1	ND<1	ND<1	1.81	0.395	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	2.2	2.5	1.1	ND<1	ND<1	ND<1	1.68	0.166	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1	
	11-Jun-03	2.4	3.4	1.8	ND<1	ND<1	ND<1	2.37	0.517	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	2.3	5.7	2.3	ND<1	ND<1	ND<1	1.77	0.636	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	2.8	5.8	2.9	ND<1	ND<1	ND<1	2.24	1.57	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	2.1	5.3	2.6	ND<1	ND<1	ND<1	1.86	1.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	1.9	5.2	3.3	ND<1	ND<1	ND<1	2.59	1.27	ND<1	ND<1	0.6	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	1.2	5.8	ND<1	ND<1	ND<1	ND<1	1.96	0.129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	2.2	6.9	3.2	ND<1	ND<1	ND<1	1.96	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	ND<1	3.6	2.2	ND<1	ND<1	ND<1	1.63	1.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	1.2	5.0	2.3	ND<1	ND<1	ND<1	3.34	0.542	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	28-Apr-04	1.3	8.8	4.4	ND<1	ND<1	ND<1	3.07	1.32	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	
	5-May-04	0.9	6.9	3.6	ND<1	ND<1	ND<1	2.07	1.96	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1	
	30-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.619	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	2.4	6.1	2.6	ND<1	ND<1	ND<1	2.07	1.79	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-4	23-Apr-03	110	3.1	ND<1	ND<1	ND<1	ND<1	3.18	0.136	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	170	5.4	1.0	ND<1	ND<1	3.4	2.38	0.023	ND<1	ND<1	ND<1	ND<1	3.3	ND<1	ND<1	ND<1	
	11-Jun-03	170	4.8	ND<1	ND<1	ND<1	ND<1	1.03	0.572	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	200	5.9	1.3	ND<1	ND<1	ND<1	2.67	0.292	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	210	5.7	1.1	ND<1	ND<1	ND<1	3.21	0.529	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	390	8.2	1.0	ND<1	ND<1	ND<1	2.95	0.922	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	380	6.8	1.6	ND<1	ND<1	ND<1	6.93	0.221	ND<1	1.2	0.9	0.8	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	270	7.9	ND<1	ND<1	ND<1	ND<1	5.45	0.0331	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	270	5.9	ND<1	ND<1	ND<1	ND<1	3.56	0.48	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	170	6.9	14.0	ND<1	ND<1	ND<1	3.28	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	170	5.8	4.5	ND<1	ND<1	ND<1	1.61	0.0691	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.982	0.173	ND<1	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1	
	5-May-04	470	6.2	7.8	ND<1	ND<1	ND<1	7.08	2.33	ND<1	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1	
	30-Jun-04	110	3.8	26	ND<1	ND<1	ND<1	4.44	1.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	110	3.2	29	ND<1	ND<1	ND<1	1.4	5.00	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	

TABLE 4

**GROUND-WATER REMEDIAL ACTION  
ROWE INDUSTRIES SUPERFUND SITE  
SAG HARBOR, NEW YORK**

**RECOVERY WELL WATER QUALITY RESULTS**

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropyl-benzene (ug/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
		5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-5	23-Apr-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	ND<1	ND<1	ND<1	0.8	6.7	0.146	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1
	11-Jun-03	21	ND<1	ND<1	ND<1	ND<1	6.2	0.76	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	11	ND<1	ND<1	ND<1	1.1	9.7	6.47	0.068	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	15	ND<1	ND<1	ND<1	0.9	7.3	0.269	0.021	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	18	ND<1	ND<1	ND<1	ND<1	8.1	0.043	0.016	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	13.1	0.0097	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	ND<1	ND<1	ND<1	ND<1	7.5	0.0523	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	14	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	14	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	18	ND<1	1.5	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	38	0.8	3.2	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	ND<1	ND<1	6.4*	ND<1	ND<1
	14-Jun-04	17	ND<1	4.6	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	21	ND<1	4.6	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.3	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	1.8	1.4	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	23-Apr-03	79	1.0	ND<1	ND<1	ND<1	ND<1	0.028	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	120	1.8	ND<1	ND<1	0.6	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	3.5	ND<1	ND<1
	11-Jun-03	120	0.7	ND<1	ND<1	ND<1	ND<1	0.0097	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	0.6	ND<1	ND<1	ND<1	ND<1	0.186	0.034	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	140	2.2	ND<1	ND<1	ND<1	ND<1	0.089	0.018	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	140	2.6	ND<1	ND<1	ND<1	ND<1	0.023	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	180	3.3	1.0	ND<1	ND<1	ND<1	0.342	0.0083	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	120	2.6	ND<1	ND<1	ND<1	ND<1	0.017	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	1.8*	ND<1	ND<1
	5-May-04	210	4.8	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.9*	ND<1	ND<1
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.9	2.0	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION  
ROWE INDUSTRIES SUPERFUND SITE  
SAG HARBOR, NEW YORK**

**RECOVERY WELL WATER QUALITY RESULTS**

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropyl-benzene (ug/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)	
		5	5	5	7	NE	300	300	NE	5	5	5	5	5	NE	NE	NE	
RW-7	23-Apr-03	100	1.8	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	140	3.1	1.0	ND<1	ND<1	ND<1	0.032	ND<0.02	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1	ND<1	
	11-Jun-03	140	2.0	ND<1	ND<1	ND<1	ND<1	0.0246	0.0086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	150	2.1	ND<1	ND<1	ND<1	ND<1	0.024	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	120	2.3	ND<1	ND<1	ND<1	ND<1	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	130	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	140	3.4	1.1	ND<1	ND<1	ND<1	0.0464	ND<0.02	ND<1	ND<1	0.2	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	110	2.8	ND<1	ND<1	ND<1	ND<1	0.0239	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	ND<1	0.0069	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	120	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1	
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1	
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	ND<1	ND<1	
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-8	23-Apr-03	41	2.0	1.8	ND<1	ND<1	ND<1	11.8	0.352	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	61	3.9	3.8	ND<1	ND<1	ND<1	10.1	0.068	ND<1	1.8	ND<1	ND<1	3.4	ND<1	ND<1	ND<1	
	11-Jun-03	57	3.1	2.7	ND<1	ND<1	ND<1	9.14	1.10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	35	1.9	3.2	ND<1	ND<1	ND<1	10.5	0.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	30	1.7	3.6	ND<1	ND<1	ND<1	11.1	1.18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	28	2.5	4.4	ND<1	ND<1	ND<1	9.93	0.40	ND<1	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	27	2.3	5.4	ND<1	ND<1	ND<1	13.3	0.21	ND<1	4.1	0.7	1.3	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	17	2.1	2.6	ND<1	ND<1	ND<1	9.16	0.05	ND<1	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	ND<1	3.5	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	ND<1	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	ND<1	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1	
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	ND<1	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1	
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	ND<1	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.1	ND<1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	ND<1	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	ND<1	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	

TABLE 4

GROUND-WATER REMEDIAL ACTION  
ROWE INDUSTRIES SUPERFUND SITE  
SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	Isopropyl-benzene	1,1-Dichloro-ethane	cis-1,2-Dichloro-ethene	1,1-Dichloro-ethene	Methylene Chloride	Bromoform	Dibromochloromethane	Naphthalene
		(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(mg/L)	(mg/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)
ARAR's		5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-9	23-Apr-03	15	1.2	1.8	ND<1	ND<1	ND<1	3.55	1.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	1.8	3.6	ND<1	ND<1	ND<1	2.95	0.046	ND<1	1.9	ND<1	ND<1	3.2	ND<1	ND<1	ND<1
	11-Jun-03	18	1.6	4.8	ND<1	ND<1	ND<1	2.75	1.74	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	4.7	1.6	7.3	ND<1	ND<1	ND<1	3.60	0.467	ND<1	3.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	25	1.2	3.5	ND<1	ND<1	ND<1	4.05	2.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	22	2.1	5.8	ND<1	ND<1	ND<1	3.49	2.88	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.2	8.2	ND<1	ND<1	ND<1	5.39	1.72	ND<1	5.2	ND<1	1.4	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	1.7	5.4	ND<1	ND<1	ND<1	1.94	1.57	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.3	2.2	13	ND<1	ND<1	ND<1	0.638	0.029	ND<1	1.8	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	ND<1	3.7	ND<1	1.3	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	ND<1	5.9	ND<1	2.0	2.0*	ND<1	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	ND<1	6.7	ND<1	1.7	7.1*	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	ND<1	1.9	ND<1	ND<1	1.6	ND<1	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

ND: Not detected

PCE: Tetrachloroethylene

1,1-DCE: 1,1-Dichloroethene

\*Methylene Chloride detected in laboratory method blank

&lt;#: Less than method detection limit

TCE: Trichloroethene

1,2-DCE: 1,2-Dichloroethene

NE: ARAR goal was not established for this compound by the EPA.

ug/L: Micrograms per liter

TCA: 1,1,1-Trichloroethane

MTBE: Methyl Tertiary Butyl Ether

\*\* The July 14, 2004 sample collected for RW-8 only represents water in the pipe since the RW-8 pump was not operating at this time.

-: Not analyzed

1,1-DCA: 1,1-Dichloroethane

NM: Not Measured

\*\*\* The August 26, 2004 samples were lost during shipment.


ARAR's are chemical specific aquifer restoration goals for ground-water at the Former Rowe Industries Superfund Site.

Bold values indicate an exceedance of the ARAR standard established for the site.

## **GRAPHS**


**GRAPH 1**  
GROUND-WATER REMEDIAL ACTION  
ROWE INDUSTRIES SUPERFUND SITE  
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA  
(April 1, 2005 through April 30, 2005)




**GRAPH 2**  
**GROUND-WATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**

**RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER**



**GRAPH 3**  
**GROUND-WATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**

**RECOVERY WELL PCE CONCENTRATION FOR SELECT RECOVERY WELLS**



**APPENDIX I**  
**APRIL 2005 LABORATORY ANALYTICAL REPORTS**

Friday, April 22, 2005

Mark Goldberg  
Leggette Brashears & Graham Inc.  
126 Monroe Turnpike  
Trumball, CT 06611

TEL: (203) 452-3110  
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0504098

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/12/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735 • (631) 454-6100 • FAX: (631) 454-8027


**American Analytical Laboratories, LLC.**

**Date: 22-Apr-05**

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** Rowe Industries  
**Lab Order:** 0504098

**Work Order Sample Summary**

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Tag Number</b>	<b>Collection Date</b>	<b>Date Received</b>
0504098-01A	WQ040705:1430 NP2-6	4625	4/7/2005	4/12/2005
0504098-01B	WQ040705:1430 NP2-6	4625	4/7/2005	4/12/2005
0504098-01C	WQ040705:1430 NP2-6	4625	4/7/2005	4/12/2005
0504098-02A	WQ040705:1435 NP2-7	4625	4/7/2005	4/12/2005
0504098-02B	WQ040705:1435 NP2-7	4625	4/7/2005	4/12/2005
0504098-02C	WQ040705:1435 NP2-7	4625	4/7/2005	4/12/2005
0504098-03A	WQ040705:1440 NP2-10	4625	4/7/2005	4/12/2005
0504098-03B	WQ040705:1440 NP2-10	4625	4/7/2005	4/12/2005
0504098-03C	WQ040705:1440 NP2-10	4625	4/7/2005	4/12/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735  
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 4625

1418  
1SDOH  
CTDOH  
NJDEP  
NY050  
PADEP  
PH-0205  
68-573

## CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>LBG</i> 126 Monroe Turnpike Trumbull, CT 06611		CONTACT: <i>Mark Goldberg</i>		SAMPLER (SIGNATURE) <i>Steve Silvestri (MNG)</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
PROJECT LOCATION: <i>Rowe</i>				SAMPLER NAME (PRINT) <i>Steve Silvestri</i>	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED S260 ✓ MTBE ✓ From 13 ✓ Total Diss Fe ✓ TDS ✓
0504098- G24	✓	4	4/7/05	04040705; 1430 MP26	✓ ✓ ✓ ✓
0504098- G24	✓	4		↓ ; 1435 MP2-7	✓ ✓ ✓ ✓
0504098- G38	✓	5	↓	↓ ; 1440 MP2-10	✓ ✓ ✓ ✓ ✓
FOR METHANOL PRESERVED SAMPLES [ VOLATILE VIAL # ]					

					COOLER TEMPERATURE:
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON			TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY / /		COMMENTS / INSTRUCTIONS
RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>	DATE <u>4/11/05</u> TIME <u>16:00</u>	PRINTED NAME <i>Mark M. Goldberg</i>	RECEIVED BY LAB (SIGNATURE) 	DATE <u>04-11-05</u> TIME <u>16:18</u>	PRINTED NAME <i>J. CRAIG</i>
RELINQUISHED BY (SIGNATURE)	DATE	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

**AMERICAN ANALYTICAL LABORATORIES, LLC**  
**56 TOLEDO STREET**  
**FARMINGDALE, NEW YORK 11735**  
**TELEPHONE: (631) 454-6100 FAX: (631) 454-8027**

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1430 NP2-6
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-01A	<b>Date Received:</b>	4/12/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
				<b>SW8260B</b>		<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
2-Butanone	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
2-Hexanone	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Acetone	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Benzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Bromobenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Bromoform	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Bromomethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Chloroethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date: 22-Apr-05**

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1430 NP2-6
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-01A	<b>Date Received:</b>	4/12/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
Chloroform	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Chloromethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Dibromomethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/21/2005 1:19:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Methylene chloride	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Naphthalene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
o-Xylene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Styrene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Tetrachloroethene	14	1.0		µg/L	1	4/21/2005 1:19:00 PM
Toluene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Trichloroethene	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/21/2005 1:19:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/21/2005 1:19:00 PM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1430 NP2-6
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-01B	<b>Date Received:</b>	4/12/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

<b>TOTAL IRON</b> Iron	10.8	E200.7 0.0200		(SW3010A) mg/L	1	<b>Analyst:</b> JP 4/13/2005 12:00:28 PM
---------------------------	------	------------------	--	-------------------	---	---

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1430 NP2-6
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-01C	<b>Date Received:</b>	4/12/2005
<b>Analyses</b>		<b>Matrix:</b>	LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

DISSOLVED IRON Iron	0.101	E200.7 0.0200		(SW3005A) mg/L	1	Analyst: JP 4/13/2005 11:58:29 AM
------------------------	-------	------------------	--	-------------------	---	--------------------------------------

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1435 NP2-7
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-02A	<b>Date Received:</b>	4/12/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>				<b>SW8260B</b>		<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
2-Butanone	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
2-Hexanone	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Acetone	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Benzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Bromobenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Bromoform	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Bromomethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Chloroethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ040705:1435 NP2-7
Lab Order:	0504098	Tag Number:	4625
Project:	Rowe Industries	Collection Date:	4/7/2005
Lab ID:	0504098-02A	Date Received:	4/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Chloromethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Dibromomethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/21/2005 1:52:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Methylene chloride	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Naphthalene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
o-Xylene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Styrene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Toluene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Trichloroethene	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/21/2005 1:52:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/21/2005 1:52:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1435 NP2-7			
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625			
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005			
<b>Lab ID:</b>	0504098-02B	<b>Date Received:</b>	4/12/2005			
<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>TOTAL IRON</b> Iron	17.5	E200.7 0.0200		(SW3010A) mg/L	1	Analyst: JP 4/13/2005 12:05:06 PM

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1435 NP2-7
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-02C	<b>Date Received:</b>	4/12/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>DISSOLVED IRON</b> Iron	0.228	E200.7 0.0200		(SW3005A) mg/L	1	Analyst: JP 4/13/2005 12:03:10 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1440 NP2-10
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-03A	<b>Date Received:</b>	4/12/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
	<b>SW8260B</b>					<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
2-Butanone	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
2-Hexanone	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Acetone	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Benzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Bromobenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Bromoform	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Bromomethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Chloroethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1440 NP2-10
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-03A	<b>Date Received:</b>	4/12/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Chloromethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Dibromomethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/21/2005 2:24:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Methylene chloride	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Naphthalene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
o-Xylene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Styrene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Toluene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Trichloroethene	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/21/2005 2:24:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/21/2005 2:24:00 PM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1440 NP2-10		
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625		
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005		
<b>Lab ID:</b>	0504098-03B	<b>Date Received:</b>	4/12/2005		
<b>Matrix:</b> LIQUID					
Analyses	Result	Limit	Qual Units	DF	Date Analyzed
TOTAL IRON Iron	8.55	E200.7 0.0200	(SW3010A) mg/L	1	Analyst: JP 4/13/2005 12:09:21 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ040705:1440 NP2-10
<b>Lab Order:</b>	0504098	<b>Tag Number:</b>	4625
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/7/2005
<b>Lab ID:</b>	0504098-03C	<b>Date Received:</b>	4/12/2005
		<b>Matrix:</b>	LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
DISSOLVED IRON Iron	0.277	E200.7 0.0200		(SW3005A) mg/L	1	Analyst: JP 4/13/2005 12:07:09 PM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	110	E160.1 1.0		mg/L	1	Analyst: AT 4/14/2005

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Friday, April 22, 2005

Mark Goldberg  
Leggette Brashears & Graham Inc.  
126 Monroe Turnpike  
Trumball, CT 06611  
TEL: (203) 452-3110  
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0504132

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/15/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,



Lori Beyer  
Lab Director



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735 • (631) 454-6100 • FAX: (631) 454-8027

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** Rowe Industries  
**Lab Order:** 0504132

**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0504132-01A	WQ041305:1445 NP2-6	4627	4/13/2005	4/15/2005
0504132-01B	WQ041305:1445 NP2-6	4627	4/13/2005	4/15/2005
0504132-01C	WQ041305:1445 NP2-6	4627	4/13/2005	4/15/2005
0504132-02A	WQ041305:1447 NP2-7	4627	4/13/2005	4/15/2005
0504132-02B	WQ041305:1447 NP2-7	4627	4/13/2005	4/15/2005
0504132-02C	WQ041305:1447 NP2-7	4627	4/13/2005	4/15/2005
0504132-03A	WQ041305:1449 NP2-10	4627	4/13/2005	4/15/2005
0504132-03B	WQ041305:1449 NP2-10	4627	4/13/2005	4/15/2005
0504132-03C	WQ041305:1449 NP2-10	4627	4/13/2005	4/15/2005
0504132-03D	WQ041305:1449 NP2-10	4627	4/13/2005	4/15/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735  
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 4627

NYSDOH  
CTDOH  
NJDEP  
NY050  
PADEP  
11418  
PH-0205  
68-573

## CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS

LBG  
126 Monroe Turnpike  
Trumbull, CT 06611

CONTACT:

Mark Goldberg

SAMPLER (SIGNATURE)

Steve Silvestri (MMS)

SAMPLE(S)  
SEALED

YES  NO

SAMPLER NAME (PRINT)

Steve Silvestri

CORRECT  
CONTAINER(S)

YES  NO

PROJECT LOCATION:

Ronc

ANALYSIS  
REQUIRED

6260

MTBE

Frozen 13

Total + VSS E4

TDS

FOR  
METHANOL PRESERVED  
SAMPLES  
(VOLATILE VIAL #)

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION
0504132- 01A 01B 01C	L	4	4/13/05	WQ041305:1445 MP2-6
0504132- 02A 02B	L	4		:1447 MP2-7
0504132- 03A 03B 03C 03D	↓	5	↓	:1449 MP2-10

COOLER TEMPERATURE:					
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL		TURNAROUND REQUIRED:		COMMENTS / INSTRUCTIONS	
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON		NORMAL <input checked="" type="checkbox"/>	STAT <input type="checkbox"/>	BY / /	
RELINQUISHED BY (SIGNATURE)	DATE <u>4/14/05</u> TIME <u>16:00</u>	PRINTED NAME <u>Mark M. Goldberg</u>	RECEIVED BY LAB (SIGNATURE) <u>Jon Bex</u>	DATE <u>4/15/05</u> TIME <u>10:30</u>	
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

**AMERICAN ANALYTICAL LABORATORIES, LLC**

**56 TOLEDO STREET**

**FARMINGDALE, NEW YORK 11735**

**TELEPHONE: (631) 454-6100 FAX: (631) 454-8027**

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1445 NP2-6
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-01A	<b>Date Received:</b>	4/15/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
	<b>SW8260B</b>					<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,1,1-Trichloroethane	3.2	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
2-Butanone	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
2-Hexanone	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Acetone	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Benzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Bromobenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Bromoform	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Bromomethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Chloroethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analytic detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1445 NP2-6
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-01A	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Chloromethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Dibromomethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/18/2005 8:16:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Methylene chloride	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Naphthalene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
o-Xylene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Styrene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Tetrachloroethene	32	1.0		µg/L	1	4/18/2005 8:16:00 PM
Toluene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Trichloroethene	1.6	1.0		µg/L	1	4/18/2005 8:16:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/18/2005 8:16:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/18/2005 8:16:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

---

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1445 NP2-6
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-01B	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

---

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
TOTAL IRON Iron	1.67	E200.7 0.0200		(SW3010A) mg/L	1	Analyst: JP 4/21/2005 9:53:16 AM

---

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 3 of 13

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1445 NP2-6
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-01C	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>DISSOLVED IRON</b>		<b>E200.7</b>				<b>Analyst: JP</b>
Iron	0.0361	0.0200		mg/L	1	4/21/2005 9:50:33 AM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1447 NP2-7
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-02A	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
SW8260B						Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
2-Butanone	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
2-Hexanone	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Acetone	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Benzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Bromobenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Bromochlormethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Bromodichlormethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Bromoform	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Bromomethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Chloroethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1447 NP2-7
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-02A	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Chloromethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Dibromomethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/18/2005 8:49:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Methylene chloride	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Naphthalene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
o-Xylene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Styrene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Toluene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Trichloroethene	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/18/2005 8:49:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/18/2005 8:49:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1447 NP2-7		
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627		
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005		
<b>Lab ID:</b>	0504132-02B	<b>Date Received:</b>	4/15/2005		
<b>Matrix:</b> LIQUID					
Analyses	Result	Limit	Qual Units	DF	Date Analyzed
TOTAL IRON Iron	2.52	E200.7 0.0200	(SW3010A) mg/L	1	Analyst: JP 4/21/2005 9:58:49 AM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1447 NP2-7
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-02C	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
DISSOLVED IRON Iron	0.0662	0.0200	E200.7	mg/L	1	Analyst: JP 4/21/2005 9:56:30 AM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1449 NP2-10
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-03A	<b>Date Received:</b>	4/15/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
				<b>SW8260B</b>		<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
2-Butanone	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
2-Hexanone	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Acetone	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Benzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Bromobenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Bromoform	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Bromomethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Chloroethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
 E Value above quantitation range  
 J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit  
 U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1449 NP2-10
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-03A	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Chloromethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Dibromomethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/18/2005 9:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Methylene chloride	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Naphthalene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
o-Xylene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Styrene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Toluene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Trichloroethene	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/18/2005 9:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/18/2005 9:21:00 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1449 NP2-10
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-03B	<b>Date Received:</b>	4/15/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON</b> Iron	2.04	E200.7 0.0200		(SW3010A) mg/L	1	Analyst: JP 4/21/2005 10:05:27 AM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 22-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1449 NP2-10
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-03C	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>DISSOLVED IRON</b>		<b>E200.7</b>				<b>Analyst: JP</b>
Iron	0.0799	0.0200		mg/L	1	4/21/2005 10:02:30 AM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 22-Apr-05

---

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041305:1449 NP2-10
<b>Lab Order:</b>	0504132	<b>Tag Number:</b>	4627
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/13/2005
<b>Lab ID:</b>	0504132-03D	<b>Date Received:</b>	4/15/2005
			<b>Matrix:</b> LIQUID

---

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

---

<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				<b>Analyst:</b> AT
Total Dissolved Solids (Residue, Filterable)	110	1.0		mg/L	1	4/19/2005

---

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 13 of 13



NYSDOH 11418  
NJDEP NY050  
CTDOH PH-0205  
PADEP 68-00573

Friday, April 29, 2005

Mark Goldberg  
Leggette Brashears & Graham Inc.  
126 Monroe Turnpike  
Trumball, CT 06611  
TEL: (203) 452-3110  
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0504224

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/26/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** Rowe Industries  
**Lab Order:** 0504224

**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0504224-01A	WQ041905:0930 NP2-6	3216	4/19/2005	4/26/2005
0504224-01B	WQ041905:0930 NP2-6	3216	4/19/2005	4/26/2005
0504224-01C	WQ041905:0930 NP2-6	3216	4/19/2005	4/26/2005
0504224-02A	WQ041905:0932 NP2-7	3216	4/19/2005	4/26/2005
0504224-02B	WQ041905:0932 NP2-7	3216	4/19/2005	4/26/2005
0504224-02C	WQ041905:0932 NP2-7	3216	4/19/2005	4/26/2005
0504224-03A	WQ041905:0935 NP2-10	3216	4/19/2005	4/26/2005
0504224-03B	WQ041905:0935 NP2-10	3216	4/19/2005	4/26/2005
0504224-03C	WQ041905:0935 NP2-10	3216	4/19/2005	4/26/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735  
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 3216

NYSDOH 11418  
CTDOH PH-0205  
NJDEP NY050  
PADEP 68-573

## CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>LBG 126 Monroe Turnpike Trumbull, CT 06611</i>		CONTACT: <i>Mark Goldberg</i>	SAMPLER (SIGNATURE) <i>Mark M. Goldberg</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO							
			SAMPLER NAME (PRINT) <i>Mark M. Goldberg</i>	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO							
PROJECT LOCATION: <i>Ronse</i>			ANALYSIS REQUIRED <i>SOIL MBF Filter 13 Total 105 Fe TDS</i>	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)							
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION							
0504224-1ABC	L	4	4/19/05	WQ041905:930 NP2-6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
2ABC	L	4		WQ041905:932 NP2-7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
3ABC	L	5		WQ041905:935 NP2-10	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
Labels on bottles have "WQ042005...", Samples were collected on 4/19/05											
						COOLER TEMPERATURE:					
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON						TURNAROUND REQUIRED:			COMMENTS / INSTRUCTIONS		
RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>		DATE <u>4/25/05</u> TIME <u>16:00</u>	PRINTED NAME <i>Mark M. Goldberg</i>	RECEIVED BY LAB (SIGNATURE) <i>VAT</i>	DATE <u>4/26/05</u> TIME <u>13:30</u>	PRINTED NAME <i>R. Antonio</i>					
RELINQUISHED BY (SIGNATURE)		DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME					

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

**AMERICAN ANALYTICAL LABORATORIES, LLC**

**56 TOLEDO STREET**

**FARMINGDALE, NEW YORK 11735**

**TELEPHONE: (631) 454-6100 FAX: (631) 454-8027**

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0930 NP2-6
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-01A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,1,1-Trichloroethane	2.7	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
2-Butanone	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
2-Hexanone	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Acetone	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Benzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Bromobenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Bromoform	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Bromomethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Chloroethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0930 NP2-6
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-01A	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 7:39:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Tetrachloroethene	14	1.0		µg/L	1	4/27/2005 7:39:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Trichloroethene	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 7:39:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 7:39:00 PM

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0930 NP2-6
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-01B	<b>Date Received:</b>	4/26/2005
<b>Matrix:</b> LIQUID			

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON</b> Iron	2.71	E200.7 0.0200		(SW3010A) mg/L	1	Analyst: JP 4/28/2005 2:10:38 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0930 NP2-6
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-01C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

<b>DISSOLVED IRON</b>		<b>E200.7</b>		<b>(SW3005A)</b>		<b>Analyst:</b> JP
Iron	0.0861	0.0200		mg/L	1	4/28/2005 2:07:52 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0932 NP2-7
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-02A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>		<b>SW8260B</b>				<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
2-Butanone	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
2-Hexanone	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Acetone	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Benzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Bromobenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Bromoform	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Bromomethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Chloroethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
 E Value above quantitation range  
 J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit  
 U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.		Client Sample ID: WQ041905:0932 NP2-7			
Lab Order:	0504224		Tag Number: 3216			
Project:	Rowe Industries		Collection Date: 4/19/2005			
Lab ID:	0504224-02A	Date Received:	4/26/2005	Matrix: LIQUID		
Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 8:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Trichloroethene	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 8:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 8:12:00 PM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0932 NP2-7
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-02B	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

<b>TOTAL IRON</b>		E200.7		(SW3010A)		Analyst: JP
Iron	4.60	0.0200		mg/L	1	4/28/2005 2:15:13 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0932 NP2-7
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-02C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

DISSOLVED IRON Iron	0.0834	E200.7 0.0200		(SW3005A) mg/L	1	Analyst: JP 4/28/2005 2:13:07 PM
------------------------	--------	------------------	--	-------------------	---	-------------------------------------

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b> WQ041905:0935 NP2-10				
<b>Lab Order:</b>	0504224	<b>Tag Number:</b> 3216				
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b> 4/19/2005				
<b>Lab ID:</b>	0504224-03A	<b>Date Received:</b>	4/26/2005	<b>Matrix:</b>	LIQUID	
Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
	SW8260B					<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,1,1-Trichloroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,1,2,2-Tetrachloroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,1,2-Trichloroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,1-Dichloroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,1-Dichloroethene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,1-Dichloropropene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2,3-Trichlorobenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2,3-Trichloropropane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2,4-Trichlorobenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2,4-Trimethylbenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2-Dibromo-3-chloropropane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2-Dibromoethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2-Dichlorobenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2-Dichloroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,2-Dichloropropane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,3,5-Trimethylbenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,3-Dichlorobenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,3-dichloropropane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
1,4-Dichlorobenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
2,2-Dichloropropane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
2-Butanone	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
2-Chloroethyl vinyl ether	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
2-Chlorotoluene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
2-Hexanone	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
4-Chlorotoluene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
4-Isopropyltoluene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
4-Methyl-2-pentanone	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Acetone	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Benzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Bromobenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Bromochloromethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Bromodichloromethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Bromoform	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Bromomethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Carbon disulfide	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Carbon tetrachloride	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Chlorobenzene	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	
Chloroethane	U	1.0	µg/L	1	4/27/2005 8:44:00 PM	

Qualifiers: \* Value exceeds Maximum Contaminant Level  
 E Value above quantitation range  
 J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit  
 U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0935 NP2-10
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-03A	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
Chloroform	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 8:44:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Trichloroethene	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 8:44:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 8:44:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

---

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0935 NP2-10
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-03B	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

---

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

---

<b>TOTAL IRON</b>		<b>E200.7</b>		<b>(SW3010A)</b>		<b>Analyst: JP</b>
Iron	1.07	0.0200		mg/L	1	4/28/2005 2:19:42 PM

---

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 11 of 12

**American Analytical Laboratories, LLC.****Date: 29-Apr-05**

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ041905:0935 NP2-10
<b>Lab Order:</b>	0504224	<b>Tag Number:</b>	3216
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504224-03C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>DISSOLVED IRON</b> Iron	0.0969	E200.7 0.0200		(SW3005A) mg/L	1	Analyst: JP 4/28/2005 2:17:35 PM
<b>TOTAL DISSOLVED SOLIDS</b> Total Dissolved Solids (Residue, Filterable)	92	E160.1 1.0		mg/L	1	Analyst: AT 4/26/2005

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected



NYSDOH 11418  
NJDEP NY050  
CTDOH PH-0205  
PADEP 68-00573

Friday, April 29, 2005

Mark Goldberg  
Leggette Brashears & Graham Inc.  
126 Monroe Turnpike  
Trumball, CT 06611

TEL: (203) 452-3110  
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0504225

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 4/26/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** Rowe Industries  
**Lab Order:** 0504225

**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0504225-01A	GWQ041905:1000 NP1-1-1	4628	4/19/2005	4/26/2005
0504225-01B	GWQ041905:1000 NP1-1-1	4628	4/19/2005	4/26/2005
0504225-01C	GWQ041905:1000 NP1-1-1	4628	4/19/2005	4/26/2005
0504225-01D	GWQ041905:1000 NP1-1-1	4628	4/19/2005	4/26/2005
0504225-02A	GWQ041905:1010 NP1-1-2	4628	4/19/2005	4/26/2005
0504225-02B	GWQ041905:1010 NP1-1-2	4628	4/19/2005	4/26/2005
0504225-02C	GWQ041905:1010 NP1-1-2	4628	4/19/2005	4/26/2005
0504225-02D	GWQ041905:1010 NP1-1-2	4628	4/19/2005	4/26/2005
0504225-03A	GWQ041905:1020 NP1-1-3	4628	4/19/2005	4/26/2005
0504225-03B	GWQ041905:1020 NP1-1-3	4628	4/19/2005	4/26/2005
0504225-03C	GWQ041905:1020 NP1-1-3	4628	4/19/2005	4/26/2005
0504225-03D	GWQ041905:1020 NP1-1-3	4628	4/19/2005	4/26/2005
0504225-04A	GWQ041905:1030 NP1-1-5	4628	4/19/2005	4/26/2005
0504225-04B	GWQ041905:1030 NP1-1-5	4628	4/19/2005	4/26/2005
0504225-04C	GWQ041905:1030 NP1-1-5	4628	4/19/2005	4/26/2005
0504225-04D	GWQ041905:1030 NP1-1-5	4628	4/19/2005	4/26/2005
0504225-05A	GWQ041905:1040 NP1-1-6	4628	4/19/2005	4/26/2005
0504225-05B	GWQ041905:1040 NP1-1-6	4628	4/19/2005	4/26/2005
0504225-05C	GWQ041905:1040 NP1-1-6	4628	4/19/2005	4/26/2005
0504225-05D	GWQ041905:1040 NP1-1-6	4628	4/19/2005	4/26/2005
0504225-06A	GWQ041905:1050 NP1-1-7	4628	4/19/2005	4/26/2005
0504225-06B	GWQ041905:1050 NP1-1-7	4628	4/19/2005	4/26/2005
0504225-06C	GWQ041905:1050 NP1-1-7	4628	4/19/2005	4/26/2005
0504225-06D	GWQ041905:1050 NP1-1-7	4628	4/19/2005	4/26/2005
0504225-07A	GWQ041905:1100 NP1-1-8	4628	4/19/2005	4/26/2005
0504225-07B	GWQ041905:1100 NP1-1-8	4628	4/19/2005	4/26/2005
0504225-07C	GWQ041905:1100 NP1-1-8	4628	4/19/2005	4/26/2005
0504225-07D	GWQ041905:1100 NP1-1-8	4628	4/19/2005	4/26/2005
0504225-08A	GWQ041905:1110 NP1-1-9	4628	4/19/2005	4/26/2005
0504225-08B	GWQ041905:1110 NP1-1-9	4628	4/19/2005	4/26/2005
0504225-08C	GWQ041905:1110 NP1-1-9	4628	4/19/2005	4/26/2005
0504225-08D	GWQ041905:1110 NP1-1-9	4628	4/19/2005	4/26/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735  
(631) 454-6100 • FAX (631) 454-8027

NW 5/2004

TAG # / COC 4628

NYSDOH 11418  
CTDOH PH-0205  
NJDEP NY050  
PADEP 68-573

## CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <b>LBG</b> 126 Monroe Turnpike Trumbull, CT 06611		CONTACT: <i>Mark Goldberg</i>	SAMPLER (SIGNATURE) <i>Mark M. Goldberg</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO														
PROJECT LOCATION: <i>Roxie</i>			SAMPLER NAME (PRINT) <i>Mark M. Goldberg</i>	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO														
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	SL60	MTBE	From 1/3	Total + 1/5	Fe	Total + 1/5	HA	Lunch 1/4	Hardness	TDS	FOR METHANOL PRESERVED SAMPLES [ VOLATILE VIAL # ]		
0504225-1ABCD	L	5	4/9/05	GWQ041905:1000 NPI-1-1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
	2ABCD			:1010 NPI-1-2														
	3ABCD			:1020 NPI-1-3														
	4ABCD			:1030 NPI-1-5														
	5ABCD			:1040 NPI-1-6														
	6ABCD			:1050 NPI-1-7														
	7ABCD			:1100 NPI-1-8														
	8ABCD			:1110 NPI-1-9	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			
Labels on bottles have "GWQ042005..". Samples were collected on 4/9/05										COOLER TEMPERATURE:								
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON					TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY / /					COMMENTS / INSTRUCTIONS								
RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>		DATE <u>4/25/05</u> TIME <u>16:00</u>	PRINTED NAME <u>Mark M. Goldberg</u>		RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>		DATE <u>4/26/05</u> TIME <u>1345</u>	PRINTED NAME <u>P. Antoniou</u>										
RELINQUISHED BY (SIGNATURE)		DATE TIME	PRINTED NAME		RECEIVED BY LAB (SIGNATURE)		DATE	PRINTED NAME										

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

**AMERICAN ANALYTICAL LABORATORIES, LLC**  
56 TOLEDO STREET  
FARMINGDALE, NEW YORK 11735  
TELEPHONE: (631) 454-6100      FAX: (631) 454-8027

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 29-Apr-05

**CLIENT:** Leggette Brashears & Graham Inc.      **Client Sample ID:** GWQ041905:1000 NP1-1-1  
**Lab Order:** 0504225      **Tag Number:** 4628  
**Project:** Rowe Industries      **Collection Date:** 4/19/2005  
**Lab ID:** 0504225-01A      **Date Received:** 4/26/2005      **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
				<b>SW8260B</b>		<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
2-Butanone	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
2-Hexanone	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Acetone	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Benzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Bromobenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Bromoform	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Bromomethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Chloroethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ041905:1000 NP1-1-1
Lab Order:	0504225	Tag Number:	4628
Project:	Rowe Industries	Collection Date:	4/19/2005
Lab ID:	0504225-01A	Date Received:	4/26/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	1.5	1.0		µg/L	1	4/27/2005 9:17:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
cls-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 9:17:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Trichloroethene	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 9:17:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 9:17:00 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ041905:1000 NP1-1-1
Lab Order:	0504225	Tag Number:	4628
Project:	Rowe Industries	Collection Date:	4/19/2005
Lab ID:	0504225-01B	Date Received:	4/26/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON,MANGANESE</b>						
Iron	0.0357	0.0200		mg/L	1	4/28/2005 2:38:56 PM
Manganese	0.107	0.0200		mg/L	1	4/28/2005 2:38:56 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1000 NP1-1-1
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-01C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON,MANGANESE</b>		E200.7		(SW3005A)		
Iron	0.0217	0.0200		mg/L	1	4/28/2005 2:36:54 PM
Manganese	0.105	0.0200		mg/L	1	4/28/2005 2:36:54 PM
<b>TURBIDITY</b>		E180.1				
Turbidity	U	1.00	H	NTU	1	4/29/2005
<b>TOTAL DISSOLVED SOLIDS</b>		E160.1				
Total Dissolved Solids (Residue, Filterable)	250	1.0		mg/L	1	4/26/2005

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1000 NP1-1-1
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-01D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>HARDNESS</b> Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	54.4	1.00	M2340 B	mg/L	1	Analyst: JP 4/28/2005

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1010 NP1-1-2
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-02A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
2-Butanone	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
2-Hexanone	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Acetone	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Benzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Bromobenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Bromoform	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Bromomethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Chloroethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1010 NP1-1-2
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-02A	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 9:49:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Tetrachloroethylene	9.0	1.0		µg/L	1	4/27/2005 9:49:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Trichloroethene	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 9:49:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 9:49:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1010 NP1-1-2
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-02B	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON,MANGANESE</b>		E200.7		(SW3010A)		<b>Analyst:</b> JP
Iron	4.51	0.0200		mg/L	1	4/28/2005 2:44:18 PM
Manganese	0.997	0.0200		mg/L	1	4/28/2005 2:44:18 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ041905:1010 NP1-1-2
Lab Order:	0504225	Tag Number:	4628
Project:	Rowe Industries	Collection Date:	4/19/2005
Lab ID:	0504225-02C	Date Received:	4/26/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.128	0.0200		mg/L	1	4/28/2005 2:41:08 PM
Manganese	1.00	0.0200		mg/L	1	4/28/2005 2:41:08 PM
TURBIDITY		E180.1				Analyst: KK
Turbidity	8.50	1.00	H	NTU	1	4/29/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	4/26/2005

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1010 NP1-1-2
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-02D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>HARDNESS</b> Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	53.5	1.00		mg/L	1	Analyst: JP 4/28/2005

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 10 of 40

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

**CLIENT:** Leggette Brashears & Graham Inc.      **Client Sample ID:** GWQ041905:1020 NP1-1-3  
**Lab Order:** 0504225      **Tag Number:** 4628  
**Project:** Rowe Industries      **Collection Date:** 4/19/2005  
**Lab ID:** 0504225-03A      **Date Received:** 4/26/2005      **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
SW8260B						Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
2-Butanone	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
2-Hexanone	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Acetone	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Benzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Bromobenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Bromoform	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Bromomethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Chloroethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

# American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1020 NP1-1-3
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-03A	<b>Date Received:</b>	4/26/2005

**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 10:22:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Trichloroethene	2.0	1.0		µg/L	1	4/27/2005 10:22:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 10:22:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 10:22:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

Page 12 of 40

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

---

**CLIENT:** Leggette Brashears & Graham Inc.      **Client Sample ID:** GWQ041905:1020 NP1-1-3  
**Lab Order:** 0504225      **Tag Number:** 4628  
**Project:** Rowe Industries      **Collection Date:** 4/19/2005  
**Lab ID:** 0504225-03B      **Date Received:** 4/26/2005      **Matrix:** LIQUID

---

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
-----------------	---------------	--------------	-------------	--------------	-----------	----------------------

---

<b>TOTAL IRON,MANGANESE</b>		<b>E200.7</b>	<b>(SW3010A)</b>		<b>Analyst: JP</b>	
Iron	46.1	0.0200	mg/L	1	4/28/2005 2:50:49 PM	
Manganese	0.161	0.0200	mg/L	1	4/28/2005 2:50:49 PM	

---

<b>Qualifiers:</b>	<b>*</b> Value exceeds Maximum Contaminant Level	<b>B</b> Analyte detected in the associated Method Blank
	<b>E</b> Value above quantitation range	<b>H</b> Holding times for preparation or analysis exceeded
	<b>J</b> Analyte detected below quantitation limits	<b>ND</b> Not Detected at the Reporting Limit
	<b>S</b> Spike Recovery outside accepted recovery limits	<b>U</b> Indicates the compound was analyzed for but not detected

Page 13 of 40

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1020 NP1-1-3
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-03C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON,MANGANESE</b>		<b>E200.7</b>		(SW3005A)		<b>Analyst: JP</b>
Iron	0.539	0.0200		mg/L	1	4/28/2005 2:46:56 PM
Manganese	0.0916	0.0200		mg/L	1	4/28/2005 2:46:56 PM
<b>TURBIDITY</b>		<b>E180.1</b>				<b>Analyst: KK</b>
Turbidity	2.20	1.00	H	NTU	1	4/29/2005
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				<b>Analyst: AT</b>
Total Dissolved Solids (Residue, Filterable)	89	1.0		mg/L	1	4/26/2005

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

---

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1020 NP1-1-3
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-03D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

---

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
----------	--------	-------	------	-------	----	---------------

---

<b>HARDNESS</b>		<b>M2340 B</b>				<b>Analyst:</b> JP
Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	39.3	1.00		mg/L	1	4/28/2005

---

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
E	Value above quantitation range	H Holding times for preparation or analysis exceeded
J	Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
S	Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 15 of 40

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1030 NP1-1-5
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-04A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,1,1-Trichloroethane	4.1	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
2-Butanone	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
2-Hexanone	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Acetone	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Benzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Bromobenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Bromoform	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Bromomethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Chloroethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date: 29-Apr-05**

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1030 NP1-1-5
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-04A	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 10:54:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Tetrachloroethene	9.0	1.0		µg/L	1	4/27/2005 10:54:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Trichloroethene	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 10:54:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 10:54:00 PM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1030 NP1-1-5
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-04B	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON,MANGANESE</b>						
Iron	0.0887	0.0200		mg/L	1	4/28/2005 2:56:36 PM
Manganese	0.00810	0.0200	J	mg/L	1	4/28/2005 2:56:36 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1030 NP1-1-5
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-04C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON,MANGANESE</b>		E200.7		(SW3005A)		
Iron	0.0187	0.0200	J	mg/L	1	4/28/2005 2:54:17 PM
Manganese	0.00787	0.0200	J	mg/L	1	4/28/2005 2:54:17 PM
<b>TURBIDITY</b>		E180.1				
Turbidity	U	1.00	H	NTU	1	4/29/2005
<b>TOTAL DISSOLVED SOLIDS</b>		E160.1				
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	4/26/2005

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date: 29-Apr-05**

---

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1030 NP1-1-5
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-04D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

---

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>HARDNESS</b> Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	30.9	1.00	M2340 B	mg/L	1	Analyst: JP 4/28/2005

---

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 20 of 40

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1040 NP1-1-6
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-05A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
	SW8260B					Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,1,1-Trichloroethane	7.0	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
2-Butanone	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
2-Hexanone	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Acetone	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Benzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Bromobenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Bromoform	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Bromomethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Chloroethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

**B** Analyte detected in the associated Method Blank  
**H** Holding times for preparation or analysis exceeded  
**ND** Not Detected at the Reporting Limit  
**U** Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.****Date:** 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1040 NP1-1-6
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-05A	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Chloromethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Dibromomethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/27/2005 11:27:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Methylene chloride	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Naphthalene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
o-Xylene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Styrene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Tetrachloroethene	74	1.0		µg/L	1	4/27/2005 11:27:00 PM
Toluene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Trichloroethene	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/27/2005 11:27:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/27/2005 11:27:00 PM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1040 NP1-1-6
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-05B	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON,MANGANESE</b>		E200.7		(SW3010A)		Analyst: JP
Iron	0.0509	0.0200		mg/L	1	4/28/2005 3:03:06 PM
Manganese	0.251	0.0200		mg/L	1	4/28/2005 3:03:06 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	.U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1040 NP1-1-6
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-05C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON,MANGANESE</b>		E200.7		(SW3005A)		<b>Analyst:</b> JP
Iron	U	0.0200		mg/L	1	4/28/2005 3:00:58 PM
Manganese	0.229	0.0200		mg/L	1	4/28/2005 3:00:58 PM
<b>TURBIDITY</b>		E180.1				<b>Analyst:</b> KK
Turbidity	U	1.00	H	NTU	1	4/29/2005
<b>TOTAL DISSOLVED SOLIDS</b>		E160.1				<b>Analyst:</b> AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	4/26/2005

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected
				Page 24 of 40

**American Analytical Laboratories, LLC.****Date: 29-Apr-05**

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1040 NP1-1-6
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-05D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>HARDNESS</b> Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	31.7	1.00		mg/L	1	Analyst: JP 4/28/2005

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1050 NP1-1-7
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-06A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
				<b>SW8260B</b>		<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,2-Dichloroethane	U	1.0	b	µg/L	1	4/28/2005 2:09:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
2-Butanone	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
2-Hexanone	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Acetone	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Benzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Bromobenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Bromoform	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Bromomethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Chloroethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analytic detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1050 NP1-1-7
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-06A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Chloromethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Dibromomethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/28/2005 2:09:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Methylene chloride	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Naphthalene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
o-Xylene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Styrene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Tetrachloroethene	22	1.0		µg/L	1	4/28/2005 2:09:00 AM
Toluene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Trichloroethene	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/28/2005 2:09:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/28/2005 2:09:00 AM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
 E Value above quantitation range  
 J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit  
 U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1050 NP1-1-7
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-06B	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON,MANGANESE</b>		E200.7		(SW3010A)		Analyst: JP
Iron	0.107	0.0200		mg/L	1	4/28/2005 3:27:54 PM
Manganese	0.0484	0.0200		mg/L	1	4/28/2005 3:27:54 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 28 of 40

**American Analytical Laboratories, LLC.****Date:** 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1050 NP1-1-7
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-06C	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON,MANGANESE</b>		<b>E200.7</b>		<b>(SW3005A)</b>		
Iron	0.0152	0.0200	J	mg/L	1	4/28/2005 3:24:40 PM
Manganese	0.0470	0.0200		mg/L	1	4/28/2005 3:24:40 PM
<b>TURBIDITY</b>		<b>E180.1</b>				<b>Analyst: KK</b>
Turbidity	U	1.00	H	NTU	1	4/29/2005
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				<b>Analyst: AT</b>
Total Dissolved Solids (Residue, Filterable)	78	1.0		mg/L	1	4/26/2005

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1050 NP1-1-7
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-06D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>HARDNESS</b> Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	27.0	1.00		mg/L	1	Analyst: JP 4/28/2005

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0504225  
**Project:** Rowe Industries  
**Lab ID:** 0504225-07A      **Date Received:** 4/26/2005      **Matrix:** LIQUID

**Client Sample ID:** GWQ041905:1100 NP1-1-8  
**Tag Number:** 4628  
**Collection Date:** 4/19/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
				<b>SW8260B</b>		<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,1,1-Trichloroethane	3.5	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
2-Butanone	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
2-Hexanone	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Acetone	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Benzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Bromobenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Bromoform	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Bromomethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Chloroethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1100 NP1-1-8
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-07A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Chloromethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Dibromomethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/28/2005 2:41:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Methylene chloride	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Naphthalene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
o-Xylene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Styrene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Tetrachloroethene	3.5	1.0		µg/L	1	4/28/2005 2:41:00 AM
Toluene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Trichloroethene	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/28/2005 2:41:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/28/2005 2:41:00 AM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- B Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

**B** Analyte detected in the associated Method Blank  
**H** Holding times for preparation or analysis exceeded  
**ND** Not Detected at the Reporting Limit  
**U** Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ041905:1100 NP1-1-8
Lab Order:	0504225	Tag Number:	4628
Project:	Rowe Industries	Collection Date:	4/19/2005
Lab ID:	0504225-07B	Date Received:	4/26/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	8.89	0.0200		mg/L	1	4/28/2005 3:32:48 PM
Manganese	0.678	0.0200		mg/L	1	4/28/2005 3:32:48 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1100 NP1-1-8
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-07C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON,MANGANESE</b>		E200.7		(SW3005A)		
Iron	0.321	0.0200		mg/L	1	4/28/2005 3:30:11 PM
Manganese	0.623	0.0200		mg/L	1	4/28/2005 3:30:11 PM
<b>TURBIDITY</b>		E180.1				
Turbidity	2.00	1.00	H	NTU	1	4/29/2005
<b>TOTAL DISSOLVED SOLIDS</b>		E160.1				
Total Dissolved Solids (Residue, Filterable)	83	1.0		mg/L	1	4/26/2005

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1100 NP1-1-8
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-07D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>
<b>HARDNESS</b> Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	23.7	1.00	M2340 B	mg/L	1	Analyst: JP 4/28/2005

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1110 NP1-1-9
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-08A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,1,1-Trichloroethane	4.5	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
2-Butanone	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
2-Chirotoluene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
2-Hexanone	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Acetone	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Benzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Bromobenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Bromoform	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Bromomethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Chloroethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1110 NP1-1-9
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-08A	<b>Date Received:</b>	4/26/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Chloromethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Dibromomethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Ethybenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/28/2005 3:13:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Methylene chloride	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Naphthalene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
o-Xylene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Styrene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Tetrachloroethene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Toluene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Trichloroethene	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/28/2005 3:13:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/28/2005 3:13:00 AM

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
E	Value above quantitation range	H Holding times for preparation or analysis exceeded
J	Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
S	Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1110 NP1-1-9
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-08B	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON,MANGANESE</b>		E200.7		(SW3010A)		<b>Analyst:</b> JP
Iron	1.59	0.0200		mg/L	1	4/28/2005 3:39:27 PM
Manganese	1.09	0.0200		mg/L	1	4/28/2005 3:39:27 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1110 NP1-1-9
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-08C	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON,MANGANESE</b>		E200.7		(SW3005A)		
Iron	0.0910	0.0200		mg/L	1	4/28/2005 3:36:59 PM
Manganese	1.05	0.0200		mg/L	1	4/28/2005 3:36:59 PM
<b>TURBIDITY</b>		E180.1				
Turbidity	U	1.00	H	NTU	1	4/29/2005
<b>TOTAL DISSOLVED SOLIDS</b>		E160.1				
Total Dissolved Solids (Residue, Filterable)	83	1.0		mg/L	1	4/26/2005

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 29-Apr-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ041905:1110 NP1-1-9
<b>Lab Order:</b>	0504225	<b>Tag Number:</b>	4628
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/19/2005
<b>Lab ID:</b>	0504225-08D	<b>Date Received:</b>	4/26/2005
			<b>Matrix:</b> LIQUID

<b>Analyses</b>	<b>Result</b>	<b>Limit</b>	<b>Qual</b>	<b>Units</b>	<b>DF</b>	<b>Date Analyzed</b>	<b>Analyst:</b>
<b>HARDNESS</b> Hardness, Calcium/Magnesium (As CaCO <sub>3</sub> )	24.7	1.00		M2340 B mg/L	1	4/28/2005	JP

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected



NYSDOH 11418  
NJDEP NY050  
CTDOH PH-0205  
PADEP 68-00573

Monday, May 09, 2005

Mark Goldberg  
Leggette Brashears & Graham Inc.  
126 Monroe Turnpike  
Trumball, CT 06611

TEL: (203) 452-3110  
FAX (203) 452-3111

RE: Rowe Industries  
Dear Mark Goldberg:

Order No.: 0504250

American Analytical Laboratories, LLC. received 3 sample(s) on 4/28/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director

**American Analytical Laboratories, LLC.**

**Date: 09-May-05**

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** Rowe Industries  
**Lab Order:** 0504250

**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0504250-01A	WQ042705:0930 NP2-6	4614	4/27/2005	4/28/2005
0504250-01B	WQ042705:0930 NP2-6	4614	4/27/2005	4/28/2005
0504250-01C	WQ042705:0930 NP2-6	4614	4/27/2005	4/28/2005
0504250-02A	WQ042705:0940 NP2-7	4614	4/27/2005	4/28/2005
0504250-02B	WQ042705:0940 NP2-7	4614	4/27/2005	4/28/2005
0504250-02C	WQ042705:0940 NP2-7	4614	4/27/2005	4/28/2005
0504250-03A	WQ042705:0950 NP2-10	4614	4/27/2005	4/28/2005
0504250-03B	WQ042705:0950 NP2-10	4614	4/27/2005	4/28/2005
0504250-03C	WQ042705:0950 NP2-10	4614	4/27/2005	4/28/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735  
(631) 454-6100 • FAX (631) 454-8027

NYSDOH

TAG # / COC 4614

NYSDOH 11418  
CTDOH PH-0205  
NJDEP NY050  
PADEP 68-573

## CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <b>LBC Inc.</b> <b>126 Monroe Tpk</b> <b>Trumbull, CT 06611</b>		CONTACT: <b>M. Goldberg</b> <b>203-452-3100</b>		SAMPLER (SIGNATURE) <i>Steve Silvestri</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES / NO	
PROJECT LOCATION: <b>B Rowe</b>				SAMPLER NAME (PRINT) <b>Steve Silvestri</b>	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES / NO	
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
					<i>C260</i> <i>C113</i> <i>C108</i>	
0504250- <i>C113</i>	L	4	4/27/05 9 <sup>30</sup>	WQ042705: <sup>930</sup> NPZ-6	XX X XX	
0504250- <i>C26</i>	↓	4	1 <sup>40</sup>	WQ042705: 940 NPZ-7	XX X XX	
0504250- <i>C26</i>	↓	5	9 <sup>50</sup>	WQ042705: 950 NPZ-10	X X X X XX	
						COOLER TEMPERATURE: <i>41.28/05</i>
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON				TURNAROUND REQUIRED: <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> STAT BY <i>1</i>	COMMENTS / INSTRUCTIONS	
RELINQUISHED BY (SIGNATURE) <i>Steve Silvestri</i>		DATE <i>4/27/05</i> TIME <i>1500</i>	PRINTED NAME <i>Steve Silvestri</i>	RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>	DATE <i>4/28/05</i> TIME <i>1100</i>	PRINTED NAME <i>P. Artonio</i>
RELINQUISHED BY (SIGNATURE)		DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

**AMERICAN ANALYTICAL LABORATORIES, LLC**

**56 TOLEDO STREET**

**FARMINGDALE, NEW YORK 11735**

**TELEPHONE: (631) 454-6100 FAX: (631) 454-8027**

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

**American Analytical Laboratories, LLC.**

Date: 09-May-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ042705:0930 NP2-6
<b>Lab Order:</b>	0504250	<b>Tag Number:</b>	4614
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/27/2005
<b>Lab ID:</b>	0504250-01A	<b>Date Received:</b>	4/28/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
SW8260B						<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
1,1,1-Trichloroethane		2.7		µg/L	1	4/30/2005 12:33:00 AM
1,1,2,2-Tetrachloroethane		U		µg/L	1	4/30/2005 12:33:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane		U		µg/L	1	4/30/2005 12:33:00 AM
1,1,2-Trichloroethane		U		µg/L	1	4/30/2005 12:33:00 AM
1,1-Dichloroethane		U		µg/L	1	4/30/2005 12:33:00 AM
1,1-Dichloroethene		U		µg/L	1	4/30/2005 12:33:00 AM
1,1-Dichloropropene		U		µg/L	1	4/30/2005 12:33:00 AM
1,2,3-Trichlorobenzene		U		µg/L	1	4/30/2005 12:33:00 AM
1,2,3-Trichloropropane		U		µg/L	1	4/30/2005 12:33:00 AM
1,2,4-Trichlorobenzene		U		µg/L	1	4/30/2005 12:33:00 AM
1,2,4-Trimethylbenzene		U		µg/L	1	4/30/2005 12:33:00 AM
1,2-Dibromo-3-chloropropane		U		µg/L	1	4/30/2005 12:33:00 AM
1,2-Dibromoethane		U		µg/L	1	4/30/2005 12:33:00 AM
1,2-Dichlorobenzene		U		µg/L	1	4/30/2005 12:33:00 AM
1,2-Dichloroethane		U		µg/L	1	4/30/2005 12:33:00 AM
1,2-Dichloropropane		U		µg/L	1	4/30/2005 12:33:00 AM
1,3,5-Trimethylbenzene		U		µg/L	1	4/30/2005 12:33:00 AM
1,3-Dichlorobenzene		U		µg/L	1	4/30/2005 12:33:00 AM
1,3-dichloropropane		U		µg/L	1	4/30/2005 12:33:00 AM
1,4-Dichlorobenzene		U		µg/L	1	4/30/2005 12:33:00 AM
2,2-Dichloropropane		U		µg/L	1	4/30/2005 12:33:00 AM
2-Butanone		U		µg/L	1	4/30/2005 12:33:00 AM
2-Chloroethyl vinyl ether		U		µg/L	1	4/30/2005 12:33:00 AM
2-Chlorotoluene		U		µg/L	1	4/30/2005 12:33:00 AM
2-Hexanone		U		µg/L	1	4/30/2005 12:33:00 AM
4-Chlorotoluene		U		µg/L	1	4/30/2005 12:33:00 AM
4-Isopropyltoluene		U		µg/L	1	4/30/2005 12:33:00 AM
4-Methyl-2-pentanone		U		µg/L	1	4/30/2005 12:33:00 AM
Acetone		U		µg/L	1	4/30/2005 12:33:00 AM
Benzene		U		µg/L	1	4/30/2005 12:33:00 AM
Bromobenzene		U		µg/L	1	4/30/2005 12:33:00 AM
Bromochloromethane		U		µg/L	1	4/30/2005 12:33:00 AM
Bromodichloromethane		U		µg/L	1	4/30/2005 12:33:00 AM
Bromoform		U		µg/L	1	4/30/2005 12:33:00 AM
Bromomethane		U		µg/L	1	4/30/2005 12:33:00 AM
Carbon disulfide		U		µg/L	1	4/30/2005 12:33:00 AM
Carbon tetrachloride		U		µg/L	1	4/30/2005 12:33:00 AM
Chlorobenzene		U		µg/L	1	4/30/2005 12:33:00 AM
Chloroethane		U		µg/L	1	4/30/2005 12:33:00 AM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 09-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ042705:0930 NP2-6
Lab Order:	0504250	Tag Number:	4614
Project:	Rowe Industries	Collection Date:	4/27/2005
Lab ID:	0504250-01A	Date Received:	4/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Chloromethane	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Dibromomethane	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/30/2005 12:33:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Methylene chloride	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Naphthalene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
o-Xylene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Styrene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Tetrachloroethene	27	1.0		µg/L	1	4/30/2005 12:33:00 AM
Toluene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Trichloroethene	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/30/2005 12:33:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/30/2005 12:33:00 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 09-May-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ042705:0930 NP2-6		
<b>Lab Order:</b>	0504250	<b>Tag Number:</b>	4614		
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/27/2005		
<b>Lab ID:</b>	0504250-01B	<b>Date Received:</b>	4/28/2005		
<b>Matrix:</b> LIQUID					
Analyses	Result	Limit	Qual Units	DF	Date Analyzed
TOTAL IRON Iron	1.58	E200.7 0.0200	(SW3010A) mg/L	1	Analyst: JP 4/28/2005 4:11:18 PM

<b>Qualifiers:</b>	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 09-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ042705:0930 NP2-6
Lab Order:	0504250	Tag Number:	4614
Project:	Rowe Industries	Collection Date:	4/27/2005
Lab ID:	0504250-01C	Date Received:	4/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
----------	--------	-------	------	-------	----	---------------

DISSOLVED IRON Iron	0.765	E200.7 0.0200	(SW3005A) mg/L	1	Analyst: JP 4/28/2005 4:08:47 PM
------------------------	-------	------------------	-------------------	---	-------------------------------------

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-May-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ042705:0940 NP2-7
<b>Lab Order:</b>	0504250	<b>Tag Number:</b>	4614
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/27/2005
<b>Lab ID:</b>	0504250-02A	<b>Date Received:</b>	4/28/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
			<b>SW8260B</b>			<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,1,1-Trichloroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,1,2,2-Tetrachloroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,1,2-Trichloroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,1-Dichloroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,1-Dichloroethene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,1-Dichloropropene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2,3-Trichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2,3-Trichloropropane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2,4-Trichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2,4-Trimethylbenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2-Dibromo-3-chloropropane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2-Dibromoethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2-Dichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2-Dichloroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,2-Dichloropropane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,3,5-Trimethylbenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,3-Dichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,3-dichloropropane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
1,4-Dichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
2,2-Dichloropropane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
2-Butanone	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
2-Chloroethyl vinyl ether	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
2-Chlorotoluene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
2-Hexanone	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
4-Chlorotoluene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
4-Isopropyltoluene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
4-Methyl-2-pentanone	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Acetone	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Benzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Bromobenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Bromochloromethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Bromodichloromethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Bromoform	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Bromomethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Carbon disulfide	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Carbon tetrachloride	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Chlorobenzene	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	
Chloroethane	U	1.0	μg/L	1	4/30/2005 1:05:00 AM	

Qualifiers: \* Value exceeds Maximum Contaminant Level  
 E Value above quantitation range  
 J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit  
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-May-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b> WQ042705:0940 NP2-7				
<b>Lab Order:</b>	0504250	<b>Tag Number:</b> 4614				
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b> 4/27/2005				
<b>Lab ID:</b>	0504250-02A	<b>Date Received:</b>	4/28/2005	<b>Matrix:</b>	LIQUID	
<hr/>						
Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Chloromethane	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Dibromomethane	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/30/2005 1:05:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Methylene chloride	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Naphthalene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
o-Xylene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Styrene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Tetrachloroethene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Toluene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Trichloroethene	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/30/2005 1:05:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/30/2005 1:05:00 AM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
 E Value above quantitation range  
 J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit  
 U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 09-May-05

---

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ042705:0940 NP2-7
Lab Order:	0504250	Tag Number:	4614
Project:	Rowe Industries	Collection Date:	4/27/2005
Lab ID:	0504250-02B	Date Received:	4/28/2005
		Matrix:	LIQUID

---

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	0.725	E200.7 0.0200		(SW3010A) mg/L	1	Analyst: JP 4/28/2005 4:16:05 PM

---

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 7 of 12

**American Analytical Laboratories, LLC.**

Date: 09-May-05

---

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ042705:0940 NP2-7
Lab Order:	0504250	Tag Number:	4614
Project:	Rowe Industries	Collection Date:	4/27/2005
Lab ID:	0504250-02C	Date Received:	4/28/2005
		Matrix:	LIQUID

---

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.214	0.0200		mg/L	1	4/28/2005 4:13:26 PM

---

---

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 8 of 12

American Analytical Laboratories, LLC.

Date: 09-May-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ042705:0950 NP2-10
<b>Lab Order:</b>	0504250	<b>Tag Number:</b>	4614
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/27/2005
<b>Lab ID:</b>	0504250-03A	<b>Date Received:</b>	4/28/2005
		<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILES SW-846 8260 PLUS MTBE &amp; FREON1</b>						
			<b>SW8260B</b>			<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,1,1-Trichloroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,1,2,2-Tetrachloroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,1,2-Trichloroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,1-Dichloroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,1-Dichloroethene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,1-Dichloropropene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2,3-Trichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2,3-Trichloropropane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2,4-Trichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2,4-Trimethylbenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2-Dibromo-3-chloropropane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2-Dibromoethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2-Dichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2-Dichloroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,2-Dichloropropane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,3,5-Trimethylbenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,3-Dichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,3-dichloropropane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
1,4-Dichlorobenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
2,2-Dichloropropane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
2-Butanone	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
2-Chloroethyl vinyl ether	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
2-Chlorotoluene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
2-Hexanone	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
4-Chlorotoluene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
4-Isopropyltoluene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
4-Methyl-2-pentanone	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Acetone	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Benzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Bromobenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Bromochloromethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Bromodichloromethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Bromoform	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Bromomethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Carbon disulfide	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Carbon tetrachloride	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Chlorobenzene	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	
Chloroethane	U	1.0	μg/L	1	4/30/2005 1:37:00 AM	

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 09-May-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ042705:0950 NP2-10
<b>Lab Order:</b>	0504250	<b>Tag Number:</b>	4614
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/27/2005
<b>Lab ID:</b>	0504250-03A	<b>Date Received:</b>	4/28/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Chloromethane	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Dibromomethane	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/30/2005 1:37:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Methylene chloride	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Naphthalene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
o-Xylene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Styrene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Tetrachloroethene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Toluene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Trichloroethene	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/30/2005 1:37:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/30/2005 1:37:00 AM

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 09-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ042705:0950 NP2-10
Lab Order:	0504250	Tag Number:	4614
Project:	Rowe Industries	Collection Date:	4/27/2005
Lab ID:	0504250-03B	Date Received:	4/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	0.614	E200.7	0.0200	(SW3010A) mg/L	1	Analyst: JP 4/28/2005 4:20:24 PM

Qualifiers: \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

**American Analytical Laboratories, LLC.**

Date: 09-May-05

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ042705:0950 NP2-10
<b>Lab Order:</b>	0504250	<b>Tag Number:</b>	4614
<b>Project:</b>	Rowe Industries	<b>Collection Date:</b>	4/27/2005
<b>Lab ID:</b>	0504250-03C	<b>Date Received:</b>	4/28/2005
			<b>Matrix:</b> LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.173	E200.7 0.0200		(SW3005A) mg/L	1	Analyst: JP 4/28/2005 4:18:16 PM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	110	E160.1 1.0		mg/L	1	Analyst: AT 5/3/2005

**Qualifiers:** \* Value exceeds Maximum Contaminant Level  
E Value above quantitation range  
J Analyte detected below quantitation limits  
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Reporting Limit  
U Indicates the compound was analyzed for but not detected

# ANALYTICAL REPORT

JOB NUMBER: 209231


Prepared For:

LEGGETTE, BRASHEARS & GRAHAM  
126 Monroe Turnpike  
Trumbull, CT 06611

Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 04/21/2005




Signature

Name: William D. Goodman

Title: Project Manager

E-Mail: wgoodman@stl-inc.com



4/21/2005

Date

STL Connecticut  
128 Long Hill Cross Road  
Shelton, CT 06484

This Report Contains (10) Pages

STL Report : 209231  
LEGGETTE, BRASHEARS, & GRAHAM

Case Narrative

**Sample Receipt** – All samples were received in good condition.

**Volatile Organics** – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

The samples in this job were collected in both tedlar bags and tubes. Samples AQ040705:1430NP4-1, AQ040705:1432NP4-2 and AQ040705:1434NP4-3 were transferred by the laboratory to Air Toxic TO-17 tubes and analyzed at sample volumes of 1L except for sample 1430NP4-1 which was also analyzed at a sample volume of .4L for high targets. Both analyses were reported for this sample with the .4L analysis designated with the suffix “DL”.

Sample Calculation:

Sample ID- 1432NP4-2

Compound-Bromomethane

$$\frac{(118334\text{area})(25\text{ng})}{(489603\text{area})(.231\text{area/ng})} = 26.15 = 26 \text{ ng}$$

$$\frac{(26\text{NG})(.08206)(298)}{(1\text{L})(95)(1.0\text{ATM})} = 6.69 = 6.7 \text{ nL/L.}$$

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

## S A M P L E   I N F O R M A T I O N

Date: 04/21/2005

Job Number.: 209231  
Customer....: LEGGETTE, BRASHEARS & GRAHAM  
Attn.....: Mark Goldberg

Project Number.....: 20000283  
Customer Project ID....: ROWE INDUSTRIES  
Project Description....: Rowe Industries

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
209231-1	AQ040705:1430NP4-1	Air	04/07/2005	14:30	04/08/2005	12:15
209231-2	AQ040705:1432NP4-2	Air	04/07/2005	14:32	04/08/2005	12:15
209231-3	AQ040705:1434NP4-3	Air	04/07/2005	14:34	04/08/2005	12:15
209231-4	TUBE(NP4-1)	Air	04/07/2005	14:30	04/08/2005	12:15
209231-5	TUBE(NP4-2)	Air	04/07/2005	14:32	04/08/2005	12:15
209231-6	TUBE(NP4-3)	Air	04/07/2005	14:34	04/08/2005	12:15

Form 1					
STL Connecticut	Client Sample ID		1430NP4-1		
Method: T017	Lab Sample ID			209231-1	
Sample Volume (L)	1.000	Date Sampled		4/7/2005	
Temp (C)	25	Date Analyzed		4/12/2005	
Compound	nL/L (ppbv/v)	Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7		0.0200 U	0.020
Vinyl Chloride	7.8 U	7.8		0.0200 U	0.020
Bromomethane	5.1 U	5.1		0.0200 U	0.020
Chloroethane	7.6 U	7.6		0.0200 U	0.020
1,1-Dichloroethene	1.5 J	2.5		0.0060 J	0.010
Carbon Disulfide	4.8	3.2		0.0150	0.010
Methylene Chloride	15.3 B	2.9		0.0530 B	0.010
trans-1,2-Dichloroethene	2.5 U	2.5		0.0100 U	0.010
1,1-Dichloroethane	4.9	2.5		0.0200	0.010
cis-1,2-Dichloroethene	2.5 U	2.5		0.0100 U	0.010
Chloroform	1.2 J	2.1		0.0060 J	0.010
1,1,1-Trichloroethane	10.7	1.8		0.0580	0.010
Carbon Tetrachloride	1.6 U	1.6		0.0100 U	0.010
Benzene	3.8 B	3.1		0.0120 B	0.010
1,2-Dichloroethane	2.5 U	2.5		0.0100 U	0.010
Trichloroethene	5.0	1.9		0.0270	0.010
1,2-Dichloropropane	2.2 U	2.2		0.0100 U	0.010
Bromodichloromethane	1.5 U	1.5		0.0100 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2		0.0100 U	0.010
Toluene	7.7	2.7		0.0290	0.010
trans-1,3-Dichloropropene	2.2 U	2.2		0.0100 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8		0.0100 U	0.010
Tetrachloroethene	50.1 A	1.5		0.3400 A	0.010
Dibromochloromethane	1.2 U	1.2		0.0100 U	0.010
Chlorobenzene	2.2 U	2.2		0.0100 U	0.010
Ethylbenzene	2.3 U	2.3		0.0100 U	0.010
m&p-Xylenes	0.7 J	2.3		0.0030 J	0.010
o-Xylene	2.3 U	2.3		0.0100 U	0.010
Styrene	0.5 J	2.4		0.0020 J	0.010
Bromoform	1.0 U	1.0		0.0100 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5		0.0100 U	0.010

Form 1					
STL Connecticut		Client Sample ID		1430NP4-1DL	
Method: T017		Lab Sample ID		209231-1DL	
Sample Volume (L)	0.400	Date Sampled		4/7/2005	
Temp (C)	25	Date Analyzed		4/12/2005	
Compound	nL/L (ppbv/v)	Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	24.2 U	24.2		0.0500 U	0.050
Vinyl Chloride	19.6 U	19.6		0.0500 U	0.050
Bromomethane	12.9 U	12.9		0.0500 U	0.050
Chloroethane	19.0 U	19.0		0.0500 U	0.050
1,1-Dichloroethene	6.3 U	6.3		0.0250 U	0.025
Carbon Disulfide	8.0 U	8.0		0.0250 U	0.025
Methylene Chloride	12.2 B	7.2		0.0425 B	0.025
trans-1,2-Dichloroethene	6.4 U	6.4		0.0250 U	0.025
1,1-Dichloroethane	6.2 U	6.2		0.0250 U	0.025
cis-1,2-Dichloroethene	6.4 U	6.4		0.0250 U	0.025
Chloroform	1.0 J	5.1		0.0050 J	0.025
1,1,1-Trichloroethane	8.7	4.6		0.0475	0.025
Carbon Tetrachloride	4.0 U	4.0		0.0250 U	0.025
Benzene	6.3 JB	7.8		0.0200 JB	0.025
1,2-Dichloroethane	6.2 U	6.2		0.0250 U	0.025
Trichloroethene	3.7 J	4.7		0.0200 J	0.025
1,2-Dichloropropane	5.4 U	5.4		0.0250 U	0.025
Bromodichloromethane	3.7 U	3.7		0.0250 U	0.025
cis-1,3-Dichloropropene	5.5 U	5.5		0.0250 U	0.025
Toluene	4.6 J	6.6		0.0175 J	0.025
trans-1,3-Dichloropropene	5.5 U	5.5		0.0250 U	0.025
1,1,2-Trichloroethane	4.6 U	4.6		0.0250 U	0.025
Tetrachloroethene	40.5	3.7		0.2750	0.025
Dibromochloromethane	2.9 U	2.9		0.0250 U	0.025
Chlorobenzene	5.4 U	5.4		0.0250 U	0.025
Ethylbenzene	5.8 U	5.8		0.0250 U	0.025
m&p-Xylenes	5.8 U	5.8		0.0250 U	0.025
o-Xylene	5.8 U	5.8		0.0250 U	0.025
Styrene	5.9 U	5.9		0.0250 U	0.025
Bromoform	2.4 U	2.4		0.0250 U	0.025
1,1,2,2-Tetrachloroethane	3.6 U	3.6		0.0250 U	0.025

Form 1					
STL Connecticut		Client Sample ID	<b>1432NP4-2</b>		
Method: T017		Lab Sample ID	209231-2		
Sample Volume (L)	1.000	Date Sampled	4/7/2005		
Temp (C)	25	Date Analyzed	4/12/2005		
<b>Compound</b>	nL/L (ppbv/v)	Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7		0.0200 U	0.020
Vinyl Chloride	7.8 U	7.8		0.0200 U	0.020
Bromomethane	6.7 B	5.1		0.0260 B	0.020
Chloroethane	7.6 U	7.6		0.0200 U	0.020
1,1-Dichloroethene	1.3 J	2.5		0.0050 J	0.010
Carbon Disulfide	3.2 U	3.2		0.0100 U	0.010
Methylene Chloride	14.4 B	2.9		0.0500 B	0.010
trans-1,2-Dichloroethene	2.5 U	2.5		0.0100 U	0.010
1,1-Dichloroethane	3.5	2.5		0.0140	0.010
cis-1,2-Dichloroethene	0.8 J	2.5		0.0030 J	0.010
Chloroform	1.2 J	2.1		0.0060 J	0.010
1,1,1-Trichloroethane	12.7	1.8		0.0690	0.010
Carbon Tetrachloride	1.6 U	1.6		0.0100 U	0.010
Benzene	0.6 JB	3.1		0.0020 JB	0.010
1,2-Dichloroethane	2.5 U	2.5		0.0100 U	0.010
Trichloroethene	1.9 U	1.9		0.0100 U	0.010
1,2-Dichloropropane	2.2 U	2.2		0.0100 U	0.010
Bromodichloromethane	1.5 U	1.5		0.0100 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2		0.0100 U	0.010
Toluene	3.2	2.7		0.0120	0.010
trans-1,3-Dichloropropene	2.2 U	2.2		0.0100 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8		0.0100 U	0.010
Tetrachloroethene	0.6 J	1.5		0.0040 J	0.010
Dibromochloromethane	1.2 U	1.2		0.0100 U	0.010
Chlorobenzene	2.2 U	2.2		0.0100 U	0.010
Ethylbenzene	2.3 U	2.3		0.0100 U	0.010
m&p-Xylenes	2.3 U	2.3		0.0100 U	0.010
o-Xylene	2.3 U	2.3		0.0100 U	0.010
Styrene	2.4 U	2.4		0.0100 U	0.010
Bromoform	1.0 U	1.0		0.0100 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5		0.0100 U	0.010

Form 1						
STL Connecticut		Client Sample ID	<b>1434NP4-3</b>			
Method: T017		Lab Sample ID	209231-3			
Sample Volume (L)	1.000	Date Sampled	4/7/2005			
Temp (C)	25	Date Analyzed	4/12/2005			
Compound	nL/L (ppbv/v)	Qualifier	RL	mg/M3	Qualifier	RL
Chloromethane	9.7 U	9.7		0.0200 U		0.020
Vinyl Chloride	7.8 U	7.8		0.0200 U		0.020
Bromomethane	3.9 JB	5.1		0.0150 JB		0.020
Chloroethane	7.6 U	7.6		0.0200 U		0.020
1,1-Dichloroethene	1.5 J	2.5		0.0060 J		0.010
Carbon Disulfide	3.2 U	3.2		0.0100 U		0.010
Methylene Chloride	4.3 B	2.9		0.0150 B		0.010
trans-1,2-Dichloroethene	2.5 U	2.5		0.0100 U		0.010
1,1-Dichloroethane	4.0	2.5		0.0160		0.010
cis-1,2-Dichloroethene	2.5 U	2.5		0.0100 U		0.010
Chloroform	1.4 J	2.1		0.0070 J		0.010
1,1,1-Trichloroethane	3.7	1.8		0.0200		0.010
Carbon Tetrachloride	1.6 U	1.6		0.0100 U		0.010
Benzene	0.6 JB	3.1		0.0020 JB		0.010
1,2-Dichloroethane	2.5 U	2.5		0.0100 U		0.010
Trichloroethene	1.9 U	1.9		0.0100 U		0.010
1,2-Dichloropropane	2.2 U	2.2		0.0100 U		0.010
Bromodichloromethane	1.5 U	1.5		0.0100 U		0.010
cis-1,3-Dichloropropene	2.2 U	2.2		0.0100 U		0.010
Toluene	3.5	2.7		0.0130		0.010
trans-1,3-Dichloropropene	2.2 U	2.2		0.0100 U		0.010
1,1,2-Trichloroethane	1.8 U	1.8		0.0100 U		0.010
Tetrachloroethene	0.1 J	1.5		0.0010 J		0.010
Dibromochloromethane	1.2 U	1.2		0.0100 U		0.010
Chlorobenzene	2.2 U	2.2		0.0100 U		0.010
Ethylbenzene	2.3 U	2.3		0.0100 U		0.010
m&p-Xylenes	2.3 U	2.3		0.0100 U		0.010
o-Xylene	2.3 U	2.3		0.0100 U		0.010
Styrene	2.4 U	2.4		0.0100 U		0.010
Bromoform	1.0 U	1.0		0.0100 U		0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5		0.0100 U		0.010

Form 1						
STL Connecticut		Client Sample ID	TUBE(NP4-1)			
Method: T017		Lab Sample ID	209231-4			
Sample Volume (L)	1.000	Date Sampled	4/7/2005			
Temp (C)	25	Date Analyzed	4/13/2005			
Compound	nL/L (ppbv/v)	Qualifier	RL	mg/M3	Qualifier	RL
Chloromethane	9.7 U	9.7		0.0200 U		0.020
Vinyl Chloride	7.8 U	7.8		0.0200 U		0.020
Bromomethane	4.6 JB	5.1		0.0180 JB		0.020
Chloroethane	7.6 U	7.6		0.0200 U		0.020
1,1-Dichloroethene	2.5 U	2.5		0.0100 U		0.010
Carbon Disulfide	3.2 U	3.2		0.0100 U		0.010
Methylene Chloride	2.0 JB	2.9		0.0070 JB		0.010
trans-1,2-Dichloroethene	2.5 U	2.5		0.0100 U		0.010
1,1-Dichloroethane	3.7	2.5		0.0150		0.010
cis-1,2-Dichloroethene	2.5 U	2.5		0.0100 U		0.010
Chloroform	0.8 J	2.1		0.0040 J		0.010
1,1,1-Trichloroethane	9.7	1.8		0.0530		0.010
Carbon Tetrachloride	1.6 U	1.6		0.0100 U		0.010
Benzene	1.6 JB	3.1		0.0050 JB		0.010
1,2-Dichloroethane	2.5 U	2.5		0.0100 U		0.010
Trichloroethene	5.0	1.9		0.0270		0.010
1,2-Dichloropropane	2.2 U	2.2		0.0100 U		0.010
Bromodichloromethane	1.5 U	1.5		0.0100 U		0.010
cis-1,3-Dichloropropene	2.2 U	2.2		0.0100 U		0.010
Toluene	0.5 J	2.7		0.0020 J		0.010
trans-1,3-Dichloropropene	2.2 U	2.2		0.0100 U		0.010
1,1,2-Trichloroethane	1.8 U	1.8		0.0100 U		0.010
Tetrachloroethene	51.6 A	1.5		0.3500 A		0.010
Dibromochloromethane	1.2 U	1.2		0.0100 U		0.010
Chlorobenzene	2.2 U	2.2		0.0100 U		0.010
Ethylbenzene	2.3 U	2.3		0.0100 U		0.010
m&p-Xylenes	2.3 U	2.3		0.0100 U		0.010
o-Xylene	2.3 U	2.3		0.0100 U		0.010
Styrene	2.4 U	2.4		0.0100 U		0.010
Bromoform	1.0 U	1.0		0.0100 U		0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5		0.0100 U		0.010

Form 1							
STL Connecticut		Client Sample ID	TUBE(NP4-2)				
Method: T017		Lab Sample ID	209231-5				
Sample Volume (L)	1.000	Date Sampled	4/7/2005				
Temp (C)	25	Date Analyzed	4/12/2005				
Compound	(ppbv/v)	nL/L	Qualifier	RL	mg/M3	Qualifier	RL
Chloromethane		9.7 U	9.7		0.0200 U		0.020
Vinyl Chloride		7.8 U	7.8		0.0200 U		0.020
Bromomethane		92.7 AB	5.1		0.3600 AB		0.020
Chloroethane		7.6 U	7.6		0.0200 U		0.020
1,1-Dichloroethene		2.5 U	2.5		0.0100 U		0.010
Carbon Disulfide		3.2 U	3.2		0.0100 U		0.010
Methylene Chloride		2.0 JB	2.9		0.0070 JB		0.010
trans-1,2-Dichloroethene		2.5 U	2.5		0.0100 U		0.010
1,1-Dichloroethane		4.0	2.5		0.0160		0.010
cis-1,2-Dichloroethene		0.8 J	2.5		0.0030 J		0.010
Chloroform		0.8 J	2.1		0.0040 J		0.010
1,1,1-Trichloroethane		14.3	1.8		0.0780		0.010
Carbon Tetrachloride		1.6 U	1.6		0.0100 U		0.010
Benzene		0.9 JB	3.1		0.0030 JB		0.010
1,2-Dichloroethane		2.5 U	2.5		0.0100 U		0.010
Trichloroethene		1.9 U	1.9		0.0100 U		0.010
1,2-Dichloropropane		2.2 U	2.2		0.0100 U		0.010
Bromodichloromethane		1.5 U	1.5		0.0100 U		0.010
cis-1,3-Dichloropropene		2.2 U	2.2		0.0100 U		0.010
Toluene		2.7 U	2.7		0.0100 U		0.010
trans-1,3-Dichloropropene		2.2 U	2.2		0.0100 U		0.010
1,1,2-Trichloroethane		1.8 U	1.8		0.0100 U		0.010
Tetrachloroethene		1.5 U	1.5		0.0100 U		0.010
Dibromochloromethane		1.2 U	1.2		0.0100 U		0.010
Chlorobenzene		2.2 U	2.2		0.0100 U		0.010
Ethylbenzene		2.3 U	2.3		0.0100 U		0.010
m&p-Xylenes		2.3 U	2.3		0.0100 U		0.010
o-Xylene		2.3 U	2.3		0.0100 U		0.010
Styrene		2.4 U	2.4		0.0100 U		0.010
Bromoform		1.0 U	1.0		0.0100 U		0.010
1,1,2,2-Tetrachloroethane		1.5 U	1.5		0.0100 U		0.010

Form 1					
STL Connecticut		Client Sample ID		TUBE(NP4-3)	
Method: T017		Lab Sample ID		209231-6	
Sample Volume (L)	1.000	Date Sampled		4/7/2005	
Temp (C)	25	Date Analyzed		4/12/2005	
nL/L					
Compound	(ppbv/v)	Qualifier	RL	mg/M3	Qualifier
Chloromethane	9.7 U	9.7		0.0200 U	0.020
Vinyl Chloride	7.8 U	7.8		0.0200 U	0.020
Bromomethane	6.7 B	5.1		0.0260 B	0.020
Chloroethane	7.6 U	7.6		0.0200 U	0.020
1,1-Dichloroethene	2.5 U	2.5		0.0100 U	0.010
Carbon Disulfide	3.2 U	3.2		0.0100 U	0.010
Methylene Chloride	0.9 JB	2.9		0.0030 JB	0.010
trans-1,2-Dichloroethene	2.5 U	2.5		0.0100 U	0.010
1,1-Dichloroethane	1.7 J	2.5		0.0070 J	0.010
cis-1,2-Dichloroethene	2.5 U	2.5		0.0100 U	0.010
Chloroform	0.2 J	2.1		0.0010 J	0.010
1,1,1-Trichloroethane	1.8	1.8		0.0100	0.010
Carbon Tetrachloride	1.6 U	1.6		0.0100 U	0.010
Benzene	0.9 JB	3.1		0.0030 JB	0.010
1,2-Dichloroethane	2.5 U	2.5		0.0100 U	0.010
Trichloroethene	1.9 U	1.9		0.0100 U	0.010
1,2-Dichloropropane	2.2 U	2.2		0.0100 U	0.010
Bromodichloromethane	1.5 U	1.5		0.0100 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2		0.0100 U	0.010
Toluene	0.2 J	2.7		0.0008 J	0.010
trans-1,3-Dichloropropene	2.2 U	2.2		0.0100 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8		0.0100 U	0.010
Tetrachloroethene	1.5 U	1.5		0.0100 U	0.010
Dibromochloromethane	1.2 U	1.2		0.0100 U	0.010
Chlorobenzene	2.2 U	2.2		0.0100 U	0.010
Ethylbenzene	2.3 U	2.3		0.0100 U	0.010
m&p-Xylenes	2.3 U	2.3		0.0100 U	0.010
o-Xylene	2.3 U	2.3		0.0100 U	0.010
Styrene	2.4 U	2.4		0.0100 U	0.010
Bromoform	1.0 U	1.0		0.0100 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5		0.0100 U	0.010

## LABORATORY CHRONICLE

Job Number: 209231

Date: 04/21/2005

CUSTOMER: LEGGETTE, BRASHEARS &amp; GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID: 209231-1	Client ID: AQ040705:1430NP4-1	Date Recvd: 04/08/2005	Sample Date: 04/07/2005	
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT #(S) DATE/TIME ANALYZED DILUTION
T017	Volatile Organics (Air)	1	47442	04/12/2005 1838 1.00000
T017	Volatile Organics (Air)	2	47442	04/13/2005 1136 1.00000
Lab ID: 209231-2	Client ID: AQ040705:1432NP4-2	Date Recvd: 04/08/2005	Sample Date: 04/07/2005	
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT #(S) DATE/TIME ANALYZED DILUTION
T017	Volatile Organics (Air)	1	47442	04/12/2005 1727 1.00000
Lab ID: 209231-3	Client ID: AQ040705:1434NP4-3	Date Recvd: 04/08/2005	Sample Date: 04/07/2005	
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT #(S) DATE/TIME ANALYZED DILUTION
T017	Volatile Organics (Air)	1	47442	04/12/2005 1802 1.00000
Lab ID: 209231-4	Client ID: TUBE(NP4-1)	Date Recvd: 04/08/2005	Sample Date: 04/07/2005	
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT #(S) DATE/TIME ANALYZED DILUTION
T017	Volatile Organics (Air)	1	47442	04/13/2005 1037 1.00000
Lab ID: 209231-5	Client ID: TUBE(NP4-2)	Date Recvd: 04/08/2005	Sample Date: 04/07/2005	
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT #(S) DATE/TIME ANALYZED DILUTION
T017	Volatile Organics (Air)	1	47442	04/13/2005 0926 1.00000
Lab ID: 209231-6	Client ID: TUBE(NP4-3)	Date Recvd: 04/08/2005	Sample Date: 04/07/2005	
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT #(S) DATE/TIME ANALYZED DILUTION
T017	Volatile Organics (Air)	1	47442	04/13/2005 1002 1.00000

AIR

2A  
WATER VOLATILE SYSTEM MONITORING COMPOUND RECOVERY

P.M. 4/19/05

Lab Name: STL-CT

Contract:

Lab Code: STL-CT

Case No.: 209231 SAS No.:

SDG No.: 209231

	EPA SAMPLE NO.	SMC1 #	SMC2 (DCE) #	SMC3 (TOL) #	OTHER (BFB) #	TOT OUT
01	VBLKTZ	103	89	107	105	
02	LCS	102	92	105	104	
03	1432NP4-2	104	91	102	101	
04	1434NP4-3	101	89	103	101	
05	1430NP4-1DL	103	89	105	101	
06	TUBE(NP4-2)	91	80	104	97	
07	TUBE(NP4-3)	93	86	102	100	
08	TUBE(NP4-1)	109	89	102	97	
09	1430NP4-1	106	89	98	94	
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

## QC LIMITS

SMC1 = Dibromofluoromethane (70-130)  
 SMC2 (DCE) = 1,2-Dichloroethane-d4 (70-130)  
 SMC3 (TOL) = Toluene-d8 (70-130)  
 OTHER (BFB) = Bromofluorobenzene (70-130)

# Column to be used to flag recovery values

\* Values outside of contract required QC limits

D System Monitoring Compound diluted out

## FORM 3

Data File: \\TARGET1\_CT\Files\chem\VOA\mst.i\T054683.b\T4689.D Page 3  
 Report Date: 15-Apr-2005 13:13

STL-CT

## RECOVERY REPORT

Client Name:  
 Sample Matrix: LIQUID  
 Lab Smp Id: LCS  
 Level: LOW  
 Data Type: MS DATA  
 SpikeList File: AIRQCS.spk  
 Sublist File: all.sub  
 Method File: \\TARGET1\_CT\Files\chem\VOA\mst.i\T054683.b\TAIRFULL.m  
 Misc Info: : LCS;;: 020\_ppbQCS ; TO-17 ; \* 1 mL\* ; AIR

Client SDG: SDGa24843  
 Fraction: VOA  
 Client Smp ID: LCS  
 Operator: M.Crowe  
 SampleType: LCS  
 Quant Type: ISTD

SPIKE COMPOUND	CONC ADDED ug/L	CONC RECOVERED ug/L	% RECOVERED	LIMITS
4 Vinyl Chloride	20	14	70.65	60-140
5 Bromomethane	20	14	68.74	60-140
6 Chloroethane	20	15	76.62	60-140
12 1,1-Dichloroethene	20	17	84.44	60-140
11 Trichlorotrifluoro	20	15	76.48	60-140
17 Acetone	20	20	98.54	60-140
13 Carbon Disulfide	20	16	79.99	60-140
16 Methylene Chloride	20	19	95.28	60-140
18 trans-1,2-Dichloro	20	16	79.69	60-140
28 1,1-Dichloroethane	20	16	79.03	60-140
30 cis-1,2-Dichloroet	20	14	72.44	60-140
40 2-Butanone	20	17	87.06	60-140
33 Chloroform	20	15	76.23	60-140
38 1,1,1-Trichloroeth	20	17	86.59	60-140
39 Carbon Tetrachlori	20	20	100.04	60-140
51 1,2-Dichloroethane	20	15	77.27	60-140
48 Benzene	20	16	79.26	60-140
56 Trichloroethene	20	15	76.81	60-140
63 cis-1,3-Dichloropr	20	16	80.53	60-140
72 4-Methyl-2-Pentano	20	16	78.39	60-140
69 Toluene	20	16	79.25	60-140
66 trans-1,3-Dichloro	20	12	62.37	60-140
67 1,1,2-Trichloroeth	20	16	78.72	60-140
73 Tetrachloroethene	20	16	79.93	60-140
75 Dibromochlorometha	20	16	81.77	60-140
80 Chlorobenzene	20	16	77.76	60-140
82 Ethylbenzene	20	16	78.40	60-140
83 Xylene (total)mp	40	30	74.33	60-140
84 Xylene (total)o	20	15	77.13	60-140
85 Styrene	20	15	75.29	60-140
86 Bromoform	20	16	80.28	60-140
89 1,1,2,2-Tetrachlor	20	16	82.30	60-140
101 1,3-Dichlorobenzen	20	16	80.23	60-140
102 1,4-Dichlorobenzen	20	16	82.19	60-140
103 1,2-Dichlorobenzen	20	16	78.43	60-140

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 04/21/2005

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
  - < Not detected at or above the reporting limit.
  - J Result is less than the RL, but greater than or equal to the method detection limit.
  - B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
  - S Result was determined by the Method of Standard Additions.
- Inorganic Flags (Flag Column)
- ICV,CCV,ICB,CCK,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed th upper or lower control limits.
  - \* LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
  - + MSA correlation coefficient is less than 0.995.
  - 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
  - E SD: Serial dilution exceeds the control limits.
  - H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
  - N MS, MSD: Spike recovery exceeds the upper or lower control limits.
  - W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags (Flags Column)

- MB,EB, MLE: Batch QC is greater than reporting limit.
- \* LCS, LCD, CCV, MS, MSD, Surrogate, RS:Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

## QUALITY ASSURANCE METHODS

### REFERENCES AND NOTES

Report Date: 04/21/2005

#### Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil Fac	Dilution Factor
DL	Secondary dilution and analysis
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

**STL-Connecticut**  
**Certification Summary (as of October 2004)**

The laboratory identification numbers for the STL-Connecticut laboratory are provided in the following table. Many states certify laboratories for specific parameters or tests within a category (i.e. method 325.2 for wastewater). The information in the following table indicates the lab is certified in a general category of testing such as drinking water or wastewater analysis. The laboratory should be contacted directly if parameter-specific certification information is required.

State	Responsible Agency	Certification Category	Expiration Date	Lab Number
Connecticut	Department of Health Services	Drinking Water, Wastewater	12/31/04	PH-0497
Maine	Department of Health and Environmental Services	Drinking Water, Wastewater/Solid, Hazardous Waste	04/18/06	CT023
Massachusetts	Department of Environmental Protection	Potable/Non-Potable Water	06/30/05	CT023
New Hampshire	Department of Environmental Services	Drinking Water, Wastewater	08/29/05	2528
New Jersey	Department of Environmental Protection	Drinking Water, Wastewater	06/30/05	46410
New York	Department of Health	CLP, Drinking Water, Wastewater, Solid/ Hazardous Waste NELAC	04/01/05	10602
Rhode Island	Department of Health	Chemistry...Non- Potable Water and Wastewater	12/30/04	A43
Utah	Department of Health	RCRA	05/31/05	2032614458

**OFFICES LOCATED IN:**

**MASSACHUSETTS • CONNECTICUT • NEW YORK • NEW JERSEY**

**PENNSYLVANIA • FLORIDA • OHIO • WISCONSIN • ILLINOIS • MISSOURI**

**MINNESOTA • TEXAS • SOUTH DAKOTA**