
Appendix G - Transformer T2 ICM - Confirmatory Samples Rep



ENVIRONMENTAL SERVICES, INC.

32 BASK ROAD • GLENMONT, NY 12077

(518) 434-0149 • FAX (518) 434-9118

February 23, 1997
AL TECH Specialty Steel Corp.
PO Box 91
Watervliet, N.Y. 12189-0091
Attn.: Mr. Tom Ragosta

Dear Mr. Ragosta:

On Friday January 24, 1997 a Clean Harbors Environmental Services, Inc. work crew removed loose dirt from 2 transformers formerly located in T2 at Al Tech specialty Steel in Watervliet, N.Y.. The transformers were then wiped down with rags wetted with a degreasing agent. All wastes generated from this process were loaded into a Clean Harbor Environmental Services, Inc. supplied roll off container for ultimate disposition at CWM Model City, N.Y. secure chemical landfill.

On Saturday February 1, 1997 a Clean Harbors Environmental Services work crew returned to Al Tech Specialty Steel in Watervliet, N.Y. to remove all loose dirt and soil from the floor area in T2 and to steam clean and decontaminate the concrete floor of T2. All solid wastes generated from this cleaning operation were loaded into the on site roll off container supplied by Clean Harbors Environmental Services, Inc. for ultimate disposition at CWM Model City, N.Y. secure chemical landfill. Liquid wastes were drummed for disposal at a later date.

6 samples of the concrete floor and walls were taken by the Clean Harbors Environmental Services work crew and were submitted to ADIRONDACK Environmental Services, Inc. for certified lab analysis for PCB via EPA method 8080 on Monday February 3, 1997.

Documents that follow are.

1. Hazardous waste manifest for the roll off of PCB contaminated material generated from the clean up.
2. Chain of custody for PCB samples.
3. Certified lab analysis of samples taken.

Thank you for the opportunity to present our report and I trust that it addresses all your requirements. If you should have any questions or require additional information, please call me at (518) 434-0149.

A handwritten signature in black ink, appearing to read "Anthony Tullio". The signature is fluid and cursive, written over a white background.

HAZARDOUS WASTE MANIFEST

Please print or type. Do not staple. NY

P.O. Box 12820, Albany, New York, 12212

Form Approved. OMB No. 8250-0033. Expired 9-30-86

UNIFORM HAZARDOUS WASTE MANIFEST

1. Generator's US EPA No. **XXXXXXXXXXXX** Manifest Document No. **117**

2. Page 1 of 2 Information in the shaded areas is not required by Federal Law.

3. Generator's Name and Mailing Address
**12-1000 SPECTRUM DRIVE
LAWRENCEVILLE, GEORGIA 30046**

A. State **GA**

4. Generator's Phone **404-772-2111** **Attn: Tom Ingosta**

B. Generator's City **LAWRENCEVILLE**

5. Transporter 1 (Company Name) **Cross Country Bus Services, Inc.** 6. US EPA ID Number **GA0020322290**

C. State **GA**

7. Transporter 2 (Company Name) 8. US EPA ID Number

D. Transporter's City

9. Designated Facility Name and Site Address
**COR CHEMICAL SERVICES, INC
1335 WILSON ROAD
MOBILE CITY, TN 38507** 10. US EPA ID Number **NYD949836679**

E. State **NY**
F. Transporter's City
G. State Facility's City
H. Facility's Phone

11. US DOT Description (Including Proper Shipping Name, Hazard Class and ID Number)	12. Containers No. Type	13. Total Quantity	14. Unit Wt/Vol	15. EPA Waste No.	
				EPA	STATE
90 POLYCHLORINATED BIPHENYL, 9, 002115, SOLID, S	XXIX	XXIX	XXIX	XXIX	XXIX
a.				EPA	STATE
b.				EPA	STATE
c.				EPA	STATE
d.				EPA	STATE

J. Additional Descriptions for Materials Listed Above
K. Handling Codes for Wastes Listed Above

15. Special Handling Instructions and Additional Information
117 MOBILE CITY 13310
In case of Emergency call 1-800-645-6285
MOBILE CITY 38507

16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked and labeled, and are in full compliance with applicable Federal, State and local laws and regulations.

Printed/Typed Name **Thomas D. Ingosta** Signature **[Signature]** Mo. Day Year **11 25 90**

17. Transporter 1 (Acknowledgement of Receipt of Materials)
Printed/Typed Name **[Name]** Signature **[Signature]** Mo. Day Year **[Date]**

18. Transporter 2 (Acknowledgement of Receipt of Materials)
Printed/Typed Name **[Name]** Signature **[Signature]** Mo. Day Year **[Date]**

19. Discrepancy Indication Space
Actual Received 5307K

20. Facility Owner or Operator: Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19
Printed/Typed Name **JOSEPH N. SHARP** Signature **[Signature]** Mo. Day Year **02 06 91**

In case of emergency or spill immediately call the National Response Center (800) 424-6802 and the N.Y. Dept. of Environmental Conservation (516) 457-7362.

EPA Form 8700-22 (Rev. 9-88) Previous editions are obsolete.

COPY 7—Transporter Copy—retained by transporter

White: Records Green & Canary: Accts Rec. Pink: Environmental Gold/Red: Driver



314 North Pearl Street
 Albany, New York 12207
 518-434-4546/434-0891 FAX

A full service analytical research laboratory offering solutions to environmental concerns

CHAIN OF CUSTODY RECORD

CLIENT NAME <i>Clear Harbor</i>	PROJECT NAME (Location) <i>ALTECH</i>	SAMPLERS: (Names) <i>Anthony Truscillo</i>
ADDRESS <i>32 BASIL RD</i>	PO NUMBER <i>1896</i>	SAMPLERS: (Signature) <i>Anthony Truscillo</i>

AES SAMPLE NUMBER	CLIENT SAMPLE IDENTIFICATION & LOCATION	DATE SAMPLED	TIME A.M. P.M.	SAMPLE TYPE			NUMBER OF CONT'S	ANALYSIS REQUIRED
				MATRIX	CONTAINER	CLASS		
970203 #01	RIGHT BACK WALL #1	2/1	11	(A) P Solid	X		1	PCB
#02	RIGHT CENTER FLOOR #2	↓	↓	A P			1	↓
#03	RIGHT FRONT FLOOR #3	↓	↓	A P			1	↓
#04	LEFT FRONT FLOOR #4	↓	↓	A P			1	↓
#05	LEFT CENTER FLOOR #5	↓	↓	A P			1	↓
#06	LEFT BACK FLOOR #6	↓	↓	A P			1	↓
				A P				
				A P				
				A P				
				A P				
				A P				
				A P				
				A P				
				A P				
				A P				
				A P				
				A P				
				A P				

Turnaround Time: _____ Laboratory Approval: _____

Relinquished by: (Signature) <i>Anthony Truscillo</i>	Received by: (Signature)	Date/Time	
Relinquished by: (Signature)	Received by: (Signature)	Date/Time	
Relinquished by: (Signature)	Received by: (Signature)	Date/Time	
Dispatched by: (Signature)	Date/Time	Received for Laboratory by: <i>MAL</i>	Date/Time <i>2/3/97/11:22</i>
Method of Shipment:	Send Report To: <i>Anthony Truscillo</i>	Client Phone No.:	

The Laboratory reserves the right to return hazardous samples to the client or may levy an appropriate fee per container for disposal.

WHITE - Lab Copy YELLOW - Sampler Copy PINK - Generator Copy





Experience is the solution

314 North Pearl Street • Albany, New York 12207 • 800-848-4983 • (518) 434-4546 • Fax (518) 434-0891

LABORATORY REPORT

for

Clean Harbors, Inc.
32 Bask Road
Glenmont, NY 12077

Attention: Anthony Truscelio

Purchase Order #: 1896

Report date: 02/06/97
Number of samples analyzed: 6
AES Project ID: 970203 H
Invoice #: 172122

ELAP ID#: 10709

AIHA ID#: 12144-001
Page 1



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • 800-848-4983 • (518) 434-4546 • Fax (518) 434-0891

CLIENT: Clean Harbors, Inc. Date Sampled: 02/01/97
 CLIENT'S SAMPLE ID: Right Back Wall 1 Date sample received: 02/03/97
 AES sample #: 970203 H01 Samples taken by: A. Truscello Location: Aitech
 MATRIX: Solid Sample () grab

<u>PARAMETER PERFORMED</u>	<u>METHOD</u>	<u>RESULT</u>	<u>UNITS</u>	<u>NOTEBK REF</u>	<u>TEST DATE</u>
PCB	EPA-8080	1.2	ug/g	KF-PCB-U33	02/04/97



Experience is the solution

314 North Pearl Street - Albany, New York 12207 - 800-848-4983 - (518) 434-4546 - Fax (518) 434-0891

CLIENT: Clean Harbors, Inc.	Date Sampled: 02/01/97
CLIENT'S SAMPLE ID: Right Center Floor 2	Date sample received: 02/03/97
AES sample #: 970203 H02	Samples taken by: A. Truscello
	Location: Altech
MATRIX: Solid Sample	grab

<u>PARAMETER PERFORMED</u>	<u>METHOD</u>	<u>RESULT</u>	<u>UNITS</u>	<u>NOTEBK REF</u>	<u>TEST DATE</u>
PCB	EPA-8080	<1	ug/g	KF-PCB-U33	02/04/97



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • 800-848-4983 • (518) 434-4546 • Fax (518) 434-0891

CLIENT: Clean Harbors, Inc. Date Sampled: 02/01/97
 CLIENT'S SAMPLE ID: Right Front Floor 3 Date sample received: 02/03/97
 AES sample #: 970203 HO3 Samples taken by: A. Truscello Location: Altech
 MATRIX: Solid Sample grab

<u>PARAMETER PERFORMED</u>	<u>METHOD</u>	<u>RESULT</u>	<u>UNITS</u>	<u>NOTEBOOK REF</u>	<u>TEST DATE</u>
PCB	EPA-8080	<1	ug/g	KF-PCB-U33	02/04/97



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • 800-848-4983 • (518) 434-4546 • Fax (518) 434-0891

CLIENT: Clean Harbors, Inc. Date Sampled: 02/01/97
 CLIENT'S SAMPLE ID: Left Front Floor 4 Date sample received: 02/03/97
 AES sample #: 970203 H04 Samples taken by: A. Truscello Location: Altech
 MATRIX: Solid Sample grab

<u>PARAMETER PERFORMED</u>	<u>METHOD</u>	<u>RESULT</u>	<u>UNITS</u>	<u>NOTEBOOK REF</u>	<u>TEST DATE</u>
PCB	EPA-8080	<1	ug/g	KF-PCB-U33	02/04/97



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • 800-848-4983 • (518) 434-4546 • Fax (518) 434-0891

CLIENT: Clean Harbors, Inc. Date Sampled: 02/01/97
 CLIENT'S SAMPLE ID: Left Center Floor 5 Date sample received: 02/03/97
 AES sample #: 970203 H05 Samples taken by: A. Truscello Location: Altech
 MATRIX: Solid Sample grab

<u>PARAMETER PERFORMED</u>	<u>METHOD</u>	<u>RESULT</u>	<u>UNITS</u>	<u>NOTEBK REF</u>	<u>TEST DATE</u>
PCB	EPA-8080	5.1	ug/g	KF-PCB-U33	02/04/97



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • 800-848-4983 • (518) 434-4546 • Fax (518) 434-0891

CLIENT: Clean Harbors, Inc.

Date Sampled: 02/02/97

CLIENT'S SAMPLE ID: Left Back Floor 6

Date sample received: 02/03/97

AES sample #: 970203 H06


Samples taken by: A. Truscelio

Location: Aitech

MATRIX: Solid Sample

grab

<u>PARAMETER PERFORMED</u>	<u>METHOD</u>	<u>RESULT</u>	<u>UNITS</u>	<u>NOTEBOOK REF</u>	<u>TEST DATE</u>
PCB	EPA-8080	1.6	ug/g	KF-PCB-U33	02/04/97

APPROVED BY: 
Report date: 02/06/97