



TETRA TECH EC, INC.

18 2005

14 July 2005  
RAC II-2005-106

Ms. Sharon Trocher  
Work Assignment Manager  
U.S. Environmental Protection Agency  
290 Broadway, 20<sup>th</sup> Floor  
New York, NY 10007-1866

**SUBJECT: USEPA RAC II CONTRACT NUMBER 68-W-98-214  
WORK ASSIGNMENT NUMBER 109-RALR-0238  
VESTAL WATER SUPPLY WELL, OPERABLE UNIT 1  
APRIL 2005 PERFORMANCE MONITORING REPORT**

Dear Ms. Trocher:

I am pleased to provide the April 2005 Monthly Performance Monitoring Report for the Vestal Water Supply Well treatment facility.

#### **A. Monthly Operations**

The treatment system at the Vestal Water Supply Well was shut down from 6 April through 11 April due to flooding in the area. Numerous attempts to re-start the system from 12 April through 19 April were not successful due to malfunctions with the clear well pump and blower system. On 20 April, the system was restarted in auto mode. The problem appears to be the result of mice short-circuiting the wiring. A summary of the operation and maintenance activities performed during April is as follows:

- Routine inspections of the facility were performed;
- Pumps were checked and lubricated;
- Air filters were cleaned or replaced;
- Water was pumped out of the foundation after flooding;
- The sump pump was replaced;
- The blower malfunction was repaired; and
- The monthly influent and effluent samples were collected.



1000 The American Road, Morris Plains, NJ 07950  
Tel 973.630.8000 Fax 973.630.8025  
www.tteci.com

**B. Operational Data**

The following table presents operational data for the year 2005, arranged by month:

Month	Operating Days	Average flow Meter %	Average flow rate (gpm)	Amount of groundwater treated (mg)
January	31	47	541	24.2
February	28	46	529	21.3
March	31	45	517.5	22.4
April	17	48	552	13.5
Volume of groundwater treated for 2005				81.4
Volume of groundwater treated for the OU-1				2684.8

gpm - gallons per minute  
 mg - millions of gallons

**C. Comparison of Influent and Effluent Concentrations with Discharge Criteria**

The treatment plant influent and effluent analytical data received from the EPA-DESA laboratory for the month of April 2005 are included in Attachment 1. A summary of the data for the compounds detected in the plant influent and effluent is as follows:

Compound	Discharge Criteria (ug/L)	Influent Concentration (ug/L)												Effluent Concentration (ug/L) January
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Vinyl Chloride	2	3.5	3.9	3.4	4.4									0.5 U
Chloroethane		0.5	0.6	0.5	0.73									0.5 U
1,1-Dichloroethene*	5	13	9.3	8.4	11									0.5 U
1,1,2 Trichloro-1,2,2-Trifluoroethane		3.1	2.9	2.6	3.2									0.5 U
Acetone		1.0 U	2.3	1.0 U	1.0U									1.0 U
Trans 1,2-Dichloroethene*	5	0.5 U	0.5 U	0.5 U	0.5U									0.5 U
Methyl Tert-Butyl Ether		4.7	4.3	4.3	3.9									2.2
1,1-Dichloroethane	5	18	17	17	24									2.7
Cis-1,2-Dichloroethene*	5	50	46	46	54									8.1
Chloroform	7	0.5 U	0.5 U	0.5 U	0.5U									0.5 U
1,1,1-Trichloroethane*	5	110	120	110	140									7.3
Trichloroethene*	5	43	40	40	47									4.0
Total Volatile Organics*	100	245.8	246.3	232.2	288.23									24.3

Note:

- ug/L = micrograms per liter
- \* = Site Contaminant of Concern
- U = Below Reporting Limit
- NS = Not Sampled

**D. Next Month's Activities**


The following activities are planned for May 2005:

- Paint pump house, weather permitting;
- Repair chlorinator pipe;
- Repair actuator valve;
- Restore phone service (interrupted during flooding); and
- Perform monthly performance monitoring sampling.

**E. Summary and Recommendations**

Based on the treatment plant influent and effluent data summarized above, it can be concluded the treated water continues to meet the discharge limits. Please feel free to contact me at (973) 630-8412 if you should have any questions.

Sincerely,



Wendy DeMaio  
Project Manager

Attachment

cc: M. Dunham (NYSDEC)

**ATTACHMENT A**

**Case Narrative:**  
**Vestal 1-1. #05040039**

The Laboratory has met all data quality objectives, e.g., Target Reporting Limits, Accuracy and Precision, established for this project except were noted below..

Comment(s):

None


Reporting Limit(s):

The Laboratory was able to achieve the Contract Required Quantitation Limits (CRQLs) for each analyte requested.

Method(s):

Low Level Volatile Organic Analysis, ESAT-SOP-132 (GC/MS Method).

Approval: \_\_\_\_\_



Date: 7-5-05



U.S. Environmental Protection Agency  
Region 2 Laboratory

**Data Report: Vestal Well 1-1 [04/05]**

**Project Number: 05040039**

Program: Y206E

Project Leader: L. Arabia

Remark Codes	Explanation
U	THE ANALYTE WAS NOT DETECTED AT OR ABOVE THE REPORTING LIMIT.
J	THE IDENTIFICATION OF THE ANALYTE IS ACCEPTABLE; THE REPORTED VALUE IS AN ESTIMATE.
UJ	THE ANALYTE WAS NOT DETECTED AT OR ABOVE THE REPORTING LIMIT. THE REPORTING LIMIT IS AN ESTIMATE.
N	THERE IS PRESUMPTIVE EVIDENCE THAT THE ANALYTE IS PRESENT; THE ANALYTE IS REPORTED AS A TENTATIVE IDENTIFICATION.
NJ	THERE IS PRESUMPTIVE EVIDENCE THAT THE ANALYTE IS PRESENT; THE ANALYTE IS REPORTED AS A TENTATIVE IDENTIFICATION. THE REPORTED VALUE IS AN ESTIMATE.
R	THE PRESENCE OR ABSENCE OF THE ANALYTE CANNOT BE DETERMINED FROM THE DATA DUE TO SEVERE QUALITY CONTROL PROBLEMS. THE DATA ARE REJECTED AND CONSIDERED UNUSABLE.
K	THE IDENTIFICATION OF THE ANALYTE IS ACCEPTABLE; THE REPORTED VALUE MAY BE BIASED HIGH. THE ACTUAL VALUE IS EXPECTED TO BE LESS THAN THE REPORTED VALUE.
L	THE IDENTIFICATION OF THE ANALYTE IS ACCEPTABLE; THE REPORTED VALUE MAY BE BIASED LOW. THE ACTUAL VALUE IS EXPECTED TO BE GREATER THAN THE REPORTED VALUE.
NV	NOT VALIDATED
INC	RESULT NOT ENTERED



U.S. EPA Region 2 Laboratory  
Data Report

Survey Name: Vestal Well 1-1 [04/05]

Project Number: 05040039

\*Sorted By Sample ID

AG00872 Field/Station ID: INFLUENT  
Matrix: Aqueous

Date Received: 4/26/2005

Sample Description:

Analysis Type: VOA GCMS LOW LEVEL DRINKING WATER

CAS Number	Analyte Name	Result	Remark Codes	Units
75-43-4	DICHLORODIFLUOROMETHANE	---	0.50U	ug/L
000074873	CHLOROMETHANE	---	0.50U	ug/L
000075014	VINYL CHLORIDE	4.4		ug/L
000074839	BROMOMETHANE	---	0.50U	ug/L
000075003	CHLOROETHANE	0.73		ug/L
000075694	TRICHLOROFLUOROMETHANE	---	0.50U	ug/L
000075354	1,1-DICHLOROETHENE	---		ug/L
76-13-1	1,1,2-TRICHLORO-1,2,2-TRIFLUOROETHANE	3.2		ug/L
000075150	CARBON DISULFIDE	---	0.50U	ug/L
000067641	ACETONE	---	1.0U	ug/L
79-20-9	METHYL ACETATE	---	0.50U	ug/L
000075092	METHYLENE CHLORIDE	---	0.50U	ug/L
000156605	TRANS-1,2-DICHLOROETHENE	---	0.50U	ug/L
001634044	METHYL TERT-BUTYL ETHER	3.9		ug/L
000075343	1,1-DICHLOROETHANE	---		ug/L
000156592	CIS-1,2-DICHLOROETHENE	54		ug/L
594-20-7	2,2-DICHLOROPROPANE	---	0.50U	ug/L
000078933	2-BUTANONE	---	1.0U	ug/L
000074975	BROMOCHLOROMETHANE	---	0.50U	ug/L
000067663	CHLOROFORM	---	0.50U	ug/L
71-55-6	1,1,1-TRICHLOROETHANE	---		ug/L
110-82-7	CYCLOHEXANE	---	0.50U	ug/L
000056235	CARBON TETRACHLORIDE	---	0.50U	ug/L
000563586	1,1-DICHLOROPROPENE	---	0.50U	ug/L
000071432	BENZENE	---	0.50U	ug/L
000107062	1,2-DICHLOROETHANE	---	0.50U	ug/L
025323891	TRICHLOROETHENE	---		ug/L
108-87-2	METHYLCYCLOHEXANE	---	0.50U	ug/L
000078875	1,3-DICHLOROPROPENE	---	0.50U	ug/L
000074953	DIBROMOMETHANE	---	0.50U	ug/L
000075274	BROMODICHLOROMETHANE	---	0.50U	ug/L
010061015	CIS-1,3-DICHLOROPROPENE	---	0.50U	ug/L
000108101	4-METHYLBENZENE	---		ug/L
000108883	TOLUENE	---	0.50U	ug/L
010061026	TRANS-1,3-DICHLOROPROPENE	---	0.50U	ug/L
000079005	1,1,2-TRICHLOROETHANE	---	0.50U	ug/L
000127184	TETRACHLOROETHENE	---	0.50U	ug/L
000142289	1,3-DICHLOROPROPANE	---	0.50U	ug/L
000124481	DIBROMOCHLOROMETHANE	---	0.50U	ug/L
000106934	1,2-DIBROMOETHANE	---	0.50U	ug/L
000591786	2-HEXANONE	---	1.0U	ug/L
000108907	CHLOROBENZENE	---	0.50U	ug/L



U.S. EPA Region 2 Laboratory  
Data Report

Survey Name: Vestal Well 1-1 [04/05]

Project Number: 05040039

\*Sorted By Sample ID

**AG00872** Field/Station ID: INFLUENT  
Matrix: Aqueous

Date Received: 4/26/2005

Sample Description:

Analysis Type: VOA GCMS LOW LEVEL DRINKING WATER

CAS Number	Analyte Name	Result	Remark Codes	Units
000630206	1,1,1,2-TETRACHLOROETHANE	---	0.50U	ug/L
100-41-4	ETHYLBENZENE	---	0.50U	ug/L
001330207	M-P-XYLENE	---	0.50U	ug/L
000095476	O-XYLENE	---	0.50U	ug/L
000100425	STYRENE	---	0.50U	ug/L
000075252	BROMOFORM	---	0.50U	ug/L
000098828	ISOPROPYLBENZENE	---	0.50U	ug/L
000108861	BROMOBENZENE	---	0.50U	ug/L
000096184	1,2,3-TRICHLOROPROPANE	---	0.50U	ug/L
000079345	1,1,1,2-TETRACHLOROETHANE	---	0.50U	ug/L
000103651	N-PROPYLBENZENE	---	0.50U	ug/L
000095498	2-CHLOROTOLUENE	---	0.50U	ug/L
106-41-4	4-CHLOROTOLUENE	---	0.50U	ug/L
000108678	1,3,5-TRIMETHYLBENZENE	---	0.50U	ug/L
000098066	1,2,4-TRIMETHYLBENZENE	---	0.50U	ug/L
000095636	1,2,4-TRIMETHYLBENZENE	---	0.50U	ug/L
135-98-8	1,3,5-TRIMETHYLBENZENE	---	0.50U	ug/L
000541731	1,3-DICHLOROBENZENE	---	0.50U	ug/L
000106467	1,4-DICHLOROBENZENE	---	0.50U	ug/L
000095501	1,2-DICHLOROBENZENE	---	0.50U	ug/L
000098876	1,3,5-TRIMETHYLBENZENE	---	0.50U	ug/L
000104518	N-BUTYLBENZENE	---	0.50U	ug/L
000096128	1,2-DIBROMOETHANE	---	0.50U	ug/L
000120821	1,2,4-TRICHLOROBENZENE	---	0.50U	ug/L
87-58-5	HEXACHLOROBENZENE	---	0.50U	ug/L
000091203	NAPHTHALENE	---	0.50U	ug/L
000087616	1,2,3-TRICHLOROBENZENE	---	0.50U	ug/L
1330-20-7	TOTAL XYLENES	---	0.50U	ug/L
	ETHANE, 1,2-DICHLORO-1,1,2-TRIFLUORO-	0.67	NF	ug/L

**AG00873** Field/Station ID: EFFLUENT  
Matrix: Aqueous

Date Received: 4/26/2005

Sample Description:





U.S. EPA Region 2 Laboratory  
Data Report

Survey Name: Vestal Well 1-1 [04/05]

Project Number: 05040039

\*Sorted By Sample ID

AG00873 Field/Station ID: EFFLUENT  
Matrix: Aqueous

Date Received: 4/26/2005

Sample Description:

Analysis Type: VOA GCMS LOW LEVEL DRINKING WATER

CAS Number	Analyte Name	Result	Remark Codes	Units
75-43-4	DICHLORODIFLUOROMETHANE	---	0.50U	ug/L
000074873	CHLOROMETHANE	---	0.50U	ug/L
000075014	VINYL CHLORIDE	---	0.50U	ug/L
000074839	BROMOMETHANE	---	0.50U	ug/L
000075003	CHLOROETHANE	---	0.50U	ug/L
000075694	TRICHLORODIFLUOROMETHANE	---	0.50U	ug/L
000075354	1,1-DICHLOROETHENE	---	0.50U	ug/L
76-13-1	1,1,2-TRICHLORO-1,2-DIFLUOROETHANE	---	0.50U	ug/L
000075150	CARBON DISULFIDE	---	0.50U	ug/L
000067641	ACETONE	---	0.50U	ug/L
79-20-9	METHYL ACETATE	---	0.50U	ug/L
000075092	METHYLENE CHLORIDE	---	0.50U	ug/L
000156605	TRANS-1,2-DICHLOROETHENE	---	0.50U	ug/L
001634044	METHYL TERMBUTYL ETHER	---	0.50U	ug/L
000075343	1,1-DICHLOROETHANE	2.7		ug/L
000156592	CIS-1,2-DICHLOROPROPENE	---	0.50U	ug/L
594-20-7	2,2-DICHLOROPROPANE	---	0.50U	ug/L
000078933	2-BUTANONE	---	1.0U	ug/L
000074975	BROMOCHLOROMETHANE	---	0.50U	ug/L
000067663	CHLOROFORM	---	0.50U	ug/L
71-55-6	1,1,1-TRICHLOROETHANE	7.3		ug/L
110-82-7	CYCLOHEXANE	---	0.50U	ug/L
000056235	CARBON TETRACHLORIDE	---	0.50U	ug/L
000563586	1,1-DICHLOROPROPENE	---	0.50U	ug/L
000071432	BENZENE	---	0.50U	ug/L
000107062	1,2-DICHLOROETHANE	---	0.50U	ug/L
025323891	TRICHLOROETHENE	4.0		ug/L
108-87-2	METHYL CYCLOHEXANE	---	0.50U	ug/L
000078875	1,2-DICHLOROPROPANE	---	0.50U	ug/L
000074953	DIBROMOMETHANE	---	0.50U	ug/L
000075274	BROMODICHLOROMETHANE	---	0.50U	ug/L
010061015	CIS-1,3-DICHLOROPROPENE	---	0.50U	ug/L
000108101	4-METHYL-2-PENTANONE	---	1.0U	ug/L
000108883	TOLUENE	---	0.50U	ug/L
010061026	TRANS-1,3-DICHLOROPROPENE	---	0.50U	ug/L
000079005	1,1,2-TRICHLOROETHANE	---	0.50U	ug/L
000127184	TETRACHLOROETHENE	---	0.50U	ug/L
000142289	1,3-DICHLOROPROPANE	---	0.50U	ug/L

Refer to Page 1 for an explanation of Remark Codes

Report Date: 6/27/2005 3:44PM



U.S. EPA Region 2 Laboratory  
Data Report

Survey Name: Vestal Well 1-1 [04/05]

Project Number: 05040039

\*Sorted By Sample ID

AG00873 Field/Station ID: EFFLUENT

Date Received: 4/26/2005

Matrix: Aqueous

Sample Description:

Analysis Type: VOA GCMS LOW LEVEL DRINKING WATER

CAS Number	Analyte Name	Result	Remark Codes	Units
000124481	DIBROMOCHLOROMETHANE	---	0.50U	ug/L
000106934	1,2-DIBROMOETHANE	---	0.50U	ug/L
000591786	2-HEXANONE	---	1.0U	ug/L
000108907	CHLOROBENZENE	---	0.50U	ug/L
000630206	1,1,1,2-TETRACHLOROETHANE	---	0.50U	ug/L
100-41-4	ETHYLBENZENE	---	0.50U	ug/L
001330207	M/P-XYLENE	---	0.50U	ug/L
000095476	O-XYLENE	---	0.50U	ug/L
000100425	STYRENE	---	0.50U	ug/L
000075252	BROMOFORM	---	0.50U	ug/L
000098828	ISOPROPYLBENZENE	---	0.50U	ug/L
000108861	BROMOBENZENE	---	0.50U	ug/L
000096184	1,2,3-TRICHLOROPROPANE	---	0.50U	ug/L
000079345	1,1,2,2-TETRACHLOROETHANE	---	0.50U	ug/L
000103651	N-PROPYLBENZENE	---	0.50U	ug/L
000093498	2-CHLOROTOLUENE	---	0.50U	ug/L
106-43-4	4-CHLOROTOLUENE	---	0.50U	ug/L
000108678	1,3-DIMETHYLBENZENE	---	0.50U	ug/L
000098066	TERT-BUTYLBENZENE	---	0.50U	ug/L
000095636	1,2-DIMETHYLBENZENE	---	0.50U	ug/L
135-98-8	SEC-BUTYLBENZENE	---	0.50U	ug/L
000517730	1,3-DICHLOROBENZENE	---	0.50U	ug/L
000106467	1,4-DICHLOROBENZENE	---	0.50U	ug/L
000095501	1,2-DICHLOROBENZENE	---	0.50U	ug/L
000099876	4-ISOPROPYLTOLUENE	---	0.50U	ug/L
000104518	N-BUTYLBENZENE	---	0.50U	ug/L
000096128	1,2-DIBROMO-3-CHLOROPROPANE	---	0.50U	ug/L
000120821	1,2,4-TRICHLOROBENZENE	---	0.50U	ug/L
87-68-3	HEXACHLOROBUTADIENE	---	0.50U	ug/L
000091203	NAPHTHALENE	---	0.50U	ug/L
000087616	1,2,3-TRICHLOROBENZENE	---	0.50U	ug/L
1330-20-7	TOTAL XYLENES	---	0.50U	ug/L

Project Approval: J. D. [Signature]

Date: 7-5-05

Refer to Page 1 for an explanation of Remark Codes

Report Date: 6/27/2005 3:44PM