



ecology and environment engineering, p.c.

International Specialists in the Environment

BUFFALO CORPORATE CENTER
368 Pleasant View Drive
Lancaster, New York 14086
Tel: (716) 684-8060, Fax: (716) 684-0844

October 7, 2011

Mr. William Welling, Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation
625 Broadway, 12th Floor
Albany, New York 12233 - 7013

Re: Mr. C's Dry Cleaners Site, Contract # D004442.DC13, Site # 9-15-157
September 2011 Operations, Maintenance, and Monitoring Report

Dear Mr. Welling:

Ecology and Environment Engineering, P.C. (EEEEPC) is pleased to provide the September 2011 Operations, Maintenance, and Monitoring (OM&M) Report for the Mr. C's Dry Cleaners Site, NYSDEC Site # 9-15-157, located in East Aurora, New York. Copies of weekly inspection reports prepared by EEEPC's subcontractor, Iyer Environmental Group, PLLC (IEG) are provided in Attachment A. Selected pages from the individual analytical data package prepared by Mitkem Laboratories, Inc. (MLI) are provided as Attachments B. The full analytical report along with QA/QC information will be retained by EEEPC. Remedial treatment system utility costs for the Mr. C's and Agway sites are provided as Attachment C.

In review of the on-site treatment system operations, monitoring and maintenance for September 2011, EEEPC offers the following comments and highlights:

Operational Summary

Mr. C's Site – Remedial Operations Information

- Checklists for weekly system inspections from IEG are provided as Attachment A for 9/5, 9/12, 9/20, 9/26, and 10/3 2011.
- Based on the weekly inspection results performed by IEG, the remedial treatment system had a 100.00% operational up-time (Table 1) and the treatment of contaminated groundwater totaling of 196,557 gallons (Table 2) for September 2011.
- Lower groundwater flows this month were attributed to level transducer problems in pumping wells – PW-4 and PW-5 and pump issues in RW-1. Corrective actions are in process and to be completed in October 2011.
- The analytical samples for the monthly compliance were taken on September 7, 2011. The sampling results were received by EEEPC on September 28, 2011.
- Excerpts from the Analytical Data packages for the sampling events are presented in Attachments B.

Mr. William Welling, Project Manager

October 7, 2011

Page 2 of 2

- A review of the analytical data from September 28, 2011 indicated no non-compliance issues were encountered.
- The analytical results revealed the influent concentration to be 1845.0 µg/L or 1845 ppb, and 0.0 µg/L or 0 ppb of treated effluent. The summary of influent and effluent contaminant concentrations for the September 28, 2011 sampling event is presented in Table 4.
- Overall cleanup efficiency for the contaminants of concern at the site during the reporting / operating period 9/5/11 to 10/3/11 was 100.0%. The air stripper unit on the Mr. C's property is in compliance and MLI continues to provide analytical data to sub-ppb accuracy, supporting the accurate determination of effluent contaminant levels. The summary of Effluent Discharge Criteria & Analytical Compliance Results for September 2011 is presented in Table 3.
- The Mr. C's treatment system based on the total monthly flows has effectively removed 3.03 lbs. of targeted contaminants from the groundwater below the site in the month of September 2011. The calculations and data for the month are presented in Table 5.

Agway Site Remedial Information

- No current operational issues.

Subslab Depressurization Systems (SSDS) – First Presbyterian Church and 27 Whaley Ave. sites

- No current operational issues.
- Reports of analytical results and system operations reports both sites were issued September 12, and 13, 2011.


Mr. C's and Agway Energy Usage Information

A copy of the site utility costs from the Mr. C's and Agway remedial operations for September 2011 are provided as Attachment C.

If you have questions regarding the September 2011 OM&M report summary, please do not hesitate to contact me at 716-684-8060.

Very Truly Yours,

Ecology and Environment Engineering, P. C.



Michael G. Steffan

Project Manager

cc: D. Szymanski, Region 9, NYSDEC - Buffalo w/ attachments
D. Iyer, IEG – w/attachments
CTF- 002700.DC13.02.01.01

Table 1
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
System Operational Time

Month	Reporting Hours	Operational Up-time
(Up-time from inception to 1/5/11)	70,656.50	96.11%
January 5, 2011 - February 1, 2011	648	100.00%
February 1, 2011 - March 7, 2011	840	100.00%
March 7, 2011 - March 29, 2011	528	100.00%
March 29, 2011 - May 3, 2011	775	92.26%
May 3, 2011 - May 31, 2011	672	100.00%
May 31, 2011 - July 5, 2011	840	100.00%
July 5, 2011 - July 25, 2011	480	100.00%
July 25, 2011 - September 5, 2011	1008	100.00%
September 5, 2011 - October 3, 2011	672	100.00%
Total Hours from System Startup '2/02'	77,119.50	
Average Operational Up-time from startup =		96.35%
Average Operational Up-time for 2011 =		99.00%

NOTES:

1. Up-time based as percentage of total reporting hours.
2. Treatment system operated by the Tyree Organization Ltd. from 9/02 - 9/03.
3. Treatment system operated by O&M Enterprises Inc. from 10/03 - 7/07.
4. Treatment system operated by Iyer Environmental Group from 7/07 to present.

Table 1
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
System Operational Time

Month	Reporting Hours	Operational Up-time
(Up-time from inception to 1/5/11)	70,656.50	96.11%
January 5, 2011 - February 1, 2011	648	100.00%
February 1, 2011 - March 7, 2011	840	100.00%
March 7, 2011 - March 29, 2011	528	100.00%
March 29, 2011 - May 3, 2011	775	92.26%
May 3, 2011 - May 31, 2011	672	100.00%
May 31, 2011 - July 5, 2011	840	100.00%
July 5, 2011 - July 25, 2011	480	100.00%
July 25, 2011 - September 5, 2011	1008	100.00%
September 5, 2011 - October 3, 2011	672	100.00%
Total Hours from System Startup '2/02'	77,119.50	
Average Operational Up-time from startup =		96.35%
Average Operational Up-time for 2011 =		99.00%

NOTES:

1. Up-time based as percentage of total reporting hours.
2. Treatment system operated by the Tyree Organization Ltd. from 9/02 - 9/03.
3. Treatment system operated by O&M Enterprises Inc. from 10/03 - 7/07.
4. Treatment system operated by Iyer Environmental Group from 7/07 to present.

Table 2
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
Monthly Process Water Volumes

Month	Actual Period	Gallons (Treated Effluent)
Total - Inception to December 2010	9/5/02 - 1/5/11	114,331,011
January 2011 ³	1/5/11 - 2/1/11	369,337
February 2011 ³	2/1/11 - 3/7/11	472,292
March 2011 ³	3/7/11 - 3/29/11	345,421
April 2011 ³	3/29/11 - 5/3/11	515,800
May 2011 ³	5/3/11 - 5/31/11	437,681
June 2011 ³	5/31/11 - 7/5/11	538,190
July 2011 ³	7/5/11 - 7/25/11	227,334
August 2011 ³	7/25/11 - 9/5/11	371,276
September 2011 ³	9/5/11 - 10/3/11	196,557
October 2011 ³		
November 2011 ³		
December 2011 ³		
Total Gallons Treated in 2011		3,473,888
Total Gallons Treated To Date:		117,804,899

NOTES:

1. System operated by Tyree Organization Ltd. From 9/02 - 9/03.
2. System operated by O&M Enterprises from 10/03 - 7/07.
3. System operated by IEG PLLC from 7/07 - present.

Table 3
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
Effluent Discharge Criteria & Analytical Compliance Results

Parameter/Analyte	Daily Maximum	Units	September 7, 2011 - Effluent Analytical Values ⁴ - Compliance
Flow	N/A	gpd	7,020
pH	6.0 - 9.0	standard units	8.30
1,1 Dichloroethene	10	µg/L	ND(<1.0)
1,1 Dichloroethane	10	µg/L	ND(<1.0)
cis-1,2-dichloroethene	10	µg/L	ND(<1.0)
Trichloroethene	10	µg/L	ND(<1.0)
Tetrachloroethene	10	µg/L	ND(<1.0)
Vinyl Chloride	10	µg/L	ND(<1.0)
Benzene	5	µg/L	ND(<1.0)
Ethylbenzene	5	µg/L	ND(<1.0)
Methylene Chloride	10	µg/L	ND(<1.0)
1,1,1 Trichloroethane	10	µg/L	ND(<1.0)
Toluene	5	µg/L	ND(<1.0)
Methyl-t-Butyl Ether (MTBE)	NA	ug/L	ND(<1.0)
o-Xylene ²	5	µg/L	NA
m, p-Xylene ²	10	µg/L	NA
Total Xylenes	NA	ug/L	ND(<1.0)
Iron, total	600	µg/L	NA ⁹
Aluminum	4,000	µg/L	NA ⁹
Copper	48	µg/L	NA ⁹
Lead	11	µg/L	NA ⁹
Manganese	2,000	µg/L	NA ⁹
Silver	100	µg/L	NA ⁹
Vanadium	28	µg/L	NA ⁹
Zinc	230	µg/L	NA ⁹
Total Dissolved Solids	350	mg/L	NA ⁹
Total Suspended Solids	20	mg/L	NA ⁹
Hardness	N/A	mg/L	530
Cyanide, Free	10	µg/L	NA ⁹

NOTES:

1. "Daily Maximum" excerpted from Attachment E of Addendum 1 to the Construction Contract Documents dated October 2000.
2. Analytical report did not differentiate between o-Xylene and m, p-Xylene. Total Xylene value reported is given in each line.
3. Shaded cells indicate that analytical value exceeds the "Daily Maximum."
4. "ND" indicates that the compound was not detected and lists the practical quantitation limit in parentheses.
5. "NA" indicates that analyses were not performed and data is unavailable.
6. Average flows based on effluent readings taken September 5, 2011 through October 3, 2011. Total gallons: 196,557 divided by 28 operating days.
7. "J" indicates an estimated value below the detection limit.
8. "B" indicates analyte found in the associated blank.
9. Removed from the required analysis list by NYSDEC Region 9 in February 2005.

40 Indicates non-compliance with the NYSDEC effluent discharge requirements
NR Indicates Not Reported by Lab

Table 4
Mr. C's Dry Cleaners Site Remediation
NYSDEC Site #9-15-157
September 2011 VOC Analytical Summary

Compound	Based on the 9/28/11 Effluent Sampling Results		
	Influent Concentration* (ug/L)	Effluent Concentration* (ug/L)	Cleanup Efficiency** (%)
Acetone	ND (<50.0)	U	NA
Benzene	ND (<10.0)	U	NA
2-Butanone	ND (<50.0)	U	NA
cis-1, 2-Dichloroethene	100.0	U	100.00%
Methylene chloride	ND (<10.0)	U	NA
Methyl tert-butyl ether (MTBE)	15	U	100.00%
Tetrachloroethene	1600.0	U	100.00%
Toluene	ND (<10.0)	U	NA
Trichloroethene	130.0	U	100.00%
Carbon Disulfide	ND (<10.0)	U	NA
1,1,2 Trichloro-1,2,2-trifluoroethane	ND (<10.0)	U	NA
Cyclohexane	ND (<10.0)	U	NA
trans-1,2-dichloroethene	ND (<10.0)	U	NA
Chlorobenzene	ND (<10.0)	U	NA
Methylcyclohexane	ND (<10.0)	U	NA
Methyl acetate	ND (<10.0)	U	NA
Total Xylenes	ND (<10.0)	U	NA
September 2011 TOTALs (in ug/L) =	1845.0	0.00	100.00%

- Notes:
1. "NA" = Not applicable
 2. "ND" or "U" = Compound analyzed, but was not detected. Detection limit in parentheses.
 3. "J" indicates an estimated value below the practical quantitation limit but above the method detection limit.
 4. Non-detect values are assumed to be equal to zero for calculation of monthly average concentrations.
 5. "D" = Compounds identified in analysis required secondary dilution factoring.
 6. "B" indicates analyte found in the associated blank.

* (<50) - Detection Limit
 ** Contaminants of Concern only

Table 5
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
Monthly VOCs Removed From Groundwater

Month	Actual Period	Influent VOCs (µg/L)	Effluent VOCs (µg/L)	VOCs Removed (lbs.)
Total pounds of VOCs removed from inception to December 2010 =				1479.64
January 2011	1/5/11 - 2/1/11	1035.3	3.81	4.15
February 2011	2/1/11 - 3/7/11	1310.0	0.73	3.03
March 2011	3/7/11 - 3/29/11	1541.0	0.00	4.44
April 2011	3/29/11 - 5/3/11	1121.0	0.74	4.82
May 2011	5/3/11 - 5/31/11	785.0	5.20	2.85
June 2011	5/31/11 - 7/5/11	1447.8	3.10	6.49
July 2011	7/5/11 - 7/25/11	1625.3	3.01	3.08
August 2011	7/25/11 - 9/5/11	1330.0	0.97	4.12
September 2011	9/5/11 - 10/3/11	1845.0	0.00	3.03
October 2011				
November 2011				
December 2011				
Total pounds of VOCs removed from inception =				1,515.65
Total pounds of VOCs removed in 2011 =				32.98

HISTORICAL NOTES:

1. Calculations are based on monthly water samples and assumes samples are representative of the entire reporting period.
2. Calculations assume that non-detect values = 0 ug/L.
3. Total VOCs summations include estimated "J" values.
4. Calculations are based on effluent totalizer readings.
5. "Influent VOCs" and "Effluent VOCs" values given above is the summation of values for individual compounds given in monthly analytical reports.
6. No samples were collected in September 2003. August 2003 values are used.
7. Treatment system operated by Tyree Organization, Ltd. from 9/02 to 9/03.
8. Treatment system operated by O&M Enterprises from 10/03 to 7/07.
9. Treatment system operated by IEG from 7/07 to present.

CONVERSIONS:

- 1 pound = 453.5924 grams
- 1 gallon = 3.785 liters

Based on the Analytical Results from Each Month:

Pounds of VOCs removed calculated by the following formula:

$$(VOCs_{Influent} - VOCs_{Effluent})(\mu g/L) \cdot (1g/10^6 \mu g) \cdot (1 lb/453.5924 g) \cdot (Monthly\ process\ water)(gal) \cdot (3.785 L/gallon)$$

Attachment A
IEG Weekly Inspection Reports
September 2011

Including:

9/5/11

9/12/11

9/20/11

9/26/11

10/3/11

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 5-Sep-11 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____

WEATHER CONDITIONS: Cloudy, warm OUTSIDE TEMPERATURE (° F): 68

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
RW-1, PW-4, PW-5 and PW-8 are OFF due to maintenance problems.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: <input checked="" type="checkbox"/>	OFF: <u>11</u> ft	PW-5	ON: <input checked="" type="checkbox"/>	OFF: <u>192</u> ft
PW-2	ON: <input checked="" type="checkbox"/>	OFF: <u>98</u> ft	PW-6	ON: _____	OFF: <input checked="" type="checkbox"/> <u>7</u> ft
PW-3	ON: _____	OFF: <input checked="" type="checkbox"/> <u>5</u> ft	PW-7	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>4</u> ft
PW-4	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>23</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>17</u> ft

EQUALIZATION TANK: 4 ft Last Alarm D/T/Condition: 8/26/11 RW-1 Overload

NOTES: _____

INFLUENT FLOW RATE: 9 gpm INFLUENT TOTALIZER READING: 8,486,575.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 15 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 25.5 gallons
 SEQUESTERING AGENT FEED RATE: 8.0 ml/min METERING PUMP PRESSURE: 3.0 psi

		Top	Bottom		Top	Bottom
BAG FILTER PRESSURES:	LEFT:	<u>35</u>	<u>0</u> psi	RIGHT:	<u>42</u>	<u>0</u> psi

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 14 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 26.0 in. H₂O
 AIR STRIPPER DIFFERENTIAL PRESSURE: 0.032 in. H₂O DISCHARGE PRESSURE: 1.8 in. H₂O

EFFLUENT PUMP IN USE: #1 _____ #2 EFFLUENT FEED PUMP PRESSURE: 5.0 psi
 EFFLUENT FLOW RATE: _____ gpm EFFLUENT TOTALIZER READING: 65,376,706 761980 gallons

ARE BUILDING HEATERS IN USE? YES: _____ NO: INSIDE TEMPERATURE (° F): 76

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:
 WATER LEVEL IN SUMP: 6.5 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE
NYSDEC Site #90150157
SITE INSPECTION FORM

5-Sep-11

SAMPLES COLLECTED? YES: NO:

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	INF	9:00 AM	7.17	12.00	17.5	2795
AIR STRIPPER EFFLUENT:	EFF	9:00 AM	8.62	9.07	19.9	2772

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS? YES: NO:

WERE MANHOLES INSPECTED? YES: NO:

WERE ELECTRICAL BOXES INSPECTED? YES: NO:

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: NO:

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 and PZ-4B have collapsed inner rings.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks:

Other Actions: Changed bag filters.

PZ-4B - replaced collapsed inner ring.

AGWAY

SYSTEM VACUUM: <u>-20</u> in. H ₂ O				AIR PRESSURE: <u>120</u> psi					
SP-1:	<u>0.0</u>	scfm	<u>26.0</u>	psi	SP-5:	<u>-----</u>	scfm	<u>-----</u>	psi
SP-2:	<u>0.0</u>	scfm	<u>> 30</u>	psi	SP-6:	<u>-----</u>	scfm	<u>-----</u>	psi
SP-3:	<u>0.0</u>	scfm	<u>30.0</u>	psi	SP-7:	<u>-----</u>	scfm	<u>-----</u>	psi
SP-4:	<u>0.0</u>	scfm	<u>> 30</u>	psi	SP-8:	<u>-----</u>	scfm	<u>-----</u>	psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: SVE vacuum drum is dry.

Recommend leveling shed.

Other Actions:

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 12-Sep-11 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____

WEATHER CONDITIONS: Partly cloudy, warm OUTSIDE TEMPERATURE (° F): 70

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
RW-1, PW-4, PW-5 and PW-8 are OFF due to maintenance problems.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: <input checked="" type="checkbox"/>	OFF: <u>11</u> ft	PW-5	ON: <input checked="" type="checkbox"/>	OFF: <u>198</u> ft
PW-2	ON: <input checked="" type="checkbox"/>	OFF: <u>21</u> ft	PW-6	ON: _____	OFF: <input checked="" type="checkbox"/> <u>7</u> ft
PW-3	ON: _____	OFF: <input checked="" type="checkbox"/> <u>4</u> ft	PW-7	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>6</u> ft
PW-4	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>17</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>12</u> ft

EQUALIZATION TANK: 4 ft Last Alarm D/T/Condition: 9/5/11 Air Stripper Low Level

NOTES: PW-8 remains ON at a steady level 4.

INFLUENT FLOW RATE: 6 gpm INFLUENT TOTALIZER READING: 8,558,631.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 3 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 5 gallons
 SEQUESTERING AGENT FEED RATE: 7.0 ml/min METERING PUMP PRESSURE: 3.0 psi

BAG FILTER PRESSURES:	Top	Bottom	Top	Bottom
	LEFT: <u>0</u>	<u>0</u> psi	RIGHT: <u>8</u>	<u>0</u> psi

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 14 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 30.0 in. H₂O
 AIR STRIPPER DIFFERENTIAL PRESSURE: 0.03 in. H₂O DISCHARGE PRESSURE: 1.7 in. H₂O

EFFLUENT PUMP IN USE: #1 _____ #2 EFFLUENT FEED PUMP PRESSURE: 5.0 psi
 EFFLUENT FLOW RATE: 114 gpm EFFLUENT TOTALIZER READING: 65,418,576 804370 gallons

ARE BUILDING HEATERS IN USE? YES: _____ NO: INSIDE TEMPERATURE (° F): 78

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:
 WATER LEVEL IN SUMP: 7.0 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE
NYSDEC Site #90150157
SITE INSPECTION FORM

12-Sep-11

SAMPLES COLLECTED? YES: _____ NO: ✓

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	_____	_____	_____	_____	_____	_____
AIR STRIPPER EFFLUENT:	_____	_____	_____	_____	_____	_____

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS: ? YES: _____ NO: ✓

WERE MANHOLES INSPECTED? YES: ✓ NO: _____

WERE ELECTRICAL BOXES INSPECTED? YES: ✓ NO: _____

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: _____ NO: ✓

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has collapsed inner ring.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks: _____

Other Actions: PZ-4B - applied Sakrete asphalt patch up to grade.

Switched Redux pickup to new drum. Have (2) full drums.

AGWAY

SYSTEM VACUUM: <u>-20</u> in. H ₂ O				AIR PRESSURE: <u>100</u> psi			
SP-1:	<u>0.0</u>	scfm	<u>26.5</u> psi	SP-5:	-----	scfm	----- psi
SP-2:	<u>0.0</u>	scfm	<u>> 30</u> psi	SP-6:	-----	scfm	----- psi
SP-3:	<u>0.0</u>	scfm	<u>30.0</u> psi	SP-7:	-----	scfm	----- psi
SP-4:	<u>0.0</u>	scfm	<u>> 30</u> psi	SP-8:	-----	scfm	----- psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: SVE vacuum drum is dry.

Bank 2 is OFF due to maintenance problem. Replaced Bank 2 timer motor.

Other Actions: _____

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 20-Sep-11 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____

WEATHER CONDITIONS: Partly cloudy, warm OUTSIDE TEMPERATURE (° F): 65

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
RW-1, PW-4 and PW-5 are OFF due to maintenance problems.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: <input checked="" type="checkbox"/>	OFF: <u>11</u> ft	PW-5	ON: <input checked="" type="checkbox"/>	OFF: <u>183</u> ft
PW-2	ON: <input checked="" type="checkbox"/>	OFF: <u>23</u> ft	PW-6	ON: _____	OFF: <input checked="" type="checkbox"/> <u>5</u> ft
PW-3	ON: <input checked="" type="checkbox"/>	OFF: <u>28</u> ft	PW-7	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>4</u> ft
PW-4	ON: <input checked="" type="checkbox"/>	OFF: <u>16</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>5</u> ft

EQUALIZATION TANK: 4 ft Last Alarm D/T/Condition: 9/5/11 Air Stripper Low Level

NOTES: _____

INFLUENT FLOW RATE: 10 gpm INFLUENT TOTALIZER READING: 8,662,929.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 26 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 44 gallons
 SEQUESTERING AGENT FEED RATE: 4.0 ml/min METERING PUMP PRESSURE: 3.0 psi

BAG FILTER PRESSURES:	LEFT:	Top	Bottom	RIGHT:	Top	Bottom
		<u>24</u>	<u>0</u> psi		<u>29</u>	<u>0</u> psi

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 14 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 33.0 in. H₂O
 AIR STRIPPER DIFFERENTIAL PRESSURE: 0.026 in. H₂O DISCHARGE PRESSURE: 1.4 in. H₂O

EFFLUENT PUMP IN USE: #1 _____ #2 EFFLUENT FEED PUMP PRESSURE: 4.5 psi
 EFFLUENT FLOW RATE: 116 gpm EFFLUENT TOTALIZER READING: 65,479,660 866020 gallons

ARE BUILDING HEATERS IN USE? YES: _____ NO: INSIDE TEMPERATURE (° F): 78

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:
 WATER LEVEL IN SUMP: 6.0 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE
NYSDEC Site #90150157
SITE INSPECTION FORM

20-Sep-11

SAMPLES COLLECTED? YES: NO:

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	_____	_____	_____	_____	_____	_____
AIR STRIPPER EFFLUENT:	_____	_____	_____	_____	_____	_____

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS: ? YES: NO:

WERE MANHOLES INSPECTED? YES: NO:

WERE ELECTRICAL BOXES INSPECTED? YES: NO:

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: NO:

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has a collapsed inner ring.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks: Sent Lab Samples: (2) Influent HCL vials; (2) Effluent HCL vials.

Other Actions: Increased Redux pump slightly to: Left 2.5; Right 1.5.

AGWAY

SYSTEM VACUUM: <u>-21</u> in. H ₂ O				AIR PRESSURE: <u>60</u> psi					
SP-1:	<u>0.0</u>	scfm	<u>26.0</u>	psi	SP-5:	<u>0.0</u>	scfm	<u>28.5</u>	psi
SP-2:	<u>0.0</u>	scfm	<u>> 30</u>	psi	SP-6:	<u>0.0</u>	scfm	<u>> 30</u>	psi
SP-3:	<u>0.0</u>	scfm	<u>30.0</u>	psi	SP-7:	<u>0.0</u>	scfm	<u>> 30</u>	psi
SP-4:	<u>0.0</u>	scfm	<u>> 30</u>	psi	SP-8:	<u>0.0</u>	scfm	<u>> 30</u>	psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: SVE vacuum drum is dry.

Other Actions:

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: <u>26-Sep-11</u>		ACTIVITIES: <u>Site Inspection</u>	
INSPECTION PERSONNEL: <u>R. Allen</u>		OTHER PERSONNEL: _____	
WEATHER CONDITIONS: <u>Sunny, warm</u>		OUTSIDE TEMPERATURE (° F): <u>79</u>	
ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: <input checked="" type="checkbox"/>			
If "NO", provide explanation below <u>RW-1, PW-4 and PW-5 are OFF due to maintenance problems.</u>			
PROVIDE WATER LEVEL READINGS ON CONTROL PANEL			
RW-1	ON: <input checked="" type="checkbox"/>	OFF: <u>11</u> ft	PW-5 ON: <input checked="" type="checkbox"/> OFF: <u>181</u> ft
PW-2	ON: _____	OFF: <input checked="" type="checkbox"/> <u>65519</u> ft	PW-6 ON: <input checked="" type="checkbox"/> OFF: <u>5</u> ft
PW-3	ON: <input checked="" type="checkbox"/>	OFF: <u>32</u> ft	PW-7 ON: <input checked="" type="checkbox"/> OFF: <u>7</u> ft
PW-4	ON: <input checked="" type="checkbox"/>	OFF: <u>20</u> ft	PW-8 ON: <input checked="" type="checkbox"/> OFF: <u>7</u> ft
EQUALIZATION TANK: <u>4</u> ft		Last Alarm D/T/Condition: <u>9/5/11 Air Stripper Low Level</u>	
NOTES: <u>PW-7 and PW-8 remain ON at a steady level 6 or 7.</u>			
INFLUENT FLOW RATE: <u>8</u> gpm		INFLUENT TOTALIZER READING: <u>8,736,664.0</u> gallons	
SEQUESTERING AGENT DRUM LEVEL: <u>20</u> inches		(x 1.7=) AMOUNT OF AGENT REMAINING: <u>34</u> gallons	
SEQUESTERING AGENT FEED RATE: <u>4.0</u> ml/min		METERING PUMP PRESSURE: <u>2.0</u> psi	
BAG FILTER PRESSURES:			
LEFT: <u>38</u> ^{Top} <u>0</u> ^{Bottom} psi		RIGHT: <u>45</u> ^{Top} <u>0</u> ^{Bottom} psi	
INFLUENT FEED PUMP IN USE: #1 <input checked="" type="checkbox"/> #2 _____		INFLUENT PUMP PRESSURE: <u>14</u> psi	
AIR STRIPPER BLOWER IN USE: #1 <input checked="" type="checkbox"/> #2 _____		AIR STRIPPER PRESSURE: <u>35.0</u> in. H ₂ O	
AIR STRIPPER DIFFERENTIAL PRESSURE: <u>0.026</u> in. H ₂ O		DISCHARGE PRESSURE: <u>1.2</u> in. H ₂ O	
EFFLUENT PUMP IN USE: #1 _____ #2 <input checked="" type="checkbox"/>		EFFLUENT FEED PUMP PRESSURE: <u>4.0</u> psi	
EFFLUENT FLOW RATE: <u>108</u> gpm		EFFLUENT TOTALIZER READING: <u>65,523,443</u> <u>910090</u> gallons	
ARE BUILDING HEATERS IN USE? YES: _____ NO: <input checked="" type="checkbox"/>		INSIDE TEMPERATURE (° F): <u>88</u>	
IS SUMP PUMP IN USE: YES: <input checked="" type="checkbox"/> NO: _____		ARE ANY LEAKS PRESENT? YES: _____ NO: <input checked="" type="checkbox"/>	
WATER LEVEL IN SUMP: <u>7.0</u> in.		TREATMENT BUILDING CLEAN & ORGANIZED? YES: <input checked="" type="checkbox"/> NO: _____	

MR. C's DRY CLEANERS SITE
NYSDEC Site #90150157
SITE INSPECTION FORM

26-Sep-11

SAMPLES COLLECTED? YES: _____ NO: √

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	_____	_____	_____	_____	_____	_____
AIR STRIPPER EFFLUENT:	_____	_____	_____	_____	_____	_____

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS: ? YES: _____ NO: √
 WERE MANHOLES INSPECTED? YES: √ NO: _____
 WERE ELECTRICAL BOXES INSPECTED? YES: √ NO: _____
 IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: _____ NO: √

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has a collapsed inner ring

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks: _____

Other Actions: Changed bag filters.

Cleaned Air Stripper through port access with steel brushes.

AGWAY

SYSTEM VACUUM: <u> -20 </u> in. H ₂ O				AIR PRESSURE: <u> 105 </u> psi			
SP-1:	<u> 0.0 </u>	scfm	<u> 26.0 </u> psi	SP-5:	<u> 0.0 </u>	scfm	<u> 28.0 </u> psi
SP-2:	<u> 0.0 </u>	scfm	<u> > 30 </u> psi	SP-6:	<u> 0.0 </u>	scfm	<u> 30.0 </u> psi
SP-3:	<u> 0.0 </u>	scfm	<u> 30.0 </u> psi	SP-7:	<u> 0.0 </u>	scfm	<u> > 30 </u> psi
SP-4:	<u> 0.0 </u>	scfm	<u> > 30 </u> psi	SP-8:	<u> 0.0 </u>	scfm	<u> > 30 </u> psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: SVE vacuum drum is dry.

Other Actions: _____

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 3-Oct-11 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____

WEATHER CONDITIONS: Partly cloudy, warm OUTSIDE TEMPERATURE (° F): 66

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
RW-1, PW-4 and PW-5 are OFF due to maintenance problems.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>11</u> ft	PW-5	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>180</u> ft
PW-2	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>103</u> ft	PW-6	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>4</u> ft
PW-3	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>31</u> ft	PW-7	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>7</u> ft
PW-4	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>22</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>4</u> ft

EQUALIZATION TANK: 4 ft Last Alarm D/T/Condition: 9/26/11 Air Stripper Low Level

NOTES: _____

INFLUENT FLOW RATE: 8 gpm INFLUENT TOTALIZER READING: 8,819,812.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 12 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 20.5 gallons
 SEQUESTERING AGENT FEED RATE: 6.0 ml/min METERING PUMP PRESSURE: 3.0 psi

BAG FILTER PRESSURES:	Top	Bottom	psi	RIGHT:	Top	Bottom	psi
	LEFT:	<u>0</u>			<u>0</u>	<u>0</u>	

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 14 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 19.0 in. H₂O
 AIR STRIPPER DIFFERENTIAL PRESSURE: 0.032 in. H₂O DISCHARGE PRESSURE: 2.2 in. H₂O

EFFLUENT PUMP IN USE: #1 _____ #2 EFFLUENT FEED PUMP PRESSURE: 5.0 psi
 EFFLUENT FLOW RATE: 114 gpm EFFLUENT TOTALIZER READING: 65,573,263 960670 gallons

ARE BUILDING HEATERS IN USE? YES: _____ NO: INSIDE TEMPERATURE (° F): 72

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:
 WATER LEVEL IN SUMP: 7.5 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE
NYSDEC Site #90150157
SITE INSPECTION FORM

3-Oct-11

SAMPLES COLLECTED? YES: NO:

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	INF	1:00 PM	7.22	10.13	15.7	2559
AIR STRIPPER EFFLUENT:	EFF	1:00 PM	8.61	9.44	17.3	2608

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS? YES: NO:

WERE MANHOLES INSPECTED? YES: NO:

WERE ELECTRICAL BOXES INSPECTED? YES: NO:

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: NO:

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has collapsed inner ring.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks:

Other Actions:

AGWAY

SYSTEM VACUUM: <u>-21</u> in. H ₂ O				AIR PRESSURE: <u>70</u> psi					
SP-1:	<u>0.0</u>	scfm	<u>26.0</u>	psi	SP-5:	<u>0.0</u>	scfm	<u>28.5</u>	psi
SP-2:	<u>0.0</u>	scfm	<u>> 30</u>	psi	SP-6:	<u>0.0</u>	scfm	<u>30.0</u>	psi
SP-3:	<u>0.0</u>	scfm	<u>30.0</u>	psi	SP-7:	<u>0.0</u>	scfm	<u>> 30</u>	psi
SP-4:	<u>0.0</u>	scfm	<u>> 30</u>	psi	SP-8:	<u>0.0</u>	scfm	<u>> 30</u>	psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: Drained (3) gals from SVE drum.

Other Actions:

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: PIEZOMETER WATER LEVEL LOG

Date: 28-Sep-11

Measurements taken by: R. Allen

RW-1	<u>13.90</u> ft	Comments:	
PZ-1A	<u>11.67</u> ft	Comments:	
PZ-1B	<u>20.15</u> ft	Comments:	
PZ-1C	<u>12.65</u> ft	Comments:	
PZ-1D	<u>12.81</u> ft	Comments:	
PW-2	<u>26.70</u> ft	Comments:	
PZ-2A	<u>26.67</u> ft	Comments:	
PZ-2B	<u>11.69</u> ft	Comments:	
PZ-2C	<u>11.12</u> ft	Comments:	
MW-7	<u>11.66</u> ft	Comments:	Substitute for 2D
PW-3	<u>27.30</u> ft	Comments:	
PZ-3A	<u>11.72</u> ft	Comments:	
PZ-3B	<u>11.85</u> ft	Comments:	
PZ-3C	<u>12.34</u> ft	Comments:	
PZ-3D	<u>11.84</u> ft	Comments:	
PW-4	<u>-----</u> ft	Comments:	collapsed ring
PZ-4A	<u>11.65</u> ft	Comments:	
PZ-4B	<u>19.05</u> ft	Comments:	
PZ-4C	<u>-----</u> ft	Comments:	sealed over
PZ-4D	<u>10.74</u> ft	Comments:	

PW-5	<u>19.00</u> ft	Comments:	
PZ-5A	<u>11.13</u> ft	Comments:	
PZ-5B	<u>11.12</u> ft	Comments:	
PZ-5C	<u>10.70</u> ft	Comments:	
PZ-5D	<u>11.56</u> ft	Comments:	
PW-6	<u>19.30</u> ft	Comments:	
PZ-6A	<u>12.12</u> ft	Comments:	
PZ-6B	<u>11.98</u> ft	Comments:	
PZ-6C	<u>12.15</u> ft	Comments:	
PZ-6D	<u>15.63</u> ft	Comments:	Shown as RW-2 on map
PW-7	<u>17.60</u> ft	Comments:	
MPI-6S	<u>11.58</u> ft	Comments:	
PZ-7B	<u>11.94</u> ft	Comments:	
OW-B	<u>20.05</u> ft	Comments:	
PZ-7D	<u>11.52</u> ft	Comments:	
PW-8	<u>18.30</u> ft	Comments:	
PZ-8A	<u>8.68</u> ft	Comments:	
PZ-8B	<u>8.68</u> ft	Comments:	
PZ-8C	<u>8.50</u> ft	Comments:	
PZ-8D	<u>8.09</u> ft	Comments:	

PUMPS IN OPERATION DURING MEASUREMENTS

RW-1 pump on?	<u> </u> Yes	<u> √ </u> No	PW-5 pump on?	<u> </u> Yes	<u> √ </u> No
PW-2 pump on?	<u> √ </u> Yes	<u> </u> No	PW-6 pump on?	<u> √ </u> Yes	<u> </u> No
PW-3 pump on?	<u> √ </u> Yes	<u> </u> No	PW-7 pump on?	<u> </u> Yes	<u> √ </u> No
PW-4 pump on?	<u> </u> Yes	<u> </u> No	PW-8 pump on?	<u> </u> Yes	<u> √ </u> No

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: PIEZOMETER WATER LEVEL LOG

Date: 28-Sep-11

Measurements taken by: R. Allen

RW-1	<u>13.90</u> ft	Comments:	
PZ-1A	<u>11.67</u> ft	Comments:	
PZ-1B	<u>20.15</u> ft	Comments:	
PZ-1C	<u>12.65</u> ft	Comments:	
PZ-1D	<u>12.81</u> ft	Comments:	
PW-2	<u>26.70</u> ft	Comments:	
PZ-2A	<u>26.67</u> ft	Comments:	
PZ-2B	<u>11.69</u> ft	Comments:	
PZ-2C	<u>11.12</u> ft	Comments:	
MW-7	<u>11.66</u> ft	Comments:	Substitute for 2D
PW-3	<u>27.30</u> ft	Comments:	
PZ-3A	<u>11.72</u> ft	Comments:	
PZ-3B	<u>11.85</u> ft	Comments:	
PZ-3C	<u>12.34</u> ft	Comments:	
PZ-3D	<u>11.84</u> ft	Comments:	
PW-4	<u>-----</u> ft	Comments:	collapsed ring
PZ-4A	<u>11.65</u> ft	Comments:	
PZ-4B	<u>19.05</u> ft	Comments:	
PZ-4C	<u>-----</u> ft	Comments:	sealed over
PZ-4D	<u>10.74</u> ft	Comments:	

PW-5	<u>19.00</u> ft	Comments:	
PZ-5A	<u>11.13</u> ft	Comments:	
PZ-5B	<u>11.12</u> ft	Comments:	
PZ-5C	<u>10.70</u> ft	Comments:	
PZ-5D	<u>11.56</u> ft	Comments:	
PW-6	<u>19.30</u> ft	Comments:	
PZ-6A	<u>12.12</u> ft	Comments:	
PZ-6B	<u>11.98</u> ft	Comments:	
PZ-6C	<u>12.15</u> ft	Comments:	
PZ-6D	<u>15.63</u> ft	Comments:	Shown as RW-2 on map
PW-7	<u>17.60</u> ft	Comments:	
MPI-6S	<u>11.58</u> ft	Comments:	
PZ-7B	<u>11.94</u> ft	Comments:	
OW-B	<u>20.05</u> ft	Comments:	
PZ-7D	<u>11.52</u> ft	Comments:	
PW-8	<u>18.30</u> ft	Comments:	
PZ-8A	<u>8.68</u> ft	Comments:	
PZ-8B	<u>8.68</u> ft	Comments:	
PZ-8C	<u>8.50</u> ft	Comments:	
PZ-8D	<u>8.09</u> ft	Comments:	

PUMPS IN OPERATION DURING MEASUREMENTS

RW-1 pump on?	<u> </u> Yes	<u> √ </u> No	PW-5 pump on?	<u> </u> Yes	<u> √ </u> No
PW-2 pump on?	<u> √ </u> Yes	<u> </u> No	PW-6 pump on?	<u> √ </u> Yes	<u> </u> No
PW-3 pump on?	<u> √ </u> Yes	<u> </u> No	PW-7 pump on?	<u> </u> Yes	<u> √ </u> No
PW-4 pump on?	<u> </u> Yes	<u> </u> No	PW-8 pump on?	<u> </u> Yes	<u> √ </u> No

Mr. C's CLEANERS OM&M

SUMMARY OF FIELD ACTIVITIES BY IEG - 09/2011

DATE	ACTIVITY
5-Sep	Weekly Inspection. Clean Treatment Room. Change bag filters. PZ-4B - prepare to replace inner ring.
6-Sep	PZ-4B - mobilize equipment, remove old ring and install new ring. OM&M office work.
7-Sep	Sampling and PZ-4B inspection.
8-Sep	End of month summaries. PZ-4B inspection and add additional traffic barrier.
12-Sep	OM&M Weekly Inspection and office work. PZ-4B -Add cold patch around well. Get supplies.
14-Sep	Switched Redux pickup to new drum. PZ-4B - picked up traffic cones. Bank 2 Timer - replaced timer motor.
20-Sep	OM&M Weekly Inspection and office work. Get supplies.
26-Sep	OM&M Weekly Inspection. Changed bag filters.
27-Sep	OM&M office work.
28-Sep	Piezometer Readings and office work.
29-Sep	Air Stripper - cleaned through access ports with steel brushes. Poured old Redux drum into present drum.

Mr. C's CLEANERS OM&M
SUMMARY OF FIELD ACTIVITIES BY IEG - 09/2011

ACTIVITY	DESCRIPTION	COMPLETION DATE/STATUS
Replace faulty Redux valve	Redux ball valve above influent pipe is leaking. Replaced with a chemical resistant ball valve.	Jun-11
PW-8 Well Pump not cycling down	Well pump stays on & GW level does not drop; horizontal line may be plugged. Inspected & cleaned pump & transducer. Purged horizontal line. Replaced pump.	Aug-11
PW-7 Well needs cleanout	PW-7 needs a horizontal line purge and well purge after PW-8 receives its purges.	Aug-11
Replace SVE Vacuum Drum	Present Vacuum Drum inside Agway Shed is corroded. Replace drum.	To be ordered
AS / SVE System Evaluation	Agway Shed - test & evaluate air sparge system and Soil Vapor Extraction system. Installed fittings to measure pressure and flow. Tested air sparging and SVE lines.	in progress
PW-4 Well Repair and Level	Asphalt around PW-4 well has sunk, due to collapse of corroded inner ring. Replace inner ring and bring parking lot up to level with asphalt patch.	in progress
PW-4 UE Level	Asphalt around Underground Enclosure has sunk, leaving it vulnerable to damage. Bring parking lot up to level with asphalt patch.	in progress
Install MW Ring	Piezometer in Agway Site parking lot was damaged by the road repair crew. To instal new Monitoring Well Ring around damaged Piezometer for protection.	in progress
Rebuild JAC Pump as needed	Jesco America Corp recommends rebuilding the Redux pump when needed. Purchased rebuild kit.	in progress
Brace Effluent Pipe	David Szymanski (NYSDEC) inspected Treatment Room and said that the effluent pipe should be braced in (3) places to the north wall.	in progress
Inspect and clean Manholes	Inspect manholes near operating pumps. Pump out water in manholes and clean out remaining sediment and other material.	in progress
Repair PW-5	PW-5 triggered an Autodialer overload alarm. Inspect, purge well, clean pump, plastic pipe and transducer. Trouble shoot.	in progress
Agway Shed Concrete Dump	Approximately 1/4 yard of concrete was washed out on the north side of the Agway Shed. Concrete should be removed.	in progress
Trim Broken Piezometers	Many of the piezometers are broken. Measuring water levels is not precise when a pipe is broken. Identify and trim all broken piezometers.	in progress
Cool Treatment Room	Temperature in Treatment Room is well above 90 degrees during the summer months. Need to increase outside air inflow to the room.	in progress
Replace Air Stripper Exhaust	Present Air Stripper exhaust is very heavy and leaks moisture. Replace with lighter system.	in progress
Add Inline filter to Compressor	The Condensate Removal Valve (CRV) on the Air Compressor gets stuck open by occasional pieces of debris from the air tank. Put filter on hose before the CRV.	in progress
PW-5 Well Pump not cycling down	The well pump stays on after the water level drops. Transducer could be bad. Inspect and clean well pump and transducer.	in progress
PZ-4B Repair	Corroded inner ring cause collapse of top cover. Replace inneer ring.	in progress
Repair Blower #2	Determined that bearing is failing in Air Stripper Blower Motor. Removed motor and take to repair shop. Reinstalled motor.	in progress
Bank 2 Timer is defective	The Bank 2 Timer inside the Agway Shed stopped working. Dismantle Timer and take for repair or replace defective parts.	in progress
Agway Shed is unlevel	Agway Shed has sunk down at the southwest corner making the alignment of the door handles poor. Raise and shim the shed floor as needed.	in progress
PW-2 & PW3 level	Water level reading is high. Inspect transducer and make necessary repairs	in progress
PW-7 pitless adapter	Pitless adapter does not seal well. Repair or replacer pitless adapter	in progress
PW-8 pitless adapter	Pitless adapter feels brokent/does not seal well. Repair/replace pitless adapter	in progress

Mr. C's CLEANERS OM&M

SUMMARY OF WATER PUMP MAINTENANCE BY IEG - 2011

as of Sep 11

ID	CLEAN & INSPECT PUMP	REPLACED PUMP	REPAIR PUMP	PITLESS ADAPTER	HORIZONTAL PIPE	CLEAN & INSPECT TRANSDUCER	REPLACE TRANSDUCER	REPAIR TRANSDUCER	PUMP OUT WELL	CLEAN OUT & INSPECT ELECTRICAL BOX	ELECTRICAL BOX REPAIR
RW - 1	May-10	Feb-08	May-10			May-10					
PW - 2	Aug 09, May 10	Jul-08				Aug 09, May 10	Sep-09		Aug-09		Sep-09
PW - 3	Aug 09, May 10	Jul-08		Repair adapter		Aug-09			Aug-09		
PW - 4	Sep 09, May 10	Dec-07	NEED			May-10			Jul 09, Sep 09	Sep-09	Sep-09
PW - 5		Jul-08				Mar-11		Sep-09			
PW - 6	Jul-09	Jun 08, Jul 09			Pipe 8/09	Apr 09, Aug 09	Sep-09		Aug-09	Aug 09, Sep 09	Jul 09, Sep 09
PW - 7	May 10, Oct 10, Aug 11	Nov 07, Jul 09, Oct 10			Pipe 8/09	Aug 09, May 10, Oct 10, Aug 11			Aug 09, May 10, Aug 11		
PW - 8	Aug 09, May 10, Aug 11	Jul 08, Sep 09, Aug 11			Pipe 8/09	Aug 09, May 10, Aug 11			Aug 09, May 10, Aug 11		


Attachment B
Analytical Report from
Mitkem Laboratories

Analytical Data Package Work Order ID: K1374

Sampled: September 7, 2011

Received: September 28, 2011

Report Date:
28-Sep-11 14:54



- Final Report
 Re-Issued Report
 Revised Report

Laboratory Report

Ecology and Environment Engineering P.C.
368 Pleasant View Drive
Lancaster, NY 14086

Work Order: K1669
Project: Mr. C's Dry Cleaning
Project #: 002700.DC13.02.01.01

Attn: Michael Steffan

<u>Laboratory ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Sampled</u>	<u>Date Received</u>
K1669-01	INFLUENT	Aqueous	07-Sep-11 09:30	08-Sep-11 09:04
K1669-02	EFFLUENT	Aqueous	07-Sep-11 10:00	08-Sep-11 09:04

I attest that the information contained within the report has been reviewed for accuracy and checked against the quality control requirements for each method. The results relate only to the samples(s) as received. This report may not be reproduced, except in full, without written approval from Mitkem Laboratories.

All applicable NELAC or USEPA CLP requirements have been met.

Spectrum Analytical (Rhode Island) is accredited under the National Environmental Laboratory Approval Program (NELAP) and is certified by several States, as well as USEPA and US Department of Defense. The current list of our laboratory approvals and certifications is available on the Certifications page on our web site at www.mitkem.com.

Please contact the Laboratory or Technical Director at 401-732-3400 with any questions regarding the data contained in the laboratory report.

Department of Defense	N/A
Connecticut	PH-0153
Delaware	N/A
Maine	2007037
Massachusetts	M-RI907
New Hampshire	2631
New Jersey	RI001
New York	11522
North Carolina	581
Pennsylvania	68-00520
Rhode Island	LAI00301
USDA	P330-08-00023
USEPA - ISM	EP-W-09-039
USEPA - SOM	EP-W-11-033



LABORATORY
ACCREDITATION
BUREAU
ACCREDITED




Certificate # L2247 Testing

Authorized by:

Yihai Ding
Laboratory Director

Sample Transmittal Documentation



A DIVISION OF SPECTROM ANALYTICAL, INC. FARMING HANBAL TECHNOLOGY

CHAIN OF CUSTODY RECORD

Page 1 of 1

Special Handling: std
 TAT- Indicate Date Needed:
 All TATs subject to laboratory approval.
 Min. 24-hour notification needed for rushes.
 Samples disposed of after 30 days unless otherwise instructed.

Report To: E & E 1 Inc
368 Pleasantview Dr
Lan caster, NY 14086
 Telephone # (716) 684-8060
 Project Mgr.: Mike Steffan

Invoice To: E & E, Inc
 P.O. No.: _____ RQN: _____

Project No.: _____
 Site Name: Mr Cs O M & M State: NY
 Location: East Aurora
 Sampler(s): R. Allen

1=Na₂S₂O₃ 2=HCl 3=H₂SO₄ 4=HNO₃ 5=NaOH 6=Ascorbic Acid 7=CH₃OH
 8= NaHSO₄ 9= _____ 10= _____ 11= _____

DW=Drinking Water GW=Groundwater WW=Wastewater
 O=Oil SW= Surface Water SO=Soil SL=Sludge A=Air
 X1= _____ X2= _____ X3= _____

List preservative code below:

1 4 2

Containers:

of VOA Vials
 # of Amber Glass
 # of Clear Glass
 # of Plastic

Matrix Type

Lab Id:	Sample Id:	Date:	Time:
1	INFLUENT	sep 7, 2011	9:30 A
1	INFLUENT	}	9:30 A
1	INFLUENT		9:30 A
2	EFFLUENT		10:00 A
2	EFFLUENT	}	10:00 A
2	EFFLUENT		10:00 A

G=Grab C=Composite

Analyses:

PH
 Hardness
 VOC

QA/QC Reporting Level

Level I Level II
 Level III Level IV
 Other CAT A

State specific reporting standards:

Notes:
NOTE: (1) of the 250 ml bottles came with a HNO₃ sticker on. Neither of the 500 ml bottles had a HNO₃ sticker on them. The 250 ml bottles were dry. The 500 ml bottles both had liquid.

E-mail to ms.steffan@ene.com

EDD Format PDF

Reinquished by:

Richard C Allen Jr

Received by:

Daniel McClean

Date: _____ Time: _____


Condition upon receipt: Iced Ambient 5°C

SPECTRUM ANALYTICAL, INC. RI DIVISION
Sample Condition Form

Received By: <u>Daniel Miller</u>		Reviewed By: <u>CJA</u>		Date: <u>9-8-11</u>		Spectrum RI Work Order #: <u>K1669</u>			
Client Project: <u>MRC's</u>		Client: <u>EGE</u>				Soil		Headspace or	
		Lab Sample ID		Preservation (pH)				VOA	Air Bubble ≥
				HNO ₃	H ₂ SO ₄	HCl	NaOH	H ₃ PO ₄	Matrix
1) Cooler Sealed		<u>Yes</u> / No	<u>K1619</u>	<u>01</u>	<u><1</u>				<u>H</u>
			<u>K1669</u>	<u>02</u>	<u><2</u>				<u>H</u>
2) Custody Seal(s)		Present / Absent							
		<u>Present</u> / Absent							
		Coolers / Bottles							
		<u>Coolers</u> / Bottles							
		Intact / Broken							
		<u>Intact</u> / Broken							
3) Custody Seal Number(s)		<u>MA</u>							
4) Chain-of-Custody		<u>Present</u> / Absent							
5) Cooler Temperature		<u>5°C</u>							
IR Temp Gun ID		<u>M7-1</u>							
Coolant Condition		<u>Full</u>							
6) Airbill(s)		<u>Present</u> / Absent							
Airbill Number(s)		<u>INDEX</u>							
		<u>7974 8980 1116</u>							
7) Samples Bottles		<u>Intact</u> / Broken / Leaking							
8) Date Received		<u>9-8-11</u>							
9) Time Received		<u>9:04</u>							
Preservative Name/Lot No.:									

VOA Matrix Key:
 US = Unpreserved Soil A = Air
 UA = Unpreserved Aqueous H = HCl
 M = MeOH E = Encore
 N = NaHSO₄ F = Freeze

See Sample Condition Notification/Corrective Action Form yes / no



SPECTRUM ANALYTICAL, INC.

Featuring

HANIBAL TECHNOLOGY

*** Volatiles ***

REPORT NARRATIVE

Spectrum Analytical, Inc. Featuring Hanibal Technology, RI Division.

Client : Ecology and Environment Engineering P.C.

Project: Mr. C's Dry Cleaning

Laboratory Workorder / SDG #: K1669

SW846 8260C, VOC by GC-MS

I. SAMPLE RECEIPT

No exceptions or unusual conditions were encountered unless a Sample Condition Notification Form, or other record of communication is included with the Sample Receipt Documentation.

II. HOLDING TIMES

A. Sample Preparation:

All samples were prepared within the method-specified holding times.

B. Sample Analysis:

All samples were analyzed within the method-specified holding times.

III. METHODS

Samples were analyzed following procedures in laboratory test code:
SW846 8260C

IV. PREPARATION

Aqueous Samples were prepared following procedures in laboratory test code: SW5030

V. INSTRUMENTATION

The following instrumentation was used

Instrument Code: V6
Instrument Type: GCMS-VOA
Description: HP6890 / HP5973
Manufacturer: Hewlett-Packard
Model: 6890 / 5973

VI. ANALYSIS

A. Calibration:

Calibrations met the method/SOP acceptance criteria.

B. Blanks:

All method blanks were within the acceptance criteria.

C. Surrogates:

Surrogate standard percent recoveries were within the QC limits.

D. Laboratory Control Spikes (LCS):

Percent recoveries for lab control samples were within the QC limits.

E. Internal Standards:

Internal standard peak areas were within the QC limits.

F. Dilutions:

The following samples were analyzed at dilution:

INFLUENT (K1669-01A) : Dilution Factor: 10

G. Samples:


No other unusual occurrences were noted during sample analysis.

I certify that this data package is in compliance with the terms and conditions agreed to by the client and Spectrum, both technically and for completeness, except for the conditions noted above. Release of the data contained in this hardcopy data package has been authorized by the Laboratory Manager or designated person, as verified by the following signature.



Signed: _____


Date: _____ 9/28/11 _____



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

Data Flag/Qualifiers:

- U Not Detected. This compound was analyzed-for but not detected. For most analyses the reporting limit (lowest standard concentration) is the value listed. For Department of Defense programs, this is the Limit of Detection (LOD).
- J This flag indicates an estimated value due to either
- the compound was detected below the reporting limit, or
 - estimated concentration for Tentatively Identified Compound
- B This flag indicates the compound was also detected in the associated Method Blank. The B flag has an alternative meaning for Inorganics analyses reported using CLP ILM-type metals forms, indicating a "trace" concentration below the reporting limit and equal to or above the detection limit.
- D For Organics analysis, this flag indicates the compound concentration was obtained from a secondary dilution analysis
- E This flag indicates the compound concentration exceeded the Calibration Range. The E flag has an alternative meaning for Inorganics analyses reported using CLP metals forms, indicating an estimated concentration due to the presence of interferences, as determined by the serial dilution analysis.
- P This flag is used for pesticides/PCB/herbicide compound when there is a greater than 40% difference for detected concentration between the two GC columns used for primary and confirmation analyses. This difference typically indicates an interference, causing one value to be unusually high. The **lower** of the two values is generally reported on the Form 1, and both values reported on the Form 10.
- A Used to flag semivolatile organic Tentatively Identified Compound library search results for compounds identified as aldol condensation byproducts.
- N Used to flag results for volatile and semivolatile Organics analysis Tentatively Identified Compounds where an analyte has passed the identification criteria, and is considered to be positively identified. For Inorganics analysis the N flag indicates the matrix spike recovery falls outside of the control limit.
- * For Inorganics analysis the * flag indicates Relative Percent Difference for duplicate analyses is outside of the control limit.



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

Sample ID Suffixes

- DL** Diluted analysis. The sample was diluted and reanalyzed. The DL may be followed by a digit if more than one diluted reanalysis is provided. The DL suffix is not attached to an analysis initially performed at dilution, only to reanalyses performed at dilution
- RE** Reanalysis. Appended to the client sample ID to indicate a reextraction and reanalysis or a reanalysis of the original sample extract.
- RA** Reanalysis. Appended to the laboratory sample ID indicates a reanalysis of the original sample extract.
- RX** Reextraction. Appended to the laboratory sample ID indicates a reextraction of the sample.
- MS** Matrix Spike.
- MSD** Matrix Spike Duplicate
- DUP** Duplicate analysis
- SD** Serial Dilution
- PS** Post-digestion or Post-distillation spike. For metals or inorganic analyses

1A - FORM I VOA-1
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.

INFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: K1669 Mod. Ref No.: _____ SDG No.: SK1669
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: K1669-01A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V6I2559.D
 Level: (TRACE/LOW/MED) LOW Date Received: 09/08/2011
 % Moisture: not dec. Date Analyzed: 09/12/2011
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 10.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	µg/L	
75-71-8	Dichlorodifluoromethane		10	U
74-87-3	Chloromethane		10	U
75-01-4	Vinyl chloride		10	U
74-83-9	Bromomethane		10	U
75-00-3	Chloroethane		10	U
75-69-4	Trichlorofluoromethane		10	U
75-35-4	1,1-Dichloroethene		10	U
67-64-1	Acetone		50	U
75-15-0	Carbon disulfide		10	U
75-09-2	Methylene chloride		10	U
156-60-5	trans-1,2-Dichloroethene		10	U
1634-04-4	Methyl tert-butyl ether		15	
75-34-3	1,1-Dichloroethane		10	U
78-93-3	2-Butanone		50	U
156-59-2	cis-1,2-Dichloroethene		100	
67-66-3	Chloroform		10	U
71-55-6	1,1,1-Trichloroethane		10	U
56-23-5	Carbon tetrachloride		10	U
107-06-2	1,2-Dichloroethane		10	U
71-43-2	Benzene		10	U
79-01-6	Trichloroethene		130	
78-87-5	1,2-Dichloropropane		10	U
75-27-4	Bromodichloromethane		10	U
10061-01-5	cis-1,3-Dichloropropene		10	U
108-10-1	4-Methyl-2-pentanone		50	U
108-88-3	Toluene		10	U
10061-02-6	trans-1,3-Dichloropropene		10	U
79-00-5	1,1,2-Trichloroethane		10	U
127-18-4	Tetrachloroethene		1600	
591-78-6	2-Hexanone		50	U
124-48-1	Dibromochloromethane		10	U
106-93-4	1,2-Dibromoethane		10	U
108-90-7	Chlorobenzene		10	U
100-41-4	Ethylbenzene		10	U
1330-20-7	Xylene (Total)		10	U

1B - FORM I VOA-2
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.

INFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: K1669 Mod. Ref No.: _____ SDG No.: SK1669
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: K1669-01A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V6I2559.D
 Level: (TRACE/LOW/MED) LOW Date Received: 09/08/2011
 % Moisture: not dec. Date Analyzed: 09/12/2011
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 10.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	µG/L	
100-42-5	Styrene		10	U
75-25-2	Bromoform		10	U
98-82-8	Isopropylbenzene		10	U
79-34-5	1,1,2,2-Tetrachloroethane		10	U
541-73-1	1,3-Dichlorobenzene		10	U
106-46-7	1,4-Dichlorobenzene		10	U
95-50-1	1,2-Dichlorobenzene		10	U
96-12-8	1,2-Dibromo-3-chloropropane		10	U
120-82-1	1,2,4-Trichlorobenzene		10	U
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane		10	U
110-82-7	Cyclohexane		10	U
79-20-9	Methyl acetate		10	U
108-87-2	Methylcyclohexane		10	U

1A - FORM I VOA-1
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.

EFFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: K1669 Mod. Ref No.: _____ SDG No.: SK1669
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: K1669-02A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V6I2551.D
 Level: (TRACE/LOW/MED) LOW Date Received: 09/08/2011
 % Moisture: not dec. Date Analyzed: 09/12/2011
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 1.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)


CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	µg/L	
75-71-8	Dichlorodifluoromethane		1.0	U
74-87-3	Chloromethane		1.0	U
75-01-4	Vinyl chloride		1.0	U
74-83-9	Bromomethane		1.0	U
75-00-3	Chloroethane		1.0	U
75-69-4	Trichlorofluoromethane		1.0	U
75-35-4	1,1-Dichloroethene		1.0	U
67-64-1	Acetone		5.0	U
75-15-0	Carbon disulfide		1.0	U
75-09-2	Methylene chloride		1.0	U
156-60-5	trans-1,2-Dichloroethene		1.0	U
1634-04-4	Methyl tert-butyl ether		1.0	U
75-34-3	1,1-Dichloroethane		1.0	U
78-93-3	2-Butanone		5.0	U
156-59-2	cis-1,2-Dichloroethene		1.0	U
67-66-3	Chloroform		1.0	U
71-55-6	1,1,1-Trichloroethane		1.0	U
56-23-5	Carbon tetrachloride		1.0	U
107-06-2	1,2-Dichloroethane		1.0	U
71-43-2	Benzene		1.0	U
79-01-6	Trichloroethene		1.0	U
78-87-5	1,2-Dichloropropane		1.0	U
75-27-4	Bromodichloromethane		1.0	U
10061-01-5	cis-1,3-Dichloropropene		1.0	U
108-10-1	4-Methyl-2-pentanone		5.0	U
108-88-3	Toluene		1.0	U
10061-02-6	trans-1,3-Dichloropropene		1.0	U
79-00-5	1,1,2-Trichloroethane		1.0	U
127-18-4	Tetrachloroethene		1.0	U
591-78-6	2-Hexanone		5.0	U
124-48-1	Dibromochloromethane		1.0	U
106-93-4	1,2-Dibromoethane		1.0	U
108-90-7	Chlorobenzene		1.0	U
100-41-4	Ethylbenzene		1.0	U
1330-20-7	Xylene (Total)		1.0	U

1B - FORM I VOA-2
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.
EFFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: K1669 Mod. Ref No.: _____ SDG No.: SK1669
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: K1669-02A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V6I2551.D
 Level: (TRACE/LOW/MED) LOW Date Received: 09/08/2011
 % Moisture: not dec. Date Analyzed: 09/12/2011
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 1.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	µG/L	
100-42-5	Styrene		1.0	U
75-25-2	Bromoform		1.0	U
98-82-8	Isopropylbenzene		1.0	U
79-34-5	1,1,2,2-Tetrachloroethane		1.0	U
541-73-1	1,3-Dichlorobenzene		1.0	U
106-46-7	1,4-Dichlorobenzene		1.0	U
95-50-1	1,2-Dichlorobenzene		1.0	U
96-12-8	1,2-Dibromo-3-chloropropane		1.0	U
120-82-1	1,2,4-Trichlorobenzene		1.0	U
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane		1.0	U
110-82-7	Cyclohexane		1.0	U
79-20-9	Methyl acetate		1.0	U
108-87-2	Methylcyclohexane		1.0	U



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

** Wet Chemistry **

REPORT NARRATIVE

Spectrum Analytical, Inc. Featuring Hanibal Technology, RI Division.

Client : Ecology and Environment Engineering P.C.

Project: Mr. C's Dry Cleaning

Laboratory Workorder / SDG #: K1669

SM 2340B, SM 4500 H+ B

I. SAMPLE RECEIPT

No exceptions or unusual conditions were encountered unless a Sample Condition Notification Form, or other record of communication is included with the Sample Receipt Documentation.

II. HOLDING TIMES

A. Sample Preparation:

All samples were prepared within the method-specified holding times.

B. Sample Analysis:

All samples were analyzed within the method-specified holding times.

III. METHODS

Samples were analyzed following procedures in laboratory test code: SM 2340B, SM 4500 H+ B

IV. PREPARATION

Aqueous Samples were prepared following procedures in laboratory test code: SW3005

V. INSTRUMENTATION

The following instrumentation was used to perform

Instrument Code: OPTIMA3
Instrument Type: ICP
Description: Optima ICP-OES
Manufacturer: Perkin-Elmer
Model: 4300 DV

Instrument Code: WC01
Instrument Type: Probe
Description: pH Meter
Manufacturer: Thermo Electron Corporation
Model: Orion 520A+

VI. ANALYSIS

A. Calibration:

Calibrations met the method/SOP acceptance criteria.

B. Blanks:

All method blanks were within the acceptance criteria.


C. Samples:

No unusual occurrences were noted during sample analysis.

I certify that this data package is in compliance with the terms and conditions agreed to by the client and Spectrum, both technically and for completeness, except for the conditions noted above. Release of the data contained in this hardcopy data package has been authorized by the Laboratory Manager or designated person, as verified by the following signature.

Signed:  _____

Date: _____ 9/28/11 _____




SPECTRUM ANALYTICAL, INC.

Featuring

HANIBAL TECHNOLOGY

Data Flag/Qualifiers:

- U** Not Detected. This compound was analyzed-for but not detected. For most analyses the reporting limit (lowest standard concentration) is the value listed. For Department of Defense programs, this is the Limit of Detection (LOD).
- J** This flag indicates an estimated value due to either
- the compound was detected below the reporting limit, or
 - estimated concentration for Tentatively Identified Compound
- B** This flag indicates the compound was also detected in the associated Method Blank. The B flag has an alternative meaning for Inorganics analyses reported using CLP ILM-type metals forms, indicating a "trace" concentration below the reporting limit and equal to or above the detection limit.
- D** For Organics analysis, this flag indicates the compound concentration was obtained from a secondary dilution analysis
- E** This flag indicates the compound concentration exceeded the Calibration Range. The E flag has an alternative meaning for Inorganics analyses reported using CLP metals forms, indicating an estimated concentration due to the presence of interferences, as determined by the serial dilution analysis.
- P** This flag is used for pesticides/PCB/herbicide compound when there is a greater than 40% difference for detected concentration between the two GC columns used for primary and confirmation analyses. This difference typically indicates an interference, causing one value to be unusually high. The **lower** of the two values is generally reported on the Form 1, and both values reported on the Form 10.
- A** Used to flag semivolatile organic Tentatively Identified Compound library search results for compounds identified as aldol condensation byproducts.
- N** Used to flag results for volatile and semivolatile Organics analysis Tentatively Identified Compounds where an analyte has passed the identification criteria, and is considered to be positively identified. For Inorganics analysis the N flag indicates the matrix spike recovery falls outside of the control limit.
- *** For Inorganics analysis the * flag indicates Relative Percent Difference for duplicate analyses is outside of the control limit.



SPECTRUM ANALYTICAL, INC.

Featuring

HANIBAL TECHNOLOGY

Sample ID Suffixes

- DL** Diluted analysis. The sample was diluted and reanalyzed. The DL may be followed by a digit if more than one diluted reanalysis is provided. The DL suffix is not attached to an analysis initially performed at dilution, only to reanalyses performed at dilution
- RE** Reanalysis. Appended to the client sample ID to indicate a reextraction and reanalysis or a reanalysis of the original sample extract.
- RA** Reanalysis. Appended to the laboratory sample ID indicates a reanalysis of the original sample extract.
- RX** Reextraction. Appended to the laboratory sample ID indicates a reextraction of the sample.
- MS** Matrix Spike.
- MSD** Matrix Spike Duplicate
- DUP** Duplicate analysis
- SD** Serial Dilution
- PS** Post-digestion or Post-distillation spike. For metals or inorganic analyses

Spectrum Analytical, Inc. Featuring Hanibal Technology -- Rhode Island Division

09/23/2011

Client: Ecology and Environment Engineering P.C.

Client Sample ID: INFLUENT

Lab ID: K1669-01

Project: Mr. C's Dry Cleaning

Collection Date: 09/07/11 9:30

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
SM 2340B -- HARDNESS by Calculation							SM2340_W
Hardness, Ca/Mg (As CaCO3)	520		4.0	mg/L CaCO3		109/15/2011 9:03	61528
SM 4500 H+ B -- pH VALUE							SM4500_H+
pH	6.9		1.0	S.U.		109/08/2011 11:55	R61163

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 B - Analyte detected in the associated Method Blank
 DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 E - Value above quantitation range
 RL - Reporting Limit

Attachment C
Summary of Site Utility Costs and Projections
January to December 2011

Spectrum Analytical, Inc. Featuring Hanibal Technology -- Rhode Island Division 09/23/2011

Client: Ecology and Environment Engineering P.C.
 Client Sample ID: EFFLUENT Project: Mr. C's Dry Cleaning
 Lab ID: K1669-02 Collection Date: 09/07/11 10:00

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
SM 2340B -- HARDNESS by Calculation							SM2340_W
Hardness, Ca/Mg (As CaCO3)	530		4.0	mg/L CaCO3		109/15/2011 9:06	61528
SM 4500 H+ B -- pH VALUE							SM4500_H+
pH	8.3		1.0	S.U.		109/08/2011 11:57	R61163

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 B - Analyte detected in the associated Method Blank
 DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 E - Value above quantitation range
 RL - Reporting Limit

