



ecology and environment engineering, p.c.

International Specialists in the Environment

BUFFALO CORPORATE CENTER
368 Pleasant View Drive
Lancaster, New York 14086
Tel: (716) 684-8060, Fax: (716) 684-0844

June 8, 2012

Mr. William Welling, Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation
625 Broadway, 12th Floor
Albany, New York 12233 - 7013

Re: Mr. C's Dry Cleaners Site, Contract # D004442.DC13, Site # 9-15-157
May 2012 Operations, Maintenance, and Monitoring Report

Dear Mr. Welling:

Ecology and Environment Engineering, P.C. (EEEPC) is pleased to provide the May 2012 Operations, Maintenance, and Monitoring (OM&M) Report for the Mr. C's Dry Cleaners Site, NYSDEC Site # 9-15-157, located in East Aurora, New York. Copies of weekly inspection reports prepared by EEEPC's subcontractor, Iyer Environmental Group, PLLC (IEG) are provided in Attachment A. Selected pages from the individual analytical data package prepared by Mitkem Laboratories, Inc. (MLI) are provided as in Attachments B and C. A second analytical sampling was performed after system correctives actions were taken as a results of non-compliance issues on the effluent discharge for PCE. The corrective actions taken and analytical results received indicated the system was back in compliance. The full analytical reports along with QA/QC information will be retained by EEEPC. Remedial treatment system utility costs for the Mr. C's and Agway sites are provided as Attachment D.

In review of the on-site treatment system operations, monitoring and maintenance for May 2012, EEEPC offers the following comments and highlights:

Operational Summary

Mr. C's Site – Remedial Operations Information

- Checklists for weekly system inspections from IEG are provided as Attachment A for 4/30, 5/7, 5/14, 5/21, 5/30, and 6/6/12.
- Based on the weekly inspection results performed by IEG, the remedial treatment system had a 100.00% operational up-time (Table 1) and the treatment of contaminated groundwater totaling of 348,980 gallons (Table 2) for May 2012.

- Initial sampling occurred on May 7, 2012 with the analytical results received on May 25, 2012. The initial analytical results indicated non compliance issues with the effluent discharge requirements for Tetrachloroethene (PCE). The results were 27 ug/L .Once the results were known, IEG was contacted and corrective actions were performed according to the requirements in the Site Management Plan (SMP). After completion of the corrective actions to the system a second set of analytical samples were taken on May 30, 2012 and analyzed. The results received on June 6, 2012, indicated compliance with PCE levels according to the SPDES Equivalency Permit.
- The cleanup efficiency for the contaminants of concern at the site during the reporting / operating period 4/30/12 to 6/6/12 was 99.65%. The air stripper unit on the Mr. C's property is currently in compliance and MLI continues to provide analytical data to sub-ppb accuracy, supporting the accurate determination of effluent contaminant levels. The summary of Effluent Discharge Criteria & Analytical Compliance Results for May 2012 is presented in Table 3.
- The analytical results revealed the influent concentration to be 431.5 µg/L or 431.5 ppb, and 1.52 µg/L or 1.52 ppb of treated effluent. PCE effluent concentrations after corrective actions were performed were 0.94J µg/L or 0.94J ppb which is under the 10 µg/L or 10 ppb limit. The summary of influent and effluent contaminant concentrations for the May 7, 2012 and May 30, 2012 sampling events is presented in Table 4.
- The Mr. C's treatment system based on the total monthly flows removed 1.25 lbs. of targeted contaminants from the groundwater below the site in the month of May 2012. The calculations and data for the month are presented in Table 5.

Mr. C's Site – Updated Property Information

- In December 2011, operations ceased with the Mr. C's Dry Cleaners business. Dry cleaning equipment and ancillary equipment were removed from the premises from January to April 2012. In May, activity was noticed with cosmetic changes inside and outside of the building. In late May, the exterior siding of the building was removed and west side of the building was repainted and refurbished (A photo-documentation report will be sent under separate cover). During the week of June 4, the parking lot west of the treatment building is to be repaved. IEG will be on-site to observe the paving program will not damage any pumping and monitoring wells that are part of the remedial action.
- Contact information regarding the property owner and party leasing the Mr. C's building was provided to the NYSDEC. The information provided is as follows: Property owner – DelTora LLC – Point of Contact - Mr. Paul Bendrowski – 231-313-1954 (Traverse City, MI). Property Lease – Intrepid Automotive Partners – Dave Kern – 716-481-5703 (East Aurora, NY).

Mr. William Welling, Project Manager

June 8, 2012

Page 3 of 3

Agway Site Remedial Information

- The Agway facility treatment unit was turned off in December 2011.
- The facility was turned off as a result of future bioaugmentation work in that area and as directed by the NYSDEC Project manager.
- Contact was received from a local architect regarding redevelopment of the former Agway for a single story building without a basement. Contact report information was passed onto NYSDEC and the architectural firm to discuss the issues related to the property.

Subslab Depressurization Systems (SSDS) – First Presbyterian Church and 27 Whaley Ave. sites


- No current operational issues.

Mr. C's and Agway Energy Usage Information

- A copy of the site utility costs from the Mr. C's and Agway remedial operations for January through May 2012 are provided as Attachment D.
- The Agway system power was turned off in December 2011.

If you have questions regarding the May 2012 OM&M report summary, please do not hesitate to contact me at 716-684-8060.

Very Truly Yours,
Ecology and Environment Engineering, P. C.



Michael G. Steffan
Project Manager

cc: D. Szymanski, Region 9, NYSDEC - Buffalo w/ attachments
D. Iyer, IEG - w/attachments
CTF- 002700.DC13.02.01.01

Table 1
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
System Operational Time

Month	Reporting Hours	Operational Up-time
(Up-time from inception to 1/4/12)	79,183.50	96.27%
January 4, 2012 - February 2, 2012	696	100.00%
February 2, 2012 - March 5, 2012	768	100.00%
March 5, 2012 - April 4, 2012	720	100.00%
April 4, 2012 - April 30, 2012	624	100.00%
April 30, 2012 - June 6, 2012	888	100.00%
		#DIV/0!
		#DIV/0!
		#DIV/0!
		#DIV/0!
		#DIV/0!
		#DIV/0!
		#DIV/0!
Total Hours from System Startup '2/02'	82,879.50	
Average Operational Up-time from startup =		96.43%
Average Operational Up-time for 2012 =		100.00%

NOTES:

1. Up-time based as percentage of total reporting hours.
2. Treatment system operated by the Tyree Organization Ltd. from 9/02 - 9/03.
3. Treatment system operated by O&M Enterprises Inc. from 10/03 - 7/07.
4. Treatment system operated by Iyer Environmental Group from 7/07 to present.

Table 3
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
Effluent Discharge Criteria & Analytical Compliance Results

Parameter/Analyte	Daily Maximum	Units	May 7, 2012 Effluent Analytical Values	Compliance	May 30, 2012 Effluent Analytical Values	Compliance
Flow	N/A	gpd		9,432		9,432
pH	6.0 - 9.0	standard units		8.1		8.1
1,1 Dichloroethene	10	µg/L		1.0 U		1.0 U
1,1 Dichloroethane	10	µg/L		1.0 U		1.0 U
cis-1,2-dichloroethene	10	µg/L		1.0 U		1.0 U
Trichloroethene	10	µg/L		1.2		1.0 U
Tetrachloroethene	10	µg/L		27		0.94J
Vinyl Chloride	10	µg/L		1.0 U		1.0 U
Benzene	5	µg/L		1.0 U		1.0 U
Ethylbenzene	5	µg/L		1.0 U		1.0 U
Methylene Chloride	10	µg/L		1.0 U		1.0 U
1,1,1 Trichloroethane	10	µg/L		1.0 U		1.0 U
Toluene	5	µg/L		1.0 U		1.0 U
Methyl-t-Butyl Ether (MTBE)	NA	µg/L		1.0 U		1.0 U
o-Xylene ²	5	µg/L		NA		NA
m, p-Xylene ²	10	µg/L		NA		NA
Total Xylenes	NA	µg/L		1.0 U		1.0 U
Iron, total	600	µg/L		NA ³		NA ³
Aluminum	4,000	µg/L		NA ³		NA ³
Copper	48	µg/L		NA ³		NA ³
Lead	14	µg/L		NA ³		NA ³
Manganese	2,000	µg/L		NA ³		NA ³
Silver	100	µg/L		NA ³		NA ³
Vanadium	28	µg/L		NA ³		NA ³
Zinc	230	µg/L		NA ³		NA ³
Total Dissolved Solids	850	mg/L		NA ³		NA ³
Total Suspended Solids	20	mg/L		NA ³		NA ³
Hardness	N/A	mg/L		480		480
Cyanide, Free	10	µg/L		NA ³		NA ³

NOTES:

- "Daily Maximum" excerpted from Attachment B of Addendum 1 to the Construction Contract Documents dated October 2000.
- Analytical report did not differentiate between o-Xylene and m, p-Xylene. Total Xylene value reported is given in each line.
- Shaded cells indicate that analytical value exceeds the "Daily Maximum"
- "ND" indicates that the compound was not detected and lists the practical quantification limit in parentheses.
- "N/A" indicates that analyses were not performed and data is unavailable.
- Average flows based on effluent readings taken April 30, 2012 through June 6, 2012. Total gallons: 348,980 divided by 37 operating days.
- "J" indicates an estimated value below the detection limit.
- "B" indicates analyte found in the associated blank.
- Removed from the required analysis list by NYSDDEC Region 9 in February 2005.

40 Indicates non-compliance with the NYSDEC effluent discharge requirements

NR Indicates Not Reported by Lab

Table 4
Mr. C's Dry Cleaners Site Remediation
NYSDEC Site #9-15-157
May 2012 VOC Analytical Summary

Compound	Based on the 5/30/12 Effluent Sampling Results		
	Influent Concentration* (ug/L)	Effluent Concentration* (ug/L)	Cleanup Efficiency** (%)
Acetone	ND (<5.0)	U	NA
Benzene	ND (<1.0)	U	NA
2-Butanone	ND (<5.0)	U	NA
cis-1, 2-Dichloroethene	5.5 *	J	100.00%
Chloroform	ND (<1.0)	U	NA
Methylene chloride	ND (<1.0)	U	NA
Methyl tert-butyl ether (MTBE)	ND (<1.0)	U	NA
Tetrachloroethene	390.0	0.94	99.76%
Toluene	ND (<1.0)	U	NA
Trichloroethene	24.0	ND (<1.0)	100.00%
Carbon Disulfide	12	0.58	95.17%
1,1,2 Trichloro-1,2,2-trifluoroethane	ND (<1.0)	U	NA
Cyclohexane	ND (<1.0)	U	NA
trans-1,2-dichloroethene	ND (<1.0)	U	NA
Chlorobenzene	ND (<1.0)	U	NA
Methylcyclohexane	ND (<1.0)	U	NA
Methyl acetate	ND (<1.0)	U	NA
Total Xylenes	ND (<1.0)	U	NA
May 2012 TOTALs (in ug/L) =	431.5	1.52	99.65%

- Notes:
1. "NA" = Not applicable
 2. "U" = Compound analyzed, but was not detected. Detection limit in parentheses.
 3. "DJ" or "J" indicates an estimated value below the practical quantitation limit but above the method detection limit.
 4. Non-detect values are assumed to be equal to zero for calculation of monthly average concentrations.
 5. "D" indicates the compound concentration was obtained from a secondary dilution analysis..

* (<50) - Detection Limit
 ** Contaminants of Concern only

Table 5
Mr. C's Dry Cleaners Site Remediation
Site #9-15-157
Monthly VOCs Removed From Groundwater

Month	Actual Period	Influent VOCs (µg/L)	Effluent VOCs (µg/L)	VOCs Removed (lbs.)
Total pounds of VOCs removed from inception to December 2011 =				1525.66
January 2012	1/4/12 - 2/2/12	2829.0	2.90	10.77
February 2012	2/2/12 - 3/5/12	809.7	3.77	3.03
March 2012	3/5/12 - 4/4/12	653.0	3.30	1.94
April 2012	4/4/12 - 4/30/12	602.0	2.10	1.05
May 2012	4/30/12 - 6/6/12	431.5	1.52	1.25
June 2012				
July 2012				
August 2012				
September 2012				
October 2012				
November 2012				
December 2012				
Total pounds of VOCs removed from inception =				1543.71
Total pounds of VOCs removed in 2012 =				18.05

HISTORICAL NOTES:

1. Calculations are based on monthly water samples and assumes samples are representative of the entire reporting period.
2. Calculations assume that non-detect values = 0 ug/L.
3. Total VOCs summations include estimated "J" values.
4. Calculations are based on effluent totalizer readings.
5. "Influent VOCs" and "Effluent VOCs" values given above is the summation of values for individual compounds given in monthly analytical reports.
6. No samples were collected in September 2003. August 2003 values are used.
7. Treatment system operated by Tyree Organization, Ltd. from 9/02 to 9/03,
8. Treatment system operated by O&M Enterprises from 10/03 to 7/07.
9. Treatment system operated by IEG from 7/07 to present.

CONVERSIONS:

- 1 pound = 453.5924 grams
- 1 gallon = 3.785 liters

Based on the Analytical Results from Each Month:

Pounds of VOCs removed calculated by the following formula:

$$(VOCs_{Influent} - VOCs_{Effluent})(\mu g/L) \cdot (1g/10^6 \mu g) \cdot (1 lb/453.5924 g) \cdot (Monthly\ process\ water)(gal) \cdot (3.785 L/gallon)$$

Attachment A
IEG Weekly Inspection Reports
May 2012

Including:

4/30/12

5/7/12

5/14/12

5/21/12

5/30/12

6/6/12

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 30-Apr-12 ACTIVITIES: Site Inspection
 INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____
 WEATHER CONDITIONS: Partly cloudy, cool OUTSIDE TEMPERATURE (°F): 51

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
PW-7 and PW-8 are OFF due to maintenance problems. PW-7 and PW-8 do not cycle down.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: _____	OFF: <input checked="" type="checkbox"/> <u>7</u> ft	PW-5	ON: _____	OFF: <input checked="" type="checkbox"/> <u>5</u> ft
PW-2	ON: _____	OFF: <input checked="" type="checkbox"/> <u>7</u> ft	PW-6	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>6</u> ft
PW-3	ON: _____	OFF: <input checked="" type="checkbox"/> <u>3</u> ft	PW-7	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>18</u> ft
PW-4	ON: _____	OFF: <input checked="" type="checkbox"/> <u>8</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>18</u> ft

EQUALIZATION TANK: 4 ft Last Alarm DT/Condition: 4/26/12 Air Stripper Low Level

NOTES: _____

INFLUENT FLOW RATE: 14 gpm INFLUENT TOTALIZER READING: 2,243,734.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 12 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 20.5 gallons
 SEQUESTERING AGENT FEED RATE: 7.0 ml/min METERING PUMP PRESSURE: 3.0 psi

BAG FILTER PRESSURES: LEFT:

Top	Bottom
<u>0</u>	<u>0</u>

 psi RIGHT:

Top	Bottom
<u>6</u>	<u>0</u>

 psi

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 14 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 8.0 in. H₂O
 AIR STRIPPER DIFFERENTIAL PRESSURE: 0.025 in. H₂O DISCHARGE PRESSURE: 4.7 in. H₂O

EFFLUENT PUMP IN USE: #1 #2 _____ EFFLUENT FEED PUMP PRESSURE: 2.0 psi
 EFFLUENT FLOW RATE: 94 gpm EFFLUENT TOTALIZER READING: 67,644,677 79880 gallons

ARE BUILDING HEATERS IN USE? YES: NO: _____ INSIDE TEMPERATURE (°F): 62

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:

WATER LEVEL IN SUMP: 7.5 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 7-May-12 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____

WEATHER CONDITIONS: Cloudy, warm OUTSIDE TEMPERATURE (°F): 62

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
PW-7 and PW-8 are OFF due to maintenance problems. PW-7 and PW-8 do not cycle down.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>7</u> ft	PW-5	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>4</u> ft
PW-2	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>5</u> ft	PW-6	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>6</u> ft
PW-3	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>6</u> ft	PW-7	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>19</u> ft
PW-4	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>4</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>18</u> ft

EQUALIZATION TANK: 3 ft Last Alarm D/T/Condition: 4/26/12 Air Stripper Low Level

NOTES: _____

INFLUENT FLOW RATE: 57 gpm INFLUENT TOTALIZER READING: 2,360,887.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 2 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 3.4 gallons

SEQUESTERING AGENT FEED RATE: 8.0 ml/min METERING PUMP PRESSURE: 3.0 psi

		Top	Bottom			Top	Bottom
BAG FILTER PRESSURES:	LEFT:	<u>0</u>	<u>0</u> psi	RIGHT:	<u>8</u>	<u>0</u> psi	

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 15 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 9.0 in. H₂O

AIR STRIPPER DIFFERENTIAL PRESSURE: 0.019 in. H₂O DISCHARGE PRESSURE: 4.5 in. H₂O

EFFLUENT PUMP IN USE: #1 #2 _____ EFFLUENT FEED PUMP PRESSURE: 2.0 psi

EFFLUENT FLOW RATE: 95 gpm EFFLUENT TOTALIZER READING: 67,716,597 153130 gallons

ARE BUILDING HEATERS IN USE? YES: _____ NO: INSIDE TEMPERATURE (°F): 73

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:

WATER LEVEL IN SUMP: 7.0 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE

NYSDEC Site #90150157

SITE INSPECTION FORM

7-May-12

SAMPLES COLLECTED? YES: NO:

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	INF	2:00 PM	7.32	9.07	15.2	2789
AIR STRIPPER EFFLUENT:	EFF	2:00 PM	8.51	7.14	17.3	2921

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS: ? YES: NO:

WERE MANHOLES INSPECTED? YES: NO:

WERE ELECTRICAL BOXES INSPECTED? YES: NO:

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: NO:

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has collapsed inner ring. PZ-1B has missing top cover and is temporarily sealed.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks: Turned Jesco pump down slightly: Left 2.25; Right 1.25.

Other Actions: Switched Redux pickup to new drum. Have (2) full drums.

Removed vent cover over man door in Treatment Room for the warm season.

Ground off sharp corners on Air Stripper base, influent pump base and drum base ramp.

AGWAY

SYSTEM VACUUM: _____ in. H ₂ O			AIR PRESSURE: _____ psi		
SP-1: _____ scfm _____ psi	SP-5 _____ scfm _____ psi				
SP-2: _____ scfm _____ psi	SP-6 _____ scfm _____ psi				
SP-3: _____ scfm _____ psi	SP-7 _____ scfm _____ psi				
SP-4: _____ scfm _____ psi	SP-8 _____ scfm _____ psi				

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: System is OFF until further instructions.

Other Actions:

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 14-May-12 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: Carroll Plumbing

WEATHER CONDITIONS: Cloudy, warm OUTSIDE TEMPERATURE (° F): 67

ARE WELL PUMPS OPERATING IN AUTO: YES: NO: ✓ If "NO", provide explanation below
PW-7 and PW-8 are OFF due to maintenance problems. PW-7 and PW-8 do not cycle down.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: <u> </u>	OFF: <u>✓</u>	<u>6</u> ft	PW-5	ON: <u> </u>	OFF: <u>✓</u>	<u>4</u> ft
PW-2	ON: <u> </u>	OFF: <u>✓</u>	<u>6</u> ft	PW-6	ON: <u>✓</u>	OFF: <u> </u>	<u>10</u> ft
PW-3	ON: <u> </u>	OFF: <u>✓</u>	<u>7</u> ft	PW-7	ON: <u>✓</u>	OFF: <u> </u>	<u>19</u> ft
PW-4	ON: <u> </u>	OFF: <u>✓</u>	<u>5</u> ft	PW-8	ON: <u>✓</u>	OFF: <u> </u>	<u>18</u> ft

EQUALIZATION TANK: 3 ft Last Alarm D/T/Condition: 4/26/12 Air Stripper Low Level

NOTES:

INFLUENT FLOW RATE: 49 gpm INFLUENT TOTALIZER READING: 2,472,591.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 22 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 37.5 gallons

SEQUESTERING AGENT FEED RATE: 6.0 ml/min METERING PUMP PRESSURE: 2.0 psi

		Top	Bottom		Top	Bottom
BAG FILTER PRESSURES:	LEFT:	<u>0</u>	<u>0</u> psi	RIGHT:	<u>8</u>	<u>0</u> psi

INFLUENT FEED PUMP IN USE: #1 ✓ #2 INFLUENT PUMP PRESSURE: 15 psi

AIR STRIPPER BLOWER IN USE: #1 ✓ #2 AIR STRIPPER PRESSURE: 8.0 in. H₂O

AIR STRIPPER DIFFERENTIAL PRESSURE: 0.019 in. H₂O DISCHARGE PRESSURE: 4.5 in. H₂O

EFFLUENT PUMP IN USE: #1 ✓ #2 EFFLUENT FEED PUMP PRESSURE: 2.0 psi

EFFLUENT FLOW RATE: 96 gpm EFFLUENT TOTALIZER READING: 67,784,608 222510 gallons

ARE BUILDING HEATERS IN USE? YES: NO: ✓ INSIDE TEMPERATURE (° F): 75

IS SUMP PUMP IN USE: YES: ✓ NO: ARE ANY LEAKS PRESENT? YES: NO: ✓

WATER LEVEL IN SUMP: 6.5 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: ✓ NO:

MR. C's DRY CLEANERS SITE

NYSDEC Site #90150157

SITE INSPECTION FORM

14-May-12

SAMPLES COLLECTED? YES: _____ NO: ✓

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	_____	_____	_____	_____	_____	_____
AIR STRIPPER EFFLUENT:	_____	_____	_____	_____	_____	_____

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS? YES: _____ NO: ✓

WERE MANHOLES INSPECTED? YES: ✓ NO: _____

WERE ELECTRICAL BOXES INSPECTED? YES: ✓ NO: _____

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: _____ NO: ✓

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has collapsed inner ring. PZ-1B has missing top cover and is temporarily sealed.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks: Changed Main Control Panel switch light bulb.

Other Actions: Changed bag filters.

Removed Blower Motor #2 for warranty repair.

Removed Blower Fan #2 for balancing.

AGWAY

SYSTEM VACUUM: _____ in. H₂O AIR PRESSURE: _____ psi

SP-1: _____ scfm _____ psi SP-5 _____ scfm _____ psi

SP-2: _____ scfm _____ psi SP-6 _____ scfm _____ psi

SP-3: _____ scfm _____ psi SP-7 _____ scfm _____ psi

SP-4: _____ scfm _____ psi SP-8 _____ scfm _____ psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: System is OFF until further instructions.

Other Actions:

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 21-May-12 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____

WEATHER CONDITIONS: Sunny, warm OUTSIDE TEMPERATURE (° F): 74

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
PW-7 and PW-8 are OFF due to maintenance problems. PW-7 and PW-8 do not cycle down.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>5</u> ft	PW-5	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>7</u> ft
PW-2	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>6</u> ft	PW-6	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>9</u> ft
PW-3	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>7</u> ft	PW-7	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>18</u> ft
PW-4	ON: _____	OFF: <input checked="" type="checkbox"/>	<u>6</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____	<u>18</u> ft

EQUALIZATION TANK: 3 ft Last Alarm DTT/Condition: 5/18/12 Air Stripper Low Level

NOTES: _____

INFLUENT FLOW RATE: 12 gpm INFLUENT TOTALIZER READING: 2,577,337.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 4 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 7 gallons

SEQUESTERING AGENT FEED RATE: 6.0 ml/min METERING PUMP PRESSURE: 2.0 psi

BAG FILTER PRESSURES:	LEFT:	Top	Bottom	RIGHT:	Top	Bottom
		<u>0</u>	<u>0</u> psi		<u>6</u>	<u>0</u> psi

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 15 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 8.0 in. H₂O

AIR STRIPPER DIFFERENTIAL PRESSURE: 0.019 in. H₂O DISCHARGE PRESSURE: 4.3 in. H₂O

EFFLUENT PUMP IN USE: #1 #2 _____ EFFLUENT FEED PUMP PRESSURE: 1.0 psi

EFFLUENT FLOW RATE: 112 gpm EFFLUENT TOTALIZER READING: 67,847,030 286310 gallons

ARE BUILDING HEATERS IN USE? YES: _____ NO: INSIDE TEMPERATURE (° F): 82

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:

WATER LEVEL IN SUMP: 7.5 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE

NYSDEC Site #90150157

SITE INSPECTION FORM

21-May-12

SAMPLES COLLECTED? YES: _____ NO: ✓

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	_____	_____	_____	_____	_____	_____
AIR STRIPPER EFFLUENT:	_____	_____	_____	_____	_____	_____

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS? YES: _____ NO: ✓

WERE MANHOLES INSPECTED? YES: ✓ NO: _____

WERE ELECTRICAL BOXES INSPECTED? YES: ✓ NO: _____

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: _____ NO: ✓

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has collapsed inner ring. PZ-1B has missing top cover and is temporarily sealed.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks:

Other Actions: Emptied remains of old Redux drum into new drum.

Took Blower Motor #2 fan to ACT in Clarence, NY to get balanced.

AGWAY

SYSTEM VACUUM: _____ in. H₂O

AIR PRESSURE: _____ psi

SP-1: _____ scfm _____ psi	SP-5 _____ scfm _____ psi
SP-2: _____ scfm _____ psi	SP-6 _____ scfm _____ psi
SP-3: _____ scfm _____ psi	SP-7 _____ scfm _____ psi
SP-4: _____ scfm _____ psi	SP-8 _____ scfm _____ psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: System is OFF until further instructions.

Other Actions:

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 30-May-12 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: E & E, Inc, Carol Plumbing

WEATHER CONDITIONS: Sunny, warm OUTSIDE TEMPERATURE (°F): 70

ARE WELL PUMPS OPERATING IN AUTO: YES: NO: ✓ If "NO", provide explanation below
PW-6, PW-7 and PW-8 are OFF due to maintenance problems. PW-7 and PW-8 do not cycle down.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: <u>✓</u>	OFF: <u> </u>	<u>8</u> ft	PW-5	ON: <u> </u>	OFF: <u>✓</u>	<u>6</u> ft
PW-2	ON: <u> </u>	OFF: <u>✓</u>	<u>7</u> ft	PW-6	ON: <u>✓</u>	OFF: <u> </u>	<u>14</u> ft
PW-3	ON: <u> </u>	OFF: <u>✓</u>	<u>4</u> ft	PW-7	ON: <u>✓</u>	OFF: <u> </u>	<u>13</u> ft
PW-4	ON: <u> </u>	OFF: <u>✓</u>	<u>6</u> ft	PW-8	ON: <u>✓</u>	OFF: <u> </u>	<u>18</u> ft

EQUALIZATION TANK: 4 ft Last Alarm D/T/Condition: 5/29/12 Air Stripper High Level

NOTES: _____

INFLUENT FLOW RATE: 65 gpm INFLUENT TOTALIZER READING: 2,712,404.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 4 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 6.8 gallons

SEQUESTERING AGENT FEED RATE: 5.0 ml/min METERING PUMP PRESSURE: 2.0 psi

		Top	Bottom		Top	Bottom
BAG FILTER PRESSURES:	LEFT:	<u>0</u>	<u>0</u> psi	RIGHT:	<u>8</u>	<u>0</u> psi

INFLUENT FEED PUMP IN USE: #1 ✓ #2 INFLUENT PUMP PRESSURE: psi

AIR STRIPPER BLOWER IN USE: #1 ✓ #2 AIR STRIPPER PRESSURE: 8.0 in. H₂O

AIR STRIPPER DIFFERENTIAL PRESSURE: 0.019 in. H₂O DISCHARGE PRESSURE: 4.5 in. H₂O

EFFLUENT PUMP IN USE: #1 #2 ✓ EFFLUENT FEED PUMP PRESSURE: 3.0 psi

EFFLUENT FLOW RATE: 0.019 gpm EFFLUENT TOTALIZER READING: 67,927,570 368320 gallons

ARE BUILDING HEATERS IN USE? YES: NO: ✓ INSIDE TEMPERATURE (°F): 77

IS SUMP PUMP IN USE: YES: ✓ NO: ARE ANY LEAKS PRESENT? YES: NO: ✓

WATER LEVEL IN SUMP: 7.0 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: ✓ NO:

MR. C's DRY CLEANERS SITE

NYSDEC Site #90150157

SITE INSPECTION FORM

30-May-12

SAMPLES COLLECTED? YES: NO:

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	_____	_____	_____	_____	_____	_____
AIR STRIPPER EFFLUENT:	_____	_____	_____	_____	_____	_____

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS? YES: NO:

WERE MANHOLES INSPECTED? YES: NO:

WERE ELECTRICAL BOXES INSPECTED? YES: NO:

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: NO:

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has collapsed inner ring. PZ-1B has missing top cover and is temporarily sealed.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks: Redux system is OFF until shipment arrives due to lack of product.

Other Actions: Took delivery of (3) drums of Redux (May 31).

Met with Intrepid Automotive Enterprises (Tracy Smith) to discuss repaving Mr Cs parking lot and MWs.

Picked up balance fan from ACT in Clarence, NY.

Replaced repaired Blower Motor #2 and the balanced fan.

AGWAY

SYSTEM VACUUM: _____ in. H₂O

AIR PRESSURE: _____ psi

SP-1: _____ scfm _____ psi	SP-5 _____ scfm _____ psi
SP-2: _____ scfm _____ psi	SP-6 _____ scfm _____ psi
SP-3: _____ scfm _____ psi	SP-7 _____ scfm _____ psi
SP-4: _____ scfm _____ psi	SP-8 _____ scfm _____ psi

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: System is OFF until further instructions.

Other Actions:

MR. C's DRY CLEANERS SITE
NYSDEC Site #9-15-157
OM&M: SITE INSPECTION FORM

DATE: 6-Jun-12 ACTIVITIES: Site Inspection

INSPECTION PERSONNEL: R. Allen OTHER PERSONNEL: _____

WEATHER CONDITIONS: Partly cloudy, warm OUTSIDE TEMPERATURE (°F): 72

ARE WELL PUMPS OPERATING IN AUTO: YES: _____ NO: If "NO", provide explanation below
PW-6, PW-7 and PW-8 are OFF due to maintenance problems. PW-7 and PW-8 do not cycle down.

PROVIDE WATER LEVEL READINGS ON CONTROL PANEL

RW-1	ON: _____	OFF: <input checked="" type="checkbox"/> <u>8</u> ft	PW-5	ON: _____	OFF: <input checked="" type="checkbox"/> <u>6</u> ft
PW-2	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>5</u> ft	PW-6	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>14</u> ft
PW-3	ON: _____	OFF: <input checked="" type="checkbox"/> <u>7</u> ft	PW-7	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>13</u> ft
PW-4	ON: _____	OFF: <input checked="" type="checkbox"/> <u>7</u> ft	PW-8	ON: <input checked="" type="checkbox"/>	OFF: _____ <u>18</u> ft

EQUALIZATION TANK: 3 ft Last Alarm D/T/Condition: 6/1/12 Air Stripper Low Level

NOTES: _____

INFLUENT FLOW RATE: 50 gpm INFLUENT TOTALIZER READING: 2,823,890.0 gallons

SEQUESTERING AGENT DRUM LEVEL: 29 inches (x 1.7=) AMOUNT OF AGENT REMAINING: 49 gallons

SEQUESTERING AGENT FEED RATE: 5.0 ml/min METERING PUMP PRESSURE: 3.0 psi

BAG FILTER PRESSURES:	LEFT:	Top	Bottom	RIGHT:	Top	Bottom
		<u>0</u>	<u>0</u> psi		<u>12 - 6</u>	<u>0</u> psi

INFLUENT FEED PUMP IN USE: #1 #2 _____ INFLUENT PUMP PRESSURE: 12 psi

AIR STRIPPER BLOWER IN USE: #1 #2 _____ AIR STRIPPER PRESSURE: 8.0 in. H₂O

AIR STRIPPER DIFFERENTIAL PRESSURE: 0.015 in. H₂O DISCHARGE PRESSURE: 4.5 in. H₂O

EFFLUENT PUMP IN USE: #1 _____ #2 EFFLUENT FEED PUMP PRESSURE: 3.0 psi

EFFLUENT FLOW RATE: 115 gpm EFFLUENT TOTALIZER READING: 67,993,657 435730 gallons

ARE BUILDING HEATERS IN USE? YES: _____ NO: INSIDE TEMPERATURE (°F): 75

IS SUMP PUMP IN USE: YES: NO: _____ ARE ANY LEAKS PRESENT? YES: _____ NO:

WATER LEVEL IN SUMP: 6.5 in. TREATMENT BUILDING CLEAN & ORGANIZED? YES: NO: _____

MR. C's DRY CLEANERS SITE

NYSDEC Site #90150157

SITE INSPECTION FORM

6-Jun-12

SAMPLES COLLECTED? YES: _____ NO: _____

	Sample ID	Time of Sampling	pH	Turbidity	Temp.	Sp. Cond.
AIR STRIPPER INFLUENT:	_____	_____	_____	_____	_____	_____
AIR STRIPPER EFFLUENT:	_____	_____	_____	_____	_____	_____

IS THERE EVIDENCE OF TAMPERING/VANDALISM OF WELLS: ? YES: _____ NO:

WERE MANHOLES INSPECTED? YES: NO: _____

WERE ELECTRICAL BOXES INSPECTED? YES: NO: _____

IS WATER PRESENT IN ANY MANHOLES OR ELECTRICAL BOXES? YES: _____ NO:

If yes, provide manhole/electric box ID and description of any corrective measures below:

PW-4 has collapsed inner ring. PZ-1B has missing top cover and is temporarily sealed.

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON MR. C's SITE

Remarks:

Other Actions:

AGWAY

SYSTEM VACUUM: _____ in. H ₂ O			AIR PRESSURE: _____ psi		
SP-1: _____	scfm _____	psi _____	SP-5 _____	scfm _____	psi _____
SP-2: _____	scfm _____	psi _____	SP-6 _____	scfm _____	psi _____
SP-3: _____	scfm _____	psi _____	SP-7 _____	scfm _____	psi _____
SP-4: _____	scfm _____	psi _____	SP-8 _____	scfm _____	psi _____

INCLUDE REMARKS & DESCRIBE ANY OTHER SYSTEM MAINTENANCE PERFORMED ON AGWAY SITE

Remarks: System is OFF until further instructions.

Other Actions:

MR. C's DRY CLEANERS SITE

NYSDEC Site #9-15-157

OM&M: PIEZOMETER WATER LEVEL LOG

Date: 11-May-12

Measurements taken by: R. Allen

RW-1	17.60 ft	Comments:
PZ-1A	----- ft	Comments: car over well
PZ-1B	----- ft	Comments: sealed over
PZ-1C	12.25 ft	Comments:
PZ-1D	12.35 ft	Comments:
PW-2	14.79 ft	Comments:
PZ-2A	10.88 ft	Comments:
PZ-2B	11.22 ft	Comments:
PZ-2C	10.60 ft	Comments:
MW-7	11.25 ft	Comments: Substitute for 2D
PW-3	19.80 ft	Comments:
PZ-3A	11.37 ft	Comments:
PZ-3B	11.44 ft	Comments:
PZ-3C	11.95 ft	Comments:
PZ-3D	11.45 ft	Comments:
PW-4	----- ft	Comments: damaged ring
PZ-4A	13.98 ft	Comments:
PZ-4B	10.76 ft	Comments:
PZ-4C	----- ft	Comments: sealed over
PZ-4D	10.39 ft	Comments:

PW-5	15.10 ft	Comments:
PZ-5A	12.31 ft	Comments:
PZ-5B	10.72 ft	Comments:
PZ-5C	10.31 ft	Comments:
PZ-5D	12.39 ft	Comments:
PW-6	19.40 ft	Comments:
PZ-6A	11.54 ft	Comments:
PZ-6B	11.41 ft	Comments:
PZ-6C	11.70 ft	Comments:
PZ-6D	11.30 ft	Comments: Shown as RW-2 on map
PW-7	5.10 ft	Comments:
MPI-6S	11.13 ft	Comments:
PZ-7B	11.13 ft	Comments:
OW-B	11.09 ft	Comments:
PZ-7D	10.82 ft	Comments:
PW-8	13.00 ft	Comments:
PZ-8A	8.01 ft	Comments:
PZ-8B	7.96 ft	Comments:
PZ-8C	7.65 ft	Comments:
PZ-8D	7.90 ft	Comments:

PUMPS IN OPERATION DURING MEASUREMENTS

RW-1 pump on?	Yes	<input checked="" type="checkbox"/>	No
PW-2 pump on?	Yes	<input checked="" type="checkbox"/>	No
PW-3 pump on?	<input checked="" type="checkbox"/> Yes		No
PW-4 pump on?	Yes		No

PW-5 pump on?	Yes	<input checked="" type="checkbox"/>	No
PW-6 pump on?	Yes	<input checked="" type="checkbox"/>	No
PW-7 pump on?	Yes	<input checked="" type="checkbox"/>	No
PW-8 pump on?	Yes	<input checked="" type="checkbox"/>	No

Mr. C's CLEANERS OM&M

SUMMARY OF FIELD ACTIVITIES BY IEG - 5/2012

DATE	ACTIVITY
2-May	OM&M end of month office work.
7-May	OM&M Weekly Inspection and sampling and office work. UM office work.
10-May	Remove vent cover for warm season. Grind off sharp corners on metal bases and ramp.
11-May	Piezometer Readings
14-May	OM&M Weekly Inspection
16-May	Change bag filters
18-May	Remove Blower motor #2. Take motor in for warranty repair. Take blower fan to ACT to be balanced.
21-May	OM&M Weekly Inspection. Emptied remains of old Redux drum into new drum.
24-May	Get Jesco pump parts at Treatment Room. UM office work.
29-May	Clean Air Stripper with power sprayer. Readjust Air Stripper. Get supplies.
30-May	OM&M Weekly Inspection and office work. Special sampling. Pick up blower fan.
31-May	Take shipment of Redux. Meet with property manager about parking lot repaving.

Mr. C's CLEANERS OM&M
STATUS OF FIELD ACTIVITIES BY IEG - 5/2012

ACTIVITY	DESCRIPTION	COMPLETION DATE/STATUS
Repair (2) Filter Baskets	(1) Filter Basket is splitting open along its seam. (1) Filter Basket has a broken handle. Take both baskets to Buffalo Well Products for repair.	Mar-12
Dig containment trench around Library Parking Lot	Spruce needles wash onto Library Parking Lot around groups PW-6 and PW-7 during rain storms. The needles wash into pump wells and underground enclosures where they obstruct the flow of water in the pipes. Re-dig small trench around the entire back parking lot.	Mar-12
Clean Effluent Pumps and	Effluent Meter is running slowly. Disassemble and clean pumps and meter.	Apr-12
Repair Blower #2	Determined that bearing is failing in Air Stripper Blower Motor. Replace motor with new motor. Determine that replacement motor is defective. Pull new motor for warranty repair.	May-12
Add Inline filter to Compressor	The Condensate Removal Valve (CRV) on the Air Compressor gets stuck open by occasional pieces of debris from the air tank. Put filter on hose before the CRV.	on hold
Replace SVE Vacuum Drum	Present Vacuum Drum inside Agway Shed is corroded. Replace drum.	on hold
AS / SVE System Evaluation	Agway Shed - test & evaluate air sparge system and Soil Vapor Extraction system. Installed fittings to measure pressure and flow. Tested air sparging and SVE lines.	on hold
PW-4 Well Repair and Level	Asphalt around PW-4 well has sunk, due to collapse of corroded inner ring. Replace inner ring and bring parking lot up to level with asphalt patch.	in progress
PW-4 UE Level	Asphalt around Underground Enclosure has sunk, leaving it vulnerable to damage. Bring parking lot up to level with asphalt patch.	in progress
Install MW Ring	Piezimeter in Agway Site parking lot was damaged by the road repair crew. To instal new Monitoring Well Ring around damaged Piezometer for protection.	in progress
Rebuild JAC Pump as needed	Jesco America Corp recommends rebuilding the Redux pump when needed. Purchased rebuild kit.	in progress
Brace Effluent Pipe	David Szymanski (NYSDEC) inspected Treatment Room and said that the effluent pipe should be braced in (3) places to the north wall.	in progress
Inspect and clean Manholes	Inspect manholes near operating pumps. Pump out water in manholes and clean out remaining sediment and other material.	in progress
Agway Shed Concrete Dump	Approximately 1/4 yard of concrete was washed out on the north side of the Agway Shed. Concrete should be removed.	on hold
Trim Broken Piezometers	Many of the piezometers are broken. Measuring water levels is not precise when a pipe is broken. Identify and trim all broken piezometers.	in progress
Cool Treatment Room	Temperature in Treatment Room is well above 90 degrees during the summer months. Need to increase outside air inflow to the room.	in progress
Replace Air Stripper Exhaust	Present Air Stripper exhaust is very heavy and leaks moisture. Replace with lighter system.	in progress
Bank 2 Timer is defective	The Bank 2 Timer inside the Agway Shed stopped working. Dismantle Timer and take for repair or replace defective parts.	on hold
PW-7 pitless adapter	Pitless adapter does not seal well. Repair or replacer pitless adapter	in progress
PW-8 pitless adapter	Pitless adapter feels brokent/does not seal well. Repair/replace pitless adapter	in progress
PZ-1B Repair	Top cover was knocked off and lost by snowplow. Replace inner ring and lower height so MW will not be as susceptible to snowplow damage.	in progress
Adjust Air Stripper	Effluent lab results were below standard. Troubleshoot and adjust Air Stripper to achieve better results.	in progress
PW-7 is not pumping down	Inspect and clean pump and transducer. Inspect pitless adapter to gauge condition of horizontal lines.	in progress
PW-6 is not pumping down	Inspect/clean pump & transducer. Inspect pitless adapter to gauge condition of horizontal lines.	in progress
Mr Cs Building Remodel	The Mr Cs building is being remodeled - In May, it included siding and lights around the Treatment Room. Photo document the remodeling.	in progress
Mr Cs Parking Lot Repaving	During early June the paved parking lot is being repaved. Talk to property manager and paving contractors about MWs and UEs. Photo document the remodeling.	in progress

Mr. C's CLEANERS OM&M

SUMMARY OF WATER PUMP MAINTENANCE BY IEG - 2012

as of May 12

ID	CLEAN & INSPECT PUMP	REPLACED PUMP	REPAIR PUMP	PITLESS ADAPTER	HORIZONTAL PIPE	CLEAN & INSPECT TRANSDUCER	REPLACE TRANSDUCER	REPAIR TRANSDUCER	PUMP OUT WELL	CLEAN OUT & INSPECT ELECTRICAL BOX	ELECTRICAL BOX REPAIR
RW - 1	May 10, Jan 12	Feb 08, Jan 12	May-10			May 10, Jan 12					
PW - 2	Aug 09, May 10	Jul-08				Nov 11, May 10	Sep 09, Nov 11		Aug-09	Nov-11	Sep-09
PW - 3	Aug 09, May 10	Jul 08, Dec 11		Repair adapter		Aug 09, Nov 11	Nov-11		Aug-09	Nov-11	
PW - 4	Sep 09, May 10, Jan 12	Dec 07, Jan 12				May 10, Nov 11	Nov-11		Jul 09, Sep 09	Sep 09, Nov 11	Sep-09
PW - 5	Jan-12	Jul 08, Jan 12				Mar-11	Jan-12	Sep-09		Jan-12	
PW - 6	Jul-09	Jun 08, Jul 09			Pipe 8/09	Apr 09, Aug 09	Sep-09		Aug-09	Aug 09, Sep 09	Jul 09, Sep 09
PW - 7	May 10, Oct 10, Aug 11, Mar 12	Nov 07, Jul 09, Oct 10			Pipe 8/09	Aug 09, May 10, Oct 10, Aug 11, Mar 12			Aug 09, May 10, Aug 11		
PW - 8	Aug 09, May 10, Aug 11	Jul 08, Sep 09, Aug 11			Pipe 8/09	Aug 09, May 10, Aug 11			Aug 09, May 10, Aug 11		

Mr. C's CLEANERS OM&M

SUMMARY OF WATER PUMP STATUS - 2012

as of May 12

ID	NEEDS CLEANING & INSPECTION	NEEDS NEW PUMP	NEEDS NEW INNER PUMP	NEEDS P.A. OR PIPE	NEEDS WELL CLEAN-OUT	PITLESS ADAPTER	NEEDS HORIZONTAL LINE PURGE	NEEDS TRANSDUCER INSPECTION	NEEDS NEW TRANSDUCER	NEEDS ANEROID BELLOWS	NEEDS U.E. CLEANED	NEEDS U.E. REPAIR
RW-1	DONE 1/12	NO	PZ-1B		YES			NO	NO	NO	NO	YES - bolts
PW-2	NO	NO			YES			NO		NO	NO	YES - bolts
PW-3	NO	NO		REPAIRED 8/09	DONE 8/09			NO		NO	NO	NO
PW-4	DONE 1/12	NO	YES		DONE 9/09			NO		NO	NO	YES - Asphalt patch
PW-5	DONE 1/12	NO			YES			NO	DONE 1/12	DONE 1/12	NO	NO
PW-6	YES	DONE 8/09		Replaced pipe 8/09	DONE 8/09			YES	NO	DONE 9/09	NO	DONE
PW-7	YES	DONE 10/10		Replaced pipe 8/09	YES	YES	YES	NO	NO	DONE	NO	NO
PW-8	YES	DONE 8/11		Replaced pipe 8/09	NO	YES	YES	NO	NO	YES	NO	NO

Mr. C's CLEANERS OM&M

SUMMARY OF FIELD ACTIVITIES BY IEG - 5/2012

DATE	ACTIVITY
2-May	OM&M end of month office work.
7-May	OM&M Weekly Inspection and sampling and office work. UM office work.
10-May	Remove vent cover for warm season. Grind off sharp corners on metal bases and ramp.
11-May	Piezometer Readings
14-May	OM&M Weekly Inspection
16-May	Change bag filters
18-May	Remove Blower motor #2. Take motor in for warranty repair. Take blower fan to ACT to be balanced.
21-May	OM&M Weekly Inspection. Emptied remains of old Redux drum into new drum.
24-May	Get Jesco pump parts at Treatment Room. UM office work.
29-May	Clean Air Stripper with power sprayer. Readjust Air Stripper. Get supplies.
30-May	OM&M Weekly Inspection and office work. Special sampling. Pick up blower fan.
31-May	Take shipment of Redux. Meet with property manager about parking lot repaving.

Mr. C's CLEANERS OM&M
STATUS OF FIELD ACTIVITIES BY IEG - 5/2012

ACTIVITY	DESCRIPTION	COMPLETION DATE/STATUS
Repair (2) Filter Baskets	(1) Filter Basket is splitting open along its seam. (1) Filter Basket has a broken handle. Take both baskets to Buffalo Well Products for repair.	Mar-12
Dig containment trench around Library Parking Lot	Spruce needles wash onto Library Parking Lot around groups PW-6 and PW-7 during rain storms. The needles wash into pump wells and underground enclosures where they obstruct the flow of water in the pipes. Re-dig small trench around the entire back parking lot.	Mar-12
Clean Effluent Pumps and	Effluent Meter is running slowly. Disassemble and clean pumps and meter.	Apr-12
Repair Blower #2	Determined that bearing is failing in Air Stripper Blower Motor. Replace motor with new motor. Determine that replacement motor is defective. Pull new motor for warranty repair.	May-12
Add Inline filter to Compressor	The Condensate Removal Valve (CRV) on the Air Compressor gets stuck open by occasional pieces of debris from the air tank. Put filter on hose before the CRV.	on hold
Replace SVE Vacuum Drum	Present Vacuum Drum inside Agway Shed is corroded. Replace drum.	on hold
AS / SVE System Evaluation	Agway Shed - test & evaluate air sparge system and Soil Vapor Extraction system. Installed fittings to measure pressure and flow. Tested air sparging and SVE lines.	on hold
PW-4 Well Repair and Level	Asphalt around PW-4 well has sunk, due to collapse of corroded inner ring. Replace inner ring and bring parking lot up to level with asphalt patch.	in progress
PW-4 UE Level	Asphalt around Underground Enclosure has sunk, leaving it vulnerable to damage. Bring parking lot up to level with asphalt patch.	in progress
Install MW Ring	Piezimeter in Agway Site parking lot was damaged by the road repair crew. To instal new Monitoring Well Ring around damaged Piezometer for protection.	in progress
Rebuild JAC Pump as needed	Jesco America Corp recommends rebuilding the Redux pump when needed. Purchased rebuild kit.	in progress
Brace Effluent Pipe	David Szymanski (NYSDEC) inspected Treatment Room and said that the effluent pipe should be braced in (3) places to the north wall.	in progress
Inspect and clean Manholes	Inspect manholes near operating pumps. Pump out water in manholes and clean out remaining sediment and other material.	in progress
Agway Shed Concrete Dump	Approximately 1/4 yard of concrete was washed out on the north side of the Agway Shed. Concrete should be removed.	on hold
Trim Broken Piezometers	Many of the piezometers are broken. Measuring water levels is not precise when a pipe is broken. Identify and trim all broken piezometers.	in progress
Cool Treatment Room	Temperature in Treatment Room is well above 90 degrees during the summer months. Need to increase outside air inflow to the room.	in progress
Replace Air Stripper Exhaust	Present Air Stripper exhaust is very heavy and leaks moisture. Replace with lighter system.	in progress
Bank 2 Timer is defective	The Bank 2 Timer inside the Agway Shed stopped working. Dismantle Timer and take for repair or replace defective parts.	on hold
PW-7 pitless adapter	Pitless adapter does not seal well. Repair or replacer pitless adapter	in progress
PW-8 pitless adapter	Pitless adapter feels brokent/does not seal well. Repair/replace pitless adapter	in progress
PZ-1B Repair	Top cover was knocked off and lost by snowplow. Replace inner ring and lower height so MW will not be as susceptible to snowplow damage.	in progress
Adjust Air Stripper	Effluent lab results were below standard. Troubleshoot and adjust Air Stripper to achieve better results.	in progress
PW-7 is not pumping down	Inspect and clean pump and transducer. Inspect pitless adapter to gauge condition of horizontal lines.	in progress
PW-6 is not pumping down	Inspect/clean pump & transducer. Inspect pitless adapter to gauge condition of horizontal lines.	in progress
Mr Cs Building Remodel	The Mr Cs building is being remodeled - In May, it included siding and lights around the Treatment Room. Photo document the remodeling.	in progress
Mr Cs Parking Lot Repaving	During early June the paved parking lot is being repaved. Talk to property manager and paving contractors about MWs and UEs. Photo document the remodeling.	in progress

Mr. C's CLEANERS OM&M

SUMMARY OF WATER PUMP MAINTENANCE BY IEG - 2012

as of May 12

ID	CLEAN & INSPECT PUMP	REPLACED PUMP	REPAIR PUMP	PITLESS ADAPTER	HORIZONTAL PIPE	CLEAN & INSPECT TRANSDUCER	REPLACE TRANSDUCER	REPAIR TRANSDUCER	PUMP OUT WELL	CLEAN OUT & INSPECT ELECTRICAL BOX	ELECTRICAL BOX REPAIR
RW - 1	May 10, Jan 12	Feb 08, Jan 12	May-10			May 10, Jan 12					
PW - 2	Aug 09, May 10	Jul-08				Nov 11, May 10	Sep 09, Nov 11		Aug-09	Nov-11	Sep-09
PW - 3	Aug 09, May 10	Jul 08, Dec 11		Repair adapter		Aug 09, Nov 11	Nov-11		Aug-09	Nov-11	
PW - 4	Sep 09, May 10, Jan 12	Dec 07, Jan 12				May 10, Nov 11	Nov-11		Jul 09, Sep 09	Sep 09, Nov 11	Sep-09
PW - 5	Jan-12	Jul 08, Jan 12				Mar-11	Jan-12	Sep-09		Jan-12	
PW - 6	Jul-09	Jun 08, Jul 09			Pipe 8/09	Apr 09, Aug 09	Sep-09		Aug-09	Aug 09, Sep 09	Jul 09, Sep 09
PW - 7	May 10, Oct 10, Aug 11, Mar 12	Nov 07, Jul 09, Oct 10			Pipe 8/09	Aug 09, May 10, Oct 10, Aug 11, Mar 12			Aug 09, May 10, Aug 11		
PW - 8	Aug 09, May 10, Aug 11	Jul 08, Sep 09, Aug 11			Pipe 8/09	Aug 09, May 10, Aug 11			Aug 09, May 10, Aug 11		


Attachment B
Analytical Report from
Mitkem Laboratories

Analytical Data Package Work Order ID: L0943

Sampled: May 7, 2012

Received: May 25, 2012

Report Date:
25-May-12 12:06



- Final Report
 Re-Issued Report
 Revised Report

Laboratory Report

Ecology and Environment Engineering P.C.
368 Pleasant View Drive
Lancaster, NY 14086

Work Order: L0943
Project : Mr. C's Dry Cleaning
Project #: 002700.DC13.02.01.01

Attn: Michael Steffan

<u>Laboratory ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Sampled</u>	<u>Date Received</u>
L0943-01	INFLUENT	Aqueous	07-May-12 14:30	08-May-12 08:35
L0943-02	EFFLUENT	Aqueous	07-May-12 15:00	08-May-12 08:35

I attest that the information contained within the report has been reviewed for accuracy and checked against the quality control requirements for each method. The results relate only to the samples(s) as received. This report may not be reproduced, except in full, without written approval from Spectrum Analytical.

All applicable NELAC or USEPA CLP requirements have been met.

Spectrum Analytical (Rhode Island) is accredited under the National Environmental Laboratory Approval Program (NELAP) and DoD Environmental Laboratory Accreditation Program (ELAP), holds Organic and Inorganic contracts under the USEPA CLP Program and is certified under several states. The current list of our laboratory approvals and certifications is available on the Certifications page on our web site at www.spectrum-analytical.com.

Please contact the Laboratory or Technical Director at 401-732-3400 with any questions regarding the data contained in the laboratory report.

Department of Defense	N/A
Connecticut	PH-0153
Delaware	N/A
Florida	B87664
Maine	2007037
Massachusetts	M-R1907
New Hampshire	2631
New Jersey	RI001
New York	11522
North Carolina	581
Pennsylvania	68-00520
Rhode Island	LAI00301
USDA	P330-08-00023
USEPA - ISM	EP-W-09-039
USEPA - SOM	EP-W-11-033



Certificate # L2247 Testing

Authorized by:

Yihai Ding
Laboratory Director

Sample Transmittal Documentation



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

CHAIN OF CUSTODY RECORD

Page 1 of 1

Special Handling: Sfd
TAT - Indicate Date Needed:
All TATs subject to laboratory approval.
Min. 24-hour notification needed for rushes.
Samples disposed of after 30 days unless otherwise instructed.

Report To: EZE Inc
368 Pleasantview Dr
Lancaster, NY 14086

Invoice To: EZE, Inc
P.O. No.: _____ RQN: _____

Project No.: _____
Site Name: MF Cs OM & M
Location: East Aurora State: NY
Sampler(s): R. Allen

Telephone #: (716) 684-8060
Project Mgr.: Mike Steffan

1=Na₂S₂O₃ 2=HCl 3=H₂SO₄ 4=HNO₃ 5=NaOH 6=Ascorbic Acid 7=CH₃OH
8= NaHSO₄ 9= _____ 10= _____ 11= _____

DW=Drinking Water GW=Groundwater WW=Wastewater
O=Oil SW=Surface Water SO=Soil SL=Sludge A=Air
X1= _____ X2= _____ X3= _____

List preservative code below:

1 A 2

Notes:

QA/QC Reporting Level
 Level I Level II
 Level III Level IV
 Other CAT A

State specific reporting standards:

G=Grab C=Composite

Lab Id:	Sample Id:	Date:	Time:	Type	Matrix
<u>01</u>	<u>INFLUENT</u>	<u>May 7, 2012</u>	<u>2:30 P</u>	<u>G</u>	<u>GW</u>
	<u>INFLUENT</u>		<u>2:30 P</u>	<u>G</u>	<u>GW</u>
	<u>INFLUENT</u>		<u>2:30 P</u>	<u>G</u>	<u>GW 2</u>
<u>02</u>	<u>EFFLUENT</u>		<u>3:00 P</u>	<u>G</u>	<u>GW</u>
	<u>EFFLUENT</u>		<u>3:00 P</u>	<u>G</u>	<u>GW</u>
	<u>EFFLUENT</u>		<u>3:00 P</u>	<u>G</u>	<u>GW 2</u>

Containers:

of VOA Vials

of Amber Glass

of Clear Glass

of Plastic

Analyses:

PH
Hardness
VOC


Please send another sample kit.
Your labels are terrible! The backing will not come off.

E-mail to msteffan@eme.com
EDD Format: PDF

Relinquished by: Richard C Allen Jr
Received by: [Signature]

Date: 5/8/12 Time: 8:35

Condition upon receipt: Iced Ambient 2 °C



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

*** Volatiles ***



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

Data Flag/Qualifiers:

- U Not Detected. This compound was analyzed-for but not detected. For most analyses the reporting limit (lowest standard concentration) is the value listed. For Department of Defense programs, this is the Limit of Detection (LOD).
- J This flag indicates an estimated value due to either
- the compound was detected below the reporting limit, or
 - estimated concentration for Tentatively Identified Compound
- B This flag indicates the compound was also detected in the associated Method Blank. The B flag has an alternative meaning for Inorganics analyses reported using CLP ILM-type metals forms, indicating a "trace" concentration below the reporting limit and equal to or above the detection limit.
- D For Organics analysis, this flag indicates the compound concentration was obtained from a secondary dilution analysis
- E This flag indicates the compound concentration exceeded the Calibration Range. The E flag has an alternative meaning for Inorganics analyses reported using CLP metals forms, indicating an estimated concentration due to the presence of interferences, as determined by the serial dilution analysis.
- P This flag is used for pesticides/PCB/herbicide compound when there is a greater than 40% difference for detected concentration between the two GC columns used for primary and confirmation analyses. This difference typically indicates an interference, causing one value to be unusually high. The **lower** of the two values is generally reported on the Form 1, and both values reported on the Form 10.
-
- A Used to flag semivolatile organic Tentatively Identified Compound library search results for compounds identified as aldol condensation byproducts.
- N Used to flag results for volatile and semivolatile Organics analysis Tentatively Identified Compounds where an analyte has passed the identification criteria, and is considered to be positively identified. For Inorganics analysis the N flag indicates the matrix spike recovery falls outside of the control limit.
- * For Inorganics analysis the * flag indicates Relative Percent Difference for duplicate analyses is outside of the control limit.

Sample ID Suffixes

- DL** Diluted analysis. The sample was diluted and reanalyzed. The DL may be followed by a digit if more than one diluted reanalysis is provided. The DL suffix is not attached to an analysis initially performed at dilution, only to reanalyses performed at dilution
- RE** Reanalysis. Appended to the client sample ID to indicate a reextraction and reanalysis or a reanalysis of the original sample extract.
- RA** Reanalysis. Appended to the laboratory sample ID indicates a reanalysis of the original sample extract.
- RX** Reextraction. Appended to the laboratory sample ID indicates a reextraction of the sample.
- MS** Matrix Spike.
- MSD** Matrix Spike Duplicate
- DUP** Duplicate analysis
- SD** Serial Dilution
- PS** Post-digestion or Post-distillation spike. For metals or inorganic analyses

1A - FORM I VOA-1
VOLATILE ORGANICS ANALYSIS DATA SHEET

CLIENT SAMPLE NO.

INFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L0943 Mod. Ref No.: _____ SDG No.: SL0943
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L0943-01A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V1M6952.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/08/2012
 % Moisture: not dec. Date Analyzed: 05/18/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 10.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
75-71-8	Dichlorodifluoromethane		10	U
74-87-3	Chloromethane		10	U
75-01-4	Vinyl chloride		10	U
74-83-9	Bromomethane		10	U
75-00-3	Chloroethane		10	U
75-69-4	Trichlorofluoromethane		10	U
75-35-4	1,1-Dichloroethene		10	U
67-64-1	Acetone		50	U
75-15-0	Carbon disulfide		10	U
75-09-2	Methylene chloride		10	U
156-60-5	trans-1,2-Dichloroethene		10	U
1634-04-4	Methyl tert-butyl ether		10	U
75-34-3	1,1-Dichloroethane		10	U
78-93-3	2-Butanone		50	U
156-59-2	cis-1,2-Dichloroethene		10	U
67-66-3	Chloroform		10	U
71-55-6	1,1,1-Trichloroethane		10	U
56-23-5	Carbon tetrachloride		10	U
107-06-2	1,2-Dichloroethane		10	U
71-43-2	Benzene		10	U
79-01-6	Trichloroethene		38	
78-87-5	1,2-Dichloropropane		10	U
75-27-4	Bromodichloromethane		10	U
10061-01-5	cis-1,3-Dichloropropene		10	U
108-10-1	4-Methyl-2-pentanone		50	U
108-88-3	Toluene		10	U
10061-02-6	trans-1,3-Dichloropropene		10	U
79-00-5	1,1,2-Trichloroethane		10	U
127-18-4	Tetrachloroethene		730	
591-78-6	2-Hexanone		50	U
124-48-1	Dibromochloromethane		10	U
106-93-4	1,2-Dibromoethane		10	U
108-90-7	Chlorobenzene		10	U
100-41-4	Ethylbenzene		10	U
1330-20-7	Xylene (Total)		10	U

1B - FORM I VOA-2
VOLATILE ORGANICS ANALYSIS DATA SHEET

CLIENT SAMPLE NO.

INFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L0943 Mod. Ref No.: _____ SDG No.: SL0943
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L0943-01A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V1M6952.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/08/2012
 % Moisture: not dec. Date Analyzed: 05/18/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 10.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
100-42-5	Styrene		10	U
75-25-2	Bromoform		10	U
98-82-8	Isopropylbenzene		10	U
79-34-5	1,1,2,2-Tetrachloroethane		10	U
541-73-1	1,3-Dichlorobenzene		10	U
106-46-7	1,4-Dichlorobenzene		10	U
95-50-1	1,2-Dichlorobenzene		10	U
96-12-8	1,2-Dibromo-3-chloropropane		10	U
120-82-1	1,2,4-Trichlorobenzene		10	U
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane		10	U
110-82-7	Cyclohexane		10	U
79-20-9	Methyl acetate		10	U
108-87-2	Methylcyclohexane		10	U

1A - FORM I VOA-1
VOLATILE ORGANICS ANALYSIS DATA SHEET

CLIENT SAMPLE NO.

EFFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L0943 Mod. Ref No.: _____ SDG No.: SL0943
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L0943-02A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V1M6953.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/08/2012
 % Moisture: not dec. Date Analyzed: 05/18/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 1.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
75-71-8	Dichlorodifluoromethane		1.0	U
74-87-3	Chloromethane		1.0	U
75-01-4	Vinyl chloride		1.0	U
74-83-9	Bromomethane		1.0	U
75-00-3	Chloroethane		1.0	U
75-69-4	Trichlorofluoromethane		1.0	U
75-35-4	1,1-Dichloroethene		1.0	U
67-64-1	Acetone		5.0	U
75-15-0	Carbon disulfide		1.0	U
75-09-2	Methylene chloride		1.0	U
156-60-5	trans-1,2-Dichloroethene		1.0	U
1634-04-4	Methyl tert-butyl ether		1.0	U
75-34-3	1,1-Dichloroethane		1.0	U
78-93-3	2-Butanone		5.0	U
156-59-2	cis-1,2-Dichloroethene		1.0	U
67-66-3	Chloroform		1.0	U
71-55-6	1,1,1-Trichloroethane		1.0	U
56-23-5	Carbon tetrachloride		1.0	U
107-06-2	1,2-Dichloroethane		1.0	U
71-43-2	Benzene		1.0	U
79-01-6	Trichloroethene		1.2	
78-87-5	1,2-Dichloropropane		1.0	U
75-27-4	Bromodichloromethane		1.0	U
10061-01-5	cis-1,3-Dichloropropene		1.0	U
108-10-1	4-Methyl-2-pentanone		5.0	U
108-88-3	Toluene		1.0	U
10061-02-6	trans-1,3-Dichloropropene		1.0	U
79-00-5	1,1,2-Trichloroethane		1.0	U
127-18-4	Tetrachloroethene		27	
591-78-6	2-Hexanone		5.0	U
124-48-1	Dibromochloromethane		1.0	U
106-93-4	1,2-Dibromoethane		1.0	U
108-90-7	Chlorobenzene		1.0	U
100-41-4	Ethylbenzene		1.0	U
1330-20-7	Xylene (Total)		1.0	U


1B - FORM I VOA-2
VOLATILE ORGANICS ANALYSIS DATA SHEET

CLIENT SAMPLE NO.

EFFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L0943 Mod. Ref No.: _____ SDG No.: SL0943
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L0943-02A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V1M6953.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/08/2012
 % Moisture: not dec. Date Analyzed: 05/18/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 1.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
100-42-5	Styrene		1.0	U
75-25-2	Bromoform		1.0	U
98-82-8	Isopropylbenzene		1.0	U
79-34-5	1,1,2,2-Tetrachloroethane		1.0	U
541-73-1	1,3-Dichlorobenzene		1.0	U
106-46-7	1,4-Dichlorobenzene		1.0	U
95-50-1	1,2-Dichlorobenzene		1.0	U
96-12-8	1,2-Dibromo-3-chloropropane		1.0	U
120-82-1	1,2,4-Trichlorobenzene		1.0	U
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane		1.0	U
110-82-7	Cyclohexane		1.0	U
79-20-9	Methyl acetate		1.0	U
108-87-2	Methylcyclohexane		1.0	U



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

** Wet Chemistry **



SPECTRUM ANALYTICAL, INC.
Featuring
HANIBAL TECHNOLOGY

Data Flag/Qualifiers:

- U Not Detected. This compound was analyzed-for but not detected. For most analyses the reporting limit (lowest standard concentration) is the value listed. For Department of Defense programs, this is the Limit of Detection (LOD).
- J This flag indicates an estimated value due to either
- the compound was detected below the reporting limit, or
 - estimated concentration for Tentatively Identified Compound
- B This flag indicates the compound was also detected in the associated Method Blank. The B flag has an alternative meaning for Inorganics analyses reported using CLP ILM-type metals forms, indicating a "trace" concentration below the reporting limit and equal to or above the detection limit.
- D For Organics analysis, this flag indicates the compound concentration was obtained from a secondary dilution analysis
- E This flag indicates the compound concentration exceeded the Calibration Range. The E flag has an alternative meaning for Inorganics analyses reported using CLP metals forms, indicating an estimated concentration due to the presence of interferences, as determined by the serial dilution analysis.
- P This flag is used for pesticides/PCB/herbicide compound when there is a greater than 40% difference for detected concentration between the two GC columns used for primary and confirmation analyses. This difference typically indicates an interference, causing one value to be unusually high. The **lower** of the two values is generally reported on the Form 1, and both values reported on the Form 10.
-
- A Used to flag semivolatile organic Tentatively Identified Compound library search results for compounds identified as aldol condensation byproducts.
- N Used to flag results for volatile and semivolatile Organics analysis Tentatively Identified Compounds where an analyte has passed the identification criteria, and is considered to be positively identified. For Inorganics analysis the N flag indicates the matrix spike recovery falls outside of the control limit.
- * For Inorganics analysis the * flag indicates Relative Percent Difference for duplicate analyses is outside of the control limit.

Sample ID Suffixes

- DL** Diluted analysis. The sample was diluted and reanalyzed. The DL may be followed by a digit if more than one diluted reanalysis is provided. The DL suffix is not attached to an analysis initially performed at dilution, only to reanalyses performed at dilution
- RE** Reanalysis. Appended to the client sample ID to indicate a reextraction and reanalysis or a reanalysis of the original sample extract.
- RA** Reanalysis. Appended to the laboratory sample ID indicates a reanalysis of the original sample extract.
- RX** Reextraction. Appended to the laboratory sample ID indicates a reextraction of the sample.
- MS** Matrix Spike.
- MSD** Matrix Spike Duplicate
-
- DUP** Duplicate analysis
- SD** Serial Dilution
- PS** Post-digestion or Post-distillation spike. For metals or inorganic analyses

Client: Ecology and Environment Engineering P.C.

Project: Mr. C's Dry Cleaning

Client Sample ID: INFLUENT

Collection Date: 05/07/12 14:30

Lab ID: L0943-01

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
SM 2340B -- HARDNESS by Calculation							SM2340_W
Hardness, Ca/Mg (As CaCO3)	480		4.0	mg/L CaCO3		105/15/2012 9:09	66056
SM 4500 H+ B -- pH VALUE							SM4500_H+
pH	7.3		1.0	S.U.		105/08/2012 12:00	R67060

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 B - Analyte detected in the associated Method Blank
 DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 E - Value above quantitation range
 RL - Reporting Limit

Client: Ecology and Environment Engineering P.C.

Client Sample ID: EFFLUENT

Project: Mr. C's Dry Cleaning

Lab ID: L0943-02

Collection Date: 05/07/12 15:00

Analyses	Result	Qual	RL	Units	DF	Date Analyzed	Batch ID
SM 2340B -- HARDNESS by Calculation							SM2340_W
Hardness, Ca/Mg (As CaCO3)	480		4.0	mg/L CaCO3		105/15/2012 9:13	66056
SM 4500 H+ B -- pH VALUE							SM4500_H+
pH	8.1		1.0	S.U.		105/08/2012 12:03	R67060

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 B - Analyte detected in the associated Method Blank
 DF - Dilution Factor

S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 E - Value above quantitation range
 RL - Reporting Limit


Attachment C
Analytical Report from
Mitkem Laboratories

Analytical Data Package Work Order ID: L1188

Sampled: May 30, 2012

Received: June 6, 2012

Report Date:
06-Jun-12 16:59



- Final Report
 Re-Issued Report
 Revised Report

Laboratory Report

Ecology and Environment Engineering P.C.
368 Pleasant View Drive
Lancaster, NY 14086

Work Order: L1188
Project: Mr. C's Dry Cleaning
Project #: 002700.DC13.02.01.01

Attn: Michael Steffan

<u>Laboratory ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Sampled</u>	<u>Date Received</u>
L1188-01	INFLUENT	Aqueous	30-May-12 12:30	31-May-12 09:00
L1188-02	EFFLUENT	Aqueous	30-May-12 12:30	31-May-12 09:00

I attest that the information contained within the report has been reviewed for accuracy and checked against the quality control requirements for each method. The results relate only to the sample(s) as received. This report may not be reproduced, except in full, without written approval from Spectrum Analytical.

All applicable NELAC or USEPA CLP requirements have been met.

Spectrum Analytical (Rhode Island) is accredited under the National Environmental Laboratory Approval Program (NELAP) and DoD Environmental Laboratory Accreditation Program (ELAP), holds Organic and Inorganic contracts under the USEPA CLP Program and is certified under several states. The current list of our laboratory approvals and certifications is available on the Certifications page on our web site at www.spectrum-analytical.com.

Please contact the Laboratory or Technical Director at 401-732-3400 with any questions regarding the data contained in the laboratory report.

Department of Defense	N/A
Connecticut	PH-0153
Delaware	N/A
Florida	E87664
Maine	2007037
Massachusetts	M-RI907
New Hampshire	2631
New Jersey	RI001
New York	11522
North Carolina	581
Pennsylvania	68-00520
Rhode Island	LAI00301
USDA	P330-08-00023
USEPA - ISM	EP-W-09-039
USEPA - SOM	EP-W-11-033




Certificate # L2247 Testing

Authorized by:

Yihai Ding
Laboratory Director

Sample Transmittal Documentation




SPECTRUM ANALYTICAL, INC.

Featuring

HANIBAL TECHNOLOGY

*** Volatiles ***




SPECTRUM ANALYTICAL, INC.

Featuring

HANIBAL TECHNOLOGY

Data Flag/Qualifiers:

- U** Not Detected. This compound was analyzed-for but not detected. For most analyses the reporting limit (lowest standard concentration) is the value listed. For Department of Defense programs, this is the Limit of Detection (LOD).
- J** This flag indicates an estimated value due to either
- the compound was detected below the reporting limit, or
 - estimated concentration for Tentatively Identified Compound
- B** This flag indicates the compound was also detected in the associated Method Blank. The B flag has an alternative meaning for Inorganics analyses reported using CLP ILM-type metals forms, indicating a "trace" concentration below the reporting limit and equal to or above the detection limit.
- D** For Organics analysis, this flag indicates the compound concentration was obtained from a secondary dilution analysis
- E** This flag indicates the compound concentration exceeded the Calibration Range. The E flag has an alternative meaning for Inorganics analyses reported using CLP metals forms, indicating an estimated concentration due to the presence of interferences, as determined by the serial dilution analysis.
- P** This flag is used for pesticides/PCB/herbicide compound when there is a greater than 40% difference for detected concentration between the two GC columns used for primary and confirmation analyses. This difference typically indicates an interference, causing one value to be unusually high. The **lower** of the two values is generally reported on the Form 1, and both values reported on the Form 10.
-
- A** Used to flag semivolatile organic Tentatively Identified Compound library search results for compounds identified as aldol condensation byproducts.
- N** Used to flag results for volatile and semivolatile Organics analysis Tentatively Identified Compounds where an analyte has passed the identification criteria, and is considered to be positively identified. For Inorganics analysis the N flag indicates the matrix spike recovery falls outside of the control limit.
- *** For Inorganics analysis the * flag indicates Relative Percent Difference for duplicate analyses is outside of the control limit.



SPECTRUM ANALYTICAL, INC.

Featuring

HANIBAL TECHNOLOGY

Sample ID Suffixes

- DL** Diluted analysis. The sample was diluted and reanalyzed. The DL may be followed by a digit if more than one diluted reanalysis is provided. The DL suffix is not attached to an analysis initially performed at dilution, only to reanalyses performed at dilution
- RE** Reanalysis. Appended to the client sample ID to indicate a reextraction and reanalysis or a reanalysis of the original sample extract.
- RA** Reanalysis. Appended to the laboratory sample ID indicates a reanalysis of the original sample extract.
- RX** Reextraction. Appended to the laboratory sample ID indicates a reextraction of the sample.
- MS** Matrix Spike.
- MSD** Matrix Spike Duplicate
- DUP** Duplicate analysis
- SD** Serial Dilution
- PS** Post-digestion or Post-distillation spike. For metals or inorganic analyses

1A - FORM I VOA-1
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.

INFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L1188 Mod. Ref No.: _____ SDG No.: SL1188
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L1188-01A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V8B2065.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/31/2012
 % Moisture: not dec. Date Analyzed: 06/01/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 10.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
75-71-8	Dichlorodifluoromethane		10	U
74-87-3	Chloromethane		10	U
75-01-4	Vinyl chloride		10	U
74-83-9	Bromomethane		10	U
75-00-3	Chloroethane		10	U
75-69-4	Trichlorofluoromethane		10	U
75-35-4	1,1-Dichloroethene		10	U
67-64-1	Acetone		50	U
75-15-0	Carbon disulfide		12	
75-09-2	Methylene chloride		10	U
156-60-5	trans-1,2-Dichloroethene		10	U
1634-04-4	Methyl tert-butyl ether		10	U
75-34-3	1,1-Dichloroethane		10	U
78-93-3	2-Butanone		50	U
156-59-2	cis-1,2-Dichloroethene		5.5	J
67-66-3	Chloroform		10	U
71-55-6	1,1,1-Trichloroethane		10	U
56-23-5	Carbon tetrachloride		10	U
107-06-2	1,2-Dichloroethane		10	U
71-43-2	Benzene		10	U
79-01-6	Trichloroethene		24	
78-87-5	1,2-Dichloropropane		10	U
75-27-4	Bromodichloromethane		10	U
10061-01-5	cis-1,3-Dichloropropene		10	U
108-10-1	4-Methyl-2-pentanone		50	U
108-88-3	Toluene		10	U
10061-02-6	trans-1,3-Dichloropropene		10	U
79-00-5	1,1,2-Trichloroethane		10	U
127-18-4	Tetrachloroethene		390	
591-78-6	2-Hexanone		50	U
124-48-1	Dibromochloromethane		10	U
106-93-4	1,2-Dibromoethane		10	U
108-90-7	Chlorobenzene		10	U
100-41-4	Ethylbenzene		10	U
1330-20-7	Xylene (Total)		10	U

1B - FORM I VOA-2
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.
INFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L1188 Mod. Ref No.: _____ SDG No.: SL1188
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L1188-01A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V8B2065.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/31/2012
 % Moisture: not dec. Date Analyzed: 06/01/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 10.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
100-42-5	Styrene		10	U
75-25-2	Bromoform		10	U
98-82-8	Isopropylbenzene		10	U
79-34-5	1,1,2,2-Tetrachloroethane		10	U
541-73-1	1,3-Dichlorobenzene		10	U
106-46-7	1,4-Dichlorobenzene		10	U
95-50-1	1,2-Dichlorobenzene		10	U
96-12-8	1,2-Dibromo-3-chloropropane		10	U
120-82-1	1,2,4-Trichlorobenzene		10	U
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane		10	U
110-82-7	Cyclohexane		10	U
79-20-9	Methyl acetate		10	U
108-87-2	Methylcyclohexane		10	U

1A - FORM I VOA-1
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.

EFFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L1188 Mod. Ref No.: _____ SDG No.: SL1188
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L1188-02A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V8B2066.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/31/2012
 % Moisture: not dec. Date Analyzed: 06/01/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 1.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
75-71-8	Dichlorodifluoromethane		1.0	U
74-87-3	Chloromethane		1.0	U
75-01-4	Vinyl chloride		1.0	U
74-83-9	Bromomethane		1.0	U
75-00-3	Chloroethane		1.0	U
75-69-4	Trichlorofluoromethane		1.0	U
75-35-4	1,1-Dichloroethene		1.0	U
67-64-1	Acetone		5.0	U
75-15-0	Carbon disulfide		0.58	J
75-09-2	Methylene chloride		1.0	U
156-60-5	trans-1,2-Dichloroethene		1.0	U
1634-04-4	Methyl tert-butyl ether		1.0	U
75-34-3	1,1-Dichloroethane		1.0	U
78-93-3	2-Butanone		5.0	U
156-59-2	cis-1,2-Dichloroethene		1.0	U
67-66-3	Chloroform		1.0	U
71-55-6	1,1,1-Trichloroethane		1.0	U
56-23-5	Carbon tetrachloride		1.0	U
107-06-2	1,2-Dichloroethane		1.0	U
71-43-2	Benzene		1.0	U
79-01-6	Trichloroethene		1.0	U
78-87-5	1,2-Dichloropropane		1.0	U
75-27-4	Bromodichloromethane		1.0	U
10061-01-5	cis-1,3-Dichloropropene		1.0	U
108-10-1	4-Methyl-2-pentanone		5.0	U
108-88-3	Toluene		1.0	U
10061-02-6	trans-1,3-Dichloropropene		1.0	U
79-00-5	1,1,2-Trichloroethane		1.0	U
127-18-4	Tetrachloroethene		0.94	J
591-78-6	2-Hexanone		5.0	U
124-48-1	Dibromochloromethane		1.0	U
106-93-4	1,2-Dibromoethane		1.0	U
108-90-7	Chlorobenzene		1.0	U
100-41-4	Ethylbenzene		1.0	U
1330-20-7	Xylene (Total)		1.0	U

1B - FORM I VOA-2
VOLATILE ORGANICS ANALYSIS DATA SHEET

EPA SAMPLE NO.

EFFLUENT

Lab Name: SPECTRUM ANALYTICAL, INC. Contract: _____
 Lab Code: MITKEM Case No.: L1188 Mod. Ref No.: _____ SDG No.: SL1188
 Matrix: (SOIL/SED/WATER) WATER Lab Sample ID: L1188-02A
 Sample wt/vol: 5.00 (g/mL) ML Lab File ID: V8B2066.D
 Level: (TRACE/LOW/MED) LOW Date Received: 05/31/2012
 % Moisture: not dec. Date Analyzed: 06/01/2012
 GC Column: DB-624 ID: 0.25 (mm) Dilution Factor: 1.0
 Soil Extract Volume: _____ (uL) Soil Aliquot Volume: _____ (uL)
 Purge Volume: 5.0 (mL)

CAS NO.	COMPOUND	CONCENTRATION UNITS:		Q
		(ug/L or ug/Kg)	UG/L	
100-42-5	Styrene		1.0	U
75-25-2	Bromoform		1.0	U
98-82-8	Isopropylbenzene		1.0	U
79-34-5	1,1,2,2-Tetrachloroethane		1.0	U
541-73-1	1,3-Dichlorobenzene		1.0	U
106-46-7	1,4-Dichlorobenzene		1.0	U
95-50-1	1,2-Dichlorobenzene		1.0	U
96-12-8	1,2-Dibromo-3-chloropropane		1.0	U
120-82-1	1,2,4-Trichlorobenzene		1.0	U
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane		1.0	U
110-82-7	Cyclohexane		1.0	U
79-20-9	Methyl acetate		1.0	U
108-87-2	Methylcyclohexane		1.0	U

Attachment D
Summary of Site Utility Costs and Projections
January to December 2012

Mr. C's Dry Cleaners Site - Remedial Treatment Utility Costs

NYSDEC Work Assignment #DC13

12 Months of System Operation and Maintenance

May 2012 Report

	Optimum Operating Hours	Actual Operating Hours	Up-time Percentage	Capacity	Comments:			
January-12	692	692	100.00%	13.8%	Mild January			
February-12	766	766	100.00%	11.7%	Mild February			
March-12	720	720	100.00%	10.6%	Very Mild March			
April-12	624	624	100.00%	7.2%	Warm and Fair April			
May-12	888	888	100.00%	8.4%	Sunny May			
June-12			#DIV/0!					
July-12			#DIV/0!					
August-12			#DIV/0!					
September-12			#DIV/0!					
October-12			#DIV/0!					
November-12			#DIV/0!					
December-12			#DIV/0!					
Totals to Date	3692	3692	100.00%					
<p>* Percent Capacity is based on initial operating groundwater flows from the eight installed pumps from 9/02. Evaluated on total gallons discharged for monthly operating time. Maximum pump discharges calculated as an average of 78 gpm as the total for all 8 pumps at the site if all pumps operate 100%. With the exception of groundwater pump RW-1, all others run on a batch basis.</p>								

Monthly Average Costs

Mr. C's Electric	\$	1,120.80
Agway Electric	\$	83.73
Mr. C's Gas	\$	176.64
Mr. C's Telephone	\$	-
Ave. Utility Cost Total	\$	1,381.17

12 Month Estimate \$17,955.18

ATTACHMENT C

Budget Remaining:

Electric: \$6,777.35

Telephone: \$540.00

Gas -\$163.19

Total: \$7,154.16