



Department of
Environmental
Conservation

Bulk Storage Database Search Details

Tank Information

[First Tank](#)[Previous Tank](#)

Site No: 2-476021

Site Name: 580 GERARD AVENUE

Tank No: 011

Tank Location: Underground including vaulted with no access for inspection

Subpart: 3

Category: 2

Tank Status: In Service

Tank Install Date: 02/01/1993

Tank Closed Date:

Tank Out Of Service Date:

Tank Capacity: 2500 gal.

Product Stored: #2 fuel oil (on-site consumption)

Percentage: 100%

Tank Type: 06 - Fiberglass Reinforced Plastic (FRP)

Tank Internal Protection: Fiberglass Liner (FRP)

Tank External Protection: Fiberglass

Tank Secondary Containment: Double-Walled (Underground)

Tank Leak Detection: In-Tank System (ATG)

Overfill: None

Spill Prevention: Catch Basin

Dispenser: Suction Dispenser

Pipe Location: Underground/On-ground

Pipe Type: Fiberglass Reinforced Plastic (FRP)

Pipe External Protection: Fiberglass

Piping Secondary Containment: None

Piping Leak Detection: Exempt Suction Piping

UDC: Yes

Tank Next Test Due:

Tank Last Test:

Tank Test Method:

Line Next Test Due:

Line Last Test:

Line Test Method:

Tank Owner Information

Company: NR PROPERTY 2 LLC

Address: 44 W 55TH ST . NEW YORK, NY. 10019

Refine This Search

Return To Facility